

DEPARTMENT OF DESIGN AND CONSTRUCTION  
CITY AND COUNTY OF HONOLULU

650 SOUTH KING STREET, 11<sup>TH</sup> FLOOR  
HONOLULU, HAWAII 96813  
Phone: (808) 768-8480 • Fax: (808) 768-4567  
Web site: [www.honolulu.gov](http://www.honolulu.gov)

FILE COPY

AUG 23 2015

KIRK CALDWELL  
MAYOR



ROBERT J. KRONING, P.E.  
DIRECTOR

MARK YONAMINE, P.E.  
DEPUTY DIRECTOR

August 6, 2015

Ms. Jessica Wooley  
Office of Environmental Quality Control (OEQC)  
State Department of Health  
235 S. Beretania Street, Room 702  
Honolulu, Hawaii 96813

WW.CSE 15-092

RECEIVED  
15 AUG 11 AM 12:28  
OFFICE OF ENVIRONMENTAL  
QUALITY CONTROL

Dear Ms. Wooley:


SUBJECT: Kahanahou Wastewater Pump Station and Sewer Force Main Upgrades

With this letter, the City and County of Honolulu, Department of Design and Construction (DDC), transmits the Draft Environmental Assessment and Anticipated Finding of No Significant Impact (DEA-AFONSI) for the proposed, situated in Kaneohe in the Koolaupoko District on the island of Oahu for publication in the next available edition of the Environmental Notice.

Enclosed is a completed OEQC Publication Form, two copies of the DEA-AFONSI, an Adobe Acrobat PDF file of the same, and an electronic copy of the publication form in MS Word. Simultaneous with this letter, we have submitted the summary of the action in a text file by electronic mail to your office.

If there are any questions, please contact Roy Tamashiro of our Wastewater Division at (808) 768-8760 or Tina Speed, Planner at Townscape, Inc. at (808) 536-6999.

Sincerely,

  
Robert J. Kroning, P.E.  
Director

Enclosures: One (1) hard copy of OEQC Publication Form  
Two (2) hard copies of DEA-AFONSI  
One (1) CD with: One (1) electronic copy of DEA-AFONSI (PDF)  
One (1) electronic copy of OEQC Publication Form  
(MS Word)

**AGENCY ACTION  
SECTION 343-5(b), HRS  
PUBLICATION FORM**

**Project Name:** Draft Environmental Assessment for the proposed Kahanahou Wastewater Pump Station and Sewer Force Main Upgrades, Kaneohe, Oahu

**HRS §343-5 Trigger(s):** 1. Use of County lands and funds  
2. Use within the Special Management Area (SMA)

**Island:** Oahu

**District:** Koolaupoko

**TMK:** 4-5-047:095 (Kahanahou WWPS), 4-5-047:093 (Kahanahou Place), 4-5-047:127 (Kahanahou Place), 4-5-057:015 (Miyazaki), 4-5-057:018 (Lilipuna Place), 4-5-002:001 (Makani Kai Marina), 4-5-002:014 (Various Landowners)

**Permits:** City & County DPP: Shoreline Setback Variance, Sewer Connection Application, Trenching Permit, Grading and Grubbing Permit. City & County DTS: Street Usage Permit. State DOH: NPDES permit, Community Noise Permit and Noise Variance. State SHPD: Archaeological Monitoring Plan and possibly Archaeological Inventory Survey (AIS)

**Proposing/  
Determination Agency:** City & County of Honolulu, Department of Design and Construction, 650 S. King St., Honolulu HI 96813. Contact: Roy Tamashiro, P.E. Telephone: (808) 768-8760, email: rtamashiro2@honolulu.gov

**Accepting Authority:** N/A

**Consultant:** Townscape, Inc., 900 Fort Street Mall, Suite 1160, Honolulu HI 96813. Contact: Tina Speed Telephone: (808) 536-6999, email: [tina@townscapeinc.com](mailto:tina@townscapeinc.com)

**Status (check one only):**

**DEA-AFNSI** Submit the proposing agency notice of determination/transmittal on agency letterhead, a hard copy of DEA, a completed OEQC publication form, along with an electronic word processing summary and a PDF copy (you may send both summary and PDF to [oeqchawaii@doh.hawaii.gov](mailto:oeqchawaii@doh.hawaii.gov)); a 30-day comment period ensues upon publication in the periodic bulletin.

**FEA-FONSI** Submit the proposing agency notice of determination/transmittal on agency letterhead, a hard copy of the FEA, an OEQC publication form, along with an electronic word processing summary and a PDF copy (send both summary and PDF to [oeqchawaii@doh.hawaii.gov](mailto:oeqchawaii@doh.hawaii.gov)); no comment period ensues upon publication in the periodic bulletin.

**FEA-EISPN** Submit the proposing agency notice of determination/transmittal on agency letterhead, a hard copy of the FEA, an OEQC publication form, along with an electronic word processing summary and PDF copy (you may send both summary and PDF to [oeqchawaii@doh.hawaii.gov](mailto:oeqchawaii@doh.hawaii.gov)); a 30-day consultation period ensues upon publication in the periodic bulletin.

**Act 172-12 EISPN** Submit the proposing agency notice of determination on agency letterhead, an OEQC publication form, and an electronic word processing summary (you may send the summary to [oeqchawaii@doh.hawaii.gov](mailto:oeqchawaii@doh.hawaii.gov)). NO environmental assessment is required and a 30-day consultation period upon publication in the periodic bulletin.

**DEIS** The proposing agency simultaneously transmits to both the OEQC and the accepting authority, a hard copy of the DEIS, a completed OEQC publication form, a distribution list, along with an electronic word processing summary and PDF copy of the DEIS (you may send both the summary and PDF to [oeqchawaii@doh.hawaii.gov](mailto:oeqchawaii@doh.hawaii.gov)); a 45-day comment period ensues upon publication in the periodic bulletin.

**FEIS** The proposing agency simultaneously transmits to both the OEQC and the accepting authority, a hard copy of the FEIS, a completed OEQC publication form, a distribution list, along with an electronic word processing summary and PDF copy of the FEIS (you may send both the summary and PDF to [oeqchawaii@doh.hawaii.gov](mailto:oeqchawaii@doh.hawaii.gov)); no comment period ensues upon publication in the periodic bulletin.

\_\_\_ Section 11-200-23  
Determination

The accepting authority simultaneously transmits its determination of acceptance or nonacceptance (pursuant to Section 11-200-23, HAR) of the FEIS to both OEQC and the proposing agency. No comment period ensues upon publication in the periodic bulletin.

\_\_\_ Section 11-200-27  
Determination

The accepting authority simultaneously transmits its notice to both the proposing agency and the OEQC that it has reviewed (pursuant to Section 11-200-27, HAR) the previously accepted FEIS and determines that a supplemental EIS is not required. No EA is required and no comment period ensues upon publication in the periodic bulletin.

\_\_\_ Withdrawal (explain)

**Summary** (Provide proposed action and purpose/need in less than 200 words. Please keep the summary brief and on this one page):

The City and County of Honolulu (City), proposes to upgrade the Kahanahou Wastewater Pump Station (WWPS) in Kaneohe, Oahu. Infiltration and inflow of rainfall into the sewer system requires increasing the WWPS capacity. Proposed improvements to the WWPS include upgrades in pump capacity from 0.654 million gallons per day (mgd) to 1.26 mgd, renovations to the existing pump station, construction of a new emergency generator building, and other associated on-site improvements.

The City also proposes to increase the capacity of the force main directly downstream of the Kahanahou WWPS. Four alternative routes were evaluated, along with a delayed action and no action alternative. The preferred alternative runs west along Kahanahou Circle, turning south at Lilipuna Place, through a private residence and the Makani Kai Marina townhouse complex, and ending at the existing sewer manhole on Makahio Street. This route was selected because it meets the project objectives and design criteria, avoids problematic areas, and crosses through fewer private properties than other routes.

The proposed project will have short term impacts on traffic, noise, and air quality during construction. Efforts to minimize these impacts will be implemented to the extent practicable. The City anticipates a Finding of No Significant Impact for this project.

# Kahanahou Wastewater Pump Station and Sewer Force Main Upgrades Kaneohe, Oahu

## DRAFT ENVIRONMENTAL ASSESSMENT

**Prepared for:**  
**CITY AND COUNTY OF HONOLULU**  
**Department of Design and Construction**  
**Wastewater Division**

**August 2015**

**Prepared by:**  
**Townscape, Inc.**

*This page intentionally left blank.*

## PROJECT SUMMARY

Project Name: Kahanahou Wastewater Pump Station and Sewer Force Main Upgrades

Applicant: City and County of Honolulu  
Department of Design and Construction  
650 South King St  
Honolulu, HI 96813

Agent: Townscape, Inc.

Contact: Tina Speed, Environmental Planner

Phone: (808) 536-6999 Fax: (808) 524-4998

Approving Agency: City and County of Honolulu

Tax Map Key Parcels and Roads Potentially Affected: 4-5-047:095 (Kahanahou WWPS)  
4-5-047:093 (Kahanahou Place)  
4-5-047:127 (Kahanahou Place)  
4-5-057:015 (Miyazaki)  
4-5-057:018 (Lilipuna Place)  
4-5-002:001 (Makani Kai Marina)  
4-5-002:014 (Various Landowners)  
Ka Hanahou Circle  
Lilipuna Road  
Lilipuna Place  
Wailele Road  
Makahio Street

State Land Use District: Urban District

Existing County Zoning: Residential District R-10, R-7.5 and R-5

City Development Plan: Koolau Poko Sustainable Communities Plan

Land Use Designation: Low Density Residential

Special Designation: Special Management Area (SMA)  
Shoreline Setback Area

Anticipated Determination: Finding of No Significant Impact (FONSI)

## PROJECT SUMMARY (continued)

### Pre-Consultation Parties:

#### City and County of Honolulu

- Department of Environmental Services
- Department of Facility Maintenance
- Department of Planning and Permitting
- Department of Transportation Services
- Honolulu Board of Water Supply
- Honolulu Fire Department
- Honolulu Police Department
- Neighborhood Board #30: Kaneohe
- Honolulu City Council, District 3

#### State of Hawaii

- Department of Business, Economic Development and Tourism, Office of Planning
- Department of Health, Environmental Management Division
- Department of Land and Natural Resources
  - Commission on Water Resource Management
  - Engineering Division
  - Office of Conservation and Coastal Lands
  - State Historic Preservation Division
- Department of Transportation, Highways Division
- Office of Hawaiian Affairs
- University of Hawaii at Manoa
  - Environmental Center
  - Water Resources Research Center
- Hawaii State House of Representatives, District 48
- Hawaii State Senate, District 24

#### Utility Companies

- Hawaii Gas
- Hawaiian Electric Company
- Hawaiian Telcom

#### Private Landowners

- Makani Kai Marina townhouse complex
- Other private landowners

## **EXECUTIVE SUMMARY**

The City and County of Honolulu proposes to upgrade the Kahanahou Wastewater Pump Station (WWPS) and Sewer Force Main in Kaneohe, Oahu. The WWPS, built in 1966, was found to experience high infiltration and inflow of rainwater into the sewer system. This requires that the WWPS increase its capacity from 0.654 millions of gallons per day (mgd) to more than 1.26 mgd. The upgrades in pump capacity will also include renovations and replacement of the existing SCADA system and motor control center, piping, wet well, and ventilation system. A new emergency generator building is proposed to house a new diesel fueled generator to replace the existing propane unit.

Upgrades to the Kahanahou WWPS require upgrades to the existing 8-inch force main that conveys wastewater from the Kahanahou WWPS to a 10-inch gravity main and on to the Waikapoki WWPS. Replacing the existing force main will increase the capacity from 0.47 mgd to handle the WWPS upgrade flow. The proposed force main will be re-routed to bypass the Waikapoki WWPS to flow directly to the Kaneohe Wastewater Preliminary Treatment Facility.

Construction on the Kahanahou WWPS will occur entirely within the existing WWPS site. The new force main will follow the existing force main as it exits the WWPS property, then will follow a more northerly route along City streets until it traverses two private properties, a residential property on Lilipuna Place, and the Makani Kai Marina townhouse complex.

The proposed project is expected to cost \$3.0 million for the WWPS upgrades and \$1.3 million for the force main replacement.

Most project impacts are expected to be short term and related to construction activities, such as noise, dust, and traffic. Efforts to minimize such impacts will be taken to the extent practicable. Long term impacts are improved environmental conditions related to a reduction in sanitary sewer overflows.

This proposed project is expected to receive a Finding of No Significant Impact (FONSI).



# TABLE OF CONTENTS

<b>PROJECT SUMMARY</b> .....	<b>i</b>
<b>EXECUTIVE SUMMARY</b> .....	<b>iii</b>
<b>TABLE OF CONTENTS</b> .....	<b>iv</b>
<b>TABLE OF FIGURES</b> .....	<b>vi</b>
<b>APPENDICES</b> .....	<b>vi</b>
<b>ACRONYMS</b> .....	<b>vii</b>
<b>1. INTRODUCTION</b> .....	<b>1</b>
1.1 Project Background and Need.....	1
1.1 Kahanahou WWPS Location and Existing Facilities .....	3
1.2 Existing Sewer Force Main.....	4
<b>2. PROPOSED PROJECT DESCRIPTION</b> .....	<b>7</b>
2.1 Kahanahou WWPS .....	7
2.2 Sewer Force Main Replacement .....	10
2.3 Construction Sequence and Costs .....	12
<b>3. ENVIRONMENT, POTENTIAL IMPACTS, AND MITIGATION</b> .....	<b>13</b>
3.1 Topography and Soils.....	13
3.2 Climate and Hydrology .....	17
3.3 Air Quality and Noise.....	17
3.4 Water Quality .....	18
3.5 Wetlands .....	19
3.6 Flooding, Tsunami and Fire Hazards.....	20
3.7 Socio-Economic Conditions.....	22
3.8 Infrastructure .....	23
3.9 Historical and Cultural Resources.....	24
3.10 Flora and Fauna .....	25
3.11 Cumulative Impacts .....	25
<b>4. ALTERNATIVES TO THE PROPOSED PROJECT</b> .....	<b>27</b>
<b>5. RELATIONSHIP TO FEDERAL, STATE, AND COUNTY PLANS AND POLICIES</b> .....	<b>35</b>
5.1 Hawaii State Plan .....	35
5.2 Hawaii Administrative Rules .....	36
5.3 State Land Use Law, Conservation District Use Permit .....	37

5.4	State Historic and Cultural Site Review .....	37
5.5	Hawaii Coastal Zone Management Program .....	37
5.6	City and County of Honolulu General Plan .....	38
5.7	Koolau Poko Sustainable Communities Plan.....	39
5.8	Kaneohe Bay Master Plan.....	39
5.9	Flood District Regulations.....	40
5.10	Special Districts .....	40
5.11	Kaneohe Town Plan (2009) .....	40
5.12	City and County of Honolulu Zoning.....	40
<b>6.</b>	<b>PERMITS AND APPROVALS.....</b>	<b>42</b>
6.1	City and County of Honolulu Permits.....	42
6.2	State of Hawaii Permits .....	42
<b>7.</b>	<b>DETERMINATION.....</b>	<b>43</b>
7.1	Findings and Reasons Supporting the Determination.....	43
<b>8.</b>	<b>REFERENCES.....</b>	<b>46</b>

## TABLE OF FIGURES

Figure 1 Project Location .....	2
Figure 2 Existing and Proposed Sewer System.....	5
Figure 3 Existing Tributary Areas .....	6
Figure 4 Location of New Generator Building.....	9
Figure 5 Proposed Sewer Main and Tributary Area.....	11
Figure 6 Soil Types and Topography .....	15
Figure 7 Physical Features and Hydrology.....	16
Figure 8 Flood and Tsunami Hazards .....	21
Figure 9 Alternative Routes.....	30
Figure 10 Alternative Route 1.....	31
Figure 11 Alternative Route 2 (Selected Route) .....	32
Figure 12 Alternative Route 3.....	33
Figure 13 Alternative Route 4.....	34

## APPENDICES

- A Preliminary Design Alternatives Report for Kahanahou Wastewater Pump Station Upgrade (Okahara and Associates, Inc., January 2011)
- B Final Engineering Report - Kahanahou Wastewater Pump Station Force Main Sewer Line Study, Kaneohe, Oahu, Hawaii (Okahara and Associates, Inc., December 2013, Revised June 2015)
- C Digital Flood Insurance Map (DFIRM) (Federal Emergency Management Agency, 2013)
- D Pre-Environmental Assessment Consultation
- E Literature Review and Field Inspection Report (LRFI) (Cultural Surveys Hawaii, Inc., January 2014)
- F Special Management Area Determination Letter (City and County of Honolulu Department of Planning and Permitting, March 2010)

## ACRONYMS

AIS	Archaeological Inventory Survey
BMP	Best Management Practice
BWS	Board of Water Supply
City	City and County of Honolulu
CMU	Concrete Masonry Unit
CSH	Cultural Surveys Hawaii
CSM	Collection System Maintenance Division (ENV)
CWB	Clean Water Branch (DOH)
CWRM	Commission on Water Resource Management
CZM	Coastal Zone Management
DCAB	Disability and Communication Access Board
DDC	Department of Design and Construction (City)
DFIRM	Digital Flood Insurance Rate Map
DLNR	Department of Land and Natural Resources (State)
DOFAW	Division of Forestry and Wildlife (DLNR)
DOH	Department of Health (State)
DPP	Department of Planning and Permitting (City)
DTS	Department of Transportation Services (City)
EA	Environmental Assessment
EIS	Environmental Impact Statement
ENV	Department of Environmental Services (City)
EPA	Environmental Protection Agency (Federal)
FEMA	Federal Emergency Management Agency
FONSI	Finding of No Significant Impact
GIS	Geographic Information System
GPM	Gallons Per Minute

## ACRONYMS (continued)

HAR	Hawaii Administrative Rules
HDPE	High Density Polyethylene
HECO	Hawaiian Electric Company
HID	High Intensity Discharge
HP	Horsepower
HRS	Hawaii Revised Statutes
I/I	Inflow and Infiltration
INFIX	(City of Honolulu's wastewater flow calculation model)
KBMP	Kaneohe Bay Master Plan
KBMP TF	Kaneohe Bay Master Plan Task Force
KMCAS	Kaneohe Marine Corps Air Station
kW	Kilowatt
LRFI	Literature Review and Field Inspection
LUO	Land Use Ordinance
MCC	Motor Control Center
MGD	Million Gallons per Day
MH	Manhole
NFPA	National Fire Protection Association
NPDES	National Pollutant Discharge Elimination System
OD	Outside Diameter
PVC	Polyvinyl Chloride
SCADA	Supervisory Control and Data Acquisition
SDR	Standard Dimension Ratio
SHPD	State Historic Preservation Division (DLNR)
SMA	Special Management Area
SSO	Sanitary Sewer Overflow
TMK	Tax Map Key

## ACRONYMS (continued)

USDA	United States Department of Agriculture
VFD	Variable Frequency Drive
WWPS	Wastewater Pump Station
WWTP	Wastewater Treatment Plant

# 1. INTRODUCTION

## 1.1 PROJECT BACKGROUND AND NEED

The Kahanahou Wastewater Pump Station (WWPS) is owned and operated by the City and County of Honolulu (City) and is located in a residential subdivision in Kaneohe, Oahu (Figure 1). Wastewater from the Kahanahou WWPS tributary area flows to the Kahanahou WWPS and is pumped through an existing force main to the Waikapoki WWPS, where it is pumped through another force main to the Kaneohe Bay East interceptor sewer to the Kaneohe Wastewater Preliminary Treatment Facility (Figure 2).


The existing Kahanahou WWPS was built in 1966 and requires additional pumping capacity. The “*Sewer Rehabilitation and Infiltration and Inflow Minimization Study, Volume 3 of 9, Kailua-Kaneohe I/I Engineering Report*” (December 1999) found high infiltration and inflow (I/I), which occurs when rain water enters the sewer system. As a result, the City Department of Design and Construction (DDC) proposes to upgrade the pump capacity of the existing WWPS, as well as upgrade piping, electrical systems and the WWPS building.

In addition to upgrades to the Kahanahou WWPS, the City proposes to replace a portion of the existing force main that carries wastewater to the Waikapoki WWPS. This existing force main has a history of leak problems and was identified for upgrades. This proposed Kahanahou WWPS and Sewer Force Main Upgrade project was initiated in response to the *2010 Global Consent Decree* between the U.S. EPA and the City to eliminate sanitary sewer overflows (SSO) to further the objectives set forth by the Clean Water Act.

The proposed Kahanahou Wastewater Pump Station and Sewer Force Main Upgrades will increase the capacity of the Kahanahou WWPS to meet future projected peak flow rates and increase its reliability. Additionally, the force main upgrades will increase the capacity to accommodate the projected peak flows and will also redirect wastewater straight towards the Kaneohe Preliminary Treatment Facility and away from Waikapoki, thus eliminating the need to upgrade the Waikapoki WWPS.

Environmental review of this project is required by Chapter 343, Hawaii Revised Statutes. The statutory triggers for preparation of this Environmental Assessment are:

1. Use of County lands and funds and;
2. Use within the Special Management Area (SMA).





## 1.1 KAHANAHOU WWPS LOCATION AND EXISTING FACILITIES

The Kahanahou WWPS is located at 45-13 Ka Hanahou Place, Kaneohe, Hawaii 96744 (Tax Map Key [TMK] 4-5-047:095), a 7,893 square foot parcel in close proximity to Kaneohe Bay (Figure 1). There is an existing concrete masonry unit (CMU) wall on the northeast side of the property and a chain link fence enclosing the remaining sides with a double swinging gate at the driveway entrance. The WWPS and building was completed in 1966 and includes a generator room, pump station area, work area, toilet and service sink, motor control area, and steel stairway with grating landings that lead to the basement pump room.

The parcel is bordered on three sides by residential properties and a private access road, Ka Hanahou Place, provides access to the site. An existing drainage easement runs adjacent to the rear property line and encroaches slightly onto the property. On-site landscaping includes trees; hedges; and a large, flat grassy area at the front of the property.



*Kahanahou Wastewater Pump Station as seen from Ka Hanahou Place.*


The Kahanahou WWPS was put into service in 1966 with a peak flow capacity of 460 gallons per minute (gpm) at 41 feet total dynamic head (TDH). The WWPS was retrofitted in 2006 with a new ball valve assembly and vault and the WWPS capacity was revised to 510 gpm at 41 TDH. One pump can pump 347 gpm at 45 feet TDH and two pumps can operate at 510 gpm at 47.5 feet TDH. The WWPS consists of the following components:


- One wet well measuring 21' 4" long, 8' 0" wide, and 10' 0" high, divided into two sections and separated with isolation stop gates
- Single 15-inch vitrified clay pipe that delivers influent sewage into the wet well via a gated distribution box
- One dry well measuring 21' 4" long and 11' 6" wide and is mechanically ventilated
- One ¼ horsepower (HP) sump pump rated for 25 gpm at 18 feet TDH
- Two 10 HP separately coupled solids handling pumps with extension shafts rated for 510 gpm at 41 feet located in the dry well
- A mechanical ventilation system
- An electrical system
- Controls
- Propane-fueled standby engine generator
- A Supervisory Control and Data Acquisition (SCADA) digital display monitors the pump station operations.

## **1.2 EXISTING SEWER FORCE MAIN**

The original cast iron force main servicing the Kahanahou WWPS was put into service in 1966 and replaced in 2007 with a high density poly-ethylene (HDPE) force main to eliminate increasingly frequent pipe failures, possibly due to corrosion from age and close proximity to the ocean. The original cast iron force main was abandoned in place.

The current 8-inch diameter force main has a capacity of 0.47 mgd and is approximately 800 lineal feet in length, running from the Kahanahou WWPS to a manhole on Springer Place (Figure 2). At Springer Place, the line continues as a 10-inch gravity main for approximately 1,600 lineal feet through the marina area towards the Waikapoki WWPS. The last 272 feet of gravity main before the Waikapoki WWPS are 12 inches in diameter. The tributary areas labeled "Kahanahou Tributary," "Waikapoki Tributary 1", and "Waikapoki Tributary 2" all currently discharge to the Waikapoki WWPS.






**Legend**

- Wastewater Pump Station
- Streams
- Existing Force Main
- Existing Gravity Main
- Kahanou Force Main Route
- TMK Parcels
- Kahanahou Tributary
- Waikapoki Tributary 1
- Waikapoki Tributary 2

**KAHANAHOU WASTEWATER PUMP STATION AND SEWER LINE UPGRADES  
DRAFT ENVIRONMENTAL ASSESSMENT**



For: CITY & COUNTY OF HONOLULU  
Date: September 2014

**Figure 3 Existing Tributary Areas**

## **2. PROPOSED PROJECT DESCRIPTION**

The existing Kahanahou Wastewater Pump Station was found to have inadequate capacity to accommodate future projected peak flows. Any upgrade to the capacity of the WWPS will also require upsizing of the force main that carries the wastewater towards the Kaneohe Wastewater Preliminary Treatment Facility. The force main upgrade is coupled with the pump station upgrade and addressed in this EA. For detailed engineering information and safety measures used, please see Appendices A and B for the engineering reports.

### **2.1 KAHANAHOU WWPS**

The proposed project will replace the existing separately coupled solids handling pumps with new larger capacity constant speed dry pit submersible pumps that will increase the capacity of the WWPS from 0.654 mgd to a capacity of more than 1.26 mgd . Variable Frequency Drives (VFDs) will be installed to control electrical currents and to limit the maximum flow to avoid spills through downstream manholes. The new pump equipment will require additional power, panel space, and working clearances. This will require both interior alterations to the existing WWPS building and the construction of a new emergency generator building. Before the pump station can come online, HECO will be upgrading their surrounding wiring from 1-phase to 3-phase power to increase the voltage for the new pumps.

Within the WWPS building, the existing SCADA system and Motor Control Center (MCC) controls would be replaced and installed in a new air conditioned electrical room. All piping in the dry well would be replaced and the original wet well liner would be replaced with a corrosion-resistant polymer, monolithic lining to protect the concrete from the corrosive effects of wastewater. Additionally, in order to comply with National Fire Protection Association (NFPA) “NFPA 820” (Standard for Fire Protection in Wastewater Treatment and Collection Facilities), the ventilation system would be replaced and new supply and exhaust fans, ductwork, and intake and exhaust openings would be installed.

A new emergency generator building is proposed for construction at the front of the property to house a new diesel fueled generator to replace the existing propane fueled unit. This diesel generator has a larger capacity than the existing propane system, which is needed to accommodate the larger 15 HP pump motors. The new emergency generator building will be 350 square feet (SF) in size to accommodate the new generator and minimum work clearances in front of the electrical panel boxes that are required by code. The proposed generator building materials and finishes would complement and/or match the existing pump station building, including CMU concrete block walls, metal doors and frames, stainless steel louvers, screened openings and a low sloping concrete roof to match the pump station roof slope. Selected CMU walls, doors and louvers would be acoustically treated to minimize noise impacts.

A new 1,000 gallon fuel storage tank will be needed to power this generator with diesel fuel. Although an underground storage tank (UST) was originally intended due to City setback regulations, an aboveground storage tank (AST) was preferred by CSM due to a reduced risk of leaks and groundwater contamination, and lower costs and permitting requirements. (Note that the engineering reports in the appendices still outline details of the UST. They are currently being revised to reflect these changes and show the AST.)

Additional engineering details of pump, ventilation and electrical systems made within the facilities discussed here that are not going to affect the impacts of the project can be found in the attached Design Alternatives Report (WWPS) and Engineering Report (force main) (Appendices A and B).

**Figure 4 Location of New Generator Building**

## 2.2 SEWER FORCE MAIN REPLACEMENT

In order to accommodate the increased capacity of the Kahanahou WWPS, the existing 8-inch force main that conveys wastewater from Kahanahou WWPS to the gravity main conveying it to the Kaneohe Wastewater Preliminary Treatment Facility, must be upsized to a 10-inch force main, from the current capacity of 0.47 mgd to 1.27 mgd.


The new 10-inch force main will be about 3,100 lineal feet in length and will start at the Kahanahou WWPS, run west on Ka Hanahou Place and follow the road north to its intersection with Ka Hanahou Circle. There, it goes west along Kahanahou Circle, turning south at Lilipuna Place, and through a private residence (45-002 Lilipuna Place, TMK 4-5-057:015) at the turnaround. It then passes through the Makani Kai Marina townhouse complex (45-995 Wailele Road, TMK 4-5-002:001) and a linear extension of their parcel toward Wailele Road. The force main crosses Wailele Road and discharges at an existing sewer manhole on Makahio Street where it connects to an existing 8-inch gravity sewer line (Figure 5). Where the new force main will share the same alignment as the existing force main along Ka Hanahou Place, the old force main will be removed. The existing force main in the remainder of the alignment that runs toward the Waikapoki WWPS will be abandoned in place.

The existing 8-inch gravity sewer line at the point of connection on Makahio Street has an estimated capacity of 0.463 mgd which is not sufficient to handle the peak design flow of 1.27 mgd. However, the initial years of flow will be low enough to pass through this whole section and the City is currently looking at upgrading the existing gravity line to meet future capacity demands. Both the existing and proposed sewer systems ultimately flow to the Kaneohe Preliminary Treatment Facility; therefore there will be no change in the amount of discharge to this downstream facility.

The proposed 10-inch force main will replace the existing 8-inch force main and will no longer connect to the existing gravity main discharging to the Waikapoki WWPS. This gravity main is to remain and continue to service the Waikapoki Tributary 1 area (Figure 3). Since the proposed force main will no longer connect to the gravity main discharging to Waikapoki WWPS, the “Kahanahou Tributary” area will no longer flow to the Waikapoki WWPS. The total tributary area discharging to the Waikapoki WWPS will therefore be significantly reduced, eliminating the need for the Waikapoki WWPS to be upgraded to accommodate increased future flows.

Both trench and trenchless construction methods will be considered for this project. The final determination on which method is appropriate will be made during the design phase. Micro-tunneling will likely be used in the Marina Kai townhome complex to avoid disturbing residents.





## **2.3 CONSTRUCTION SEQUENCE AND COSTS**

The estimated construction cost for the force main is \$1,322,063. The WWPS upgrades will cost \$2,959,000. These estimates are for budgetary and preliminary engineering report purposes only, and are subject to change as design progresses. Funding for the project will be provided by the City.

The general construction sequence is as follows:

1. New force main work will be completed without connection to the pump station.
2. Temporary bypass piping and pumps will be installed while connections are made to the new sewer line.
3. New emergency generator building will be constructed and pump station upgrades will then be completed.
4. New force main will be connected and new pumps will be started.
5. Temporary systems will be shut off and removed.

Design plans for the sewer main and wastewater pump station may be found in Appendices A and B.

### 3. ENVIRONMENT, POTENTIAL IMPACTS, AND MITIGATION

#### 3.1 TOPOGRAPHY AND SOILS

The existing ground topography along the proposed sewer force main alignment varies from roughly 4.6 feet to 65.6 feet in elevation. The beginning of the proposed force main at the Kahanahou WWPS is the low point of the line (elevation 4.6 feet). The existing ground generally slopes upward to a high point near the intersection of Lilipuna Road and Lilipuna Place (elevation 65.6 feet). The ground then varies up and down in slope until the end of the proposed force main along Makahio Street (elevation 64.6 feet). See Attachment 1 of Appendix B for the plan and profile sheets with topographic survey background.


The project area is located on four soil types designated by the U.S. Department of Agriculture Soil Survey of 1972 (Figure 6). The Kahanahou Wastewater Pump Station and most of the existing sewer main to be replaced are located on “Fill land, mixed (FL)”; areas filled with material dredged from the ocean or hauled from nearby areas, or garbage and general material from other sources. Part of the existing main and the proposed new main are located on “Kaneohe silty clay, 8-15% slope (KgC)”, a well-drained soil found on terraces and alluvial fans in Windward Oahu. This soil type develops in alluvium and colluvium derived from basic igneous rock. Runoff rates are medium and erosion hazard is moderate. The proposed sewer force main then passes through “Lolekaa silty clay, 3-8% slope (LoB)”, a soil found on terraces and fans, strongly acidic with moderately rapid permeability. Runoff is slow and the erosion hazard is slight. The final portion of the new force main passes through “Hanalei silty clay, 2-6% (HnB)”, a thick, dark grey silty clay with red-brown mottles. The 10-inch thick surface layer is acidic, and the clay loam subsoil is neutral. Runoff is slow and erosion hazard is slight.

#### Impacts and Mitigation

No significant impact to ground topography or soils is expected as a result of this project. The proposed force main will be installed underground and mostly within existing road rights-of-way or easements. Minor grading may be required to return the project corridor to its pre-construction condition. The pump station upgrades are above-ground on the existing property and will not include soil disturbance or grading. For construction of the emergency generator building, there may be some soil disturbance and appropriate BMPs will be used. However, the site topography will not be affected.

Mitigation Measures: Best management practices (BMPs) will be employed to minimize erosion and soil loss during construction. Construction practices will comply with the guidelines found in the following regulations:

- *Revised Ordinances of Honolulu (ROH) Chapter 14, Articles 13-16, relating to Grading, Grubbing, Stockpiling, Soil Erosion, and Sediment Control;*
- *Rules Relating to Soil Erosion Standards and Guidelines (April 1999), Department of Planning and Permitting, City and County of Honolulu; and*
- *Erosion and Sediment Control Guide for Hawaii (1968), Soil Conservation Service, US Department of Agriculture.*





### **3.2 CLIMATE AND HYDROLOGY**

Average annual rainfall in the project area is approximately 50 inches. Predominant tradewinds bring cooler, wetter weather December through April, with slightly higher temperatures and drier conditions during the summer months. The project area is located within the Commission on Water Resource Management (CWRM) Aquifer System Area of Koolaupoko, in the Keaahala watershed between Heeia and Kaneohe watersheds (Figure 7). The CWRM sustainable yield for the Koolaupoko Aquifer System Area is 30 mgd. Perennial Keaahala Stream runs in an easterly direction to the south of the project area, emptying into Kaneohe Bay.

#### **Impacts and Mitigation**

The proposed project will have no impact on the local climate. Ground and surface water hydrology will not be affected and water quality impacts will be beneficial, if any (see Section 3.4). No mitigation measures will be needed.

### **3.3 AIR QUALITY AND NOISE**

Air quality in the vicinity of the project is primarily affected by emissions from vehicular, residential and natural sources, but is considered acceptable due to the prevailing northeasterly tradewinds. Based on data from the State Department of Health (DOH), Clear Air Branch Annual Summary of the 2011 Hawaii Air Quality Data, both State and Federal ambient air quality standards are currently being met in the project vicinity.

Noise levels in the vicinity of the project are low, as land uses in the area are primarily residential. Sources of ambient noise are vehicular travel, recreational use in Kaneohe Bay, and periodic activity at and associated with Kaneohe Marine Corps Base Hawaii.

#### **Impacts and Mitigation**

Impacts on air quality and noise from the pump station upgrades and installation of the sewer main and connections are anticipated to be minor and short-term. Installation of the sewer force main may require machinery that generates noise and dust, and emissions from construction equipment and vehicles may slightly impact air quality in the area. Force main connections are expected to be done at night during non-peak wastewater flow hours to avoid spillage, which may cause temporary noise impacts. The pump station upgrades will be completed after the force main is in place, allowing an instant connection of the new pumps and lines to bring the pump station online. The pump station and emergency generator building will be equipped with sound reducing materials, including solid walls and acoustical rated metal doors, to decrease equipment noise transmission to the neighborhood.

*Mitigation Measures:* The short-term effects on noise and air quality during construction will be mitigated by compliance with the DOH rules on air pollution and noise control. Best management practices during construction typically include:

- Planning the different phases of construction, focusing on minimizing the amount of dust generating materials and activities, centralizing on-site vehicular traffic routes, and locating potentially dusty equipment in areas of least impact;
- Providing an adequate water source at the site prior to start-up of construction activities for dust control;
- Landscaping and rapid covering of bare areas, including slopes;
- Controlling of dust from shoulder and access roads;
- Providing adequate dust control measures during weekends, after hours, and prior to daily start-up of construction activities; and
- Controlling of dust from debris being hauled away from project site.

Heavy vehicles traveling to and from the project site must comply with the provisions of the DOH's Administrative Rules, Chapter 11-42, "Vehicular Noise Control for Oahu." If needed, a noise variance will be obtained for any night work performed during construction. Furthermore, activities associated with the construction phase of the project must comply with the DOH's Administrative Rules, Chapter 11-46, "Community Noise Control" which states that:

- The contractor must obtain a noise permit if the noise levels from the construction activities are expected to exceed the allowable levels of the rules as stated in Section 11-46-6(a).
- Construction equipment and on-site vehicles requiring an exhaust of gas must be equipped with mufflers as stated in Section 11-46-6(b) (1)(A).
- The contractor must comply with the requirements pertaining to construction activities as specified in the rules and the conditions issued with the permit as stated in Section 11-46-7 (d) (4).

### **3.4 WATER QUALITY**

The waters of Kaneohe Bay near the project site are designated class AA by the DOH. The objective of class AA waters is to remain in their natural pristine state as nearly as possible with an absolute minimum of pollution or alteration of water quality from any human-caused source or actions (HAR 11-54). Water quality samples evaluated in DOH's "2014 State of Hawaii Water Quality Monitoring and Assessment Report" show Kaneohe Bay not attaining water quality standards for at least one parameter in each of seven locations.



## **Impacts and Mitigation**

No adverse impacts on surface or ground water quality are anticipated. The proposed project will reduce the risk of wastewater spills by increasing both the pump capacity of the Kahanahou WWPS and the capacity of the force main delivering wastewater to the gravity main, thereby decreasing the risk of spills and groundwater contamination. The long term impacts of the force main will be beneficial to near shore water quality and marine habitat.

*Mitigation Measures:* Best Management Practices (BMPs) will be used during the construction process to avoid dewatering effluent and construction debris from causing runoff problems. Excavated material will be hauled off-site to a site selected by the contractor. If suitable, the excavated material can be used to backfill the shafts or trenches. Excavated material will not be discharged into coastal waters.

The AST to store diesel for the emergency generator will be encased in cement to protect from damage. A double-walled tank and leak detection gauges will monitor any tank failures that could result in leaks.

Prior to construction, compliance with State water quality requirements will be sought. Construction dewatering and storm water permits will be obtained from the City and the State DOH pursuant to City Ordinance and Section 11-55 of the Hawaii Administrative Rules.

As part of the anticipated National Pollutant Discharge Elimination System (NPDES) Permit, water quality sampling and analyses will be undertaken for potential contaminants which may be anticipated. An effluent discharge control plan will be prepared incorporating BMPs, appropriate structural or non-structural mitigative measures such as containment berms and filtration or detention ponds which would control the discharge of stormwater runoff and effluent resulting from construction activities. Specific BMPs will be determined during the detailed design phase.

## **3.5 WETLANDS**

The National Wetlands Inventory identifies several types of wetlands in the State of Hawaii. Estuarine and Marine Deepwater wetlands exist in the vicinity of the project area, extending along the shoreline and up Keaahala Stream (Figure 7). These wetlands provide filtration of storm water and protection against ocean waves. The WWPS and proposed sewer main do not pass through any wetlands.

## **Impacts and Mitigation**


The proposed project does not pass through any wetlands and is not anticipated to have any impacts on wetlands in the area. No mitigative measures are proposed.

### **3.6 FLOODING, TSUNAMI AND FIRE HAZARDS**

The entire sewer force main alignment and WWPS are in the Federal Emergency Management Agency (FEMA) Digital Flood Insurance Rate Map (DFIRM) Zone X, outside the 500-year floodplain. Just south of the project area is Zone X - protected from the 1% annual chance flood by a levee, and Zone AE, a 1% annual chance floodway. See Appendix C for the location of the flood protection levee in relation to the project area. A portion of the force main passes through the tsunami evacuation zone where it passes nearest to Kaneohe Bay (Figure 8).

#### **Impacts and Mitigation**

The proposed project is not anticipated to have any impact on flooding, designated flood zones, or tsunami zones. To reduce any risk of leakage or fire hazards from the diesel AST, the tank will be double-walled, encased in cement and protected by leak gauges that monitor any potential tank failures.



### **3.7 SOCIO-ECONOMIC CONDITIONS**

Land use within the project area is primarily residential. Some recreational land uses may be found along Kaneohe Bay. A private marina is associated with the Makani Kai Marina townhome complex (45-995 Waialele Road, TMK 4-5-002:001) and several small piers extend into the nearshore waters. Windward Mall, a regional shopping center, is located within a mile of the project's western extent.

As mentioned in Section 5.7, the Koolaupoko Sustainable Communities Plan designates the area in the vicinity of the planned Kahanahou WWPS upgrade project as a low density residential area with a modest projected population growth.

#### **Impacts and Mitigation**

The proposed sewer force main and pump station upgrades will accommodate projected wastewater flows to the year 2030. This will provide adequate infrastructure to support the expected population growth in Kaneohe but is not expected to promote growth beyond the modest levels recognized in the Koolaupoko Sustainable Communities Plan (2000), as it will not greatly increase the capacity of the WWPS. However, this neighborhood is already built-out and not expected to incur any more significant development. Overall, this project is expected to benefit the community by minimizing future public health and environmental hazards. It will benefit the City and thereby taxpayers via reduced operating costs and by reducing the risk of legal actions and fines against the City for further Clean Water Act violations. The project will also provide employment for contractors and thereby benefit material suppliers and others in the construction industry.

Two private landowners are expected to be directly impacted by the proposed project: TMKs 4-5-057:015 and 4-5-002:001 (Figure 2). The selected force main alignment will run through an existing five-foot easement on TMK 4-5-057:015 (45-002 Lilipuna Place), which is a private residence. The easement is bound by an existing car port and cannot be widened. The owner of this property has been contacted and understands that a force main is proposed for this easement. While it is preferred that the easement be wider, the City can fit the proposed force main within the existing easement and has not requested that the easement be widened at this time.

The preferred route will also run through the Makani Kai Marina townhouse complex (45-995 Waialele Road, TMK 4-5-002:001). Contact has been made with the complex's General Manager and the City believes that it can route the proposed force main to accommodate the concerns of the Makani Kai Marina owners regarding landscaping and sidewalk alignments.

Additionally, the proposed force main will continue on through the Makani Kai Marina property to where the parcel runs alongside a private driveway (TMK 4-5-002:014) (Figure 5). The sewer alignment is expected to be contained within the Makani Kai Marina TMK 4-5-002:001, but the adjacent private driveway will be needed for construction access. At a minimum, a right-of-entry to this private driveway parcel will be required from the various landowners.

## **3.8 INFRASTRUCTURE**

### **3.8.1 Traffic and Roads**

Vehicular access to the Kahanahou WWPS is from Kahanahou Place, a paved City and County of Honolulu road (Figure 2). From the pump station, the proposed force main runs along Kahanahou Place and left onto Ka Hanahou Circle and continuing west onto Lilipuna Road, then takes a left on Lilipuna Place where it continues through private properties as discussed in Sections 2 and 3.7. The terminus of the proposed force main is on Makahio Street.

#### **Impacts and Mitigation**

Construction activities and the HECO 3-phase power installation will temporarily affect vehicular traffic in the vicinity of the pipe installation work, but are not expected to have a major impact on circulation. A traffic control plan will be developed during the design phase, allowing residents access to and from their homes. Portions of Kahanahou Place, Lilipuna Street and Makahio Street may be temporarily affected by construction work, and other roads in the area may see a slight increase in traffic as a result.

Transfer of construction materials and equipment will be done during off-peak hours to minimize disruption of traffic. Residents in the vicinity of the project area, the Honolulu Police Department, and Honolulu Fire Department will be informed about the timing and location of construction work and alternate routes.

### **3.8.2 Water System and Electrical Service**

Potable water is provided to the Kahanahou WWPS by the Honolulu Board of Water Supply (BWS) water line on Kahanahou Place. Daily water usage consists of sanitary fixtures, landscape irrigation, washdown and other maintenance purposes. Additional water is needed on an intermittent basis for wet well cleaning and maintenance of the odor control system. Electrical power is provided to the Kahanahou WWPS by Hawaiian Electric Company (HECO) overhead service lines along Kahanahou Place. In the event of a commercial power outage, emergency generators will start and essential loads automatically transfer to emergency power.

### **Impacts and Mitigation**

The proposed actions are not anticipated to impact utilities such as potable water and electricity. Prior to construction, all existing utility lines along and in proximity to the force main alignment will be identified and their depths located to avoid damaging them. The contractor will contact the utility companies to ensure proper coordination. In the event of a power outage in the neighborhood, the pump station will continue to operate via its back-up generator.

### **3.8.3 Wastewater System**

This project is the result of litigation aimed at inadequate wastewater systems in the County of Honolulu. The existing Kahanahou Wastewater Pump Station was found to have inadequate capacity to meet future projected flows. The proposed upgrades to the pump station will also require an upsizing of the related force main.

### **Impacts and Mitigation**

Since the construction of this project will upgrade the wastewater system, only beneficial long-term impacts are expected. The proposed project would reduce the risk of wastewater spills by increasing the capacity of the Kahanahou WWPS and the force main to accommodate the anticipated future peak flows from the Kahanahou tributary area. Due to flows from the Kahanahou tributary area bypassing the Waikapoki WWPS after construction of the new force main, the demands on the Waikapoki WWPS will be decreased. Temporary construction-related impacts on the conveyance system will be mitigated via temporary above-ground bypass piping systems and pumps that discharge into a mobile tanker.

## **3.9 HISTORICAL AND CULTURAL RESOURCES**

Cultural Surveys Hawaii (CSH) completed a Literature Review and Field Inspection (LRFI) report in 2014 and submitted it to the State Historic Preservation Division (SHPD) for review and comment. The LRFI includes an analysis of the history of the ahupuaa and previously conducted archaeological studies in the vicinity of the project area. None of the previous archaeological studies completed in Kaneohe and analyzed for the LRFI covered the project area, however some were conducted close by. The Kaneohe ahupuaa was densely populated during pre-contact times and abundant fresh water made it an agriculturally active area with many traditional crops. In post-contact times, sugar, rice, pineapple and ranching all made their way through the ahupuaa. Fishponds were another common historic feature with some fishponds and remnants still visible today.

The field inspection conducted by CSH in 2013 revealed only one historic property close to the project area: the remnants of an old fishpond wall. This stacked stone wall is the relic of Kalokohanahou Fishpond, which will not be altered by the proposed work.

### **Impacts and Mitigation**

The Kahanahou WWPS is built on a historic fishpond that was filled in decades ago. The remnants of Kalokohanahou Fishpond are still present, but will not be altered by the proposed force main and any work on the WWPS itself is not anticipated to disturb any archaeological features. The LRFI report concludes that due to the serpentine nature of the proposed work and the extensive land modifications that have taken place in modern times, the likelihood of intact cultural deposits being present in the project area is very low.

The LRFI report did not anticipate the need for an archaeological inventory survey (AIS) at this time, but an AIS will be conducted if the SHPD requires one upon completion of their review of the LRFI Report (a letter from the City requesting SHPD to review the LRFI was sent and a response is anticipated prior to construction). If SHPD concurs, an archaeological monitoring program will be implemented as part of subsurface excavation and construction activities greater than 12 inches deep. This will identify and protect any potential cultural deposits and/or burials that may be present. If subsurface archaeological materials are encountered during construction, work shall cease in the immediate area and the SHPD will be notified.

### **3.10 FLORA AND FAUNA**

Vegetation in and around the immediate vicinity of the project corridor consists mainly of residential and roadway landscaping. The State GIS vegetation maps show that little to no Federal or State listed or candidate threatened or endangered plant or animal species are currently found within the project area. Wildlife in the project area is limited to mammals and birds which have adapted to the urban environment.

### **Impacts and Mitigation**

Construction will occur primarily within existing road rights-of-way and previously landscaped areas. No threatened or endangered species are anticipated in the project area, due to its residential nature. To the extent possible, vegetation removal will be kept to a minimum, and the project is not expected to have a significant impact on flora and fauna in the area.

### **3.11 CUMULATIVE IMPACTS**

The proposed project is not expected to have a considerable cumulative effect upon the environment, or involve a commitment to larger activities. Upgrades to the Kahanahou WWPS and sewer mains will accommodate the modest population growth outlined in the Koolaupoko Sustainable Communities Plan and are consistent with the vision expressed and by the City and

County of Honolulu's low-density residential zoning in the area. The residential nature of the project area indicates that natural and cultural resources have already been altered from their original state. No threatened or endangered species are expected to be impacted by the proposed upgrades, and archaeological surveys and/ or monitoring will be implemented if required by SHPD.

The primary impacts of the proposed action would be short-term and occur during construction. Best management practices will be used to minimize and mitigate potential negative impacts such as noise, dust, traffic and erosion. Water quality may be temporarily impacted by construction activities, but BMPS will be employed to ensure that impacts are as minimal as possible. In the long-term, water quality will be improved by the proposed upgrades.

The proposed Kahanahou WWPS and sewer main upgrades are consistent with a broader City and County of Honolulu Wastewater Division strategy to maintain adequate wastewater management facilities in Kaneohe. Both the existing and proposed sewer systems flow to the Kaneohe Wastewater Preliminary Treatment Facility; therefore there will be no change in the amount of discharge to this downstream facility. Since the proposed sewer force main will no longer connect to the existing gravity main that discharges to the Waikapoki WWPS, the "Kahanahou Tributary" area will no longer flow to the Waikapoki WWPS. Therefore the Waikapoki WWPS will not need to be upgraded.



#### **4. ALTERNATIVES TO THE PROPOSED PROJECT**

This project consists of two components: (1) improvements to the Kahanahou WWPS, and (2) Replacement of the sewer force main. Each component went through its own engineering/design phase with a detailed report available describing the various routes, design parameters and mechanical alternatives (see Appendices A and B). The alternatives considered and basis for selecting the best alternative are summarized below.

##### **Alternative 1: Preferred Alternative**

The preferred alternative consists of upgrading the existing WWPS and replacing the sewer force main as described in Section 2 of this report. After evaluation of four different alternatives for the WWPS and four alternative routes for the sewer force main, this option was chosen as the least intrusive, most cost-effective and efficient alternative to comply with the requirements of the consent decree.

##### **Alternative 2: No Action Alternative**

The “no build” or “no action” alternative would consist of not making any of the proposed upgrades, resulting in no immediate impacts. However, since this project is aimed at reducing future environmental and public health impacts by increasing the safety and capacity of an aging sewer system, which is also required by the Consent Decree between the City and EPA, this is not a feasible option. The City is legally required to upgrade the WWPS.

##### **Alternative 3: Postponed Action Alternative**

The “postponed action” alternative would consist of postponing any of the proposed upgrades until a future date. As with the “no action” alternative, this would increase the risk of future wastewater spills and resulting environmental and public health problems. As set forth in the Consent Decree, EPA requires the City to upgrade its system within the specified timeline (2020). Postponing the construction could result in not meeting this deadline.

## **Alternative 4: Alternate Locations/ Designs**

### **a) Pump Station**

The purpose of the pump station upgrade is to eliminate future sanitary sewer overflows by increasing the capacity of the pump station to meet future projected peak flow rates and increase pump station reliability. The engineering report (“Design Alternatives Report”, see Appendix A) for the pump station evaluates four serious different engineering alternatives, one of which is the “no action” alternative. As discussed above, this is not feasible. The three remaining alternatives were all of a mechanical/engineering nature consisting of engineering details of the pumps themselves within the footprint of the existing building. Therefore, none of these alternatives would have a different impact on the environment as is the focus of this Environmental Assessment. However, the three alternative designs are summarized briefly as follows. Table 6-1 in the DAR shows an evaluation matrix that was used to select the best alternative.

The chosen alternative (“Alternative 4” in the DAR) involves the installation of new constant speed dry pit submersible pumps at a capacity of 0.79 mgd with one pump operating at 47 feet total dynamic head. The dismissed “Alternative 2” would have involved the installation of new constant speed dry pit submersible pumps with VFDs at a capacity of 0.90 mgd per pump at 55.5 feet total dynamic head. The dismissed “Alternative 3” would have also involved the installation of constant speed dry pit submersible pumps with a capacity of 0.90 mgd at 55.5 feet total dynamic head, but with soft starters instead of VFDs. All three alternative designs are expected to have the same environmental impacts as they only involve details of the pumping mechanism itself. The alternatives went through a rigorous cost-benefit evaluation based on six different criteria: life cycle cost, operator preferences, satisfaction of design objectives, adverse short-term impacts, adverse long-term impacts, and adequacy of addressing existing deficiencies. Alternative 4 was chosen based on this evaluation for meeting the requirements at the lowest cost with the fewest negative long-term impacts.

### **b) Sewer Force Main**


The engineering report for the force main considered four different route alternatives (see Figures 9-13 in this EA). They all started at the Kahanahou WWPS and ran southwesterly, connecting to a manhole and then splitting into various directions. Route 2 was the chosen alternative due to avoiding problematic areas discovered along the other alignments and avoiding crossing of private properties, thus lessening the impacts on the neighborhood. The other three dismissed alignments and reasons for dismissal are summarized as follows:


Route 1 (Figure 10) consisted of a force main running west along Kahanahou Circle and Lilipuna Road until it reached a high point, then beginning as a gravity main down Waialele Road


until Makahio Street, turning west and connecting to an existing manhole. This route was dismissed because the total dynamic head of over 100 feet exceeds the requirements in the City's Design Standards.


Route 3 consisted of a force main running west through a number of private properties and ending at the existing sewer manhole on Makahio Street (Figure 12). This route was dismissed due to narrow space along certain areas of the proposed alignment. This route also crossed the greatest number of private properties, making it the most difficult to implement. Avoidance of private properties is desired per City Design Standards.


Route 4 was an early version of the proposed alignment, consisting of a force main running west along Kahanahou Circle, turning south along Lilipuna Place and through some private properties, transiting a bridge on Waialele Road and connecting to an existing sewer manhole on William Henry Road. This route was dismissed due to potential impacts on an existing rock retaining wall and recently installed pond, as well as complications regarding the bridge crossing and the manhole connection.













## 5. RELATIONSHIP TO FEDERAL, STATE, AND COUNTY PLANS AND POLICIES

### 5.1 HAWAII STATE PLAN

The Hawaii State Plan, Chapter 226 of the Hawaii Revised Statutes (HRS), serves as a guide for the future long-range development of the State. The Plan, first adopted in 1978, identifies the goals, objectives, policies, and priorities for the State. The proposed project is in compliance with and directly supports multiple objectives and policies of the plan by decreasing the risk of sewage spills and protecting environmental and cultural resources. The most relevant sections of the plan in relationship to the proposed project are listed below:

- §226-13 Objectives and policies for the physical environment--land, air, and water quality.
  - (a)(1) Maintenance and pursuit of improved quality in Hawaii's land, air, and water resources.
  
  - (b)(3) Promote effective measures to achieve desired quality in Hawaii's surface, ground, and coastal waters.
  
- §226-14 Objective and policies for facility systems--in general.
  - (a) Planning for the State's facility systems in general shall be directed towards achievement of the objective of water, transportation, waste disposal, and energy and telecommunication systems that support statewide social, economic, and physical objectives.
  
  - (b) To achieve the general facility systems objective, it shall be the policy of this State to:
    - (1) Accommodate the needs of Hawaii's people through coordination of facility systems and capital improvement priorities in consonance with state and county plans.
    - (2) Encourage flexibility in the design and development of facility systems to promote prudent use of resources and accommodate changing public demands and priorities.
    - (3) Ensure that required facility systems can be supported within resource capacities and at reasonable cost to the user.
    - (4) Pursue alternative methods of financing programs and projects and cost-saving techniques in the planning, construction, and maintenance of facility systems.
  
- §226-15 Objectives and policies for facility systems--solid and liquid wastes.
  - (a) Planning for the State's facility systems with regard to solid and liquid wastes shall be directed towards the achievement of the following objectives:

(1) Maintenance of basic public health and sanitation standards relating to treatment and disposal of solid and liquid wastes.

(2) Provision of adequate sewerage facilities for physical and economic activities that alleviate problems in housing, employment, mobility, and other areas.

(b) To achieve solid and liquid waste objectives, it shall be the policy of this State to:

(1) Encourage the adequate development of sewerage facilities that complement planned growth.

## **5.2 HAWAII ADMINISTRATIVE RULES**

The Hawaii Administrative Rules, Title 11, were developed and are enforced by the State Department of Health (DOH). Chapter 62 (finalized in 2004) outlines wastewater systems management to "ensure that the disposal of wastewater from water treatment works and individual wastewater systems:

1. Does not contaminate or pollute any drinking water or potential drinking water supply, or the waters of any beaches, shores, ponds, lakes, streams, groundwater, or shellfish growing waters;
2. Does not encourage the harborage of insects, rodents or other possible vectors;
3. Does not give rise to nuisances;
4. Does not become a hazard or potential hazard to public health, safety and welfare;
5. Contributes to the achievement of wastewater management goals contained in approved county water quality management plans;
6. Reinforces state and county planning policies; and
7. Are consistent with the State's administration of the National Pollutant Discharge Elimination System (NPDES)."

The proposed project will comply with the DOH 's HAR by increasing the capacity of the Kahanahou WWPS, thus reducing the risk of overflows; potential contamination of surrounding lands and waters; nuisance conditions; and potential health impacts. It will also comply with the City's Water Quality Management Plan (1990) and National Pollutant Discharge Elimination System Permit, which were developed with the goal of preserving, restoring, and maintaining water quality. The WWPS and force main upgrades will account for planned modest growth in the area, in alignment with the City's Koolau Poko Sustainable Communities Plan. The City's NPDES permit allows for the discharge of storm water runoff and certain non-storm discharges. Wastewater spills are not a permitted non-storm discharge. This project would reduce the risk of wastewater spills and overflows.

### **5.3 STATE LAND USE LAW, CONSERVATION DISTRICT USE PERMIT**

The State Land Use Law, Chapter 205 of the Hawaii Revised Statutes (HRS), established the State Land Use Commission, which classifies all lands within the state into four land use districts: Urban, Rural, Agricultural and Conservation. The project area is within the Urban District; therefore a Conservation District Use Permit is not required.

### **5.4 STATE HISTORIC AND CULTURAL SITE REVIEW**

Cultural Surveys Hawaii completed a Literature Review and Field Inspection (LRFI) report, which was submitted to the State Historic Preservation Division (SHPD) in January 2014 and is currently under review. The LRFI concluded that based on “the extensive land modification and the seemingly low likelihood of intact cultural deposits in any specific location, an archaeological inventory survey (AIS) of the project area (per the requirements of HAR §13-276) does not appear warranted for development within the project area.” However, an archaeological monitoring program is recommended with an archaeological monitor to be present during all subsurface excavations greater than 12 inches deep to “ensure [that] any subsurface cultural deposits and/or burials as may be present can be identified.” A monitoring program of on-site archaeological monitoring is recommended for all ground disturbance conducted within the project area below the existing ground surface to facilitate the identification and treatment of any historic properties and/or burials that might be discovered during project construction. Any departure from this will require consultation with and written concurrence from SHPD.

The SHPD is currently reviewing the LRFI. It is possible that one or more AIS test excavations could be placed in the open area of the private property near Waialele Street in an area of former land court awards. If recommended, an AIS - and any other actions required by the SHPD - will be completed prior to beginning construction work. Information regarding review of historic sites is presented in Section 3.9 of this Environmental Assessment.

### **5.5 HAWAII COASTAL ZONE MANAGEMENT PROGRAM**

The Hawaii Coastal Zone Management (CZM) Program was enacted in 1977 by Chapter 205A of the Hawaii Revised Statutes. This program was created to coordinate federal, state and county agency efforts in the comprehensive management of Hawaii’s coastal resources. The Hawaii CZM Program is administered by the State Office of Planning. The four individual counties are responsible for administering the CZM program locally through the Special Management Area (SMA) Permit and Shoreline Setback Variance.

#### **5.5.1 Special Management Area (SMA) Permit**

SMA permits are administered by the City Department of Planning and Permitting (DPP). Portions of the proposed project area are within the SMA boundary. However, the SMA Permit

does not regulate “installation of underground utility lines and appurtenant aboveground fixtures less than four feet in height along existing corridors”, unless the “cumulative impact of which may have significant environmental or ecological effect on the special management area...” (LUO Chapter 25, Section 1.3[2][M]). DPP confirmed that the project is exempt from SMA requirements pursuant to Exemption Class #2 (Item 8) of the Department of Environmental Services Comprehensive Exemption List (See Appendix F).

### **5.5.2 Shoreline Setback Variance**

HRS 12-222 defines the shoreline as “the upper reaches of the wash of the waves, other than storm and seismic waves, at high tide during the season of the year in which the highest wash of the waves occurs, usually evidenced by the edge of vegetation growth.” A small portion of the project area along Kahanahou Place near the Kahanahou WWPS is within the shoreline setback area. Any proposed construction within the shoreline setback requires review and granting of a variance. In accordance with LUO Section 23-1.8(b)(2), the Director may grant a variance if the proposed construction meets the Public Interest Standard:

*A variance may be granted for an activity or structure which is undertaken by a public agency or by a public utility regulated under HRS Chapter 269...; provided that the proposal is the practicable alternative which best conforms to the purpose of this chapter and the shoreline setback rules. Public interest shall mean principally of benefit to the general public, as determined by the director.*

A Shoreline Setback Variance will be applied for with the City DPP Land Use Permits Division.

## **5.6 CITY AND COUNTY OF HONOLULU GENERAL PLAN**

The General Plan sets forth the long-range objectives and policies for the general welfare and prosperity of the people of Oahu. The proposed project is in compliance with the applicable objectives and policies, which are listed below:

### **Transportation and Utilities**

- Objective B: To meet the needs of the people of Oahu for an adequate supply of water and for environmentally sound systems of waste disposal.
  - Policy 5: Provide safe, efficient, and environmentally sensitive waste-collection and waste disposal services.
- Objective C: To maintain a high level of service for all utilities.
  - Policy 2: Provide improvements to utilities in existing neighborhoods to reduce substandard conditions.
  - Policy 3: Plan for the timely and orderly expansion of utility systems.

- Objective D: To maintain transportation and utility systems which will help Oahu continue to be a desirable place to live and visit.
  - Policy 1: Give primary emphasis in the capital improvement program to the maintenance and improvement of existing roads and utilities.

## **5.7 KOOLAU POKO SUSTAINABLE COMMUNITIES PLAN**

Oahu is divided into eight planning areas, each of which has a Development Plan or Sustainable Communities Plan adopted by City Council ordinance. The Koolau Poko Sustainable Communities Plan dated August 2000 designates the project area as *low density residential land use*, projected to have limited future population growth. The proposed Kahanahou WWPS upgrades are consistent with maintaining a low-density residential neighborhood in that it is designed to accommodate only a moderate increase in population and it does not oversize its capacity.

## **5.8 KANEOHE BAY MASTER PLAN**

Pursuant to Act 208, Session Laws of Hawaii 1990, the Legislature established the Kaneohe Bay Master Planning Task Force to develop a comprehensive master plan for Kaneohe Bay (KBMPF, 1992). The Kaneohe Bay Master Plan (KBMP) was developed through extensive public participation with the assistance of a Kaneohe fisherman, a commercial recreation businessperson, representatives from neighborhood boards and State agencies, as well as non-voting representatives of the KMCAS and the City and County of Honolulu.

In their development of the Master Plan, the Task Force stated the following land use positions that impact the proposed project:

1. Mitigate deteriorating water quality in key watersheds by installing pollution prevention measures.
2. Restrict development in the watershed in accordance with the Koolau Poko Development Plan. Limit development where a sewage collection system does not exist, and restrict use of septic individual waste water systems to residential lots with sufficient size (15, 000 square feet or more) for proper disposal.
3. Delay northward extension of the sewage collection system until existing infrastructure deficiencies are rectified. Repair and upgrade the existing sewage collection system to prevent by-passes of raw or partially treated sewage effluent into the Bay and to prevent sewage infiltration through groundwater to the Bay.

The planned improvements to the Kahanahou WWPS and force main respond to the above objectives and policies of the Master Plan. The project will help prevent sewage from leaking into surface waters and Kaneohe Bay, thus maintaining water quality and addressing

deciciencies in the existing sewage collection system. Undeveloped areas will be able to connect to the Kahanahou tributary eliminating the need for individual wastewater systems.

## **5.9 FLOOD DISTRICT REGULATIONS**

The project is located within FEMA Flood Zone X, outside of the 500-year floodplain. The National Flood Insurance Program, administered by the State Department of Land and Natural Resources Engineering Division, does not regulate developments within Zone X.

## **5.10 SPECIAL DISTRICTS**

The project is not located within any special district as identified in Chapter 21, Article 9 Special District Regulation of the Revised Ordinances of Honolulu: Hawaii Capitol, Diamond Head, Punchbowl, Chinatown, Thomas Square/Honolulu Academy of Arts, Waikiki, and Haleiwa.

## **5.11 KANEOHE TOWN PLAN (2009)**

The Kaneohe Town Plan (2009) planning area includes the neighborhood where the Kahanahou WWPS and force main replacement is proposed. However, the Plan focuses on five areas that exclude the Kahanahou project area: Windward Mall, the Civic Center Neighborhood Park, Windward City Shopping Center, Windward Community College, and the Bay View Golf Course. The vision articulated by this plan is:

*“The Kaneohe Town Center is a gathering place that is accessible, conveniently located, safe, and open to all.*

*It captures and reflects the beauty of Kaneohe and the surrounding Koolau Mountains and Kaneohe Bay.*

*It is both a resource and a place of diverse services and activities for residents and visitors, and attracts a wide range of people that range in age from the very young to the elderly.*

*It incorporates the distinctive community culture (i.e. caring, local, small scale, friendly) and strengthens the spirit of aloha that is Kaneohe.”*

The Kahanahou WWPS Sewer Force Main Upgrades would help to protect the beauty of Kaneohe by protecting against sewer overflows and should not negatively impact the vision for Kaneohe as expressed by the Kaneohe Town Plan. The Kaneohe Town Plan had no other specific proposals for the project area or its immediate vicinity.

## **5.12 CITY AND COUNTY OF HONOLULU ZONING**

The Kahanahou WWPS and the existing sewer force main are located in the City and County of Honolulu residential district R-10. Portions of the proposed force main pass through residential district R-5 and R-7.5. The proposed improvements to the Kahanahou WWPS and sewer mains

are part of a project constituting "public use" under the City and County of Honolulu Land Use Ordinance (LUO), which may occur in any zoning district. The proposed emergency generator building will fall within the 30-foot front yard setback requirement.

## **6. PERMITS AND APPROVALS**

### **6.1 CITY AND COUNTY OF HONOLULU PERMITS**

- Permit to Discharge Effluent  
*Department of Environmental Services*
- Special Management Area (SMA) Use Permit: EXEMPT  
*Department of Planning and Permitting (DPP)*
- Shoreline Setback Variance  
*Department of Planning and Permitting*  
*State Surveyor and Department of Land and Natural Resources (certification of a map of the shoreline and shoreline setback line)*
- Sewer Connection Application  
*Department of Planning and Permitting*
- Trenching Permit  
*Department of Planning and Permitting*
- Grading and Grubbing Permit  
*Department of Planning and Permitting*
- Street Usage Permit  
*Department of Transportation Services (DTS)*
- Zoning Waiver for front yard setback  
*Department of Planning and Permitting*

### **6.2 STATE OF HAWAII PERMITS**

- Chapter 6E, Hawaii Revised Statutes Review – archaeological monitoring plan approval and archaeological inventory survey (if required)  
*Department of Land and Natural Resources, State Historic Preservation Division*
- National Pollutant Discharge Elimination System (NPDES) permit  
*Department of Health*
- Community noise permit and noise variance  
*Department of Health*
- HRS 130-50 Document Transmittal Form  
*Disability and Communication Access Board*



## 7. DETERMINATION

Based on the analysis of information in this EA, the proposed project is not anticipated to have significant impacts to the natural, built, or social environment. Therefore, it is anticipated that a Finding of No Significant Impact (FONSI) will be issued and that an Environmental Impact Statement (EIS) is not required.

### 7.1 FINDINGS AND REASONS SUPPORTING THE DETERMINATION

The potential effects of the proposed project are evaluated based on the significance criteria identified in the Hawaii Administrative Rules, Section 11-200-12. The following is a summary of the potential effects of the project.

1. **Involves an irrevocable commitment to loss or destruction of any natural or cultural resource.**

The project is not expected to involve an irrevocable commitment to loss or destruction of any natural or cultural resource. The project proposes to install a force main in areas that have been previously disturbed by utility lines, residential development, or road construction. Additional proposed work is to take place within an existing pump station facility and will not extend the footprint of the facility. There are no significant biological resources in the area and recommendations by the SHPD will be followed to protect cultural resources, should any be discovered during construction.

2. **Curtails the range of beneficial uses of the environment.**

The project will not permanently curtail the beneficial uses of the environment. The proposed pipe replacement will be located underground, mostly within existing public roadways. Pump station upgrades will happen within an existing City property and facility.

3. **Conflicts with the state’s long-term environmental policies or goals and guidelines as expressed in Chapter 344, HRS, and any revisions thereof and amendments thereto, court decisions, or executive orders.**

The project will be in conformance with Chapter 344, HRS. The proposed project will increase the capacity of the Kahanahou WWPS and force main and reduce the flow through the existing gravity main servicing the Waikapoki tributary area 1. This is anticipated to reduce the risk of future wastewater spills.

4. **Substantially affects the economic or social welfare of the community or state.**

The project is not anticipated to have significant effects on the economic and social welfare of the community or state other than providing an improved wastewater system that would benefit the community it services.

5. **Substantially affects public health.**

The project will improve WWPS and force main reliability and is not anticipated to have any adverse effects on public health. Rather, it will have a positive impact on public health by reducing the risk of future wastewater spills.

6. **Involves substantial secondary impacts, such as population changes or effects on public facilities.**

The project is not anticipated to result in substantial secondary impacts. The project is designed only to prevent overflows and accommodate the modest population increase projected in the Koolaupoko Sustainable Communities Plan.

7. **Involves a substantial degradation of environmental quality.**

The project is not anticipated to degrade environmental quality; it is anticipated to protect environmental quality by preventing sewer overflows.

8. **Is individually limited but cumulatively has considerable effect upon the environment or involves a commitment for larger actions.**

The project is not anticipated to result in cumulative effects or involve a commitment for larger actions. In fact, it will reduce the demands on another existing facility and will therefore help reduce the need for additional actions.

9. **Substantially affects a rare, threatened, or endangered species, or its habitat.**

The project is not anticipated to affect any rare, threatened, or endangered species or habitat. There are no known significant biological resources in the project area.

10. **Detrimentially affects air or water quality or ambient noise levels.**

The project is not anticipated to affect long term air quality, water quality, or ambient noise levels. The project may temporarily affect air, water, or noise quality during construction but BMPs will be implemented to minimize any impacts.

11. **Affects or is likely to suffer damage by being located in an environmentally sensitive area such as a flood plain, tsunami zone, beach, erosion-prone area, geologically hazardous land, estuary, fresh water, or coastal waters.**

The project is located within the Special Management Area and a portion of the proposed force main is within the Shoreline Setback Area. However, the force main will be located underground and is not anticipated to be impacted by a tsunami. Appropriate permits and variances will be obtained for the SMA and shoreline setback. Best management practices will be used during construction to minimize any impacts on coastal waters. The WWPS is not located within the Tsunami zone or Shoreline Setback Area.

**12. Substantially affects scenic vistas and viewplanes identified in county or state plans or studies.**

The project will not affect any scenic vistas or view planes identified in county or state plans or studies because most of the upgrades will be underground. Above-ground work will not change the height of the existing building or otherwise substantially affect viewplanes.

**13. Requires substantial energy consumption.**

The project will not require substantial energy consumption. A slight increase in energy use for the new pumps will be easy to accommodate by the existing HECO system and backup generators.

## 8. REFERENCES

City and County of Honolulu, Department of Environmental Services. *Storm Water Best Management Practice Manual – Construction* (November 2011)

City and County of Honolulu, Department of Planning and Permitting. *Revised Ordinances of Honolulu (ROH) Chapter 21. Land Use Ordinance* (1990).

City and County of Honolulu. *Oahu General Plan* (2002).

City and County of Honolulu. *Koolau Poko Sustainable Communities Plan* (2000).

Okahara and Associates, Inc. *Preliminary Engineering Report for Kahanahou Wastewater Pump Station Force Main Sewer Line Study* (October 2013).

State of Hawaii. *Hawaii Administrative Rules. Chapter 11-54 Water Quality Standards*. pp. 54-13. (October 2012)

State of Hawaii. *Hawaii Revised Statutes*.

State of Hawaii Department of Health (DOH), Clear Air Branch. *Annual Summary of the 2011 Hawaii Air Quality Data*. (2012)

State of Hawaii Office of Planning. *Geographic Information System (GIS) Data Downloads* <http://planning.hawaii.gov/gis/download-gis-data/>. Accessed November 2013.

United States Department of Agriculture (USDA) Soil Conservation Service. *Soil Survey of Islands of Kauai, Oahu, Maui, Molokai, and Lanai, State of Hawaii*. (1972).

# Kahanahou Wastewater Pump Station and Sewer Force Main Upgrades Kaneohe, Oahu

## DRAFT ENVIRONMENTAL ASSESSMENT

---

### *APPENDICES*

- A Preliminary Design Alternatives Report for Kahanahou Wastewater Pump Station Upgrade (Okahara and Associates, Inc., January 2011)
- B Final Engineering Report - Kahanahou Wastewater Pump Station Force Main Sewer Line Study, Kaneohe, Oahu, Hawaii (Okahara and Associates, Inc., December 2013, Revised June 2015)
- C Digital Flood Insurance Map (DFIRM) (Federal Emergency Management Agency, 2013)
- D Pre-Environmental Assessment Consultation
- E Literature Review and Field Inspection Report (LRFI) (Cultural Surveys Hawaii, Inc., January 2014)
- F Special Management Area Determination Letter (City and County of Honolulu Department of Planning and Permitting, March 2010)

**Prepared for:**  
**CITY AND COUNTY OF HONOLULU**  
**Department of Design and Construction**  
**Wastewater Division**

**August 2015**

**Prepared by:**  
**Townscape, Inc.**



## **Appendix A**

Preliminary Design Alternatives Report for Kahanahou Wastewater Pump Station Upgrade  
Okahara and Associates, Inc., January 2011





**PRELIMINARY DESIGN ALTERNATIVES REPORT  
FOR  
KAHANAHOU WASTEWATER PUMP STATION UPGRADE**

**Prepared for :**

**City and County of Honolulu  
Department of Design and Construction  
Wastewater Division  
650 South King Street  
Honolulu, Hawaii 96813**

**Prepared By:**

**Okahara and Associates, Inc.  
677 Ala Moana Boulevard, Suite 703  
Honolulu, Hawaii 96813**

**JANUARY 2011**

# TABLE OF CONTENTS

## CHAPTER 1 – EXECUTIVE SUMMARY

Executive Summary .....	1-1
-------------------------	-----

## CHAPTER 2 – PUMP STATION

2.1 Introduction .....	2-1
2.2 Existing Pump Station Description .....	2-2
2.3 Research and Analysis .....	2-2
2.4 Flow Analysis .....	2-20
2.5 Design Alternatives .....	2-28

## CHAPTER 3 – ARCHITECTURAL

3.1 Introduction .....	3-1
3.2 Existing Conditions.....	3-1
3.3 Design Alternatives .....	3-4

## CHAPTER 4 – STRUCTURAL

4.1 Introduction .....	4-1
4.2 Emergency Generator Shed.....	4-1
4.3 Lining of the Wet Well .....	4-1

## CHAPTER 5 – ELECTRICAL

5.1 Existing Electrical System .....	5-1
5.2 New Electrical Systems.....	5-4

## **CHAPTER 6 – EVALUATION OF ALTERNATIVES AND OPTIONS**

6.1	Introduction .....	6-1
6.2	Alternative Selection Evaluation Criteria .....	6-1
6.3	Alternative Evaluation .....	6-7
6.4	Alternative Options Evaluation .....	6-11
6.5	Description of Methods for Replacement .....	6-17

## **CHAPTER 7 – RECOMMENDATIONS**

7.1	Recommendations .....	7-1
-----	-----------------------	-----

## **APPENDIX**

A	Pump Station Calculations .....	A-1
B	Kahanahou WWPS SCADA Data, Oct. 31, 2006 ~ Nov. 2, 2006.....	B-1
C	INFIX Pump Station Report.....	C-1
D	Historical Flow Rates and Power Use .....	D-1
E	Historical Rainfall Data .....	E-1
F	Mechanical Catalog Cuts .....	F-1
G	Structural Catalog Cuts .....	G-1
H	Electrical Calculations and Catalog Cuts .....	H-1
I	Cost Estimate.....	I-1
J	Present Worth Cost Analysis.....	J-1
K	Permits.....	K-1
L	References.....	L-1

## LIST OF CHARTS, TABLES AND FIGURES

Chart 2-1: Kahanahou WWPS, Existing Centrifugal Pump and System Curves for Oct 31~Nov 2, 2006.....	2-16
Chart 2-2: Kahanahou WWPS, Monthly Maximum / Average / Minimum Daily Flow Rates .....	2-23
Chart 2-3: Kahanahou WWPS, Total Flow Per Month / Energy Use Per Month / Flow Per kWh .....	2-24
Chart 2-4: Kahanahou WWPS, Instantaneous Flow Rates for Selected Days with the Highest Recorded Daily Flowrates.....	2-27
Chart A-4.1: Kahanahou WWPS, Alternative No. 1: Existing Centrifugal Pump and System Curves.....	A-15
Chart A-5.1: Kahanahou WWPS, Alternative No. 2 & 3: Dry Pit Submersible Pump and System Curves.....	A-20
Chart A-6.1: Kahanahou WWPS, Alternative No. 4: Dry Pit Submersible Pump and System Curves.....	A-23
Table 2-1: Operating and Alarm Elevations .....	2-3
Table 2-2: Limited Downstream Sewer Analysis (Manning's Equation) .....	2-10
Table 2-3: INFIX Projected Wastewater Flow Rates.....	2-21
Table 6-1: Alternative Selection Evaluation Matrix.....	6-3
Table 6-2: Alternative Option Summary .....	6-12
Table A-2.1: Minimum Wet Well Volume Based on Maximum Wastewater Retention Time .....	A-5
Table A-2.2: Motor Starts Per Hour Based on Maximum Wet Well Volume.....	A-5
Table A-2.3: Minimum Wet Well Volume Based on Maximum Motor Starts Per Hour .....	A-5
Table A-2.4: Minimum Recommended Wet Well HWL Elevation Set Point .....	A-5
Table A-3: Kahanahou WWPS, Net Positive Suction Head Available for Alternative No. 2, 3 and 4.....	A-9
Table A-4.1: Kahanahou WWPS, Alternative No. 1: Existing Centrifugal Pump and System Curves.....	A-16
Table A-5.1: Kahanahou WWPS, Alternative No. 2 & 3: Dry Pit Submersible Pump and System Curves.....	A-21
Table A-6.1: Kahanahou WWPS, Alternative No. 4: Dry Pit Submersible Pump and System Curves.....	A-24
Table B-1: Kahanahou WWPS SCADA Data (Oct. 31, 2006 ~ Nov. 2, 2006)...	B-2
Table D-1: Kahanahou WWPS Historical Flow Rates and Power Use .....	D-2
Table J-1: Kahanahou WWPS, Alternative No. 1: No Action, Present Worth Cost Analysis.....	J-2
Table J-2: Kahanahou WWPS, Alternative No. 2: New C/S Dry Pit Submersible Pumps w/ VFD, Present Worth Cost Analysis .....	J-4
Table J-3: Kahanahou WWPS, Alternative No. 3: New C/S Dry Pit Sub. Pumps w/ Soft Starters, Present Worth Cost Analysis .....	J-5
Table J-4: Kahanahou WWPS, Alternative No. 4: New C/S Dry Pit Sub. Pumps w/ Soft Starters Present Worth Analysis .....	J-6

Table K-1: Kahanahou WWPS, Project Permit List.....	K-2
Figure 1-1: Project Map .....	1-2
Figure 1-2: Existing Site Plan.....	1-3
Figure 2-1: Alternative No. 1, Existing Basement Plan and Material List .....	2-4
Figure 2-2: Alternative No. 1, Existing Intermediate and Ground Floor Plans ....	2-5
Figure 2-3: Alternative No. 1, Existing Building Section .....	2-6
Figure 2-4: Alternative No. 1, Existing Building Section .....	2-7
Figure 2-5: Sewer Site Plan .....	2-9
Figure 2-6: Alternative No. 2, 3 and 4, Existing Basement Plan and Material List.....	2-4
Figure 2-7: Alternative No. 2, 3 and 4, Existing Intermediate and Ground Floor Plans .....	2-5
Figure 2-8: Alternative No. 2, 3 and 4, Existing Building Section .....	2-6
Figure 2-9: Alternative No. 2, 3 and 4, Existing Building Section .....	2-7
Figure 3-1: Alternate Nos. 2, 3 & 4, Architectural Site Plan .....	3-8
Figure 5-1: Alternative No. 1, Existing Electrical Site Plan.....	5-10
Figure 5-2: Alternative No. 2, 3 and 4, Electrical Site Plan .....	5-11
Figure 5-3: Alternative No. 1, Existing Electrical Plan .....	5-12
Figure 5-4: Alternative No. 2, 3 and 4, Electrical Plan.....	5-13
Figure 5-5: Alternative No. 2, 3 and 4, Generator Room - Electrical Plan.....	5-14
Figure 5-6: Alternative No. 1, Existing One-Line Diagram .....	5-15
Figure 5-7: Alternative No. 2, 3 and 4, One-Line Diagram .....	5-16
Figure 6-1: New Site Plan .....	6-18


## **CHAPTER 1 – EXECUTIVE SUMMARY**

The City and County of Honolulu (City) Wastewater Division, Department of Design and Construction (DDC), proposes to correct hydraulic deficiencies with the Kahanahou Wastewater Pump Station (WWPS) identified in the "*Sewer Rehabilitation and Infiltration and Inflow Minimization Study, Volume 3 of 9, Kailua-Kaneohe I/I Engineering Report*", December 1999. The intent of this Design Alternatives Report (DAR) is to identify and evaluate hydraulic as well as structural, architectural, mechanical and electrical related problems with the WWPS, assemble basic information about the facility, present the results of field investigations, analyze and evaluate the results, and propose alternatives to address identified problems. The report is broken down into several chapters including Pump Station, Structural, Architectural, Electrical, Evaluation of Alternatives and Recommendations.

The facility is located at 45-13 Kahanahou Place, Kaneohe, Koolau District, between Kahanahou Circle and Kahanahou Place, TMK 4-5-047:095. See Figure 1-1 for a project map of the area, and Figure 1-2 for a site plan of the facility.

Kahanahou WWPS was constructed and put into service in 1966 with two (2) constant speed pumps rated at 460 gallons per minute (gpm) @41 feet total dynamic head (TDH). The WWPS was retrofitted in 2006 with a new ball valve assembly and vault, and new replacement high density poly-ethylene (HDPE) force main. The existing cast iron force main was abandoned in place and the new WWPS capacity was revised to 510 gpm @41 feet TDH.

Due to suspected high levels of infiltration/inflow, the WWPS has been determined to be undersized based on historical flow data. The required pumping capacity for each of the two pumps is approximately 0.90 million gallons per day (mgd), or 625 gpm @53 feet TDH. This project to increase the hydraulic capacity of the WWPS was recommended in the "*Final Sewer I/I Plan*", December 1999, which was



<b>LEGEND:</b>	Sewer pipes	Existing Wastewater Pump Stations	Existing Manholes
----------------	-------------	-----------------------------------	-------------------

**Kahanahou WWPS Upgrade  
Design Alternative Report**  
**Figure 1-1**  
Department of  
Design & Construction



N  
 SCALE: 1" = 750'

**PROJECT MAP**

KAHANAHOU  
 WWPS

Wastewater Division Date: January 2011

J:\D:\PROJ\21002\REPORT\FIG 1-SITE.DWG/1=240/12-19-10/XREF=0A1117.X=10122



DESCRIPTION

**EXISTING SITE PLAN**  
 SCALE: 1" = 20'-0"

DEPARTMENT OF DESIGN AND CONSTRUCTION  
 WASTEWATER DIVISION  
**KAHANAHOU WASTEWATER  
 PUMP STATION UPGRADE**  
 CITY AND COUNTY OF HONOLULU  
 KANEHOE, OAHU



submitted to the USEPA as a requirement of consent decree CIV. No. 94-00765 DAE.

Four alternatives were investigated to increase the pumping capacity of Kahanahou WWPS. The estimated construction costs of the alternatives range from \$0 for no action to \$3,076,00 to replace the existing pumps with variable frequency driven submersible pumps. The recommendation of this report is to implement and proceed with Alternative No. 4. Alternative No. 4 calls for the replacement of the existing pumps with new larger capacity constant speed submersible pumps. Alternative No. 4 is estimated will cost approximately \$2,959,000 to construct.

## **CHAPTER 2 – PUMP STATION**

### **2.1 INTRODUCTION**

The intent of this project is to correct hydraulic deficiencies with the Kahanahou WWPS identified in the "*Sewer Rehabilitation and Infiltration and Inflow Minimization Study, Volume 3 of 9, Kailua-Kaneohe I/I Engineering Report*", December 1999. The intent of this DAR is to identify and evaluate hydraulic as well as structural, architectural, mechanical and electrical related problems with the WWPS, assemble basic information about the facility, present the results of field investigations, analyze and evaluate the results, and propose alternatives to address identified problems with preliminary layouts and opinions of probable construction cost. The intent of this report does not include addressing deficiencies with the sewer collection system located upstream or downstream of the WWPS.

The Pump Station chapter is broken down into the following four (4) subchapters:

- Existing Pump Station Description: This subchapter describes the major components of the existing WWPS.
- Research and Analysis: This subchapter summarizes the findings of field investigations and background research. It also presents an evaluation of the existing WWPS and force main as to their condition, capacity and constraints.
- Flow Analysis: This subchapter presents historical flow data and flow rate projections. DAR flow projections considered the results of INFIX, a City approved sewer flow modeling computer program, and an analysis of historical sewer flow data.
- Design Alternatives: This subchapter describes alternatives that are presented for consideration. It also describes alternatives that were dismissed and reasons for the dismissal.

## **2.2 EXISTING PUMP STATION DESCRIPTION**

Kahanahou WWPS is comprised of a wet well, a dry well, two (2) separately coupled solids handling pumps with extension shafts, a mechanical ventilation system, an electrical system, controls and a propane fueled standby engine generator. The wet well interior measures approximately 21'-4" long by 8'-0" wide by 10'-0" high. The wet well is divided into two sections and are separated with isolation stop gates. A single 15-inch vitrified clay pipe (VCP) delivers influent sewage into the wet well via a gated distribution box. The dry well interior measures approximately 21'-4" long by 11'-6" wide and is mechanically ventilated. It has one (1) 1/4 horsepower sump pump rated for 25 gpm @18 feet TDH. Two (2) 10 horsepower, separately coupled, solids handling pumps with extension shafts rated for 510 gpm @41 feet TDH are located in the dry well and provide approximately 30.2 to 32.2 feet of lift depending on the wet well water level. The low water and high water level elevation set points are (-)13.50 and (-)11.50 feet respectively. Each pump has a 6" diameter suction connection, 8" diameter suction lateral, 4" diameter discharge connection, 6" diameter discharge lateral, inlet bell, valves and appurtenances. Both pumps are connected to an 8" diameter discharge header, venturi meter and force main.

## **2.3 RESEARCH AND ANALYSIS**

Extensive research was undertaken to determine the condition of the existing WWPS, force main and equipment. Record drawings, associated design reports and Wastewater records were reviewed to ascertain the intended design of the WWPS. Wastewater Division personnel with DDC and the Department of Environmental Services (ENV), including Collection System Maintenance (CSM) and Treatment & Disposal (T&D), were consulted to verify and confirm conditions reported by reference drawings or by Wastewater Division personnel.

### 2.3.1 Existing Pump Station & Level Elevation Set Points

Copies of the original WWPS design approved in 1964 as well as improvements completed in 2007 were used to evaluate the existing WWPS conditions. Field visits were conducted to photograph and visually verify the existing WWPS conditions as shown on the design drawings. The WWPS piping configuration was found to be similar to the one shown on the design drawings. See Figures 2-1, 2-2, 2-3 and 2-4 for the existing WWPS plan and sections based on a combination of field measurements and reference drawings.

A review of on-site placards, Supervisory Control and Data Acquisition (SCADA) digital display and the O&M manual suggest that the pump level control set points were altered from the original design. The original design called for a high water level of (-)11.50 feet and a low water level of (-)14.50 feet. The placard mounted on the wall calls for a high water level of (-)11.50 feet and a low water level of (-)13.50 feet. The SCADA display indicated the lead pump started at a high water level of (-)11.28 feet and stopped at a low water level of (-)13.68 feet. It is postulated that the low wet well level elevation set point was raised such that it is higher than the top of the pumps' stuffing box to prevent the loss of prime. See Table 2-1 for a summary of operating and alarm elevations.

**Table 2-1: Operating and Alarm Elevations**


Settings	Original Design Elevations <sup>1</sup>	Revised Elevations <sup>2</sup>	SCADA Elevations <sup>3</sup>
High Water Alarm	(-)9.25	(-)8.75	None Observed
Pump 2 On	(-)9.75	(-)9.00	None Observed
Pump 2 Off	(-)14.50	(-)11.00	None Observed
Pump 1 On	(-)11.50	(-)11.50	(-)11.28
Pump 1 Off	(-)14.50	(-)13.50	(-)13.68
Low Water Alarm	(-)15.50	(-)15.50	None Observed

<sup>1</sup>Original design elevations are based on Kahanahou Sewage Pumping Station & Force Main, City Job No. 63-63 Final design drawings dated 1964.

<sup>2</sup>Revised elevations are based on Operating and Alarm Elevations posted at the WWPS and in the *"Kahanahou Wastewater Pump Station, Volume I of II Operating Instructions"*, February 1997. Note that the identical lead lag pump elevations were taped on the existing Healy Ruff float switch housing.

<sup>3</sup>SCADA elevations are based on observed readouts on the SCADA panel display. Observations were made on June 10, 2010.


J:\D:\PROJ\21002\REPORT\FIG 2-PLAN-SECT.DWG/1=1/12-27-10\XREF=0A117,x-Basement,x-Int,x-plan,x-sect-a, x-sect-b



**EXISTING BASEMENT PLAN**

SCALE: 1/4" = 1'-0"

MATERIAL LIST	
ITEM NO.	DESCRIPTION
1	EXIST. 8" - 90° BEND, FLANGE AND BELL
2	EXIST. 8" - PIPE SPOOL, FE
3	EXIST. 8" - GATE VALVE, FE
4	EXIST. 8" - FLEXIBLE COUPLING
5	EXIST. 8" - PIPE SPOOL, FExPE
6	EXIST. 8"x6" - ECCENTRIC REDUCER, FE
7	EXIST. PATTERSON, MODEL FFN, SOLIDS HANDLING PUMP
8	EXIST. 6"x4" - ECCENTRIC REDUCER, FE
9	EXIST. 6" - CHECK VALVE W/ WEIGHT, FE
10	EXIST. 6" - GATE VALVE, FE
11	EXIST. 6" - LR BASE BEND, FE
12	EXIST. 6" - PIPE SPOOL, FE
13	EXIST. 6" - 45° BEND, FE
14	EXIST. 8"x8"x6" - WYE, FE
15	EXIST. 8" - PIPE SPOOL, FE/BE
16	EXIST. 8"x6" - REDUCER, FE
17	EXIST. 6" - PIPE SPOOL, FE
18	EXIST. 6" - 90° BEND, FE
19	EXIST. 10 HP MOTOR
20	EXIST. 6" - GATE VALVE WHEEL OPERATORS



DESCRIPTION

ALTERNATIVE NO. 1  
EXISTING BASEMENT PLAN  
AND MATERIAL LIST

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE**  
KANEHOE, OAHU


OKAHARA AND ASSOCIATES, INC.

JOB NUMBER DATE  
2009107 JAN 2011

FIGURE 2-1


PAGE 2-4

J:\D:\PROJ\21002\REPORT\FIG 2-PLAN-SECT.DWG/1=1/12-27-10/XREF=0A117,x-Basement,x-Int,x-plan,x-sect-a, x-sect-b




**EXISTING INTERMEDIATE PLAN**

SCALE: 1/4" = 1'-0"



**EXISTING GROUND FLOOR PLAN**

SCALE: 1/4" = 1'-0"



**NOTE:**  
SEE FIGURE 2-1 FOR MATERIAL LIST.

DESCRIPTION

**ALTERNATIVE NO. 1**  
**EXISTING INTERMEDIATE AND GROUND**  
**FLOOR PLANS**

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER**  
**PUMP STATION UPGRADE**  
KANEHOE, OAHU

**OKAHARA AND ASSOCIATES, INC.**


JOB NUMBER  
2009107

DATE  
JAN 2011

FIGURE 2-2

PAGE 2-5

J:\D:\PROJ\21002\REPORT\FIG 2-PLAN-SECT.DWG/1=1/12-27-10/XREF=OA1117,x-Baseament,x-int,x-plan,x-sect-a, x-sect-b



NOTE:  
SEE FIGURE 2-1 FOR MATERIAL LIST.


DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE**  
KANEHOHE, OAHU

ALTERNATIVE NO. 1  
EXISTING BUILDING SECTION

DESCRIPTION



J:\D:\PROJ\21002\REPORT\FIG 2-PLAN-SECT.DWG/1=1/12-27-10/XREF=OA1117,x-Baseament,x-Int,x-plan,x-sect-a, x-sect-b



EXISTING EXHAUST FAN DISCHARGE UP THRU ROOF

ELEV 6.00

EXISTING 8" DISCHARGE HEADER

ELEV 0.00

ELEV -4.75

ELEV -16.50

### EXISTING SECTION

SCALE: 1/4" = 1'-0"



SCALE: 1/4"=1'-0"

**NOTE:**  
SEE FIGURE 2-1 FOR MATERIAL LIST.

DESCRIPTION

ALTERNATIVE NO. 1  
EXISTING BUILDING SECTION

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE**  
KANEHOHE, OAHU



OKAHARA AND ASSOCIATES, INC.

JOB NUMBER  
2009107

DATE  
JAN 2011

FIGURE 2-4

PAGE 2-7







Current operating elevation settings are in compliance with the "*Design Standards of the Department of Wastewater Management, Volume 1, July 1993*" (Standards). According to the Standards, the desired high water level is the invert of the incoming sewer and the maximum allowed high water level is the crown of the incoming sewer.

The high water level of (-)11.50 feet is equal to the invert of the incoming sewer. Note that the maximum high water level of (-)9.00 is above the crown of the incoming sewer by 15 inches.


CSM was consulted about any existing surcharging problems associated with Kahanahou WWPS to determine if there are issues with existing wet well set points or capacity shortfalls. They reported no known problems with surcharging upstream of the pump station. They did however report a problem with a portion of the downstream gravity main. One of the downstream manholes apparently suffered from sanitary sewer overflow problems. The City reportedly raised the height of the manhole and also installed a throttling ball valve on the force main at the WWPS. It should be noted that although CSM did not indicate a serious surcharging problem downstream of the pump station, "*Design Alternatives Report for Kahanahou Wastewater Pump Station Force Main Reconstruction*", September 8, 2005, did suggest that there is a notable surcharge situation downstream of the pump station.

An analysis of the existing manhole inverts revealed that GIS recorded data agree with the reported information. See Figure 2-5 of existing sewer mains, sewer manholes and invert elevations in the area. According to the GIS data, the high wet well water level of (-)11.50 is lower than all of the upstream manhole inverts. Furthermore, the maximum high wet well water level of (-)9.00 is higher than only a small portion of the upstream manholes and it would suggest that there are little, if any, surcharging problems with the upstream mains.




LEGEND:					
	Sewer pipes		Existing Wastewater Pump Stations		Existing Manholes & Invert Elevations

**Kahanahou WWPS Upgrade  
Design Alternative Report**  
**Figure 2-5**  
Department of  
Design & Construction

  
 N  
 SCALE: 1" = 250'

**PROJECT MAP**

  
 KAHANAHOU  
 WWPS  
 Wastewater Division      Date: January 2011

A flow analysis of a small portion of the gravity sewer main immediately following the Kahanahou WWPS was conducted to verify the capacity of the downstream sewer system. See Table 2-2 for the results.

**Table 2-2: Limited Downstream Sewer Analysis (Manning's Equation)**

Upstream SMH			Downstream SMH Inv.	Sewer Length (ft)	T Size (In.)	Slope	Max. Vel. (fps)	Max. Capacity (gpm)
Ground Elev.	Depth	Inv.						
24.5	5.8	18.7	17.5	40.54	10	0.031	6.13	1,500
27.7	10.5	17.2	16.52	136	10	0.005	2.46	603
23.02	6.5	16.52	1.96	33.38	10	0.43619	23.0	5,629
8.46	6.5	1.96	0.05	129	10	0.01481	4.24	1,037
4.05	4	0.05	(-)0.42	139	10	0.00338	2.02	495
8.58	9	(-)0.42	(-)1.41	292.05	10	0.00339	2.02	496
8.59	10	(-)1.41	(-)1.63	65.88	10	0.00334	2.01	493
12.87	14.5	(-)1.63	(-)2.09	135	10	0.00341	2.03	498
6.81	8.9	(-)2.09	(-)2.32	69.8	10	0.00330	2.00	490
4.2	6.52	(-)2.32	(-)2.36	12	10	0.00333	2.01	492
4.1	6.46	(-)2.36	(-)2.74	119	10	0.00319	1.97	481

A number of things can be inferred from the analysis. 1) The maximum capacity of the downstream collection system is no greater than 490 gpm without causing surcharging. 2) The velocity through the sewer main with a slope of 0.43619 is approximately 23 ft/s. According to the Standards, the maximum recommended velocity is 10 ft/s. 3) A hydraulic jump is likely to occur at the sewer manhole immediately following the steep sloped sewer pipe. The hydraulic jump, if it is severe enough, could cause spills to occur through the manhole. 4) The maximum flow from SMH (Inv. = 0.05) to SMH (Inv. = (-)2.74) is estimated to be 1.2 mgd (833 gpm) before wastewater will spill from the SMH (Inv. = 0.05) cover. See Appendix A-1 for supporting estimated flow calculations.

Wet well level elevation set points were also evaluated to determine compliance with maximum retention and cycling times. See Appendix A-2 for the wet well volume calculations.

Appendix A-2 is comprised of four sets of wet well volume calculations. Table A-2.1 shows the maximum allowable wet well volume based on the Standards' 30-minute maximum wastewater retention time. The intent of limiting the maximum wastewater retention time is to minimize deposits of solids and prevent wastewater from becoming septic.

Table A-2.2 takes the maximum allowable wet well volume from Table A-2.1 and calculates the resultant maximum motor starts per hour. Table A-2.2 shows that the wet well volume calculated in Table A.2-1 can be decreased without exceeding the maximum motor starts per hour allowed by the Standards'. Exceeding the maximum motor starts per hour allowed by the Standards' can cause overheating and premature motor failure.

Table A-2.3 calculates the minimum required net wet well volume based on the maximum motor starts per hour allowed by the Standards'. The intent of minimizing the wet well volume is to minimize the wet well high water level elevation set point. Minimizing the wet well high water level elevation set point will help to minimize the extent of surcharging that occurs upstream of the WWPS and minimize the wastewater retention time in the wet well.

Table A-2.4 takes the minimum allowable net wet well volume from Table A-2.3 and calculates the minimum recommended wet well high water level elevation set point.

The wet well water level analysis indicates that the existing high water level elevation set point falls within acceptable limits.

### **2.3.2 Existing Force Main**

Kahanahou WWPS has a force main that was originally put into service in 1966 and subsequently replaced in 2007. The existing force main is approximately 800

feet in length (16 feet of 8-inch C-900 PVC, 769 feet of 8-inch DR 17 HDPE, 6 feet of 8-inch CI, and 1 foot of 8-inch DI). The existing force main starts at the WWPS, is located within the Kahanahou Place property limits, and discharges into a manhole located beneath Springer Place. The City had the original cast iron force main replaced in 2007 due to increasingly frequent pipe failures. According to the "*Design Alternatives Report for Kahanahou Wastewater Pump Station Force Main Reconstruction*", September 8, 2005, it was feared that the force main was suffering from advanced corrosion due to its age of 40+ years and its close proximity to the ocean. At the time, the force main had already failed a couple of times and required emergency repairs on both occasions.

As a part of the replacement project, a throttling ball valve was installed downstream of the meter vault. The purpose of the throttling valve is to allow operators to throttle the flow from Kahanahou WWPS. It was anticipated by the designers that the peak flow would be reduced in the future in response to I/I reduction projects. The designers had alluded to that the ball valve was also intended to throttle flow as necessary to prevent negative impacts such as surcharging and spills in the downstream collection system. It was confirmed by Okahara and CSM in November 2010 that the ball valve was in the full open position. CSM had expressed concerns that without an a flow rate display mounted adjacent to the throttling valve, and a recommended maximum allowable flow rate, they were ill equipped to "throttle" the WWPS' flow.

### **2.3.3 Sanitary Sewer Overflow**

CSM was consulted regarding sanitary sewer overflows (SSO) in the vicinity of Kahanahou WWPS. According to their records, no spills or trouble calls are recorded for 45-13 Kahanahou Place, Kaneohe, TMK: 4-5-047:095.

### **2.3.4 Existing Pump Station Flow Analysis**

The existing WWPS was designed to meet the following conditions according to design documents for Kahanahou Sewage Pumping Station & Force Main, Job

No. 63-63, and Kahanahou Wastewater Pump Station Force Main Reconstruction, Job No. W16-05. The following information is only presented to highlight the existing WWPS's basis of design. It does not represent the actual operating conditions.

- $Q_{ave} = 0.116$  mgd
- $Q_{max} = 0.451$  mgd
- $Q_{peak} = 0.654$  mgd
- Lead Pump = 510 gpm @41 feet TDH (C=120); 550 gpm @39 feet TDH (C=150)
- Wet Well Capacity = 2,870 gallons
- Wet Well Invert = (-)16.50 feet
- Low Water Elevation = (-)14.50 feet
- High Water Elevation = (-)11.50 feet
- Retention Time = (Not Indicated)
- Static Head = 29.2 feet (Minimum), 32.2 feet (Maximum)
- Force Main Length = 101 equivalent length feet of 6-inch CI; 33 equivalent length feet of 8-inch CI; 924 equivalent length feet of 8-inch HDPE/PVC.

Pump curves matching serial numbers obtained from Engineered Systems, a local equipment vendor, were obtained from the Patterson Pump Company and used to model pump curves for Kahanahou WWPS. Engineered Systems reported that the existing pumps are Model FFN, Serial Number 64PP1030-F4 and 64PP1031-F4, 500 gpm @43 feet TDH, 10 hp, 1150 RPM Patterson Pumps. Note that the existing operating pumps did not have a nameplate on them. During Okahara's field reconnaissance, two spare pumps were observed stored on a pallet in the dry well. The spare pumps were identified as Patterson Pumps, Model FFN, Serial Number 64PP1095-F6 (both pumps had the same serial number), 500 gpm @40 feet TDH. According to information obtained from Patterson Pumps, the serial numbers are for Waikapoki WWPS pumps with a flow capacity of 930 gpm @75 feet TDH. It was

assumed that the serial numbers indicated on the spare pumps were incorrect and the associated pump curves do not correctly reflect the performance of the Kahanahou WWPS pumps.

The pump curves were adjusted for minor losses and superimposed onto the system curve. See Appendix A-3 for net positive suction head available (NPSH<sub>A</sub>) calculations. See Appendix A-4 for the existing pump curves, system curves and calculations. See Appendices A-5 and A-6 for the alternative pump curves, system curves and associated calculations.

Actual WWPS operating conditions and calculated pump performance differ slightly from the design conditions and pump performance. Actual operating conditions were either field verified or extrapolated from available reference drawings. Calculated pump performance was based on installed Patterson Pump curves, Standards' frictional factors, reference drawings and adjustments by Okahara. Actual WWPS operating conditions and calculated pump performance are as follows:

- High Water Elevation = (-)11.28 (per SCADA display at WWPS)
- Low Water Elevation = (-)13.68 (per SCADA display at WWPS)
- Wet Well Invert = (-)16.50
- Wet Well Capacity = 1,724 gallons (based on (-)13.68 water level)
- Retention Time = 29.25 minutes (based on (-)11.28 water level and 139 gpm average inflow rate)
- Minimum cycle time = 27.5 minutes
- C = 100 for ductile iron
- C = 100 for PVC / HDPE (H-W factor changed from 120 to 100 to match SCADA data)
- Patterson M/N FFN; S/N 64PP1030-F4 & 64PP1031-F4; 500 gpm at 43 feet
- Pump Performance

1 Pump = 347 gpm, 0.50 mgd @45 feet TDH


2 Pumps = 510 gpm, 0.73 mgd @47.5 feet TDH

- $NPSH_A = 23.5$  feet (One Pump Operating)
- $NPSH_R = \text{Unknown}$
- Inlet Bell Fluid Velocity = 0.78 ft/sec (13.5-inch diameter bell)
- Suction Pipe Fluid Velocity = 2.22 ft/sec (based on 8" nominal pipe)
- Discharge Pipe Fluid Velocity = 3.94 ft/sec (based on 6" nominal pipe)
- 8" AWWA C900 PVC Force Main Fluid Velocity = 2.19 ft/sec
- 8" SDR-11 HDPE (Ductile Iron Dimensions) Force Main Fluid Velocity = 2.59 ft/sec

Actual WWPS pump performance differ slightly from the calculated pump performance using Standards' recommended Hazen-Williams friction factor of 120 for plastic pipe, 100 for metal pipe and 6-inch diameter pipe discharge. In order to match SCADA data, a Hazen-Williams friction factor of 100 was used for plastic pipe, 60 was used for metal pipe located in the pump station, and a 4-inch diameter was used to model the vertical portion of the pump discharge piping. See Chart 2-1 for pump curves, modified pump curves, family of system curves and SCADA data from October 31 through November 2, 2006. The pump curves were obtained directly from the factory (Patterson Pumps) based on serial numbers obtained from Engineered Systems, a local equipment manufacturer's representative. The modified pump curves were created by calculating the minor losses and subtracting them from the pump curves. The family of system curves were calculated based on several different wet well water level elevations including the LWL set point of (-)14.50 feet, the HWL set point of (-)11.50 feet, and a HHWL set point of (-)9.00 feet. See Appendices A-4, A-5 and A-6 for sample calculations. The SCADA data is a collection of WWPS operating points recorded once every 1-minute. Each point represents the total flow and corresponding discharge pressure of the WWPS. The pump station pressure tap is located immediately downstream of the discharge elbow on Pump 2 with the sensor/transmitter mounted on the wall approximately 36-inches above the finished floor (El. = (-)13.00). When Pump 1 operates, the



**CHART 2-1: KAHANAHOU WWPS  
EXIST. CENTRIFUGAL PUMP AND SYSTEM CURVES FOR OCT 31~NOV 2, 2006  
PATTERSON PUMP CO. 1175 RPM, UNKNOWN IMPELLER DIAMETER**



pressure sensor measures the WWPS discharge pressure excluding minor losses. When Pump 2 (or both pumps) operates, the pressure sensor measures the WWPS pressure excluding most of the minor losses except for the minor losses between the discharge sensor pressure tap and the discharge header. Typically, the discharge pressure tap is located on the common discharge header and not on the individual pump discharge lateral. It is estimated that the total error introduced by the existing discharge pressure tap location is on the order of 0.5 to 1.0 feet of water or 1~3%. Due to the anticipated small size of the error, it was decided to ignore the incorrect discharge pressure tap location's effects on the calculated results.

The SCADA data was modified to account for varying wet well water levels and its effect on the measured discharge pressure. In effect, the modified discharge pressure data represents the total lift (minus minor losses) provided by the WWPS. Note that the total lift (minus minor losses) provided by the WWPS differ from the WWPS discharge pressure by the amount of static pressure available in the wet well.

The SCADA data points recorded between October 31 and November 2, 2006 represents data taken over a period of moderate to high rainfall. See Appendix B for SCADA data recorded between October 31 and November 2, 2006. The WWPS operated almost continuously for 3 days and required two pumps to operate simultaneously for a good portion of that time. It was expected that the data would cluster in two groups with a few scattered points. One group of operating points was expected to cluster where the pump curve for one operating pump intersects the system curve for a wet well water elevation of (-)11.50 (i.e., HWL). The second group of operating points was expected to cluster where the pump curve for two operating pumps intersect the system curves for a wet well water elevation between (-)11.00 and (-)9.00 (i.e., Pump 2 Off and Pump 2 On elevation set points). The second group of points was expected to ride the pump curve as the wet well level fluctuated. With two pumps operating, the wet well water level would rise as long as the incoming flow rate exceeding the WWPS' capacity and fall when the incoming

flow rate fell below the WWPS' capacity. The system seemed to stabilize at 0.80 mgd at peak flow conditions.

Prior to adjusting the Hazen-Williams friction factor and the pump discharge lateral size utilized in the hydraulic analysis, it was found that the SCADA data points fell below the modified pump curve and to the left of the system curve as predicted by the analysis. The following can be inferred from the SCADA data and hydraulic analysis:

- Something in the WWPS piping assembly is increasing the magnitude of the minor losses. According to CSM, the vertical portion of the discharge laterals tend to be lined with solids over time, and it effectively reduces the usable inside pipe diameter.
- The Standards' recommended Hazen-Williams friction factor of 120 for plastic pipe is not a good representation of actual performance. It appears that HDPE behaves more like metallic pipe with a Hazen-Williams friction factor of 100.

A plausible alternative to the above inferences is that the existing WWPS' instrumentation is not calibrated properly. However, if that were true, both the flow meter and discharge pressure transmitter are reporting low values.

### **2.3.5 Pump Station Ventilation**

The existing WWPS dry well is ventilated by an inline exhaust fan that is actived while CSM is on-site. Operating the fan 24-hours a day reportedly illicit noise complaints from neighbors. The exhaust fan intakes are ducted from the dry well and exhausted vertically through a roof mounted hood. The exhaust fan was designed to exhaust 1,920 cfm at 3/8-inch water gage static pressure.

### 2.3.6 Existing Pump Station Deficiencies

There are a number of deficiencies with the existing WWPS. The following is a summary of the deficiencies and a discussion of whether the project will address the deficiencies.

- The existing WWPS does not have sufficient capacity to meet current or future flow projections. See Section 2.4 for a flow analysis of the existing WWPS. This deficiency will be addressed by Alternatives 2, 3 and 4.
- The existing inlet bell wastewater velocity of 0.78 feet per second is low. According to *Pump Intake Design* by the Hydraulic Institute, 1998, the inlet bell fluid velocity should be kept between 2.0 and 5.5 feet per second for flow rates less than 5,000 gpm. According to *Pumping Station Design* by Sanks et. al, 1998, the inlet bell fluid velocity should be kept between 2.0 feet per second and 3.0 feet per second for constant speed pumps and 2.0 feet per second and 3.5 feet per second for variable frequency drive (VFD) driven pumps. The purpose of the minimum velocity of 2.0 feet per second is to insure proper removal of grit particles during wet well cleaning. This deficiency will be addressed by Alternatives 2, 3 and 4.
- The existing pump discharge is connected to the discharge header from the bottom. According to *Pumping Station Design* by Sanks et. al, 1998, connecting the pump discharge to the bottom of a header could result in plugging of check valves and piping. CSM has also reported that long vertical discharge laterals promote clogging of the laterals. This deficiency will be addressed by Alternatives 2, 3 and 4.
- The existing dry well is not continuously ventialed per NFPA 820 nor are all of the dry well equipment explosion proof rated. NFPA 820 Standard for Fire Protection in Wastewater Treatment and Collection Facilities, 2008 Edition defines dry wells that are not continuously ventilated at a minimum of 6 air changes per hour a Class I, Group D, Division 2 area. This means that if

enough ventilation is not provided to unclassify the area, all of the electrical equipment within the dry well including the pump motors, starters and exhaust fan will need to be explosion proof. This deficiency will be addressed by Alternatives 2, 3 and 4.

- The existing float operated controller float tube short circuits the wet well and dry well. This deficiency will be addressed by Alternatives 2, 3 and 4.
- The existing 8-inch diameter gravity main that the force main discharges into does not have sufficient capacity for flow rates exceeding approximately 0.7 mgd (490 gpm) without surcharging the gravity main. The capacity increases to approximately 1.2 mgd (833 gpm) if the gravity main is allowed to be pressurized. Flow rates approaching 1.2 mgd will cause excessive surcharging and may result in SSOs through the manholes. The analysis is limited to approximately 800 linear feet of gravity main immediately downstream of the force main discharge. Increasing the capacity of the downstream collection system is beyond this project's scope of work. Provisions to limit the maximum wastewater flow from the pump station are included in Alternatives 2, 3 and 4.

See Section 2.5 Design Alternatives and Chapter 6 - Evaluation of Alternatives for a discussion regarding proposed alternatives and WWPS deficiencies. Note that a water hammer analysis was completed and the calculated intensity of anticipated pressure waves fall within tolerable limits. See Appendix A-7 for water hammer calculations.

## **2.4 FLOW ANALYSIS**

A flow analysis was completed to develop a basis for the selection of replacement sewage pumps. Two methods of determining the appropriate design flow rates were employed. The first method employed was utilizing INFIX, a City approved flow modeling software that are based on the Standards. The second method employed was analyzing historical flow data.

### 2.4.1 INFIX Flow Data Analysis

A City flow model entitled INFIX version 3.0 was used to model current and future wastewater flow projections. INFIX is a modeling program that calculates wastewater flows within a sanitary wastewater system. INFIX uses a database consisting of manholes, sewer mains, and parcels to compute the production of wastewater summed for each sewer main starting from the highest node downward to a WWTP. Calculations are by in large based on the Standards' defined factors for wastewater generation rate, infiltration rates, inflow rates and maximum flow factors. However, calculations can also be based on user defined factors.

An extensive amount of field collected data were purportedly used to supplement the INFIX version 3.0 database to allow for more accurate flow projections.

Kahanahou WWPS, designated by INFIX as Plant/Station KK 32, is projected to have the following current and future wastewater flows shown in Table 2-3. (See Appendix C for the INFIX WWPS printout). It should be noted that INFIX version 3.0's database is current as of 2002 and updates are reportedly not available. INFIX version 3.0 does not account for the Kahanahou lateral rehabilitation pilot project and the resultant I/I reduction. Consequently caution should be exercised in assigning credibility to the INFIX projections.

**Table 2-3: INFIX Projected Wastewater Flow Rates**

Criteria	Current Projection	Future Projection
Tributary Area	68.6 Acres	76.0 Acres
Residential Population	832	1,123
Other Population	22	18
Total Population	854	1,141
Average Flow Rate	0.0684 mgd	0.0913 mgd
Maximum Flow Factor	5.00	4.87
Maximum Flow Rate	0.3418 mgd	0.4447 mgd
Dry Weather I/I	0.0149 mgd	0.0206 mgd
Design Ave. Flow Rate	0.0832 mgd	0.1120 mgd

Design Max. Flow Rate	0.3567 mgd	0.4653 mgd
Wet Weather I/I	0.1218 mgd	0.1422 mgd
Design Peak Flow Rate	0.4784 mgd	0.6075 mgd


#### 2.4.2 Historical Flow Data Analysis

Manually recorded flow and energy use data for the last 10 years between January 2000 and January 2010 were collected and inputted into a spreadsheet (See Appendix D) to ascertain the WWPS' average and peak flow rates. Chart 2-2 shows the monthly maximum, average and minimum daily flow rates recorded for Kahanahou WWPS. Rain data obtained from the U.S. Department of Commerce, National Oceanic & Atmospheric Administration (NOAA) for Station 513117/99999, KANEOHE 838.1, Hawaii were superimposed on the flow data to assist with identifying flow trends. Chart 2-3 shows the associated monthly total flow, power use and flow (gallons)/kWh. See Appendix E for historical rainfall data obtained from NOAA.

Between the years of 2000 and mid 2008, Charts 2-2 and 2-3 reveal that the daily, monthly daily average and monthly flow rates closely tracked the intensity of precipitation. Monthly daily average flow rates varied from a low of 0.25 mgd in early 2000 to a high of 0.60 mgd in early 2006. The close relationship between rain intensity and flow rate suggests that wet weather I/I had a strong influence on the WWPS flow rates. Monthly WWPS energy consumption for this period was approximately 3,000 kWh in early 2000 to 7,000 kWh in late 2006. Average wastewater pumped per kWh of energy consumption was approximately 3,000 gallons.


In August of 2007, a new HDPE force main was brought on-line and replaced an existing ductile iron force main. Immediately following the replacement, average wastewater pumped per kWh of energy fell to 2,500 gallons. The drop in wastewater pumped per kWh consumed seems counterintuitive because the HDPE pipe should be smoother than the old ductile iron pipe. It is postulated that

**CHART 2-2: KAHANAHOU WWPS**  
**MONTHLY MAXIMUM / AVERAGE / MINIMUM DAILY FLOW RATES**  
 (NOTE: BASED ON MANUALLY RECORDED DATA. DO NOT USE DAILY MONTHLY MIN. & MAX. FLOW RATES)





**CHART 2-3: KAHANAHOU WWPS  
TOTAL FLOW PER MONTH / ENERGY USE PER MONTH / FLOW PER KWH**



the smaller inside diameter of HDPE (7.04" I.D.) versus ductile iron (8.39" I.D.) caused the additional recorded frictional losses.

Between the years of mid 2008 through the end of 2008, a pilot project to rehabilitate laterals in the area was completed. Between June 2008 and November 2008, there is a noticeable drop in the average daily flow rate to levels unseen in the previous 10 years. Project specifics including scope of work are still being researched. Monthly daily average flow rates fell to approximately 0.20 mgd following the completion of the project. Monthly minimum daily flow rates, total monthly flow, total monthly power consumed also dropped as compared with previous year's data. Average wastewater pumped per kWh of energy consumed remained unchanged at 2,750 gallons. Decreased total flow, average flow and total energy consumed seems to be a direct result of the lateral rehabilitation pilot project.

Of the 10 years of manually recorded daily flow data for Kahanahou WWPS, there were seven instances of recorded daily flow approaching or exceeding 1.00 million gallons. The data indicates that the monthly maximum, average and minimum daily flow rate logs may be incorrect for one of the seven instances.

The suspected instance of incorrect recorded daily flow approaching or exceeding 1.00 million gallons occurred on July 26, 2006. The monthly logs indicate that Kahanahou WWPS pumped 2.06 million gallons of wastewater that day. The logs also indicate that 255 kWh of electricity was consumed that day. 255 kWh of electricity suggests that Kahanahou WWPS pumped 0.765 million gallons of wastewater based on a pump efficacy of 3,000 gallons per kWh. SCADA recorded data appears erratic and it was concluded that instrumentation devices may not have been operating properly on that day. The maximum recorded daily flow of 2.06 million gallons was dismissed and removed from Chart 2-1 based on the discrepancy between the calculated flow of 0.765 million gallons and the recorded flow, the erratic SCADA data, and the inability of the

existing pumps to pump 2.06 million gallons. The existing pumps have a capacity of 0.792 mgd (550 gpm) per pump.

As for the remaining six (6) instances of daily flow approaching or exceeding 1.00 million gallons, a comparison of the manually recorded data versus the SCADA data suggest that the manually recorded data may be incorrect. It is suspected that the manually recorded data is not recorded at the same time everyday. This could lead to misleadingly high daily flows for days with over 24 hours recorded flow and equally misleadingly low daily flows for days with under 24 hours recorded flow.


For example, between November 5 and November 7, 2004, 0.24, 1.00 and 0.66 million gallons were manually recorded for a three day total of 1.90 million gallons. According to the SCADA data, 0.57, 0.65 and 0.65 million gallons were pumped on those three days for a three day total of 1.87 million gallons. The point is that although the accuracy of the manually recorded daily minimum and maximum flows may be in question, the trends and long term data should be fairly accurate.

No other notable anomalies were found with the six (6) instances of daily flow approaching or exceeding 1.00 million gallons. SCADA flow data for the subject days were plotted on Chart 2-4. Flows for days immediately preceding and immediately following the subject days were also plotted on the chart. Based on charted data for the six highest recorded daily flows between January 2000 and January 2010, the pump station flow rate did not exceed 568 gpm or 0.82 mgd.

### **2.4.3 Flow Analysis Conclusions**

It appears that the peak incoming flow rate into the WWPS wet well prior to the rehabilitation of laterals in the late 2000's was 0.85 mgd. Insufficient data is available following the lateral rehabilitation work to formulate concrete conclusions regarding its success in reducing I/I. *The Sewer Rehabilitation and*

**CHART 2-4: KAHANAHOU WWPS  
INSTANTANEOUS FLOWRATES  
FOR SELECTED DAYS WITH THE HIGHEST RECORDED DAILY FLOWRATES**



11/7/2006	11/6/2006	11/5/2006	11/4/2006	11/2/2006	11/1/2006	10/31/2006	2/26/2006	2/25/2006
2/24/2006	2/6/2005	2/5/2005	2/4/2005	11/7/2004	11/6/2004	11/5/2006		

*Infiltration & Inflow Minimization Study, Volume 3 of 9, Kailua-Kaneohe I/I Engineering Report*, December 1999 projects a peak flow rate of 1.19 to 1.29 mgd. INFIX projects a current peak flow rate of 0.48 to 0.61 mgd.

There is a discrepancy between the rate recommended by the December 1999 Engineering Report, INFIX version 3.0 and actual flow data. Projections presented in the December 1999 Engineering Report and INFIX version 3.0 are in large part based on guidelines presented in the Standards and old data. Actual WWPS flow data collected manually and electronically via SCADA are deemed to be more accurate. It was decided that since there are no records of SSO events at the WWPS, and Kaneohe experienced large annual rainfall in 2004 and 2006 of 30+ inches above normal, the maximum recorded flow rates would be a good approximation of the peak flow rates. Furthermore, all of the maximum recorded flows between January 2000 and January 2010 occurred before a number of the laterals were rehabilitated in 2008. Finally, the surrounding neighborhood appears to have been developed and there does not appear to be room for significant development. Arbitrarily applying a 10% "safety factor" to the maximum observed WWPS flow rate of 0.82 mgd yields a peak design flow rate of 0.90 mgd.

## **2.5 DESIGN ALTERNATIVES**

The following alternatives were developed to address deficiencies with the WWPS capacity. Detailed discussions regarding architectural, structural and electrical implications are located in their respective sections. See Table 6-1 for an evaluation matrix of alternatives. See Appendix F for mechanical related catalog cuts.

### **2.5.1 Alternative No. 1 - No Action (0.50 mgd @45 feet TDH)**

Alternative No. 1 calls for no action to be taken. This alternative is only discussed as a baseline for comparison purposes. The problem with taking no action is that the existing pumps do not have sufficient capacity (0.5 mgd capacity) to meet the

projected peak flow rate of 0.90 mgd. Historically the peak flow rate has been met with both primary and standby pumps operating together.

See Figure 1-2 for the existing site plan and Figures 2-1, 2-2, 2-3 and 2-4 for the existing WWPS plan and sections. Alternative No. 1 has no associated adverse short-term impacts.

The main adverse long-term impacts with taking no action are that the existing pumps will not be able to meet the projected flow rates and none of the deficiencies discussed in Section 2.3.6 will be corrected. Problems that may be encountered by not correcting the deficiencies include the following:

- Pumps cannot meet existing or projected peak flow rates.
- WWPS does not have a backup pump when both pumps are operating (i.e., during high flow conditions exceeding 347 gpm.)
- Pumps will have difficulty removing grit from the wet well during pump downs due to low velocities through the intake bell.
- Long vertical discharge laterals will continue to collect solids.
- The dry well and electrical room will be classified as a Class I, Group D, Division 1 area. This may pose a safety problem if the existing equipment is not rated as explosion proof.

### **2.5.2 Alternative No. 2 - Install New Constant Speed Dry Pit Submersible Pumps with VFDs (0.90 mgd @55.5 feet TDH)**

Alternative No. 2 calls for the replacement of the existing separately coupled solids handling pumps with new larger capacity constant speed dry pit submersible pumps. The pumps would be outfitted with VFDs but would be operated in constant speed mode. The following is a list of improvements that would be required in support of the pump replacement.

- Replace pumps with new larger capacity dry pit submersible pumps with a rated capacity of 0.90 mgd @55.5 feet TDH. Proposed pumps were selected to meet the projected peak flow rate of 0.90 mgd. ABS pump model number XFP100E-CB1, 1765 RPM will have a 4-inch diameter pump suction connection and require approximately 12 feet of NPSH. Each pump will have approximately 21.75 feet of NPSH available at a flow rate of 0.90 mgd and a wet well level elevation of (-)11.50.
- Install VFDs to control pump acceleration and to limit inrush electrical current. VFDs will also be used to limit the maximum flow from the pump station to avoid spills through downstream manholes. The maximum capacity of the downstream gravity main is estimated to be 1.2 mgd. Two pumps operating concurrently is projected to pump in excess of 1.26 mgd.
- Replace existing propane fueled standby emergency engine generator with a larger capacity diesel fueled unit. The engine generator needs to be upsized to accommodate the larger 15 HP pump motors, additional HVAC loads, and miscellaneous other loads.
- Install a new 1,000 gallon underground fuel storage tank. Although an above ground fuel storage tank is preferred by CSM, there is insufficient on-site space to satisfy required setbacks.
- Erect a new generator building with acoustical treatment.
- Modify existing pump building and construct a new air conditioned electrical room for new SCADA and MCC equipment.
- Replace existing controls and relocate meter vault to grassed area.
- Replace all piping located in the dry well.
- Replace existing ventilation system to comply with NFPA 820. New supply and exhaust fans, ductwork, intake and exhaust openings will be required.

See Figures 2-6, 2-7, 2-8 and 2-9 for the proposed modifications to the WWPS plan and sections.

Adverse short-term impacts include significant noise and visual unsightliness both on the WWPS premises as well as in the general vicinity during construction. One adverse long-term impact is that the use of VFDs complicates the system controls and could cause issues for operators.

Wet well level elevation set points may need to be revised if the City pursues additional rehabilitation of sewer mains and laterals in the Kahanahou area. Further rehabilitation of sewer mains and laterals could decrease the average and peak wastewater flow rates. Pump impellers may need to be trimmed or pumps may need to be replaced in cases of extreme I/I reduction.


### **2.5.3 Alternative No. 3 - Install New Constant Speed Dry Pit Submersible Pumps with Soft Starters (0.90 mgd @55.5 feet TDH)**

Alternative No. 3 calls for the replacement of the existing separately coupled solids handling pumps with new larger capacity constant speed dry pit submersible pumps. Alternative No. 3 is identical to Alternative No. 2 except for two differences. The VFDs would be replaced with soft starters. Similar to the VFDs, the soft starters would limit in-rush current to prevent overloading of the electrical system. The second difference is that two pumps would be prohibited from operating concurrently. Removal of the VFD will simplify the WWPS' control system. However, it also removes an operator's ability to limit the WWPS' maximum flow to 1.2 mgd. Exceeding a maximum flow of 1.2 mgd may cause spills through downstream sewer manholes. See Table 2.2 and write-up immediately following it for a discussion of maximum allowable flows.

See Figures 2-6, 2-7, 2-8 and 2-9 for the proposed modifications to the WWPS plan and sections.




J:\D:\PROJ\21002\REPORT\FIG 2-PLAN-SECT.DWG/1=1/12-27-10/XREF=OA1117,x-Basement,x-Int,x-plan,x-sect-a, x-sect-b



**NEW BASEMENT PLAN**

SCALE: 1/4" = 1'-0"



SCALE: 1/4"=1'-0"

MATERIAL LIST	
ITEM NO.	DESCRIPTION
1	6" - LR 90° BEND, FLANGE AND BELL
2	6" - PIPE SPOOL, FE
3	6" - GATE VALVE, FE
4	6" - FLEXIBLE COUPLING
5	6" - PIPE SPOOL, FExPE
6	6"x4" - ECCENTRIC REDUCER, FE
7	ABS, SOLIDS HANDLING PUMP
8	6"x4" - CONCENTRIC REDUCER, FE
9	6" - CHECK VALVE W/ WEIGHT, FE
10	6" - LR BASE BEND, FE
11	6" - PIPE SPOOL, FE
12	6" - LR 90° BEND, FE
13	8" BLIND FLANGE
14	8"x8"x6" WYE, FE
15	8" PIPE SPOOL, F.E.
16	8" - 90° BEND, FE
17	8" - PIPE SPOOL, F.E.
18	8" - PIPE SPOOL, F.E.
19	8" - PIPE SPOOL, FE/BE

DESCRIPTION

ALTERNATIVE NO. 2, 3 AND 4  
 NEW BASEMENT PLAN  
 AND MATERIAL LIST

DEPARTMENT OF DESIGN AND CONSTRUCTION  
 WASTEWATER DIVISION  
 CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER  
 PUMP STATION UPGRADE**  
 KANEHOE, OAHU

OKAHARA AND ASSOCIATES, INC.


JOB NUMBER  
 2009107

DATE  
 JAN 2011

FIGURE 2-6


PAGE 2-32

J:\D:\PROJ\21002\REPORT\FIG 2-PLAN-SECT.DWG/1=1/12-27-10/XREF=0A1117,x-Basement,x-Int,x-plan,x-sect-a, x-sect-b



**NEW INTERMEDIATE PLAN**  
SCALE: 1/4" = 1'-0"

**NOTE:**  
SEE FIGURE 2-6 FOR MATERIAL LIST.



**NEW GROUND FLOOR PLAN**

SCALE: 1/4" = 1'-0"  
2' 0 4' 8' 12'  
SCALE: 1/4" = 1'-0"

DESCRIPTION

**ALTERNATIVE NO. 2, 3 AND 4  
NEW INTERMEDIATE AND GROUND  
FLOOR PLANS**

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE**  
KANEOHE, OAHU

**OKAHARA AND ASSOCIATES, INC.**


JOB NUMBER  
2009107

DATE  
JAN 2011

**FIGURE 2-7**


**PAGE 2-33**

J:\D:\PROJ\21002\REPORT\FIG 2-PLAN-SECT.DWG/1=1/12-27-10/XREF=OA1117,x-Basement,x-Int,x-plan,x-sect-a, x-sect-b



**NOTE:**  
SEE FIGURE 2-6 FOR MATERIAL LIST.

**NEW SECTION**  
SCALE: 1/4" = 1'-0"



DESCRIPTION

ALTERNATIVE NO. 2, 3 AND 4  
NEW BUILDING SECTION

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE**  
KANEHOHE, OAHU

**OKAHARA AND ASSOCIATES, INC.**


JOB NUMBER  
2009107

DATE  
JAN 2011

FIGURE 2-8


PAGE 2-34

J:\D:\PROJ\21002\REPORT\FIG 2-PLAN-SECT.DWG/1=1/12-27-10/XREF=OA1117,x-Baseament,x-int,x-plan,x-sect-a, x-sect-b



NOTE:  
SEE FIGURE 2-6 FOR MATERIAL LIST.

NEW SECTION  
SCALE: 1/4" = 1'-0"



ALTERNATIVE NO. 2, 3 AND 4  
NEW BUILDING SECTION

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE  
KANEHOHE, OAHU

DESCRIPTION

OKAHARA AND ASSOCIATES, INC.

JOB NUMBER  
2009107

DATE  
JAN 2011

FIGURE 2-9

PAGE 2-35

Adverse short-term impacts include significant noise and visual unsightliness both on the WWPS premises as well as in the general vicinity during construction. One adverse long-term impact is that locking out one pump complicates the system controls and could cause issues for operators.

#### **2.5.4 Alternative No. 4 - Install New Constant Speed Dry Pit Submersible Pumps (0.79 mgd @47 feet TDH)**

Alternative No. 4 calls for the replacement of the existing separately coupled solids handling pumps with new larger capacity constant speed dry pit submersible pumps. Alternative No. 4 is identical to Alternative No. 3 except for two differences. The pumps were selected with a capacity of 0.79 mgd with one pump operating, and a capacity less than 1.14 mgd with two pumps operating. Because the maximum flow is limited to less than 1.2 mgd, no special controls are required.

Exceeding a maximum flow of 1.2 mgd may cause spills through downstream sewer manholes. See Table 2.2 and write-up immediately following it for a discussion of maximum allowable flows.

See Figures 2-6, 2-7, 2-8 and 2-9 for the proposed modifications to the WWPS plan and sections.

Adverse short-term impacts include significant noise and visual unsightliness both on the WWPS premises as well as in the general vicinity during construction. One adverse long-term impact is that sizing the pump for the peak observed current flow does not leave any room for community development. Any development that increases the wastewater flow will require increasing the capacity of the WWPS.

### **2.5.5 Alternative Options**

There were a number of alternative options that were considered in response to requests by CSM. These options do not have a direct bearing on the proposed alternatives and may be implemented as DDC deems fit. See Table 6-2 for discussion regarding proposed alternative options.

### **2.5.5 Dismissed Alternatives**

The following alternatives were briefly considered but dismissed because of what were deemed unacceptable adverse impacts. These opinions were based on designer preferences and does not account for City preferences.

- Variable speed pumps: Variable speed pumps were dismissed from consideration because they will not provide a significant benefit over constant speed pumps at Kahanahou WWPS. The relative small size of the pump station coupled with low average incoming flows severely limits the range of acceptable operating speeds that a variable speed pump could operate at while satisfying minimum required fluid velocities. For example, at a flow rate of 625 gpm, which is equivalent to the peak projected flow rate of 0.90 mgd, the velocity through the entrance of a 6-inch inlet bell is 2.1 feet per second. The minimum recommended velocity through the entrance of an inlet bell is 2.0 feet per second. A velocity of 2.0 feet per second through a 6-inch inlet bell is 592 gpm. Reducing the inlet bell to 4-inches would result in a velocity exceeding 15 feet per second through the suction pipe. Based on an acceptable flow range of 592 gpm to 625 gpm, the use of VFDs were dismissed from consideration.
- Separately coupled pumps: Separately coupled solids handling pumps with extension shafts were dismissed from consideration because the City operators prefer dry pit submersibles over separately coupled pumps and the life cycle cost difference between the two is negligible.

- Semi permanent engine driven pumps: The use of semi permanent, self priming, engine driven pumps was briefly considered because of the limited capacity of the existing electrical service. The WWPS has single phase electrical service and experiences noticeable voltage sags when pumps activate. Based on the estimated loads associated with necessary upgrades, it is believed that the existing electrical service will be sufficient. Furthermore, the use of semi permanent engine driven pumps may require an air permit. DOH reported that although emergency engine generators are exempt from air permits, emergency engine driven pumps are not exempt. They did add however that there is a mechanism to acquire an air permit exemption and that there is precedence for it at other City wastewater facilities. However, based on sufficient available electrical service, possible air permit triggers, and the temporary nature of these pumps, the use of them were dismissed from consideration.

## **CHAPTER 3 – ARCHITECTURAL**

### **3.1 INTRODUCTION**

The Kahanahou WWPS site is located on the island of Oahu, at 45-13 Ka Hanahou Place, Kaneohe, Hawaii on a property owned by the City. This existing utility wastewater pump station serves the surrounding residential properties. This chapter provides general information on the existing Kahanahou WWPS site and infrastructure.

### **3.2 EXISTING CONDITIONS**

The project site is 7,893 SF in lot area and is in very close proximity of Kaneohe Bay. It is bordered on three sides by residential properties, and a private access road - Ka Hanahou Place, is located at the front of the property. There is also an existing drainage easement that runs adjacent to the rear property line and encroaches slightly into the site. There is landscaping on site, which includes a few trees, hedges and a large, relatively flat, grassed area at the front of the property.

The wastewater pump station building permit was issued in 1964, with the construction of the building completed sometime in 1966. There is an existing CMU wall on the North East side of the property, a chain link fence surrounds the remaining sides with a double swinging gate at the driveway entrance.

The existing pump station building has CMU walls, a concrete roof with built-up roofing and concrete eaves with edge flashing. The existing doors, frames and louvers are aluminum. The building includes a generator room, pump station area, work area, toilet and service sink, motor control area, and an existing steel



stairway with grating landings that lead to the basement level, which is the pump room. In reference to available records at the Department of Planning and Permitting, it appears there have been no improvements or upgrades to the pump station building since it was built in 1966.

### **3.2.1 GENERAL PROPERTY AND LAND USE INFORMATION**

Fee Owner:	City & County of Honolulu
Address:	45-13 Ka Hanahou Place Kaneohe, Hawaii 96744
Tax Map Key:	4-5-047: 095
Total Lot Area:	7,893 SF

#### ***PROJECT CODE INFORMATION:***

*(Based on 2003 International Building Code)*

Occupancy Group:	F-1
Type of Construction:	Type V-B (minimum) Type V-A (existing)
Allowable Building Area:	8,500 sf per story for V-B 14,000 sf per story for V-A <u>Actual:</u> 506 SF
Allowable No. of Stories:	1 story for V-B 2 stories for V-A <u>Actual:</u> 1 story with basement
Automatic Fire Sprinkler:	Not required when built - None installed

**LAND USE CONTROL CODES:**

- a) Zoning: R-10 (Residential District)
- b) Principal Use: Utility Wastewater Pump Station – Type A  
*Permitted use in R-10 zoning*
- c) Flood Zone: Firm Zone X (Beyond 500 flood plain)  
*NOT subject to flood hazard district regulations of the LUO.*
- d) Height Limit: 25 feet unless sloping
- e) Historic Site: No
- f) Lot Restrictions: None
- g) SMA / Shoreline: Special Management Area
- h) Special District: No
- i) State Land Use: Urban district
- j) Street Setback (road widening): None
- k) Lot Development Standards:
  - Min. Lot Area: 10,000 SF  
Actual lot area: 7,893 SF  
*The lot is non-conforming because it does not meet the min. lot area.*
  - Min. Lot Width: 65 ft for dwellings, 100 ft for other uses  
Actual width: 60.0' min width  
*The lot is non-conforming because it does not meet the min. lot width.*
  - Min. Lot Depth: 65 ft for dwellings, 100 ft for other uses  
Actual depth: 131.23' min width
  - Max. Bldg Area: 50% of zoning lot  
Max. Allowable: 3,946.50 SF  
Actual: less than 50%

- l) Building Setbacks (yards):
 

Front: required: 10 ft for dwellings	Sides/Rear: 5 ft for dwellings
30 ft for other uses	15 ft for other uses
<u>Actual:</u> exceeds 30 feet	<u>Actual:</u> exceeds 15 feet
  
- m) Transitional Height Setback: none
  
- n) Zoning of Adjoining Property: R-10
  
- o) Easements: Existing drainage easement contiguous to rear property line.  
Existing access easement (road) at front of site.  
Refer to site plan or Exhibit 3-1.
  
- p) Encroachments: Drainage easement at rear.  
Refer to site plan or Exhibit 3-1.
  
- q) Parking Requirements:
 

No. of stalls required:	1 stall / employee
Stall Size Required:	18'-0" X 8'-3" (standard)
Off-Street Loading Requirements:	not applicable – residential property

### 3.3 **DESIGN ALTERNATIVES**

Although the existing wastewater pump station force main pipe equipment was replaced in 2006, in reference to Chapter 2, the pumping station still has deficiencies to the system and will not be capable to handle projected peak wastewater flows. The following Architectural Design Alternatives were developed to meet the space requirements for the new pumps and other related equipment, and to comply with the current building code requirements as applicable.

**Alternative No. 1:** Calls out for no action to be taken.

**Alternative Nos. 2, 3 & 4:**

Proposed improvements to upgrade the existing wastewater pump system warrants building alterations to accommodate the new mechanical and electrical equipment and to address additional space needed for required work clearances. Interior renovations to the existing wastewater pump station building, includes a conversion of the existing generator room to a new electrical room. A new emergency generator building required to support the new, upgraded pump equipment is also proposed for these alternatives. The following is required to support Alternative Nos. 2, 3 & 4:

- The existing generator room in the pump station building will be converted into an electrical room to house new SCADA equipment. In reference to Chapter 5 – Electrical, the new pump equipment will require additional power, panel space and working clearances. The double doors and louvers will be removed and openings filled in with CMU. There will be a new single door located at the existing exhaust louver location. This room will have computer equipment that requires a controlled environment, therefore, the room will be provided with an air conditioner.
- Exterior areas that are currently painted will be repainted to improve the appearance and to match the colors of the new generator building. The existing painted floors need to be repainted because they show signs of wear. Although the interior ceiling and walls below grade level appear acceptable, it is an option to paint these areas also to give the renovated pump station a good, consistent overall appearance.
- A new emergency generator building located at the front of the property to support the existing pump station is proposed. Refer to Chapter 4 – Structural, for possible settlement issues observed around the building.

As a result of this observation, any addition or major alteration to the existing structure is discouraged due to high cost impact and possible unforeseen conditions. The proposed location and separate generator building provides minimal impact to the existing pump station building. Alternate locations of the new building were considered but are limited due to the required yard setbacks that need to be maintained for R-10 zoned lots with uses other than residential. Any encroachments into the yard setbacks will require a zoning waiver (special permit).

- Sufficient outdoor air intake and exhaust is required for the new generator. The generator size and minimum work clearances in front of the electrical panel boxes that are required by code are other factors that determine the size of the building. See attached site plan, Figure 3-1, for the proposed location of the new building.
- The proposed generator building materials and finishes shall complement and/or match the existing pump station building. This includes CMU concrete block walls, metal doors and frames, stainless steel louvers, screened openings and a low sloping concrete roof to match the pump station roof slope. Selected CMU walls, doors and louvers will be acoustically treated.
- The proposal of a new building may trigger special zoning permits, such as an Environmental Impact Statement (EIS), Special Management Area (SMA) and/or shoreline permit. Any special permits that require processing will impact the project schedule. Upon final selection of the Alternative by DDC, it is recommended that a letter be submitted to the Dept. of Planning & Permitting Director to evaluate the proposed scope and determine if any special permits are required. There may be a

possibility of exemption to these special permits due to the use and function of the facility and pursuant to applicable exemption class of the Dept. of Environmental Services Comprehensive Exemption List.

LOT 6  
T.M.K.: (1) 4-5-047: 061

LOT 7  
T.M.K.: (1) 4-5-047: 060

EASEMENT 6 (10FT. WIDE)  
FOR DRAINAGE PURPOSES

224°35'30" 60.00

LOT 11  
T.M.K.: (1) 4-5-047: 096


HATCHED AREA IS  
REQD YARD SETBACK

**NEW  
GENERATOR  
BUILDING**

PROPERTY LINE

K A - H A N A H O U P L A C E ( P R I V A T E )

LOT 67  
T.M.K.: (1) 4-5-047: 093



DESCRIPTION  
ALTERNATE NOS. 2, 3 & 4

ARCHITECTURAL SITE PLAN

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE**  
KANEHOE, OAHU



OKAHARA AND ASSOCIATES, INC.

JOB NUMBER  
2009107

DATE  
JAN 2011

FIGURE 3-1

3-8

## **CHAPTER 4 – STRUCTURAL**

### **4.1 INTRODUCTION**

The structural related issues included in the renovation of the Kahanahou Wastewater Pump Station include the following:

- a. The construction of a new emergency generator building that will be independent of the pump station structure.
- b. The relining of the wet well concrete surfaces.

### **4.2 EMERGENCY GENERATOR SHED**

The emergency generator building will be constructed of CMU concrete block walls and a cast-in-place concrete roof. Acoustically treated openings will provide ventilation for the generator when in operation. The support of the building will be determined once the geotechnical soil borings and analysis report is complete. The options will include a concrete spread footing, or a deep foundation, such as micropiles or driven piles. The factors that will be considered in the foundation decision will be the weight of the shed structure and the bearing capacity of the soil.

### **4.3 LINING OF THE WET WELL**

On December 28, 2010, a cursory inspection was conducted of the wet well at Kahanahou WWPS. The inspection found that the access shafts that lead down to the wet well chambers are lined with a black coating, possibly a coal tar epoxy. Below that, within the visible portions of the wet well chambers, the black coating appears to be worn away, exposing the concrete substrate to the corrosive wastewater. In addition, the existing 8 inch pump suction pipe that currently penetrates through the concrete wall into the wet wells is being replaced with a



new 6 inch pipe. This work will require partial demolition of the existing wall surrounding the suction pipe. This demolition work will destroy whatever lining is left in that area. For long term performance, the concrete needs to be protected against the corrosive effects of the wastewater, which will erode away the concrete and reinforcing steel over time. A tactile inspection of the wet well chambers can be conducted once the wet well chambers are drained and properly ventilated. This inspection would determine what, if any, damage has occurred to the concrete surfaces by the wastewater.

Regardless of the results of any further inspection work, the wet well surfaces should be properly protected. The original protective liner should be replaced with a new, corrosion-resistant polymer, monolithic lining. One such lining system is manufactured by Sauereisen, Inc. See Appendix G for material data sheets for SewerGard No. 210T. This lining material is currently being installed in the Beachwalk WWPS wet well.

## **CHAPTER 5 – ELECTRICAL SYSTEM**

### **5.1 EXISTING ELECTRICAL SYSTEM**

Electric service for the Kahanahou WWPS is provided by Hawaiian Electric Company (HECO) via underground facilities on Kahanahou Place. Their existing service transformer is mounted on a utility pole located on Kahanahou Place. The HECO pole-top transformer bank steps down their single-phase medium voltage to 120/240 volts, 1-phase, 3-wire service which feeds the WWPS. The existing 120/240 volts, 1-phase, 3-wire secondary service conductors are run underground from the utility pole to an existing service pullbox located outside the fence line of the WWPS. From the pullbox, the service conductors are extended through an existing meter socket located on the exterior wall of the building and terminate at the existing motor control center (MCC). See the Existing Electrical Site Plan on Figure 5-1.

The existing interior electrical system consists of the existing MCC which includes the main circuit breaker for the building, an automatic transfer switch, distribution switches for the station pumps and ventilation system, and a 120/240 volt, 1-phase, 3-wire electrical panelboard to feed general electrical loads. See the Existing Electrical Plan and Existing One-Line Diagram on Figures 5-3 and 5-6.

The normal power system is backed-up by an existing propane fueled emergency generator. The existing generator is a 120/240 volt, 1-phase, 3-wire, 45 kilowatt (kW) standby generator. The existing 120/240 volt, 1-phase, 3-wire emergency power feeder is routed through the existing automatic transfer switch located in the MCC.

The existing SCADA System for the WWPS consists of a single SCADA cabinet equipped with Barrington equipment.

### **5.1.1 EXISTING ELECTRICAL SYSTEM DEFICIENCIES**

The existing electrical system has a number of deficiencies currently affecting the operation of the WWPS. The deficiencies listed below have been identified through extensive research of the existing electrical system. Each item will include a brief discussion on how the deficiencies will be addressed by the design alternatives being proposed.

- The existing electrical system experiences large voltage dips during operation of the station pumps. Specifically, when the station pumps are started. The voltage dips are significant enough to cause the light fixtures throughout the WWPS to dim momentarily. Large voltage dips do have the potential to cause premature failure of the pumps and the pump control equipment due to the increase in current draw associated with a decrease in voltage. Alternatives 2, 3 and 4 will address this deficiency.

Based on information provided HECO, the WWPS does not share its secondary electric service conductors with any of the neighboring residences so the voltage dips should not be transferred to the electrical systems of those residences.

- The existing electric service for the WWPS is a 120/240 volt, 1-phase, 3-wire service. The station pumps require a 240 volt, 3-phase, 3-wire feeder. To accommodate the electrical requirements of the pumps, phase converters are required which add a level of complexity to the electrical system that is not common at other pump stations. The process of converting a 1-phase power source to a 3-phase power source is not 100% efficient and therefore requires more energy to feed the pump than if the pump was connected directly to a 3-phase power source. This deficiency will

not be addressed by the alternatives being proposed however, it is listed as an alternative option. This alternative option is discussed at the end of this Chapter and in the alternative options list in Chapter 6, Table 6-2.

- The electrical equipment including the MCC and emergency generator are very old and deteriorating. The existing equipment was installed in 1965. Typically, the life cycle of an MCC and generator ranges between 30 and 40 years. Alternative 2, 3 and 4 will address this deficiency.
- The existing light fixtures in the WWPS consist of a mix of incandescent and fluorescent light fixtures. Fluorescent light fixtures have been installed throughout pump stations at other sites on the island to decrease energy usage. This deficiency will not be addressed by the alternatives being proposed however, it is listed as an alternative option. See Chapter 6, Table 6-2 for the alternative options.
- The existing SCADA system is based on the Barrington system. The Barrington system is no longer supported by the manufacturer and replacement parts have become difficult to source. Future repairs will become more difficult as the supply for parts is diminished. Alternative 2, 3 and 4 will address this deficiency.
- Signs of corrosion were observed on the exterior light fixtures and exterior exposed conduits feeding various light fixtures and other electrical items. The corrosion did not appear to be to the point of complete penetration of the material however, if penetration does occur, it is potentially a safety hazard if it results in the exposure of live conductors. This deficiency will not be addressed by any of the

alternatives being proposed however, it is listed as an alternative option. See Chapter 6, Table 6-2 for the alternative options.

- The exterior lighting system consists of a mix of incandescent and high intensity discharge (HID) light fixtures. The existing fixtures do not feature cutoff optics and complaints have been made by the neighboring residences about light pollution. The deficiency will not be addressed by the alternatives being proposed however, it is listed as an alternative option. See Chapter 6, Table 6-2 for the alternative options.

## **5.2 NEW ELECTRICAL SYSTEMS**

The following proposed new electrical systems were developed to support the Alternatives described in Chapter 2. See the New Electrical Site Plan, Electrical Plans, and One-Line Diagram on Figures 5-2, 5-4, 5-5 and 5-7. Electrical load calculations for each of the proposed alternative are included in Appendix H.

### **5.2.1 Alternative No. 1 – No Action**

No methods of construction will need to be undertaken. No action taken will result in the WWPS continuing to suffer from the deficiencies listed above. The voltage dips experienced by the WWPS are of the greatest concern as prolonged exposure to this condition could prematurely damage the station pumps and the associated control equipment.

Short term impacts that would result without an upgrade to the electrical system would be that the WWPS will be unable to accommodate the equipment required to meet the demand described in Chapter 2.

Long term impacts include potential failure of the MCC and emergency generator and the inability to get replacement parts for the existing

Barrington SCADA system should a failure occur.

### **5.2.2 Alternative No. 2**

Alternative No. 2 calls for the replacement of the existing MCC, replacement of the existing Barrington SCADA system, and replacement of the existing emergency generator. The following is a list of improvements that will be required.

- Replacement the existing MCC with a new smart MCC. The new MCC will be DeviceNet capable and based on the Allen Bradley Intellicenter MCC. Based on the meter data provided by HECO, the capacity of the existing electric service is sufficient to support the load of 2-15HP pumps operating concurrently however, the inrush current due to the startup of the station pumps is likely to overload the electrical system. To address this issue, variable frequency drives (VFDs) will need to be provided to limit the inrush current at the time of startup. Because the electric service is a 120/240 volt, 1-phase, 3-wire service and the station pumps are 240 volt, 3-phase, 3-wire pumps, phase converters will need to be provided in the MCC to feed the 3-phase pumps from the 1-phase electrical system.

To avoid an electrical outage to the WWPS, a temporary exterior MCC would need to be provided to operate and control the WWPS while the new MCC is installed in the existing MCC's location. The temporary MCC will remain until the installation of the new MCC has been completed.

- Replacement the existing Barrington SCADA system with a new PLC based SCADA system per the current City standards. The new SCADA equipment cabinet will be located in the existing

generator room which will be emptied upon the replacement of the existing generator.

City standards require that the WWPS be equipped with two sources of power at all times. To allow the new SCADA equipment to be installed in the existing generator room, a temporary generator will need to be provided on the site while the existing generator is removed. The temporary generator will remain until the installation of the new emergency generator has been completed. It is also possible that the replacement of the emergency generator could be phased such that the installation of the new generator is completed prior to the replacement of the SCADA equipment. This would eliminate the need for a temporary generator. The replacement of the existing generator is discussed below.

To avoid an outage to the SCADA system, the existing Barrington system will remain until the installation of the new PLC based SCADA system has been completed.

- Replace the existing propane fueled emergency generator with a new diesel engine generator. Due to the increase in size of the station pumps, the generator capacity will need to be increased to 100kW to account for the possible inrush current requirements of the pumps. Manufacturer's data for a typical 100kW generator are included in Appendix H. The new generator will be installed in a new remote generator building located on the property. A new automatic transfer switch will be located in the generator building.

The proposed location of the new generator building is directly over the existing electric and telephone service ductline. The ductlines

will need to be rerouted around the generator building footprint to allow the new building footings to be installed.

- Adverse short term impacts will include long periods of increased noise due to construction. Construction will need to be phased to avoid electrical, SCADA, and emergency system outages at all times. This phasing will result in an extended duration of construction. The project will realize increased costs due to the construction phasing.
- Adverse long term impacts will include increased complexity of the electrical system due to the presence of the phase converters required to feed the 3-phase pumps from the 1-phase electrical system. Increased complexity will also be evident in the control system due the presence of the VFDs for the larger pumps. Both items are uncommon to pump stations on the island and special training will be required for the operators to ensure proper operation of this pump station.

### **5.2.3 Alternative No. 3**

Alternative No. 3 will also include the replacement of the MCC, SCADA system and emergency generator as described in Alternative No. 2. The addition of a lockout feature to limit the operation of the station pumps to only one pump at any given time will allow the new emergency generator size to be reduced to 60kW. Manufacturer's data for a typical 60kW generator are included in Appendix H. The VFDs for the station pumps would not be required under this alternative due to the addition of the lockout feature. Soft starters would be utilized to limit the inrush current of the station pumps resulting in less complex control system. Adverse short term and long term impacts will be similar to those listed in Alternative No. 2.



#### **5.2.4 Alternative No. 4**

Alternative No. 4 will include replacement of the MCC, SCADA system and emergency generator as described in Alternatives No. 2 and 3. The reduction of the station pump sizes from 15HP in Alternatives No. 2 and 3 to 10HP will allow the new emergency generator size to be reduced to 60kW. In addition to the reduction of the generator size, the decreased pump sizes will not require the use of a VFD to limit the inrush current of the pump on startup. Soft starters would be utilized in lieu of VFDs similar to Alternative No. 3.

#### **5.2.5 Alternative Option – Upgrade Electric Service to 480 volt, 3-phase, 3-wire**

An alternative option to upgrade the electric service for the WWPS from 120/240 volt, 1-phase, 3-wire to 480 volt, 3-phase, 3-wire is indicated in the alternative options list included in Chapter 6, Table 6-2. This option directly addresses two deficiencies previously discussed in this section.

The first is the use of phase converters to feed the 3-phase station pumps from the 1-phase electrical system. Upgrading the system to a 3-phase system will eliminate the need to use such devices and simplify the electrical system to be similar to other pump stations on the island. It will also eliminate the inefficiency of the phase converter resulting in lower energy consumption by the station pumps.



The second deficiency addressed is the voltage dips caused by the large inrush current during the starting of the station pumps. Increasing the service voltage from 240 volt, 1-phase to 480 volt, 3-phase will reduce the amount of current drawn by the pumps. This decrease in startup current will reduce and/or eliminate the voltage dips being observed by the pump station in its current condition without the use of complex control devices

like the VFDs proposed in Alternate No. 2 or the soft starters in Alternative No. 3 and 4. The elimination of the VFD and/or soft starter simplifies the control system to be similar to other pump stations on the island and eliminated the need for special training to operate this pump station.

Upgrading the electric service to 480 volt, 3-phase, 3-wire will also allow for a decrease in size of the emergency generator to 50kW.

The cost of implementing this alternative option will be very high due to the current condition of HECO's electrical distribution system along Kahanahou Place. HECO's existing distribution system does not include 3-phase service along Kahanahou Place. To extend 3-phase service to the pump station, HECO's 3-phase primary distribution system will need to be extended from Lilipuna Road, down, Kahanahou Circle, and then down Kahanahou Place. Preliminary estimates to extend HECO's 3-phase distribution system to Kahanahou Place are in the range of \$150,000 to \$200,000. This cost does not include the cost of the new MCC, metering equipment, and emergency generator that would be required to implement this option.

LAST SAVE: 01/05/11 @ 13:29:46 BY: BO PLOT SC 1=20.000000  
Z:\ACAD\PROJECTS\210055\electrical\_exst\_site\_plan XREFS: X10122



DESCRIPTION

# ALTERNATIVE NO. 1 EXISTING ELECTRICAL SITE PLAN

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE**  
KAILUA, OAHU

OKAHARA AND ASSOCIATES, INC.




JOB NUMBER  
2009107

DATE  
JAN 2011

FIGURE 5-1

PAGE 5-10

LAST SAVE: 01/05/11 @ 13:30:03 BY: BO PLOT SC 1=20.000000  
 Z:\ACAD\PROJECTS\210055\002\_210055\_electrical\_site\_plan\_opt1 XREFS: XKAHANAHOU WFPSU-CONCEPTUAL TO OKAHARA 12-15-10




DESCRIPTION

**ALTERNATIVE NO. 2, 3, AND 4  
 ELECTRICAL SITE PLAN**

DEPARTMENT OF DESIGN AND CONSTRUCTION  
 WASTEWATER DIVISION  
 CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER  
 PUMP STATION UPGRADE**  
 KAILUA, OAHU


LAST SAVE: 01/05/11 @ 13:30:20 BY: BO PLOT SC 1/4"=1'  
Z:\ACAD\PROJECTS\210055\003\_210055\_exst\_elec\_plm XREFS: X-PS-MTR



DESCRIPTION

### ALTERNATIVE NO. 1 EXISTING ELECTRICAL PLAN

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE  
KAILUA, OAHU

 OKAHARA AND ASSOCIATES, INC.

JOB NUMBER  
2009107

DATE  
JAN 2011


FIGURE 5-3

PAGE 5-12

LAST SAVE: 01/05/11 @ 13:30:36 BY: BO PLOT SC 1/4"=1'  
Z:\ACAD\PROJECTS\210055\004\_210055\_elec\_plan XREFS: X-PS-MTR

EXISTING TELEPHONE  
CABINET

MCC



SCADA CABINET

DESCRIPTION

ALTERNATIVE NO. 2, 3, AND 4  
ELECTRICAL PLAN

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE  
KAILUA, OAHU

OKAHARA AND ASSOCIATES, INC.

JOB NUMBER  
2009107

DATE  
JAN 2011


FIGURE 5-4

PAGE 5-13

LAST SAVE: 01/05/11 @ 13:30:52 BY: BO PLOT SC 1/4"=1'  
Z:\ACAD\PROJECTS\210055\005\_210055\_gen\_rm\_plan XREFS: XKAHANAHOU WFPSU-CONCEPTUAL TO OKAHARA 12-15-10



EMERGENCY PANEL



METER SOCKET

AUTOMATIC TRANSFER SWITCH

EMERGENCY GENERATOR



SCALE:


GRAPHIC SCALE

1/4"=1'-0"

DESCRIPTION

ALTERNATIVE NO. 2, 3, AND 4  
GENERATOR ROOM - ELECTRICAL PLAN

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
CITY AND COUNTY OF HONOLULU  
KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE  
KAILUA, OAHU




DESCRIPTION

**ALTERNATIVE NO. 1  
 EXISTING ONE-LINE DIAGRAM**

DEPARTMENT OF DESIGN AND CONSTRUCTION  
 WASTEWATER DIVISION  
 CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER  
 PUMP STATION UPGRADE**  
 KAILUA, OAHU





**NOTES:**

- 1 SIZE TO VARY BASED ON MECHANICAL DESIGN ALTERNATIVES.
- 2 STARTER TO FEATURE VARIABLE FREQUENCY DRIVE OF SOFT START BASED ON MECHANICAL DESIGN ALTERNATIVES.

DESCRIPTION

**ALTERNATIVE NO. 2, 3, AND 4  
 ONE-LINE DIAGRAM**

DEPARTMENT OF DESIGN AND CONSTRUCTION  
 WASTEWATER DIVISION  
 CITY AND COUNTY OF HONOLULU  
**KAHANAHOU WASTEWATER  
 PUMP STATION UPGRADE**  
 KAILUA, OAHU

## **CHAPTER 6 – EVALUATION OF ALTERNATIVES AND OPTIONS**

### **6.1 INTRODUCTION**

This chapter compares the proposed design alternatives based on a summary of technical evaluations presented in the previous chapters. The purpose of this comparison is to determine the recommended course of action to upgrade Kahanahou WWPS.

This chapter also evaluates a number of options that CSM personnel requested. These options run the gambit of "nice to haves" to addressing deficiencies that are unrelated to any particular code or standard.

### **6.2 ALTERNATIVE SELECTION EVALUATION CRITERIA**

Evaluation criteria were created in order to rank the suggested alternatives. Each alternative was ranked 1 to 5 for each criterion with 1 representing an excellent score and 5 representing a poor score. The following criteria were used to evaluate the recommended alternatives:

- Life Cycle Cost: This includes all design, capital, operational and maintenance costs of an alternative. A life span of 20 years and a discount rate of 5% were used to evaluate each alternative.
- Operator Preferences: This is a rating of each alternative in the order of operator (Kailua WWTP) preference.
- Satisfy Design Objective: This is a rating of how well the alternative will increase the capacity of the WWPS to meet projected peak flow rates.
- Adverse Short-Term Impacts: Adverse short-term impacts were limited to impacts that occur during the implementation of an alternative.
- Adverse Long-Term Impacts: Adverse long-term impacts were limited to impacts that occur after the implementation of an alternative.

- Adequately Address Existing Deficiencies: This is a rating of an alternative's ability to address existing deficiencies noted in the respective sections. Deficiencies that occur beyond the boundaries of the WWPS were in large part excluded from the evaluation.

All of the alternatives and scores were inputted into an evaluation matrix. The matrix also has a weighting factor that is used to emphasize the importance of one criterion over another. See Table 6-1 for the Alternative Selection Evaluation Matrix.

### **6.2.1 Life Cycle Cost Criterion Description**

The first criterion is the life cycle cost of an alternative. This includes the cost to construct, operate and maintain Kahanahou WWPS. The intent of the criterion is to evaluate each alternative on its expected lifetime cost as opposed to evaluating capital, energy and maintenance costs separately. The following general assumptions were made to complete the evaluation. See Appendix I for rough budgetary cost estimates. See Appendix J for life cycle cost calculations and additional assumptions.

- Project will not commence till 2012. An Annual inflation rate of 5% per year was applied to all of the estimated capital costs.
- An annual discount rate of 5% per year was used.
- Electricity costs of \$0.234 per kWh (Based on HECO Schedule G Rates effective 12-01-2010)
- Maintenance costs coordinated based on professional judgment and input from CSM personnel.

**TABLE 6-1 KAHANAHOU WWPS  
ALTERNATIVE SELECTION EVALUATION MATRIX**

Alt. No.	Description	Flow Rate (MGD)	Motor (HP)	Construction Cost	Present Worth Life Cycle Cost <sup>1</sup>	Alternative Selection Rankings and Weighting														Total Points <sup>2</sup>	Rank
						Life Cycle Cost		Operator Preferences		Meet Req'd Flows		Adverse Short Term Impacts		Adverse Long Term Impacts		Address Deficiencies					
						Points	Weight	Points	Weight	Points	Weight	Points	Weight	Points	Weight	Points	Weight				
1	No Action	0.50	10	\$0	\$426,000	5	4	3	2	5	5	1	1	5	3	5	3	82	4		
2	New Dry Pit Submersible Pumps with VFD	0.90	15	\$3,076,000	\$3,363,000	5	4	1	2	1	5	4	1	3	3	2	3	46	T2		
3	New Dry Pit Submersible Pumps with Soft Starter	0.90	15	\$3,019,000	\$3,306,000	5	4	1	2	1	5	4	1	3	3	2	3	46	T2		
4	New Dry Pit Submersible Pumps	0.79	10	\$2,959,000	\$3,296,000	5	4	1	2	2	5	4	1	2	3	1	3	45	1		

Notes:

na = Not Applicable

<sup>1</sup>Alternative No. 1's life cycle cost does not include possible cleanup costs and fines.

<sup>2</sup>Low points are indicative of a good alternative while high points are indicative of a poor alternative. Lowest possible point total is 18. Highest possible point total is 83.

Alternative No. 1 calls for no pump station improvements to be made and is estimated to have a 20-year life cycle present worth cost of \$426,000. Points were assigned to each alternative as follows with \$500,000 equal to 1 point:

- 1 Point: \$0 to \$750,000
- 2 Points: \$751,000 to \$1,500,000
- 3 Points: \$1,501,000 to \$2,250,000
- 4 Points: \$2,251,000 to \$3,000,000
- 5 Points: \$3,001,000 and up

### **6.2.2 Operator Preferences Criterion Description**

Operator preferences are a ranking of the alternatives as expressed by City operators based at Kailua WWTP. The operators reported that they prefer submersible pumps over line shaft pumps. They also reported that they prefer variable speed pumps over constant speed pumps. Submersible pumps are preferred because they require little maintenance and are not adversely affected to flooding of the dry well. Variable speed pumps are preferred over constant speed pumps because they are able to mitigate some of the flow surges associated with activation/deactivation of constant speed pumps. Points were assigned to each alternative as follows:

- 1 Point: 2 preference met
- 2 Points: 1 preference met
- 3 Points: 0 preferences met

### **6.2.3 Satisfy Design Objectives Criterion Description**

The primary objective of this project is to increase the capacity of the pump station to meet projected peak flow rates. This criterion evaluates each

alternative for its ability to satisfy this objective. The projected peak design flow rate is estimated to be 0.90 mgd based on 10 years of historical daily flow data. Points were assigned based on each alternative's primary pump capacity as follows:

- 1 Point: 0.90 mgd or higher
- 2 Points: 0.81 mgd to 0.90 mgd (90% to 100% of peak design flow rate)
- 3 Points: 0.72 mgd to 0.81 mgd (80% to 90% of peak design flow rate)
- 4 Points: 0.63 mgd to 0.72 mgd (70% to 80% of peak design flow rate)
- 5 Points: 0.54 mgd to 0.63 mgd (60% to 70% of peak design flow rate)

#### **6.2.4 Adverse Short-Term Impacts Criterion Description**

Short-term impacts are defined as construction related impacts and are limited to the duration of construction and implementation of an alternative. Alternatives were assigned points based on anticipated construction time as follows:

- 1 Point: 0 to 6 months
- 2 Points: 6 to 12 months
- 3 Points: 12 to 18 months
- 4 Points: 18 to 24 months
- 5 Points: 24 months and over

#### **6.2.5 Adverse Long-Term Impacts Criterion Description**

Long-term impacts are defined as impacts that will continue to plague the WWPS long after construction is completed. Alternatives were assigned points based on qualitative evaluation as follows:

- 1 Point: No impact
- 2 Points: Minimal impact
- 3 Points: Moderate impact
- 4 Points: Large impact
- 5 Points: Severe impact resulting in compromising public safety or legal action against the City

### **6.2.6 Adequately Addresses Existing Deficiencies Criterion Description**

This criterion evaluates whether an alternative addresses deficiencies described in the previous sections. It specifically excludes satisfying peak flow rates which is covered by another criterion. Points were assigned as follows:

- 1 Point: 0 outstanding deficiencies
- 2 Points: 1 outstanding deficiencies
- 3 Points: 2 outstanding deficiencies
- 4 Points: 3 outstanding deficiencies
- 5 Points: 4+ outstanding deficiencies

### **6.2.7 Criterion Score Weighting**

In addition to the scores given for each criterion, weights were applied to each score with a weight of 1 representing important and a weight of 5 representing extremely important. The intent of applying weights to the scores is to assign degrees of importance based on City preferences. Each criterion was weighted as follows:

- Life Cycle Cost (Weight = 4): It was assumed that life cycle cost is very important and almost as important as Satisfy Design Objectives.

- Operator Preferences (Weight = 2): It was assumed that operator preferences are not as important as Satisfy Design Objects, Adverse Long-Term Impacts or Life Cycle Cost.
- Satisfy Design Objectives (Weight = 5): It was assumed that that satisfying the design objectives of increasing the capacity of the pump station to meet peak flow rates is the project's number one priority.
- Adverse Short-Term Impacts (Weight = 1): Short-term impacts are temporary and only last for the duration of construction.
- Adverse Long-Term Impacts (Weight = 3): Long-term impacts can have a perpetual negative impact on the WWPS if not corrected. It was assumed that adverse long-term impacts are as important as correcting existing deficiencies.
- Adequately Addresses Existing Deficiencies (Weight = 3): It was assumed that addressing existing deficiencies are very important but not if the benefits outweighed the costs.

### **6.3 ALTERNATIVE EVALUATION**

The following is a discussion of each alternative and how they were scored.

#### **6.3.1 Alternative No. 1 - No Action (0.50 mgd @45 feet TDH)**

- Life Cycle Cost: A score of 5 was assigned. Although Alternative No. 1 only has a present worth life cycle cost of approximately \$426,000, significant costs can be incurred should the backup pump fail during a heavy rainstorm event and a wastewater spill occur. Cleanup costs and possible fines could significantly increase the life cycle cost of the alternative.
- Operator Preferences: A score of 3 was assigned based on operator preferences.



- Satisfy Design Objectives: A score of 5 was assigned because the existing pumps do not have sufficient capacity to satisfy the design flow rates.
- Adverse Short-Term Impacts: A score of 1 was assigned because no construction is involved.
- Adverse Long-Term Impacts: A score of 5 was assigned because not upgrading the WWPS could result in SSOs. It would also violate the 1995 EPA consent decree and pending 2011 EPA consent decree.
- Adequately Address Existing Deficiencies: A score of 5 was assigned because there are more than 5 deficiencies associated with the existing WWPS.
  - Insufficient pump capacity.
  - Inlet bell velocity too low.
  - Pump discharge connected to header from bottom.
  - Dry well not continuously ventilated.
  - Dry well and wet well are not completely isolated from one another.
  - Lack of throttling valve feedback.
  - WWPS experiences large voltage dips.
  - Equipment and building components have reached the end of their useful lives.
  - Barrington SCADA system is dated and parts are difficult to find.

### **6.3.2 Alternative No. 2 - Install New Constant Speed Dry Pit Submersible Pumps with VFDs (0.90 mgd @55.5 feet TDH)**

- Life Cycle Cost: A score of 5 was assigned for a present worth life cycle cost of approximately \$3,363,000.

- Operator Preferences: A score of 1 was assigned based on operator preferences.
- Satisfy Design Objectives: A score of 1 was assigned because the pumps were sized to meet the project peak flow rates.
- Adverse Short-Term Impacts: A score of 4 was assigned because construction is anticipated to last 18-24 months.
- Adverse Long-Term Impacts: A score of 3 was assigned because there is the potential to surcharge and overwhelm the downstream collection system should the controls fail. The controls will be unique to the City and will add a level of complexity uncommon to other stations.
- Adequately Address Existing Deficiencies: A score of 2 was assigned because this alternative will not address operator concerns regarding adequate real time feedback as the throttling ball valve is adjusted.

### **6.3.3 Alternative No. 3 - Install New Constant Speed Dry Pit Submersible Pumps with Soft Starters (0.90 mgd @55.5 feet TDH)**

- Life Cycle Cost: A score of 5 was assigned for a present worth life cycle cost of approximately \$3,306,000.
- Operator Preferences: A score of 1 was assigned based on operator preferences. Note that a soft starter should achieve similar success in limiting flow surges upon activation of a pump.
- Satisfy Design Objectives: A score of 1 was assigned because the pumps were sized to meet the project peak flow rates.
- Adverse Short-Term Impacts: A score of 4 was assigned because construction is anticipated to last 18-24 months.

- Adverse Long-Term Impacts: A score of 3 was assigned because there is the potential to surcharge and overwhelm the downstream collection system should someone fail to adhere to designed protocols. Operation of two pumps simultaneously will likely overwhelm the downstream collection system. This protocol will be unique to the City and will add a level of complexity uncommon to other stations.
- Adequately Address Existing Deficiencies: A score of 2 was assigned because this alternative will not address operator concerns regarding adequate real time feedback as the throttling ball valve is adjusted.

#### **6.3.4 Alternative No. 4 - Install New Constant Speed Dry Pit Submersible Pumps (0.79 mgd @44 feet TDH)**

- Life Cycle Cost: A score of 5 was assigned for a present worth life cycle cost of approximately \$3,296,000.
- Operator Preferences: A score of 1 was assigned based on operator preferences. Note that a soft starter should achieve similar success in limiting flow surges upon activation of a pump.
- Satisfy Design Objectives: A score of 2 was assigned because the pumps were sized to avoid surcharging the downstream collection system rather than meeting the project peak flow rates. Note that each pump should have sufficient capacity to meet all of the recorded peak flow rates that have occurred over the past 10 years.
- Adverse Short-Term Impacts: A score of 4 was assigned because construction is anticipated to last 18-24 months.
- Adverse Long-Term Impacts: A score of 2 was assigned because the pumps will have marginal capacity to meet peak flow rates but will not add complexity that Alternatives 2 and 3 will.

- Adequately Address Existing Deficiencies: A score of 1 was assigned because this alternative will address all non-capacity related deficiencies. Although this alternative will not specifically satisfy operators' request for throttling valve flow feedback, the pumps were sized to avoid the need to throttle the flow.

#### **6.4 ALTERNATIVE OPTIONS EVALUATION**

The purpose of this evaluation is to document and discuss requests that CSM made to repair and/or improve the existing WWPS. See Table 6-2. The goal of this evaluation was to provide a non-biased opinion as to the merit and relative need of each request. The requests were dubbed alternative options as they are not alternatives in themselves. Rather they are options that may be implemented somewhat independently of the alternatives.

Some of the requests are necessary to implement because they are required by the proposed upgrades. For example, CSM requested that the pump station piping be replaced. The piping is required to be replaced to physically accommodate replacement equipment and to address hydraulic deficiencies. Other requests are not necessitated by proposed hydraulic upgrades but will address a number of concerns including replacing components/elements that have reached the end of their useful lives, improve safety and improve efficiency. For example, the building is in need of painting to extend the life of building surfaces.

**TABLE 6-2 KAHANAHOU WWPS  
ALTERNATIVE OPTIONS EVALUATION SUMMARY**

No.	CITY REQUEST	CONSULTANT COMMENT	COST	STRONG SUPPORT	SUPPORT	DECLINE COMMENT
1	Install new roof.	<p><u>Architectural Comment:</u> It is not known when the existing roof was re-roofed. If it is not currently leaking, then, don't install a new roof.</p> <p><u>Structural Comment:</u> A significant percentage of the pitch and gravel roofing is in poor condition. Over 50% of the gravel is missing, and along the roof ridge, the tar paper is completely exposed and has worn through several layers. It is likely that the roofing material is not providing any protection against moisture infiltration.</p>	TBD			X
2	Install new interior and exterior lights. Exterior lights shall shine straight downwards. Neighbors may complain about lights that illuminate their houses.	<p><u>Electrical Comment:</u> Replacement of the interior light fixtures is recommended to reduce energy consumption for the WWPS. At a minimum, the existing fluorescent light fixtures should be cleaned and relamped and the existing incandescent light fixtures replaced with new linear fluorescent or compact fluorescent alternatives. Replacement of the exterior light fixtures is recommended to address complaints from the neighboring residences and to address the corrosion observed on the existing fixtures.</p>	\$10,857	X		
3	Paint interior and exterior of station.	<p><u>Architectural Comment:</u> It appears that the existing walls (interior and exterior CMU - Grade Level) is not painted. The exterior roof eaves are painted and show peeling. The eaves should be repainted. The interior ceiling and walls below Grade Level appear in good shape and probably don't need repainting. The floors appear painted and show wear. The floors should be repainted.</p> <p>Construction of a new generator building is proposed under Alternative No. 2, 3 and 4. Painting of the generator building should match the existing pump station building if the generator building is constructed of CMU walls and low sloped concrete roof. Painting of the existing pump station building should match the painting of the generator building if the generator building is constructed of concrete wall.</p>	TBD		X	
4	Replace suction elbows in wet well.	<p><u>Civil/Mechanical Comment:</u> Suction elbows are proposed to be replaced as a part of Alternative No. 2, 3 and 4. Replacement of the elbows are recommended to correct a low suction fluid velocity issue. Replacement is also recommended because the elbows are approaching the end of their useful lives. The elbows are assumed to be from the original installation and are 44+ years in age.</p>	Included in Alternative Costs.	X		
5	Replace suction piping through wall.	<p><u>Civil/Mechanical Comment:</u> Suction pipes through wall are proposed to be replaced as a part of Alternative No. 2, 3 and 4. Replacement of the pipes are recommended to correct a low suction fluid velocity issue. Replacement is also recommended because the pipes are approaching the end of their useful lives. The pipes are currently 44+ years old.</p>	Included in Alternative Costs.	X		

**TABLE 6-2 KAHANAHOU WWPS  
ALTERNATIVE OPTIONS EVALUATION SUMMARY**

No.	CITY REQUEST	CONSULTANT COMMENT	COST	STRONG SUPPORT	SUPPORT	DECLINE COMMENT
6	Replace all suction and discharge piping up to venturi meter pit.	<u>Civil/Mechanical Comment:</u> All of the on-site suction and discharge piping up to the existing throttling valve is intended to be replaced as a part of Alternative No. 2, 3 and 4 to facilitate construction phasing.	Included in Alternative Costs.	X		
7	Replace all suction and discharge valves. Install gate valves.	<u>Civil/Mechanical Comment:</u> All of the on-site suction and discharge valves up to the existing throttling valve are intended to be replaced as a part of Alternative No. 2, 3 and 4 to facilitate construction phasing.	Included in Alternative Costs.	X		
8	Install new water line from meter to station and inside of station.	<u>Civil/Mechanical Comment:</u> Replacement of the underground piping is strongly supported due to the close proximity to the ocean. Replacement piping is recommended to be Type K piping with protective polyethylene sheet covers.	\$10,000	X		
9	Install new diesel fueled standby engine generator.	<u>Civil/Mechanical Comment:</u> The propane fueled standby engine generator is proposed to be replaced as a part of Alternative No. 2, 3 and 4. Replacement of the standby engine generator with a larger capacity unit is necessary to provide sufficient emergency standby power for the proposed replacement equipment. Replacement standby engine generator is recommended to be diesel fueled to be consistent with other wastewater facilities.	Included in Alternative Costs.	X		
10	Install dry pit submersible pumps.	<u>Civil/Mechanical Comment:</u> Replacement pumps are proposed to be dry pit submersible pumps as a part of Alternative No. 2, 3 and 4. The life cycle cost difference between dry pit submersible and separately coupled pumps is negligible.	Included in Alternative Costs.	X		
11	Install new MCC cabinets. New MCC cabinets shall be smart type similar to the ones installed at Enchanted Lake Wastewater Pump Station.	<u>Electrical Comment:</u> Replacement of the existing MCC is proposed in Alternatives 2, 3 and 4. Replacement is recommended due to the age of the existing MCC.	Included in Alternative Costs	X		
12	Get rid of Healy Ruff float and cable - install 2 pressure transducers.	<u>Civil/Mechanical Comment:</u> The Healy Ruff float and cable are proposed to be replaced as a part of Alternative No. 2, 3 and 4. Replacement of the float and cable is recommended to help comply with the City's effort to modernize and standardize wastewater facility controls.	Included in Alternative Costs.	X		
13	Remove existing windows and install new stainless steel louvers with screens. No glass windows.	<u>Architectural Comment:</u> Replacement of the existing louvers and windows is up to the City. If the windows above the main entry double doors are replaced, the doors would have to be replaced because the window and door frames are integral. This is also the case with the doors to the current emergency generator room because of the louver frames are integral with the louvered doors below.	TBD			X
14	Replace toilet and wash sink. New toilets and wash sink shall be outfitted with new sewer lines to the wet well.	<u>Civil/Mechanical Comment:</u> The condition of the existing plumbing is unknown. CSM will be consulted to clarify the reason for this request.	\$4,000			X

**TABLE 6-2 KAHANAHOU WWPS  
ALTERNATIVE OPTIONS EVALUATION SUMMARY**

No.	CITY REQUEST	CONSULTANT COMMENT	COST	STRONG SUPPORT	SUPPORT	DECLINE COMMENT
15	Install a permanent suction and discharge line for portable pump hook up. Install a new suction pipe to the bottom of the wet well. Add a new underground bypass line to the venturi tube from the wet well. The connection at the wet well should be a 4-inch cam lock type connection. The bypass line will be used in case the pump station needs to be bypassed.	<u>Civil/Mechanical Comment:</u> A permanent bypass line will help simplify the connection of emergency bypass pumps for the operators. Installation of a bypass line is recommended budget permitting.	Included in Alternative Costs		X	
16	Install a drain line so venturi pit sump pumps discharge into the wet well.	<u>Civil/Mechanical Comment:</u> Relocation of the meter vault to the grassed area without a top cover will require sump pumps. Collected water should primarily be rainwater but there is a possibility of sewer discharging into the meter vault during maintenance efforts. It would be safer to discharge collected water into the wet well to avoid the possibility of inadvertently and improperly discharging sewer laden water into waterways. The only drawback is that the City will need to issue an exemption to allow discharging rainwater into the sewer collection system.	Included in Alternative Costs	X		
17	Replace dry well sump pump discharge line.	<u>Civil/Mechanical Comment:</u> The condition of the existing discharge line is unknown. However, the discharge line is a relatively inexpensive item and is recommended to be replaced along with the sump pump.	Included in Alternative Costs	X		
18	Verify that floors slope towards floor drains. Modify pump room floors to slope towards drain channels if the existing floors do not slope towards the floor drains.	In the process of verifying floor slope.	TBD			
19	Install an aboveground fuel storage tank if possible. Above ground fuel tank - match sticks around tank, with ladder fiberglass or stainless steel.	<u>Civil/Mechanical Comment:</u> There is insufficient space on the property to install an aboveground fuel storage tank.	Not Applicable	X		
20	Widen driveway entrance to the pump station. Entrance is presently about 11-feet in width. Entrance should be widened to a width of 16~19 feet with half gates. Needed for fuel truck entry.	<u>Civil/Mechanical Comment:</u> The existing driveway is a bit narrow and no objections are noted to widening of the entrance and driveway if it will facilitate ease of maintenance. Estimated Costs are for chain link fence only.	\$10,000	X		
21	Repave station driveway.	<u>Civil/Mechanical Comment:</u> It is likely that the existing driveway will take a beating during construction and hence should be repaved at the end of construction.	\$20,000		X	
22	Install plastic barrier and rock where dirt or grass is at.	<u>Civil/Mechanical Comment:</u> Removal of existing onsite vegetation will reduce required landscape maintenance and will improve security by allowing for clear site vision from the property line.	TBD	X		

**TABLE 6-2 KAHANAHOU WWPS  
ALTERNATIVE OPTIONS EVALUATION SUMMARY**

No.	CITY REQUEST	CONSULTANT COMMENT	COST	STRONG SUPPORT	SUPPORT	DECLINE COMMENT
23	Bring new HECO power into station. 3-phase, 480 volt underground. If upgrading to 3-phase power is not possible, replace electrical wires from down pole to station.	<u>Electrical Comment:</u> Upgrading the existing electric service from a 120/240 volt, 1-phase, 3-wire service to a 480 volt, 3-phase, 3-wire service would help in alleviating the voltage dip issue however, the cost to achieve this will be very high. HECO does not have 3-phase facilities along Kahanahou Place and would need to extend 3-phase service from Lilipuna Road to provide 480V service to the WWPS. Replacement of the conductors between the existing utility pole and the WWPS electric service equipment is an issue that will be decided by HECO. The conductors are owned and maintained by HECO.	\$174,283		X	
24	Install SCADA connection to water meter.	<u>Civil/Mechanical Comment:</u> A SCADA connection should be made to the water meter to enable the City to monitor water usage in real time. The connection should be made to be consistent with other pump stations on the island.	Included in Alternative Costs	X		
25	Install SCADA connection to HECO meter.	<u>Electrical Comment:</u> This is consistent with other pump stations on the island.	TBD		X	
26	Install outside plug connection for portable generator.	<u>Electrical Comment:</u> The installation of a plug for a portable generator is consistent with other pump stations on the island.	\$3,242	X		
27	Install new ventilation system - stainless steel duct.	<u>Civil/Mechanical Comment:</u> Stainless steel should be installed in lieu of galvanized steel due to the close proximity to sewer gases, salt-laden air, and in the interest of longevity.	Included in Alternative Costs		X	
28	Install new SCADA PLC to include a screen of Waikapoki WWPS if onsite ball valve is used for throttling.	<u>Civil/Mechanical Comment:</u> Will need to discuss further.	TBD			X
29	Replace flow meter with a new flow meter located in the grassed area outside of the paved area. Meter should be located in an open vault to eliminate confined space entry requirements. Install sump pumps in pit.	<u>Civil/Mechanical Comment:</u> The meter vault should be relocated if it will help ease maintenance efforts.	Included in Alternative Costs	X		
30	Install new standby emergency engine generator - sound abatement on walls - exhaust thru the wall, not thru the roof.	<u>Electrical Comment:</u> Replacement of the emergency generator is proposed in Alternative 2, 3, and 4. Replacement is recommended due to the age of the existing generator.	Included in Alternative Costs	X		
31	Install new smoke detectors and connect to SCADA.	<u>Electrical Comment:</u> This is consistent with other pump stations on the island.	\$12,663	X		
32	Install day tank for standby emergency engine generator.	<u>Civil/Mechanical Comment:</u> A day tank is intended to be installed as a part of Alternative No. 2, 3 and 4.	Included in Alternative Costs	X		
33	Fuel lines shall be stainless steel with flanged joints. Do not use threaded pipe.	<u>Civil/Mechanical Comment:</u> Aboveground fuel lines are intended to be constructed of stainless steel with flanged joints to the extent necessary as a part of Alternative No. 2, 3 and 4.	Included in Alternative Costs	X		



**TABLE 6-2 KAHANAHOU WWPS  
ALTERNATIVE OPTIONS EVALUATION SUMMARY**

No.	CITY REQUEST	CONSULTANT COMMENT	COST	STRONG SUPPORT	SUPPORT	DECLINE COMMENT
34	Check condition of wet well - replace lining if necessary and install larger manholes for wet well cleaning.	<u>Structural Comment:</u> Existing lining is over 45 years old. If it is the intention to utilize the pump station for another 10 to 20 years then the liner should be replaced. Further, the 8 inch pump suction pipe that currently penetrates through the concrete wall into the wet wells is being replaced with a new 6 inch pipe. This work will require partial demolition of the existing wall surrounding the suction pipe. This demolition work will destroy whatever lining is left in that area.	Included in Alternative Costs	X		
35	Remove irrigation lines.	<u>Civil/Mechanical Comment:</u> Removal of existing onsite vegetation will reduce required landscape maintenance and will improve security by allowing for clear site vision from the property line. Cost reflects abandoning lines in place.	\$0	X		
36	The new force main discharges into a submerged manhole. Address if possible.	<u>Civil/Mechanical Comment:</u> See Chapter 2 writeup.	TBD			
37	Lower discharge header down to lower level.	<u>Civil/Mechanical Comment:</u> Discharge header is proposed to be lowered to minimize the length of idle vertical laterals. Reducing the length of the idle vertical headers should help alleviate the rate at which the laterals are plugged by non moving sewage.	Included in Alternative Costs	X		
38	Install A-Frames for replacement of pumps.	<u>Civil/Mechanical Comment:</u> Will need to discuss further to clarify request.	TBD			X
39	Consider downstream collection system and onsite throttling ball valve in analysis.	<u>Civil/Mechanical Comment:</u> Onsite throttling ball valve and limited downstream collection system analysis is included in the DAR. See Chapter 2 - Pump Station.	\$0	X		
40	Install sluice gate between the two wet wells. (Recommended by Structural)	<u>Structural Comment:</u> If work needs to be done in one of the wet wells, the facility personnel have to climb down to the bottom of the wet well and insert timber boards into the wall guides to block the flow between wells.	TBD	X		

## **6.5 DESCRIPTION OF METHODS FOR REPLACEMENT**

The following describes the methods that will be employed to implement each alternative.

### **6.5.1 Alternative No. 1 - No Action (0.50 mgd @45 feet TDH)**


No methods of construction will need to be undertaken.

### **6.5.2 Alternative No. 2 - Install New Constant Speed Dry Pit Submersible Pumps with VFDs (0.90 mgd @55.5 feet TDH)**

The following is a description of minimum steps that need to be undertaken to implement Alternative No. 2. See Figure 6-1 for proposed site plan. Proposed site plan does not reflect any of the alternative option upgrades.

- Concrete jacket gravity sewer line beneath new electrical building.
- Install new force with temporary capped ends.
- Install new meter vault, bypass piping and sump pumps.
- Construct new electrical building with piles.
- Install new underground fuel storage tank.
- Install new diesel fueled standby engine generator, fuel system, exhaust system, electrical connections, automatic transfer switch and appurtenances.
- Remove existing propane fueled standby engine generator and propane tank.
- Renovate existing generator room into a new SCADA room.
- Install new SCADA system.
- Install temporary self priming pumps and temporary motor control center.

J:\D:\PROJ\21002\REPORT\FIG 1-SITE.DWG/1=240/12-19-10/XREF=0A1117.X=10122



KAHANAHOU WWPS.  
SEE FIGURE 2-6

EXISTING WET WELL

CAP EXISTING  
FORCE MAIN TYP.

LOT 11  
T.M.K.: (1) 4-5-047: 096

ABANDON EXISTING  
FORCE MAIN IN PLACE

UNDERGROUND FUEL  
STORAGE TANK

GENERATOR BUILDING

CONCRETE JACKET  
EXIST. 8" SEWER MAIN  
LOCATED BENEATH  
GENERATOR BLDG

LOT 65  
T.M.K.: (1) 4-5-047: 094

METER VAULT

CONNECT NEW FORCE  
MAIN TO EXISTING

EXISTING THROTTLING  
BALL VALVE VAULT


EXISTING FORCE MAIN

KAHANAHOU PLACE (PRIVATE)

LOT 67  
T.M.K.: (1) 4-5-047: 093

KANEHOE BAY

LOT 66  
T.M.K.: (1) 4-5-047: 129



DESCRIPTION

**NEW SITE PLAN**  
SCALE: 1" = 20'-0"

DEPARTMENT OF DESIGN AND CONSTRUCTION  
WASTEWATER DIVISION  
**KAHANAHOU WASTEWATER  
PUMP STATION UPGRADE**  
CITY AND COUNTY OF HONOLULU  
KANEHOE, OAHU

- Rehabilitate and line wet well.
- Install new pump suction piping through wet well / dry well wall.
- Replace motor control center.
- Remove both existing pumps, supports, motors, shafts and piping.
- Install new submersible pumps, supports, piping and appurtenances.
- Install new controls.
- Install new ventilation system.
- Startup, test and commission system.
- Remove temporary equipment.

### **6.5.3 Alternative No. 3 - Install New Constant Speed Dry Pit Submersible Pumps with Soft Starters (0.90 mgd @55.5 feet TDH)**

The steps to be undertaken for Alternative No. 3 is identical to the steps in Alternative No. 2.

### **6.5.4 Alternative No. 4 - Install New Constant Speed Dry Pit Submersible Pumps (0.79 mgd @44 feet TDH)**

The steps to be undertaken for Alternative No. 4 is identical to the steps in Alternative No. 2.

## **CHAPTER 7 – RECOMMENDATIONS**

Based on the result of the Alternative Selection Evaluation Matrix presented in Chapter 6, Alternative No. 4 is recommended. Alternative No. 4 calls for the replacement of the existing pumps with new larger capacity constant speed submersible pumps. Alternative No. 4 is estimated will cost approximately \$2,959,000 to construct.

Alternatives No. 2 and 3 were very close in score to Alternative No. 4 but it is recommended that they not be pursued for the following reasons:

Alternative No. 2 will satisfy projected peak flow rates but could result in overflowing the downstream 10-inch gravity main. Should two pumps operate simultaneously, the downstream system will likely experience SSOs. In order to combat this, SCADA will monitor WWPS flow rates and adjust the speed of the VFDs to limit the maximum flow rate from the pump station. The flow limiting controls will complicate the operation of the WWPS and could cause problems if operators are not thoroughly familiar with the system.

Alternative No. 3 is identical to Alternative No. 2 except VFDs are replaced with soft starters. In order to limit WWPS flow rates and combat possible SSOs in the downstream collection system, one pump will always be locked out to prevent two pumps from operating simultaneously. Locking out one pump with SCADA will introduce operating procedures uncommon to City WWPS. Complications could arise if operators are unaware of the unique operating procedures.

Alternative No. 4 has a slightly reduced capacity that will not quite meet projected peak flow rates. Note that a 10% safety factor was added to the peak flow rates recorded over the past 10 years to develop a future projected peak flow rate. Alternative No. 4 will be able to satisfy flow rates that are in line with peak flow rates recorded over the past 10 years. Furthermore, a pilot project that rehabilitated sewer

laterals in the area was completed in Late 2008. Insufficient time has elapsed to determine if the pilot project was successful in reducing I/I and associated peak flow rates.

In summary, it is recommended that Alternative No. 4 be implemented. Alternative No. 4 utilizes features that are common to City WWPS and will not introduce unique controls or operating procedures. It is also more energy efficient than Alternatives No. 2 and 3 due to the reduced fluid velocities through the force main. Finally, it has a slightly lower first cost and life cycle cost as compared with Alternatives No. 2 and 3.

As for the Alternative Options, it is recommended that the City implement as many options as the budget allows. Most of the alternative options will go towards ensuring that the WWPS provide reliable service for a long time to come. Upgrading components that have reached or are approaching the end of their useful lives will all at once will also result in cost savings due to economies of scale.

## **APPENDIX A PUMP STATION CALCULATIONS**

A-1	Downstream Gravity Main Capacity..	A-2
A-2	Wet Well Volume. ....	A-5
A-3	NPSH Available .....	A-9
A-4	Alt. No. 1 Pump Curves .....	A-11
A-5	Alt. No. 2 & 3 Pump Curves .....	A-18
A-6	Alt. No. 4 Pump Curves .....	A-23
A-7	Water Hammer Calcs. ....	A-26

**OKAHARA & ASSOCIATES, INC.**

677 Ala Moana Blvd. Suite 703

HONOLULU, HAWAII 96813

(808) 524-1224

JOB Kahanahou WWP (210-002)SHEET NO. 1 OF 3CALCULATED BY T.T. DATE Jan 6, 2011

CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_

SCALE Downstream Gravity Main Capacity

Reference: Table 2-2: Limited Downstream Sewer Analysis (Manning's Eq)

Calculate Capacity of Downstream Gravity Main

The following were obtained from City GIS Data and only applies to the first 1,150 linear feet of gravity main downstream of force main outlet.

$$\text{Min size} = 10''$$

$$\text{Min slope} = 0.00319$$

$$V = \frac{1.486}{n} R^{2/3} S^{1/2}$$

Where:  $V$  = velocity (ft/s) $n$  = Manning's coefficient (0.015 from City standards) $R$  = hydraulic radius (ft) $S$  = slope

For Full Flow

$$R = \frac{\pi r^2}{2\pi r} = \frac{r}{2}$$

$$V = \left( \frac{1.486}{0.015} \right) \left( \frac{5/12}{2} \right)^{2/3} (0.00319)^{1/2} = 1.97 \text{ ft/s} = 481 \text{ gpm}$$

$\therefore$  Maximum capacity = 480 gpm without surcharging main.



**OKAHARA & ASSOCIATES, INC.**

677 Ala Moana Blvd. Suite 703

HONOLULU, HAWAII 96813

(808) 524-1224

JOB Kahanahou WWS (210-002)SHEET NO. 2 OF 3CALCULATED BY TT DATE Jan 6, 2011

CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_

SCALE Downstream Gravity Main Capacity

Calculate maximum capacity of downstream gravity main assuming pressurized flow and no sso's.

$$\text{Bernoulli Equation: } E_t = \frac{P}{\rho} + \frac{v^2}{2g_c} + \frac{zg}{g_c}$$

Where:  $E_t$  = Total Specific Energy (ft-lbf/lbm)

$P$  = Pressure (lbf/ft<sup>2</sup>)

$\rho$  = Density (lbm/ft<sup>3</sup>)

$v$  = Velocity (ft/s)

$g_c$  = Gravitational constant (32.2 lbm-ft/lbf-s<sup>2</sup>)

$g$  = acceleration due to gravity (32.2 ft/s<sup>2</sup>)

$$\text{Hazen Williams Equation: } h_f = \frac{(3.022)(v)^{1.85} L}{(C)^{1.85} (D)^{1.165}}$$

Where:  $h_f$  = Frictional head loss (ft)

$v$  = Velocity (ft/s)

$L$  = Pipe length (ft)

$C$  = Hazen-Williams roughness coefficient ( $C = 100$ )

$D$  = Pipe Diameter (ft)

Given: Upstream SMH

- Ground EI = 4.05 ft

- Depth = 4 ft

- Inv = 0.05

Downstream SMH

- Inv = (-) 2.74 ft

Distance Between SMHs = 833 ft

**OKAHARA & ASSOCIATES, INC.**

677 Ala Moana Blvd. Suite 703

HONOLULU, HAWAII 96813

(808) 524-1224

JOB Kahanahou WWPS (210-002)SHEET NO. 3 OF 3CALCULATED BY T.T. DATE Jan 6, 2011

CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_

SCALE Downstream Gravity Main Capacity

Set point 1 at upstream SMH Rim

$$P_1 = 0$$

$$V_1 = 0$$

$$z_1 = 4.05 \text{ ft}$$

Set point 2 at downstream SMH Rim

$$P_2 = 0$$

$$z_2 = (-) 2.74 \text{ ft}$$

$$E_{t(1)} = E_{t(2)} + h_f(1 \text{ to } 2)$$

$$\frac{z_1 g}{g_c} = \frac{V_2^2}{2g_c} + \frac{z_2 g}{g_c} - h_f(1-2)$$

$$V_2 = \left[ (2g_c) \left( \frac{z_1 g}{g_c} - \frac{z_2 g}{g_c} - h_f(1-2) \right) \right]^{1/2}$$

$$V_2 = \left[ (2g) (z_1 - z_2) - 2g_c h_f(1-2) \right]^{1/2}$$

$$V_2 = \left[ (2) \left( \frac{32.2 \text{ ft}}{\text{s}^2} \right) (4.05 \text{ ft} + 2.74 \text{ ft}) - (2) \left( \frac{32.2 \text{ lbm} \cdot \text{ft}}{\text{lb}_f \cdot \text{s}^2} \right) h_f(1-2) \right]^{1/2}$$

$$h_f = \frac{(3.022)(V_2)^{1.85}(833 \text{ ft})}{(100)^{1.85}(10/12)^{1.165}}$$

After several rounds of iteration

$$V_2 = 3.58 \text{ ft/s} \rightarrow Q_{\text{max}} = 1.26 \text{ mgd}$$

$$\text{Assuming } 6'' \text{ of safety factor } V_2 = 3.44 \text{ ft/s} \rightarrow Q_{\text{max}} = 1.21 \text{ mgd}$$

**TABLE: A-2.1 MAXIMUM WET WELL VOLUME BASED ON MAXIMUM WASTEWATER RETENTION TIME**

Alternative	Wastewater Inflow Rate i (gpm)	Pump Flow Rate q (gpm)	Max Wastewater Retention Time (min)	Maximum Wet Well Volume		Wet Well Volume Between LWL and Wet Well Floor		Net Wet Well Volume		LWL Elevation (ft)	HWL Elevation <sup>1</sup> (ft)
				(gallons)	(ft <sup>3</sup> )	(gallons)	(ft <sup>3</sup> )	(gallons)	(ft <sup>3</sup> )		
1	139	347	30.0	4,170	557	1,724	230	2,446	327	-13.68	-11.20
2	139	625	30.0	4,170	557	1,889	253	2,281	305	-13.25	-11.20
3	139	625	30.0	4,170	557	1,889	253	2,281	305	-13.25	-11.20
4	139	520	30.0	4,170	557	1,889	253	2,281	305	-13.25	-11.20

**TABLE: A-2.2 MOTOR STARTS PER HOUR BASED ON MAXIMUM WET WELL VOLUME**

Alternative	Net Wet Well Volume		Pump Flow Rate q (gpm)	Min. Cycle Time Between Starts <sup>2</sup> (min)	Maximum Motor Starts Per Hour	Manufacturer Suggested Maximum Motor Starts Per Hour
	(gallons)	(ft <sup>3</sup> )				
1	2,446	327	347	28.2	2.13	12 Based on Standards
2	2,281	305	625	14.6	4.11	12 Based on Standards
3	2,281	305	625	14.6	4.11	12 Based on Standards
4	2,281	305	520	17.5	3.42	12 Based on Standards

**TABLE: A-2.3 MINIMUM NET WET WELL VOLUME BASED ON MAXIMUM MOTOR STARTS PER HOUR**

Alternative	Net Wet Well Volume		Pump Flow Rate q (gpm)	Min. Cycle Time Between Starts <sup>2,3</sup> (min)	Maximum Motor Starts Per Hour	Manufacturer Suggested Maximum Motor Starts Per Hour
	(gallons)	(ft <sup>3</sup> )				
1	434	58	347	5.0	12.00	Based on Standards
2	781	104	625	5.0	12.00	Based on Standards
3	781	104	625	5.0	12.00	Based on Standards
4	650	87	520	5.0	12.00	Based on Standards

**TABLE: A-2.4 MINIMUM RECOMMENDED WET WELL HWL ELEVATION SET POINT**

Alternative	Wastewater Inflow Rate i (gpm)	Pump Flow Rate q (gpm)	Cycle Time Between Starts <sup>2</sup> (min)	Minimum Wet Well Volume		Wet Well Volume Between LWL and Wet Well Floor		Net Wet Well Volume		LWL Elevation (ft)	HWL Elevation (ft)
				(gallons)	(ft <sup>3</sup> )	(gallons)	(ft <sup>3</sup> )	(gallons)	(ft <sup>3</sup> )		
1	139	347	5.2	2,158	288	1,724	230	434	58	-13.50	-13.14
2	139	625	7.2	2,670	357	1,889	253	781	104	-13.25	-12.01
3	139	625	7.2	2,670	357	1,889	253	781	104	-13.25	-12.01
4	139	520	6.4	2,539	339	1,889	253	650	87	-13.25	-12.22

<sup>1</sup>Alternative No. 1 HWL elevation is currently set at -11.50.

<sup>2</sup>Minimum cycle time between starts assumes two pumps alternate after every start. Minimum Cycle time is per pump. Actual WWPS cycle time is half of reported cycle time.

<sup>3</sup>Minimum cycle time between starts occurs when  $i = 0.5 * q$ .

#### Table A-2.1 Sample Calculations

Wastewater inflow rate (i) = 0.20 mgd = 139 gpm

Pump flow rate (q) = 347 gpm (From Chart A-4.1)

Max. wastewater retention time = 30 minutes (From C&C WW Standards)

LWL elevation = -13.68 (From SCADA display at WWPS)

Wet well invert = -16.50 (From reference drawings)

Calculate Wet Well Volume Between LWL and Floor

Wet well volume between LWL and floor = (floor area)\*(LWL-invert) - (wet well taper) = 1,724 gallons

\*Due to varying cross section area, the net volume was solved for through an iterative process.

Calculate Maximum Allowable Wet Well Wastewater Volume Based on a Retention Time of 30 Minutes

$V = i * t$

Where: i = Average wastewater inflow rate (gpm)

t = Retention time (minutes)

$V = (139 \text{ gpm}) * (30 \text{ minutes}) = 4,170 \text{ gallons} = 557 \text{ ft}^3$

Calculate Net Wet Well Wastewater Volume

Volume = 4,170 gallons - 1,724 gallons = 2,446 gallons = 327 ft<sup>3</sup>

Calculate HWL Elevation

HWL = LWL + (Net wet well wastewater volume)/(wet well area) = -11.20 feet

\*Due to varying cross section area, the HWL was solved for through an iterative process.

#### Table A-2.2 Sample Calculations

Net wet well volume (From Table A-2.1)

Pump flow rate (q) = 347 gpm (From Chart A-4.1)

Assume pumps alternate starting

Calculate Minimum Cycle Time Between Starts For Each Pump

$T = 4V/q$

Where: T = Cycle time between starts (minutes)

V = Wet well wastewater volume (gallons)

$$q = \text{Pump flow rate (gpm)}$$

$$T = (4 \times (2,446 \text{ gallons})) / (347 \text{ gpm}) = 28.2 \text{ minutes}$$

Calculate Maximum Motor Starts Per Hour For Each Pump

$$\text{Max. motor starts per hour per pump} = (60 \text{ minutes}) / (28.2 \text{ minutes}) = 2.13$$

#### Table A-2.3 Sample Calculations

Maximum motor starts per hour based on WW Standards

Pump flow rate (q) = 347 gpm (From Chart A-4.1)

Calculate Minimum Cycle Time Between Starts For Each Pump

$$\text{Min. cycle time per pump} = (60 \text{ minutes}) / (12.00 \text{ minutes}) = 5.0$$

Calculate Minimum Net Wet Well Wastewater Volume

$$V = Tq/4$$

Where: V = Wet well wastewater volume (gallons)

T = Cycle time between starts (minutes)

q = Pump flow rate (gpm)

$$V = (5.0 \text{ minutes}) \times (347 \text{ gpm}) / 4 = 434 \text{ gallons}$$

#### Table A-2.4 Sample Calculations

Wastewater inflow rate (i) = 0.20 mgd = 139 gpm

Pump flow rate (q) = 347 gpm (From Chart A-4.1)

Wet well volume between LWL and wet well floor = 1,724 gallons (See Table A-2.1 sample calculations)

Net wet well wastewater volume = 425 gallons (See Table A-2.3 sample calculations)

Calculate Minimum Wet Well Wastewater Volume

$$\begin{aligned} \text{Volume} &= (\text{Wet well volume between LWL and floor}) + (\text{Net wet well volume}) \\ &= (1,724 \text{ gallons} + 434 \text{ gallons}) = 2,158 \text{ gallons} \end{aligned}$$

Calculate Cycle Time Between Starts Per Pump

$$T = V / (i - i^2 / q)$$

Where: V = Wet well wastewater volume (gallons)

i = Wastewater inflow rate (gpm)

q = Pump flow rate (gpm)

T = Cycle time between starts (minutes)

$$T = (434 \text{ gallons}) / (139 \text{ gpm} - (139 \text{ gpm})^2 / 347 \text{ gpm}) = 5.2 \text{ minutes}$$

Calculate HWL Elevation

$HWL = LWL + (\text{Net wet well wastewater volume})/(\text{wet well area}) = -13.14 \text{ feet}$

\*Due to varying cross section area, the HWL was solved for through an interative process.

**TABLE A-3: KAHANAHOU WWPS  
NET POSITIVE SUCTION HEAD AVAILABLE  
FOR ALTERNATIVE NO. 2, 3 AND 4**

**4-Inch Pump Suction Connection**

Flow Rate		Fluid Velocity		NPSH <sub>A</sub>		
				h <sub>s</sub> =1.75 ft, wse = -11.5 (ft)	h <sub>s</sub> =4.25 ft, wse = -9.0 (ft)	h <sub>s</sub> =4.5 ft, wse = -8.75 (ft)
(gpm)	(mgd)	4-inch (ft/sec)	6-inch (ft/sec)			
100	0.14	2.55	1.13	23.98	25.83	26.01
200	0.29	5.11	2.27	23.80	25.65	25.84
300	0.43	7.66	3.40	23.51	25.36	25.54
400	0.58	10.21	4.54	23.10	24.95	25.13
500	0.72	12.77	5.67	22.57	24.42	24.61
600	0.86	15.32	6.81	21.93	23.79	23.97
700	1.01	17.87	7.94	21.18	23.03	23.22
800	1.15	20.43	9.08	20.31	22.16	22.35
900	1.30	22.98	10.21	19.33	21.18	21.37
1,000	1.44	25.53	11.35	18.24	20.09	20.27

$$NPSH_A = H_{bar} + h_s - H_{vap} - h_f - h_l - h_{vol} - FS$$

- Where:
- H<sub>bar</sub>=barametric pressure (33.9 feet)
  - h<sub>s</sub>=static head of water
  - H<sub>vap</sub>=vapor pressure of fluid (1.2 feet at 80 deg F)
  - h<sub>f</sub>=pipe friction
  - h<sub>l</sub>=minor losses
  - h<sub>vol</sub>=partial pressure of dissolved gasses (2 feet)
  - FS=factor of safety (5 feet or 0.35 NPSH<sub>R</sub>)

$$v = Q/A = Q/(\pi \cdot r^2)$$

- Where:
- v = velocity (ft/sec)
  - A = Force main cross sectional area (feet)<sup>2</sup>
  - r = Force main radius (feet)

$$v_{4"} = (200 \text{ gpm}) \cdot (1 \text{ min}/60 \text{ sec}) \cdot (1 \text{ ft}^3/7.48 \text{ gal.}) / ((\pi) \cdot (2/12 \text{ feet})^2) = 5.11 \text{ ft/sec}$$

$$v_{6"} = (200 \text{ gpm}) \cdot (1 \text{ min}/60 \text{ sec}) \cdot (1 \text{ ft}^3/7.48 \text{ gal.}) / ((\pi) \cdot (6/12 \text{ feet})^2) = 2.27 \text{ ft/sec}$$

$$h_l = (0.45 \cdot (v_{6"})^2 + 0.613 \cdot (v_{4"})^2) / (2 \cdot 32.2 \text{ ft/sec}^2)$$

$$= (0.45 \cdot (2.27 \text{ ft/sec})^2 + 0.613 \cdot (5.11 \text{ ft/sec})^2) / (2 \cdot 32.2 \text{ ft/sec}^2) = 0.28 \text{ feet}$$

(See Renovated Pump Station Minor Losses)

$$h_f = (3.022/100^{1.85}) \cdot (v_{6"}^{1.85} \cdot (6.0 \text{ feet}) / (6/12 \text{ feet})^{1.165})$$

$$= (3.022/100^{1.85}) \cdot ((2.27 \text{ ft/sec})^{1.85} \cdot (6.0 \text{ feet}) / (6/12 \text{ feet})^{1.165}) = 0.04 \text{ feet}$$

(See Renovated Pump Station Minor Losses)

$$NPSH_A = (33.9 \text{ ft} + 1.75 \text{ ft} - 1.2 \text{ ft} - 0.28 \text{ ft} - 0.04 \text{ ft} - 2 \text{ ft}) / 1.35 = 23.80 \text{ feet}$$

**OKAHARA & ASSOCIATES, INC.**

677 Ala Moana Blvd. Suite 703

HONOLULU, HAWAII 96813

(808) 524-1224

JOB Kahanahou WQPS (210-002)

SHEET NO. 1

OF 1

CALCULATED BY T.T.

DATE Dec 9, 2010

CHECKED BY

DATE

SCALE Existing Net Positive Suction Head Available

$$NPSH_A = H_{bar} + h_s - H_{vap} - h_f - h_L - h_{vol} - FS$$

WHERE:  $H_{bar}$  = barometric pressure (ft of  $H_2O$ ) 33.9 ft

$h_s$  = static head of water (ft of  $H_2O$ )

$H_{vap}$  = Vapor pressure of fluid (ft of  $H_2O$ ) 1.2 ft @ 80°F

$h_f$  = pipe friction (ft of  $H_2O$ )

$h_L$  = minor pipe friction losses (ft of  $H_2O$ )

$h_{vol}$  = partial pressure of dissolved gases (ft of  $H_2O$ ) 2 ft

FS = factor of safety 5 ft or 0.35 NPSH<sub>2</sub>

$$h_s = 0 \text{ ft} \sim 2.4 \text{ ft}$$

WHERE: Top of pump impellers at = -13.67

lead pump on left at = -11.28 / -13.68

$$h_f = \frac{(3.022)(V_{(8" \phi)})^{1.85} (5'-9")}{(60)^{1.85} (8/12 \text{ ft})^{1.165}}$$

SEE EXISTING PUMP STATION  
MINOR LOSSES

$$h_L = \frac{(0.385)(V_{(8" \phi)})^2 + (0.578)(V_{(6" \phi)})^2}{2(32.2 \text{ ft/s}^2)}$$

SEE EXISTING PUMP STATION  
MINOR LOSSES

NPSH<sub>A</sub> @ 0.50 mgd

$$h_f = \frac{(3.022)(2.22 \text{ ft/s})^{1.85} (5'-9")}{(60)^{1.85} (8/12 \text{ ft})^{1.165}} = 0.06 \text{ ft}$$

$$h_L = \frac{(0.385)(2.22 \text{ ft/s})^2 + (0.578)(3.94 \text{ ft/s})^2}{2(32.2 \text{ ft/s}^2)} = 0.17 \text{ ft}$$

$$NPSH_A (0.50 \text{ mgd}) = 33.9 + (-) 13 - (-) 14.25 - 1.2 - 0.06 - 0.17 - 2 - FS$$

$$= 31.72 - FS \quad (\text{ASSUME } FS = 31.72 / 1.35)$$

$$= 23.5 \text{ ft}$$



**OKAHARA & ASSOCIATES, INC.**

677 Ala Moana Blvd. Suite 703  
HONOLULU, HAWAII 96813  
(808) 524-1224


JOB Kahanahou WWPS (210-002)

SHEET NO. 1 OF 3

CALCULATED BY T.T. DATE NOV 24, 2010

CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_

SCALE Existing Pump Station Minor Losses



**OKAHARA & ASSOCIATES, INC.**

677 Ala Moana Blvd. Suite 703  
 HONOLULU, HAWAII 96813  
 (808) 524-1224

JOB Kahanahou WWPS (210-002)

SHEET NO. 2 OF 3

CALCULATED BY TT DATE NOV 26, 2010

CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_

SCALE Existing Pump Station Minor Losses

MINOR LOSSES THROUGH FITTINGS AND VALVES

$$h_L = \frac{K V^2}{2g}$$

WHERE:  $h_L$  = HEAD LOSS (FT)  
 $K$  = RESISTANCE COEFFICIENT  
 $V$  = VELOCITY (FT/S)  
 $g$  = GRAVITATIONAL ACCELERATION (32.2 FT/S<sup>2</sup>)

$$\sum K (8" \phi) = 0.05 + 0.26 + 0.075 = 0.385$$

$$\sum K (6" \phi) = 0.25 + 0.328 + 0.18 + 2.1 + 0.11 + 0.18 + 0.18 = 3.328$$

$$h_L = \frac{0.385 (V_{(8" \phi)})^2 + 3.328 (V_{(6" \phi)})^2}{2(32.2 \text{ ft/s}^2)}$$

MINOR LOSSES THROUGH STRAIGHT PIPE

$$h_f = \frac{(3.022)(V)^{1.85} L}{(C)^{1.85} (D)^{1.165}}$$

WHERE:  $h_f$  = FRICTIONAL HEAD LOSS (FT)  
 $V$  = VELOCITY (FT/S)  
 $L$  = PIPE LENGTH (FT)  
 $C$  = HAZEN-WILLIAMS ROUGHNESS COEFFICIENT (C=60)  
 $D$  = PIPE DIAMETER (FT)

$$\sum L (8" \phi) = 3'-10" + 1'-11" = 5'-9"$$

$$\sum L (6" \phi) = 13'-7" \text{ (CHANGED TO } 4" \phi)$$

FLOW MODEL MODIFICATION NOTES

- ACCORDING TO T&D, VERTICAL PORTIONS OF PUMP DISCHARGE PIPING TENDS TO BE LINED WITH DEBRIS. THIS LINING REDUCES THE EFFECTIVE PIPE DIAMETER AND IS POSTULATED INCREASES LOSSES.

**OKAHARA & ASSOCIATES, INC.**677 Ala Moana Blvd. Suite 703  
HONOLULU, HAWAII 96813  
(808) 524-1224JOB KAHANA HOU WWPS (210-002)  
SHEET NO. 3 OF 3  
CALCULATED BY T.T. DATE DEC 5, 2010  
CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_  
SCALE Existing Pump Station Minor Losses

- 6" VERTICAL DISCHARGE PIPING MODELED AS 4"
- HAZEN-WILLIAMS COEFFICIENT OF 60 USED TO ADJUST MINOR LOSSES TO MATCH SLADA DATA

$$h_f = \frac{(3.022)}{(60)^{1.85}} \left[ \frac{(V(6"))^{1.85} (5'-9")}{(8/12 \text{ FT})^{1.85}} + \frac{(V(4"))^{1.85} (13'-7")}{(4/12 \text{ FT})^{1.85}} \right]$$

MINOR LOSSES THROUGH COUNTER WEIGHTED CHECK VALVES

 $h_c$  = ESTIMATED HEAD LOSS THROUGH CHECK VALVE

$h_c = 2.25'$

**OKAHARA & ASSOCIATES, INC.**677 Ala Moana Blvd. Suite 703  
HONOLULU, HAWAII 96813  
(808) 524-1224JOB Kahanahou WWPS (210-002)SHEET NO. 1 OF 1CALCULATED BY T.T DATE Nov 26, 2010

CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_

SCALE Existing Force Main System Curve

## FRICTIONAL LOSSES

$$h_f = \frac{(3.022)(V)^{1.85} L}{(C)^{1.85} (D)^{4.75}}$$

Where:  $h_f$  = FRICTIONAL HEAD LOSS (FT)

V = VELOCITY (FT/S)

L = PIPE LENGTH (FT)

C = HAZEN-WILLIAMS ROUGHNESS COEFFICIENT


D = PIPE DIAMETER (FT)

STN FROM	STN TO	L	D	C	MATERIAL	NOTES
		25	8/12	120	C900 PVC	ID = 8.04"
0+00	7+69	769	8/12	120	DR11 HDPE	ID = 6.963"

FORCE MAIN DISCHARGE INV = 18.70

FORCE MAIN DATA OBTAINED FROM C+ C WASTE WATER JOB  
NO. W16-05.

**CHART A-4.1: KAHANAHOU WWPS  
 ALTERNATIVE No. 1: EXISTING CENTRIFUGAL PUMP AND SYSTEM CURVES  
 PATTERSON PUMP CO. 1175 RPM, UNKNOWN IMPELLER DIAMETER**



**TABLE A-4.1: KAHANAHOU WWPS  
ALTERNATIVE No. 1: EXISTING CENTRIFUGAL PUMP AND SYSTEM CURVES  
PATTERSON PUMP CO. 1175 RPM, UNKNOWN IMPELLER DIAMETER**

Impeller Size Unknown <sup>a</sup>			Adjusted <sup>b</sup> TDH (feet)	1 Pump Flow Rate		2 Pumps Flow Rate		System Flow Rate (mgd)	System Velocity		System Curve (feet) <sup>c</sup>			
TDH (feet)	Flow Rate			(gpm)	(mgd)	(gpm)	(mgd)		8" PVC <sup>d</sup> (ft/sec)	8" HDPE <sup>e</sup> (ft/sec)	wse (-11.5)		wse (-13.50)	
	(gpm)	(mgd)	C <sub>old</sub> <sup>f</sup>					C <sub>new</sub> <sup>g</sup>			C <sub>old</sub> <sup>f</sup>	C <sub>new</sub> <sup>g</sup>		
56.5	0	0.00	54.3	0	0.00	0	0.00	0.00	0.00	0.00	30.2	30.2	32.2	32.2
51.8	119	0.17	48.8	119	0.17	237	0.34	0.25	1.10	1.29	31.6	30.9	33.6	32.9
49.3	172	0.25	45.6	172	0.25	343	0.49	0.50	2.19	2.59	35.4	32.6	37.4	34.6
49.5	192	0.28	45.5	192	0.28	384	0.55	0.75	3.29	3.88	41.2	35.4	43.2	37.4
49	206	0.30	44.8	206	0.30	412	0.59	1.00	4.39	5.18	48.9	39.0	50.9	41.0
41.8	462	0.67	30.6	462	0.67	924	1.33	1.25	5.49	6.47	58.4	43.5	60.4	45.5
								1.50	6.58	7.76	69.7	48.9	71.7	50.9

<sup>a</sup>Pump curve data taken from Mathcad data based on

<sup>b</sup>Adjusted TDH = Pump Rated TDH - Minor Losses (i.e. TDH - (h<sub>f</sub>-h<sub>i</sub>))

Sample Calculation

$$v = Q/A = Q/(\pi \cdot r^2)$$

Where: v = velocity (ft/sec)

A = Force main cross sectional area (feet)<sup>2</sup>

r = Force main radius (feet)

$$v_{4"} = (119 \text{ gpm}) \cdot (1 \text{ min}/60 \text{ sec}) \cdot (1 \text{ ft}^3/7.48 \text{ gal.}) / ((\pi) \cdot (2/12 \text{ feet})^2) = 3.03 \text{ ft/sec}$$

$$v_{6"} = (119 \text{ gpm}) \cdot (1 \text{ min}/60 \text{ sec}) \cdot (1 \text{ ft}^3/7.48 \text{ gal.}) / ((\pi) \cdot (3/12 \text{ feet})^2) = 1.34 \text{ ft/sec}$$

$$v_{8"} = (119 \text{ gpm}) \cdot (1 \text{ min}/60 \text{ sec}) \cdot (1 \text{ ft}^3/7.48 \text{ gal.}) / ((\pi) \cdot (4/12 \text{ feet})^2) = 0.76 \text{ ft/sec}$$

$$h_i = (0.385 \cdot (v_{8"})^2 + 1.438 \cdot (v_{6"})^2) / (2 \cdot 32.2 \text{ ft/sec}^2) = (0.385 \cdot (0.76 \text{ ft/sec})^2 + 1.438 \cdot (1.34 \text{ ft/sec})^2) / (2 \cdot 32.2 \text{ ft/sec}^2) = 0.10 \text{ feet}$$

$$h_f = (3.022/60^{1.85}) \cdot (v_{8"}^{1.85} \cdot (5.75 \text{ feet}) / (8/12 \text{ feet})^{1.165} + v_{4"}^{1.85} \cdot (13.58 \text{ feet}) / (4/12 \text{ feet})^{1.165}) \\ = (3.022/60^{1.85}) \cdot ((0.76 \text{ ft/sec})^{1.85} \cdot (5.75 \text{ feet}) / (8/12 \text{ feet})^{1.165} + (3.03 \text{ ft/sec})^{1.85} \cdot (13.58 \text{ feet}) / (4/12 \text{ feet})^{1.165}) = 0.60 \text{ feet}$$

$$h_c = 2.25 \text{ feet}$$

$$\text{Adjusted TDH} = 51.8 \text{ feet} - (0.10 \text{ feet} + 0.60 \text{ feet} + 2.25 \text{ feet}) = 48.8 \text{ feet}$$

<sup>c</sup>Force main data (i.e. pipe size, length, material) obtained from C&C Wastewater Job No. W16-05.

**TABLE A-4.1: KAHANAHOU WWPS  
ALTERNATIVE No. 1: EXISTING CENTRIFUGAL PUMP AND SYSTEM CURVES  
PATTERSON PUMP CO. 1175 RPM, UNKNOWN IMPELLER DIAMETER**

<sup>d</sup>Pipe dimensions based on AWWA C-900 standards

<sup>e</sup>Pipe dimensions based on HDPE SDR 11 ductile iron pipe dimensions


<sup>f</sup>Hazen-Williams Coefficient = 100 for old PVC and HDPE

<sup>g</sup>Hazen-Williams Coefficient = 150 for new PVC and HDPE

**OKAHARA & ASSOCIATES, INC.**

677 Ala Moana Blvd. Suite 703  
 HONOLULU, HAWAII 96813  
 (808) 524-1224

JOB Kahanahou WWS (210-002)  
 SHEET NO. 1 OF 2  
 CALCULATED BY TT DATE DEC 8, 2010  
 CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_  
 SCALE Renovated Pump Station Minor Losses



\* ALL FRICTION COEFFICIENTS TAKEN FROM THE  
 HYDRAULIC INSTITUTE ENGINEERING DATA BOOK, SECOND ED



**OKAHARA & ASSOCIATES, INC.**

677 Ala Moana Blvd. Suite 703

HONOLULU, HAWAII 96813

(808) 524-1224

JOB Kahanahou WWPS (210-002)SHEET NO. 2 OF 2CALCULATED BY T.T. DATE DEC 23, 2010

CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_

SCALE Renovated Pump Station Minor Losses

## MINOR LOSSES THROUGH FITTINGS AND VALVES

$$h_L = \frac{K V^2}{2g}$$

WHERE:  $h_L$  = HEAD LOSS (FT) $K$  = RESISTANCE COEFFICIENT $V$  = VELOCITY (FT/S) $g$  = GRAVITATIONAL ACCELERATION (32.2 FT/S)

$$\Sigma K(6''\phi) = 0.05 + 0.29 + 0.11 + 2.1 + 0.11 + 0.12 + 0.29 + 0.29 + 0.12 + 0.50 = 3.98$$

$$\Sigma K(4''\phi) = 0.28 + 0.333 + 0.18 = 0.793$$

$$h_L = \frac{3.98 (V_{(6''\phi)})^2 + 0.793 (V_{(4''\phi)})^2}{2(32.2 \text{ ft/s})}$$

## MINOR LOSSES THROUGH STRAIGHT PIPE

$$h_f = \frac{(3.022)(V)^{1.85} L}{(C)^{1.85} (D)^{4.75}}$$

WHERE:  $h_f$  = FRICTIONAL HEAD LOSS (FT) $V$  = VELOCITY (FT/S) $L$  = PIPE LENGTH (FT) $C$  = HAZEN-WILLIAMS ROUGHNESS COEFFICIENT ( $C=100$ ) $D$  = PIPE DIAMETER (FT)

$$\Sigma L(6''\phi) = 4'-0'' + 2'-0'' + 1'-6'' + 2'-0'' = 9'-6''$$


$$h_f = \frac{(3.022) (V_{(6''\phi)})^{1.85} (9'-6'')}{(100)^{1.85} (6/12 \text{ ft})^{4.75}}$$

## MINOR LOSSES THROUGH COUNTER WEIGHTED CHECK VALVES

 $h_c$  = ESTIMATED HEAD LOSS THROUGH CHECK VALVE

$$h_c = 2.25'$$

**CHART A-5.1: KAHANAHOU WWPS  
 ALT No. 2 & 3: DRY PIT SUBMERSIBLE PUMP AND SYSTEM CURVES  
 ABS XFP100E-CB1, 1765 RPM, 9.05" IMPELLER DIAMETER**



**TABLE A-5.1: KAHANAHOU WWPS  
ALTERNATIVE No. 2 & 3: DRY PIT SUBMERSIBLE PUMP AND SYSTEM CURVES  
ABS XFP100E-CB1, 1765 RPM, 9.05" IMPELLER DIAMETER**

8.858 Inch Impeller <sup>a</sup>			9.05 Inch Impeller <sup>b</sup>			Adjusted <sup>c</sup> TDH (feet)	1 Pump		2 Pumps		System Flow Rate (mgd)	System Velocity		System Curve (feet) <sup>d</sup>			
TDH (feet)	Flow Rate		TDH (feet)	Flow Rate			Flow Rate (gpm)	Flow Rate (mgd)	Flow Rate (gpm)	Flow Rate (mgd)		8" PVC <sup>e</sup> (ft/sec)	8" HDPE <sup>f</sup> (ft/sec)	wse (-11.5)		wse (-13.25)	
	(gpm)	(mgd)		(gpm)	(mgd)	C <sub>old</sub> <sup>g</sup>					C <sub>new</sub> <sup>h</sup>			C <sub>old</sub> <sup>g</sup>	C <sub>new</sub> <sup>h</sup>		
91.5	0	0.00	95.5	0	0.00	93.3	0	0.00	0	0.00	0.00	0.00	0.00	30.2	30.2	32.0	32.0
82	100	0.14	85.6	102	0.15	83.2	102	0.15	204	0.29	0.25	1.10	1.29	31.6	30.9	33.4	32.6
75	200	0.29	78.3	204	0.29	75.3	204	0.29	409	0.59	0.50	2.19	2.59	35.4	32.6	37.1	34.4
69.5	300	0.43	72.5	307	0.44	68.7	307	0.44	613	0.88	0.75	3.29	3.88	41.2	35.4	42.9	37.1
65	400	0.58	67.8	409	0.59	62.7	409	0.59	817	1.18	1.00	4.39	5.18	48.9	39.0	50.6	40.8
59.5	500	0.72	62.1	511	0.74	55.4	511	0.74	1,022	1.47	1.25	5.49	6.47	58.4	43.5	60.2	45.3
54	600	0.86	56.4	613	0.88	47.6	613	0.88	1,226	1.77	1.50	6.58	7.76	69.7	48.9	71.5	50.6
47	700	1.01	49.1	715	1.03	38.0	715	1.03	1,430	2.06							
40	800	1.15	41.8	817	1.18	28.0	817	1.18	1,635	2.35							
35.5	860	1.24	37.1	879	1.27	21.6	879	1.27	1,757	2.53							

<sup>a</sup>Pump curve taken from catalog data

<sup>b</sup>Pump curve data adjusted using affinity laws

Sample Calculation

$$Q_1/Q_2 = D_1/D_2$$

Where: Q = Flow rate (gpm)

D = Impeller diameter (inches)

$$Q_2 = Q_1 * D_2 / D_1 = (200 \text{ gpm}) * (9.05" / 8.858") = 204 \text{ gpm}$$

$$H_1/H_2 = (D_1/D_2)^2$$

Where: H = Head (feet)

$$H_2 = H_1 * (D_2/D_1)^2 = (75 \text{ feet}) * (9.05" / 8.858")^2 = 78.3 \text{ feet}$$

<sup>c</sup>Adjusted TDH = Pump Rated TDH - Minor Losses (i.e. TDH - (h<sub>r</sub>-h<sub>f</sub>))

Sample Calculation

$$v = Q/A = Q / (\pi * r^2)$$

Where: v = velocity (ft/sec)

A = Force main cross sectional area (feet)<sup>2</sup>

r = Force main radius (feet)

$$v_4 = (204 \text{ gpm}) * (1 \text{ min} / 60 \text{ sec}) * (1 \text{ ft}^3 / 7.48 \text{ gal.}) / ((\pi) * (2/12 \text{ feet})^2) = 5.22 \text{ ft/sec}$$

**TABLE A-5.1: KAHANAHOU WWPS  
ALTERNATIVE No. 2 & 3: DRY PIT SUBMERSIBLE PUMP AND SYSTEM CURVES  
ABS XFP100E-CB1, 1765 RPM, 9.05" IMPELLER DIAMETER**

$$v_{6"} = (204 \text{ gpm}) * (1 \text{ min}/60 \text{ sec}) * (1 \text{ ft}^3/7.48 \text{ gal.}) / ((\pi) * (3/12 \text{ feet})^2) = 2.32 \text{ ft/sec}$$

$$v_{8"} = (204 \text{ gpm}) * (1 \text{ min}/60 \text{ sec}) * (1 \text{ ft}^3/7.48 \text{ gal.}) / ((\pi) * (4/12 \text{ feet})^2) = 1.30 \text{ ft/sec}$$

$$h_l = (3.98 * (v_{6"})^2 + 0.793 * (v_{4"})^2) / (2 * 32.2 \text{ ft/sec}^2) = (3.98 * (2.32 \text{ ft/sec})^2 + 0.793 * (5.22 \text{ ft/sec})^2) / (2 * 32.2 \text{ ft/sec}^2) = 0.67 \text{ feet}$$

$$h_f = (3.022/100^{1.85}) * (v_{6"}^{1.85} * (9.5 \text{ feet}) / (6/12 \text{ feet})^{1.165}) = (3.022/100^{1.85}) * ((2.32 \text{ ft/sec})^{1.85} * (9.5 \text{ feet}) / (6/12 \text{ feet})^{1.165}) = 0.06 \text{ feet}$$

$$h_c = 2.25 \text{ feet}$$

$$\text{Adjusted TDH} = 78.3 \text{ feet} - (0.67 \text{ feet} + 0.06 \text{ feet} + 2.25 \text{ feet}) = 75.3 \text{ feet}$$

<sup>d</sup>Force main data (i.e. pipe size, length, material) obtained from C&C Wastewater Job No. W16-05.


<sup>e</sup>Pipe dimensions based on AWWA C-900 standards

<sup>f</sup>Pipe dimensions based on HDPE SDR 11 ductile iron pipe dimensions

<sup>g</sup>Hazen-Williams Coefficient = 100 for old PVC and HDPE

<sup>h</sup>Hazen-Williams Coefficient = 150 for new PVC and HDPE

**CHART A-6.1: KAHANAHOU WWPS  
 ALTERNATIVE No. 4: DRY PIT SUBMERSIBLE PUMP AND SYSTEM CURVES  
 ABS XFP100E-CB1, 1765 RPM, 8.465" (215 mm) IMPELLER DIAMETER**



**TABLE A-6.1: KAHANAHOU WWPS  
ALTERNATIVE No. 4: DRY PIT SUBMERSIBLE PUMP AND SYSTEM CURVES  
ABS XFP100E-CB1, 1765 RPM, 8.465" (215 mm) IMPELLER DIAMETER**

8.465 Inch Impeller <sup>a</sup>			Adjusted <sup>b</sup> TDH (feet)	1 Pump Flow Rate		2 Pumps Flow Rate		System Flow Rate (mgd)	System Velocity		System Curve (feet) <sup>c</sup>					
TDH (feet)	Flow Rate			(gpm)	(mgd)	(gpm)	(mgd)		8" PVC <sup>d</sup> (ft/sec)	8" HDPE <sup>e</sup> (ft/sec)	wse (-9.00)		wse (-11.5)		wse (-13.25)	
	(gpm)	(mgd)	C <sub>old</sub> <sup>f</sup>					C <sub>new</sub> <sup>g</sup>			C <sub>old</sub> <sup>f</sup>	C <sub>new</sub> <sup>g</sup>	C <sub>old</sub> <sup>f</sup>	C <sub>new</sub> <sup>g</sup>		
84.5	0	0.00	82.3	0	0.00	0	0.00	0.00	0.00	0.00	27.7	27.7	30.2	30.2	32.0	32.0
73.5	100	0.14	71.1	100	0.14	200	0.29	0.25	1.10	1.29	29.1	28.4	31.6	30.9	33.4	32.6
66.5	200	0.29	63.6	200	0.29	400	0.58	0.50	2.19	2.59	32.9	30.1	35.4	32.6	37.1	34.4
61	300	0.43	57.2	300	0.43	600	0.86	0.75	3.29	3.88	38.7	32.9	41.2	35.4	42.9	37.1
55.5	400	0.58	50.5	400	0.58	800	1.15	1.00	4.39	5.18	46.4	36.5	48.9	39.0	50.6	40.8
50	500	0.72	43.4	500	0.72	1,000	1.44	1.25	5.49	6.47	55.9	41.0	58.4	43.5	60.2	45.3
44	600	0.86	35.5	600	0.86	1,200	1.73	1.50	6.58	7.76	67.2	46.4	69.7	48.9	71.5	50.6
37.5	700	1.01	26.8	700	1.01	1,400	2.02									
31	800	1.15	17.8	800	1.15	1,600	2.30									
30	810	1.17	16.5	810	1.17	1,620	2.33									

<sup>a</sup>Pump curve taken from catalog data

<sup>b</sup>Adjusted TDH = Pump Rated TDH - Minor Losses (i.e. TDH - (h<sub>r</sub>-h<sub>f</sub>))

Sample Calculation

$$v = Q/A = Q/(\pi \cdot r^2)$$

Where: v = velocity (ft/sec)

A = Force main cross sectional area (feet)<sup>2</sup>

r = Force main radius (feet)

$$v_{4"} = (200 \text{ gpm}) \cdot (1 \text{ min}/60 \text{ sec}) \cdot (1 \text{ ft}^3/7.48 \text{ gal.}) / ((\pi) \cdot (2/12 \text{ feet})^2) = 5.11 \text{ ft/sec}$$

$$v_{6"} = (200 \text{ gpm}) \cdot (1 \text{ min}/60 \text{ sec}) \cdot (1 \text{ ft}^3/7.48 \text{ gal.}) / ((\pi) \cdot (3/12 \text{ feet})^2) = 2.27 \text{ ft/sec}$$

$$v_{8"} = (200 \text{ gpm}) \cdot (1 \text{ min}/60 \text{ sec}) \cdot (1 \text{ ft}^3/7.48 \text{ gal.}) / ((\pi) \cdot (4/12 \text{ feet})^2) = 1.28 \text{ ft/sec}$$

$$h_l = (3.98 \cdot (v_{6"})^2 + 0.793 \cdot (v_{4"})^2) / (2 \cdot 32.2 \text{ ft/sec}^2) = (3.98 \cdot (2.27 \text{ ft/sec})^2 + 0.793 \cdot (5.11 \text{ ft/sec})^2) / (2 \cdot 32.2 \text{ ft/sec}^2) = 0.64 \text{ feet}$$

$$h_f = (3.022/100^{1.85}) \cdot (v_{6"}^{1.85} \cdot (9.5 \text{ feet}) / (6/12 \text{ feet})^{1.65}) = (3.022/100^{1.85}) \cdot ((2.27 \text{ ft/sec})^{1.85} \cdot (9.5 \text{ feet}) / (6/12 \text{ feet})^{1.65}) = 0.06 \text{ feet}$$

$$h_c = 2.25 \text{ feet}$$

$$\text{Adjusted TDH} = 66.5 \text{ feet} - (0.64 \text{ feet} + 0.06 \text{ feet} + 2.25) = 63.6 \text{ feet}$$

**TABLE A-6.1: KAHANAHOU WWPS  
ALTERNATIVE No. 4: DRY PIT SUBMERSIBLE PUMP AND SYSTEM CURVES  
ABS XFP100E-CB1, 1765 RPM, 8.465" (215 mm) IMPELLER DIAMETER**

<sup>c</sup>Force main data (i.e. pipe size, length, material) obtained from C&C Wastewater Job No. W16-05.

<sup>d</sup>Pipe dimensions based on AWWA C-900 standards

<sup>e</sup>Pipe dimensions based on HDPE SDR 11 ductile iron pipe dimensions

<sup>f</sup>Hazen-Williams Coefficient = 100 for old PVC and HDPE

<sup>g</sup>Hazen-Williams Coefficient = 150 for new PVC and HDPE

**OKAHARA & ASSOCIATES, INC.**

677 Ala Moana Blvd. Suite 703

HONOLULU, HAWAII 96813

(808) 524-1224

JOB Kahanahou WWPS (210-002)SHEET NO. 1OF 2CALCULATED BY T.T.DATE DEC 23, 2010

CHECKED BY \_\_\_\_\_

DATE \_\_\_\_\_

SCALE Water Hammer Calculations

Reference: Design Standards of the Department of Wastewater Management, Volume 1, July 1993, Section 3B.10

Determine maximum water hammer pressure

$$\text{Max water hammer pressure (H)} = \text{static head (H)} + \frac{aV}{g}$$

where:  $a = \frac{4660}{(1+KB)^{1/2}}$  = velocity of sound in water in the force main in fps

K = ratio of the elastic modulus of water to that of the pipe material

B = ratio of pipe diameter to wall thickness

V = maximum velocity in the force main at peak flow or the destroyed velocity

g = acceleration due to gravity =  $32.2 \text{ ft/s}^2$

Assume 8" HDPE pipe (Most of force main pipe comprised of 8" HDPE)

@ 0.90 mgd  $\rightarrow$  136 psi water hammer (4.66 ft/s velocity)  
(see Table A- for calculations)

$\therefore$  136 psi is less than strength of pipe (160 psi, SDR 11)

@ 1.30 mgd  $\rightarrow$  194 psi water hammer (6.88 ft/s velocity)  
(see Table A- for calculations)

$\therefore$  194 psi is greater than strength of pipe (160 psi, SDR 11)  
Further investigation required.



**OKAHARA & ASSOCIATES, INC.**

677 Ala Moana Blvd. Suite 703  
 HONOLULU, HAWAII 96813  
 (808) 524-1224

JOB Kahanahou WSPS (210-002)  
 SHEET NO. 2 OF 2  
 CALCULATED BY TT. DATE DEC 23, 2010  
 CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_  
 SCALE Water Hammer Calculations

ASSUME SDR 11 HDPE PIPE (160 psi pressure class)

$$\text{One Cycle Period} = \frac{2L}{a}$$

Where: L = Length of Force Main (794 ft)

$$\text{One Cycle Period} = \frac{(2)(794 \text{ ft})}{843 \text{ ft/s}} = 1.88$$

$$\text{Line Constant} = \frac{av}{2gH}$$

Where: H = static head in feet

$$\text{Line Constant} = \frac{(843 \text{ ft/s})(6.88 \text{ ft/s})}{(2)(32.2 \text{ ft/s}^2)(31.95 \text{ ft})} = 2.82$$

Determine allowable pressure rise in Force Main

$$\begin{aligned} \text{Allowable pressure rise} &= \frac{\text{Allowable pipe strength (ft)}}{\text{Static head (ft)}} \\ &= \frac{(160 \text{ psi})(2.31 \text{ ft/psi})}{31.95 \text{ ft}} = 11.6 \end{aligned}$$

Apply factors to Allievi chart (Fig 38.10 of Design Standards)

For: Line Constant = 2.82  
 Allowable Press Rise = 11.6

$$\text{Time Constant} \left( \frac{aT}{2L} \right) = < 1 \text{ sec}$$

∴ No special design conditions required

**APPENDIX B**  
**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2, 2006**

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

Kahanahou WWPS		Discharge Pressure	Flow Rate	Wetwell Level	Flow	Pump Lift
DATE:	TIME:	(Feet)	(mgd)	(Feet)	(gpm)	(Feet)
10/31/06	00:00:00	10.7640	0.0010	-13.1840	0.694444444	10.9480
10/31/06	00:01:00	10.6600	0.0010	-12.8050	0.694444444	10.4650
10/31/06	00:02:00	10.6600	0.0010	-12.8050	0.694444444	10.4650
10/31/06	00:03:00	10.5560	0.0010	-12.3890	0.694444444	9.9450
10/31/06	00:04:00	10.5560	0.0010	-12.3890	0.694444444	9.9450
10/31/06	00:05:00	10.4520	0.0010	-12.0460	0.694444444	9.4980
10/31/06	00:06:00	10.4520	0.0010	-12.0460	0.694444444	9.4980
10/31/06	00:07:00	10.4170	0.0010	-11.7210	0.694444444	9.1380
10/31/06	00:08:00	37.5000	0.5410	-11.4870	375.6944444	35.9870
10/31/06	00:09:00	37.5000	0.5410	-11.4870	375.6944444	35.9870
10/31/06	00:10:00	37.4650	0.5380	-11.5680	373.6111111	36.0330
10/31/06	00:11:00	29.0280	0.4720	-10.9000	327.7777778	26.9280
10/31/06	00:12:00	37.4650	0.5380	-11.5680	373.6111111	36.0330
10/31/06	00:13:00	37.4650	0.5380	-11.5680	373.6111111	36.0330
10/31/06	00:14:00	36.9100	0.5350	-11.9200	371.5277778	35.8300
10/31/06	00:15:00	36.9100	0.5350	-11.9200	371.5277778	35.8300
10/31/06	00:16:00	37.0840	0.5350	-12.0640	371.5277778	36.1480
10/31/06	00:17:00	37.0840	0.5350	-12.0640	371.5277778	36.1480
10/31/06	00:18:00	36.7020	0.5340	-12.2090	370.8333333	35.9110
10/31/06	00:19:00	36.7020	0.5340	-12.2090	370.8333333	35.9110
10/31/06	00:20:00	36.9100	0.5320	-12.3620	369.4444444	36.2720
10/31/06	00:21:00	36.9100	0.5320	-12.3620	369.4444444	36.2720
10/31/06	00:22:00	36.4240	0.5290	-12.5070	367.3611111	35.9310
10/31/06	00:23:00	36.3200	0.5290	-12.6240	367.3611111	35.9440
10/31/06	00:24:00	36.3200	0.5290	-12.6240	367.3611111	35.9440
10/31/06	00:25:00	35.9030	0.5280	-12.7960	366.6666667	35.6990
10/31/06	00:26:00	36.0070	0.5250	-12.9580	364.5833333	35.9650
10/31/06	00:27:00	36.0070	0.5250	-12.9580	364.5833333	35.9650
10/31/06	00:28:00	35.7990	0.5260	-13.1390	365.2777778	35.9380
10/31/06	00:29:00	35.7990	0.5260	-13.1390	365.2777778	35.9380
10/31/06	00:30:00	35.4860	0.5240	-13.3370	363.8888889	35.8230
10/31/06	00:31:00	10.7640	0.0010	-13.2830	0.694444444	11.0470
10/31/06	00:32:00	10.7640	0.0010	-13.2830	0.694444444	11.0470
10/31/06	00:33:00	10.6250	0.0010	-12.8770	0.694444444	10.5020
10/31/06	00:34:00	10.6250	0.0010	-12.8770	0.694444444	10.5020
10/31/06	00:35:00	10.4860	0.0010	-12.4350	0.694444444	9.9210
10/31/06	00:36:00	10.4860	0.0010	-12.4350	0.694444444	9.9210
10/31/06	00:37:00	10.3820	0.0010	-12.0280	0.694444444	9.4100
10/31/06	00:38:00	10.3820	0.0010	-12.0280	0.694444444	9.4100
10/31/06	00:39:00	10.3820	0.0010	-11.7120	0.694444444	9.0940
10/31/06	00:40:00	37.2220	0.5370	-11.4870	372.9166667	35.7090
10/31/06	00:41:00	37.2220	0.5370	-11.4870	372.9166667	35.7090
10/31/06	00:42:00	37.3610	0.5380	-11.5680	373.6111111	35.9290
10/31/06	00:43:00	37.0840	0.5350	-11.6940	371.5277778	35.7780
10/31/06	00:44:00	37.0840	0.5350	-11.6940	371.5277778	35.7780
10/31/06	00:45:00	37.0490	0.5350	-11.8480	371.5277778	35.8970
10/31/06	00:46:00	36.9450	0.5330	-11.9560	370.1388889	35.9010
10/31/06	00:47:00	36.9450	0.5330	-11.9560	370.1388889	35.9010
10/31/06	00:48:00	36.8750	0.5320	-12.0830	369.4444444	35.9580
10/31/06	00:49:00	36.8750	0.5320	-12.0830	369.4444444	35.9580
10/31/06	00:50:00	36.5970	0.5320	-12.2360	369.4444444	35.8330
10/31/06	00:51:00	36.5970	0.5320	-12.2360	369.4444444	35.8330
10/31/06	00:52:00	36.4240	0.5290	-12.3990	367.3611111	35.8230
10/31/06	00:53:00	36.4240	0.5290	-12.3990	367.3611111	35.8230
10/31/06	00:54:00	36.2150	0.5290	-12.5520	367.3611111	35.7670
10/31/06	00:55:00	36.2150	0.5290	-12.5520	367.3611111	35.7670
10/31/06	00:56:00	35.7640	0.5280	-12.7240	366.6666667	35.4880
10/31/06	00:57:00	36.1810	0.5260	-12.9040	365.2777778	36.0850
10/31/06	00:58:00	36.1810	0.5260	-12.9040	365.2777778	36.0850
10/31/06	00:59:00	36.1460	0.5250	-13.0760	364.5833333	36.2220
10/31/06	01:00:00	36.1460	0.5250	-13.0760	364.5833333	36.2220
10/31/06	01:01:00	35.5900	0.5240	-13.2650	363.8888889	35.8550
10/31/06	01:02:00	10.7990	0.0010	-13.3190	0.694444444	11.1180
10/31/06	01:03:00	10.7990	0.0010	-13.3190	0.694444444	11.1180
10/31/06	01:04:00	10.6250	0.0010	-12.8050	0.694444444	10.4300
10/31/06	01:05:00	10.6250	0.0010	-12.8050	0.694444444	10.4300
10/31/06	01:06:00	10.4860	0.0010	-12.4620	0.694444444	9.9480
10/31/06	01:07:00	10.4860	0.0010	-12.4620	0.694444444	9.9480
10/31/06	01:08:00	10.4170	0.0010	-12.1730	0.694444444	9.5900
10/31/06	01:09:00	10.3820	0.0010	-11.8660	0.694444444	9.2480
10/31/06	01:10:00	10.3820	0.0010	-11.8660	0.694444444	9.2480
10/31/06	01:11:00	10.3470	0.0010	-11.6040	0.694444444	8.9510

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	01:12:00	10.3470	0.0010	-11.6040	0.694444444	8.9510
10/31/06	01:13:00	37.1530	0.5380	-11.4960	373.6111111	35.6490
10/31/06	01:14:00	37.2570	0.5360	-11.6310	372.2222222	35.8880
10/31/06	01:15:00	37.2570	0.5360	-11.6310	372.2222222	35.8880
10/31/06	01:16:00	37.1180	0.5360	-11.7490	372.2222222	35.8670
10/31/06	01:17:00	36.9100	0.5330	-11.8930	370.1388889	35.8030
10/31/06	01:18:00	36.9100	0.5330	-11.8930	370.1388889	35.8030
10/31/06	01:19:00	36.6320	0.5320	-12.0740	369.4444444	35.7060
10/31/06	01:20:00	36.6320	0.5320	-12.0740	369.4444444	35.7060
10/31/06	01:21:00	36.5630	0.5300	-12.2360	368.0555556	35.7990
10/31/06	01:22:00	36.5630	0.5300	-12.2360	368.0555556	35.7990
10/31/06	01:23:00	36.4930	0.5290	-12.3710	367.3611111	35.8640
10/31/06	01:24:00	36.1460	0.5270	-12.5250	365.9722222	35.6710
10/31/06	01:25:00	36.1460	0.5270	-12.5250	365.9722222	35.6710
10/31/06	01:26:00	36.0420	0.5300	-12.6870	368.0555556	35.7290
10/31/06	01:27:00	36.0420	0.5300	-12.6870	368.0555556	35.7290
10/31/06	01:28:00	35.9380	0.5250	-12.8770	364.5833333	35.8150
10/31/06	01:29:00	36.0770	0.5240	-13.0390	363.8888889	36.1160
10/31/06	01:30:00	36.0770	0.5240	-13.0390	363.8888889	36.1160
10/31/06	01:31:00	35.7290	0.5240	-13.2200	363.8888889	35.9490
10/31/06	01:32:00	10.8330	0.0010	-13.3460	0.694444444	11.1790
10/31/06	01:33:00	10.8330	0.0010	-13.3460	0.694444444	11.1790
10/31/06	01:34:00	10.5900	0.0010	-13.0030	0.694444444	10.5930
10/31/06	01:35:00	10.5900	0.0010	-13.0030	0.694444444	10.5930
10/31/06	01:36:00	10.3820	0.0010	-12.5340	0.694444444	9.9160
10/31/06	01:37:00	10.3820	0.0010	-12.5340	0.694444444	9.9160
10/31/06	01:38:00	10.3130	0.0010	-12.2360	0.694444444	9.5490
10/31/06	01:39:00	10.3130	0.0010	-12.2360	0.694444444	9.5490
10/31/06	01:40:00	10.2780	0.0010	-11.9650	0.694444444	9.2430
10/31/06	01:41:00	10.2430	0.0010	-11.6760	0.694444444	8.9190
10/31/06	01:42:00	10.2430	0.0010	-11.6760	0.694444444	8.9190
10/31/06	01:43:00	37.3610	0.5370	-11.4870	372.9166667	35.8480
10/31/06	01:44:00	36.8400	0.5350	-11.6040	371.5277778	35.4440
10/31/06	01:45:00	36.8400	0.5350	-11.6040	371.5277778	35.4440
10/31/06	01:46:00	36.9450	0.5330	-11.7300	370.1388889	35.6750
10/31/06	01:47:00	36.9450	0.5310	-11.8570	368.75	35.8020
10/31/06	01:48:00	36.9450	0.5310	-11.8570	368.75	35.8020
10/31/06	01:49:00	36.8060	0.5300	-12.0100	368.0555556	35.8160
10/31/06	01:50:00	36.8060	0.5300	-12.0100	368.0555556	35.8160
10/31/06	01:51:00	36.5630	0.5290	-12.1730	367.3611111	35.7360
10/31/06	01:52:00	36.5630	0.5290	-12.1730	367.3611111	35.7360
10/31/06	01:53:00	36.1110	0.5280	-12.3620	366.6666667	35.4730
10/31/06	01:54:00	36.1110	0.5280	-12.3620	366.6666667	35.4730
10/31/06	01:55:00	35.6950	0.5270	-12.5070	365.9722222	35.2020
10/31/06	01:56:00	35.6950	0.5270	-12.5070	365.9722222	35.2020
10/31/06	01:57:00	36.0420	0.5260	-12.6420	365.2777778	35.6840
10/31/06	01:58:00	35.2430	0.5230	-12.8320	363.1944444	35.0750
10/31/06	01:59:00	35.2430	0.5230	-12.8320	363.1944444	35.0750
10/31/06	02:00:00	35.6600	0.5240	-13.0120	363.8888889	35.6720
10/31/06	02:01:00	35.3820	0.5200	-13.2110	361.1111111	35.5930
10/31/06	02:02:00	35.3820	0.5200	-13.2110	361.1111111	35.5930
10/31/06	02:03:00	10.7990	0.0010	-13.3190	0.694444444	11.1180
10/31/06	02:04:00	10.7990	0.0010	-13.3190	0.694444444	11.1180
10/31/06	02:05:00	10.5210	0.0010	-12.8770	0.694444444	10.3980
10/31/06	02:06:00	10.5210	0.0010	-12.8770	0.694444444	10.3980
10/31/06	02:07:00	10.3820	0.0010	-12.5160	0.694444444	9.8980
10/31/06	02:08:00	10.3820	0.0010	-12.5160	0.694444444	9.8980
10/31/06	02:09:00	10.3470	0.0010	-12.2360	0.694444444	9.5830
10/31/06	02:10:00	10.2780	0.0010	-11.9650	0.694444444	9.2430
10/31/06	02:11:00	10.2780	0.0010	-11.9650	0.694444444	9.2430
10/31/06	02:12:00	10.2430	0.0010	-11.6940	0.694444444	8.9370
10/31/06	02:13:00	10.2430	0.0010	-11.6940	0.694444444	8.9370
10/31/06	02:14:00	37.0490	0.5360	-11.4870	372.2222222	35.5360
10/31/06	02:15:00	36.7360	0.5340	-11.5680	370.8333333	35.3040
10/31/06	02:16:00	36.7360	0.5340	-11.5680	370.8333333	35.3040
10/31/06	02:17:00	36.7710	0.5310	-11.6850	368.75	35.4560
10/31/06	02:18:00	36.7710	0.5310	-11.6850	368.75	35.4560
10/31/06	02:19:00	36.2150	0.5290	-11.8930	367.3611111	35.1080
10/31/06	02:20:00	36.2150	0.5290	-11.8930	367.3611111	35.1080
10/31/06	02:21:00	36.7020	0.5260	-12.0830	365.2777778	35.7850
10/31/06	02:22:00	36.7020	0.5260	-12.0830	365.2777778	35.7850
10/31/06	02:23:00	36.1110	0.5290	-12.2360	367.3611111	35.3470
10/31/06	02:24:00	36.1810	0.5270	-12.3890	365.9722222	35.5700
10/31/06	02:25:00	36.1810	0.5270	-12.3890	365.9722222	35.5700

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	02:26:00	35.8680	0.5250	-12.5520	364.5833333	35.4200
10/31/06	02:27:00	35.8680	0.5250	-12.5520	364.5833333	35.4200
10/31/06	02:28:00	35.7640	0.5220	-12.6960	362.5	35.4600
10/31/06	02:29:00	35.4860	0.5220	-12.8860	362.5	35.3720
10/31/06	02:30:00	35.4860	0.5220	-12.8860	362.5	35.3720
10/31/06	02:31:00	36.0070	0.5200	-13.0580	361.1111111	36.0650
10/31/06	02:32:00	36.0070	0.5200	-13.0580	361.1111111	36.0650
10/31/06	02:33:00	35.4170	0.5200	-13.3100	361.1111111	35.7270
10/31/06	02:34:00	35.4170	0.5200	-13.3100	361.1111111	35.7270
10/31/06	02:35:00	35.4170	0.5200	-13.3100	361.1111111	35.7270
10/31/06	02:36:00	35.4170	0.5200	-13.3100	361.1111111	35.7270
10/31/06	02:37:00	35.4170	0.5200	-13.3100	361.1111111	35.7270
10/31/06	02:38:00	35.4170	0.5200	-13.3100	361.1111111	35.7270
10/31/06	02:39:00	35.4170	0.5200	-13.3100	361.1111111	35.7270
10/31/06	02:40:00	10.4170	0.0010	-12.2090	0.694444444	9.6260
10/31/06	02:41:00	10.4170	0.0010	-12.2090	0.694444444	9.6260
10/31/06	02:42:00	10.3820	0.0010	-11.8930	0.694444444	9.2750
10/31/06	02:43:00	10.3470	0.0010	-11.6220	0.694444444	8.9690
10/31/06	02:44:00	10.3470	0.0010	-11.6220	0.694444444	8.9690
10/31/06	02:45:00	37.5350	0.5360	-11.4960	372.2222222	36.0310
10/31/06	02:46:00	37.1530	0.5350	-11.6310	371.5277778	35.7840
10/31/06	02:47:00	37.1530	0.5350	-11.6310	371.5277778	35.7840
10/31/06	02:48:00	37.0490	0.5310	-11.8210	368.75	35.8700
10/31/06	02:49:00	37.0490	0.5310	-11.8210	368.75	35.8700
10/31/06	02:50:00	36.9100	0.5320	-11.9560	369.4444444	35.8660
10/31/06	02:51:00	36.9100	0.5320	-11.9560	369.4444444	35.8660
10/31/06	02:52:00	36.6670	0.5300	-12.1550	368.0555556	35.8220
10/31/06	02:53:00	36.6670	0.5300	-12.1550	368.0555556	35.8220
10/31/06	02:54:00	36.3200	0.5280	-12.2900	366.6666667	35.6100
10/31/06	02:55:00	36.3540	0.5270	-12.4620	365.9722222	35.8160
10/31/06	02:56:00	36.3540	0.5270	-12.4620	365.9722222	35.8160
10/31/06	02:57:00	36.4930	0.5270	-12.5790	365.9722222	36.0720
10/31/06	02:58:00	36.4930	0.5270	-12.5790	365.9722222	36.0720
10/31/06	02:59:00	36.2150	0.5240	-12.7960	363.8888889	36.0110
10/31/06	03:00:00	36.2150	0.5240	-12.7960	363.8888889	36.0110
10/31/06	03:01:00	36.1810	0.5260	-12.9580	365.2777778	36.1390
10/31/06	03:02:00	35.9720	0.5240	-13.1390	363.8888889	36.1110
10/31/06	03:03:00	35.9720	0.5240	-13.1390	363.8888889	36.1110
10/31/06	03:04:00	1.5280	0.0010	-13.3740	0.694444444	1.9020
10/31/06	03:05:00	1.5280	0.0010	-13.3740	0.694444444	1.9020
10/31/06	03:06:00	10.7290	0.0010	-13.0670	0.694444444	10.7960
10/31/06	03:07:00	10.7290	0.0010	-13.0670	0.694444444	10.7960
10/31/06	03:08:00	10.5560	0.0010	-12.6330	0.694444444	10.1890
10/31/06	03:09:00	10.4520	0.0010	-12.3080	0.694444444	9.7600
10/31/06	03:10:00	10.4520	0.0010	-12.3080	0.694444444	9.7600
10/31/06	03:11:00	10.4170	0.0010	-12.0100	0.694444444	9.4270
10/31/06	03:12:00	10.4170	0.0010	-12.0100	0.694444444	9.4270
10/31/06	03:13:00	10.3470	0.0010	-11.7670	0.694444444	9.1140
10/31/06	03:14:00	10.3470	0.0010	-11.4960	0.694444444	8.8430
10/31/06	03:15:00	35.7990	0.5210	-11.5230	361.8055556	34.3220
10/31/06	03:16:00	35.7990	0.5210	-11.5230	361.8055556	34.3220
10/31/06	03:17:00	36.0420	0.5210	-11.6580	361.8055556	34.7000
10/31/06	03:18:00	36.0420	0.5210	-11.6580	361.8055556	34.7000
10/31/06	03:19:00	35.2430	0.5190	-11.7760	360.4166667	34.0190
10/31/06	03:20:00	35.2430	0.5190	-11.7760	360.4166667	34.0190
10/31/06	03:21:00	35.4860	0.5180	-11.8930	359.7222222	34.3790
10/31/06	03:22:00	35.4860	0.5180	-11.8930	359.7222222	34.3790
10/31/06	03:23:00	35.0700	0.5170	-11.9920	359.0277778	34.0620
10/31/06	03:24:00	35.2780	0.5170	-12.0830	359.0277778	34.3610
10/31/06	03:25:00	35.2780	0.5170	-12.0830	359.0277778	34.3610
10/31/06	03:26:00	35.2780	0.5160	-12.1370	358.3333333	34.4150
10/31/06	03:27:00	35.2780	0.5160	-12.1370	358.3333333	34.4150
10/31/06	03:28:00	35.1740	0.5160	-12.2090	358.3333333	34.3830
10/31/06	03:29:00	34.8610	0.5150	-12.2540	357.6388889	34.1150
10/31/06	03:30:00	34.8610	0.5150	-12.2540	357.6388889	34.1150
10/31/06	03:31:00	34.8610	0.5130	-12.3350	356.25	34.1960
10/31/06	03:32:00	34.8610	0.5130	-12.3350	356.25	34.1960
10/31/06	03:33:00	34.6180	0.5130	-12.3800	356.25	33.9980
10/31/06	03:34:00	34.8610	0.5120	-12.4890	355.5555556	34.3500
10/31/06	03:35:00	34.8610	0.5120	-12.4890	355.5555556	34.3500
10/31/06	03:36:00	34.8270	0.5120	-12.5700	355.5555556	34.3970
10/31/06	03:37:00	34.8270	0.5120	-12.5700	355.5555556	34.3970
10/31/06	03:38:00	35.0000	0.5100	-12.6330	354.1666667	34.6330
10/31/06	03:39:00	35.0000	0.5100	-12.6330	354.1666667	34.6330

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	03:40:00	34.6880	0.5090	-12.6960	353.4722222	34.3840
10/31/06	03:41:00	34.6530	0.5100	-12.7600	354.1666667	34.4130
10/31/06	03:42:00	34.6530	0.5100	-12.7600	354.1666667	34.4130
10/31/06	03:43:00	34.7220	0.5090	-12.7960	353.4722222	34.5180
10/31/06	03:44:00	34.7220	0.5090	-12.7960	353.4722222	34.5180
10/31/06	03:45:00	34.6180	0.5120	-12.8590	355.5555556	34.4770
10/31/06	03:46:00	34.6180	0.5120	-12.8770	355.5555556	34.4950
10/31/06	03:47:00	34.6180	0.5120	-12.8770	355.5555556	34.4950
10/31/06	03:48:00	34.8960	0.5120	-12.8950	355.5555556	34.7910
10/31/06	03:49:00	34.6530	0.5120	-12.8950	355.5555556	34.5480
10/31/06	03:50:00	34.7570	0.5120	-12.9310	355.5555556	34.6880
10/31/06	03:51:00	34.7570	0.5120	-12.9310	355.5555556	34.6880
10/31/06	03:52:00	34.6880	0.5100	-12.9490	354.1666667	34.6370
10/31/06	03:53:00	34.5490	0.5100	-13.0030	354.1666667	34.5520
10/31/06	03:54:00	34.5490	0.5100	-13.0030	354.1666667	34.5520
10/31/06	03:55:00	34.3750	0.5100	-13.0120	354.1666667	34.3870
10/31/06	03:56:00	34.3750	0.5100	-13.0120	354.1666667	34.3870
10/31/06	03:57:00	34.8610	0.5090	-13.0300	353.4722222	34.8910
10/31/06	03:58:00	34.7570	0.5100	-13.0390	354.1666667	34.7960
10/31/06	03:59:00	34.7570	0.5100	-13.0390	354.1666667	34.7960
10/31/06	04:00:00	34.8610	0.5120	-13.0670	355.5555556	34.9280
10/31/06	04:01:00	34.8270	0.5100	-13.0760	354.1666667	34.9030
10/31/06	04:02:00	34.8270	0.5100	-13.0760	354.1666667	34.9030
10/31/06	04:03:00	34.6180	0.5110	-13.1030	354.8611111	34.7210
10/31/06	04:04:00	34.6180	0.5110	-13.1030	354.8611111	34.7210
10/31/06	04:05:00	34.7220	0.5120	-13.1300	355.5555556	34.8520
10/31/06	04:06:00	34.7220	0.5120	-13.1300	355.5555556	34.8520
10/31/06	04:07:00	34.5840	0.5120	-13.1300	355.5555556	34.7140
10/31/06	04:08:00	34.5840	0.5120	-13.1300	355.5555556	34.7140
10/31/06	04:09:00	34.7920	0.5130	-13.1570	356.25	34.9490
10/31/06	04:10:00	34.7220	0.5130	-13.1840	356.25	34.9060
10/31/06	04:11:00	34.7220	0.5130	-13.1840	356.25	34.9060
10/31/06	04:12:00	34.7570	0.5140	-13.2020	356.9444444	34.9590
10/31/06	04:13:00	34.9310	0.5130	-13.2110	356.25	35.1420
10/31/06	04:14:00	34.9310	0.5130	-13.2110	356.25	35.1420
10/31/06	04:15:00	34.5140	0.5130	-13.2470	356.25	34.7610
10/31/06	04:16:00	34.5140	0.5130	-13.2470	356.25	34.7610
10/31/06	04:17:00	34.4450	0.5140	-13.2830	356.9444444	34.7280
10/31/06	04:18:00	34.6530	0.5100	-13.3190	354.1666667	34.9720
10/31/06	04:19:00	34.6530	0.5100	-13.3190	354.1666667	34.9720
10/31/06	04:20:00	34.3750	0.5110	-13.3460	354.8611111	34.7210
10/31/06	04:21:00	34.3750	0.5110	-13.3460	354.8611111	34.7210
10/31/06	04:22:00	10.4170	0.0000	-13.2740	0	10.6910
10/31/06	04:23:00	10.4170	0.0000	-13.2740	0	10.6910
10/31/06	04:24:00	10.0700	0.0000	-12.6240	0	9.6940
10/31/06	04:25:00	10.0700	0.0000	-12.6240	0	9.6940
10/31/06	04:26:00	9.9650	0.0000	-12.2090	0	9.1740
10/31/06	04:27:00	9.8960	0.0000	-11.7760	0	8.6720
10/31/06	04:28:00	9.8960	0.0000	-11.7760	0	8.6720
10/31/06	04:29:00	35.4520	0.5250	-11.4960	364.5833333	33.9480
10/31/06	04:30:00	35.9720	0.5250	-11.4960	364.5833333	34.4680
10/31/06	04:31:00	35.9720	0.5250	-11.4960	364.5833333	34.4680
10/31/06	04:32:00	35.6250	0.5240	-11.5590	363.8888889	34.1840
10/31/06	04:33:00	35.0700	0.5220	-11.6130	362.5	33.6830
10/31/06	04:34:00	35.0700	0.5220	-11.6130	362.5	33.6830
10/31/06	04:35:00	35.0700	0.5220	-11.6130	362.5	33.6830
10/31/06	04:36:00	36.2150	0.5310	-11.6850	368.75	34.9000
10/31/06	04:37:00	36.2150	0.5310	-11.6850	368.75	34.9000
10/31/06	04:38:00	36.8060	0.5300	-11.6940	368.0555556	35.5000
10/31/06	04:39:00	36.6320	0.5310	-11.7490	368.75	35.3810
10/31/06	04:40:00	36.6320	0.5310	-11.7490	368.75	35.3810
10/31/06	04:41:00	36.7360	0.5310	-11.7670	368.75	35.5030
10/31/06	04:42:00	36.7360	0.5310	-11.7670	368.75	35.5030
10/31/06	04:43:00	36.4240	0.5310	-11.8210	368.75	35.2450
10/31/06	04:44:00	36.9100	0.5310	-11.8480	368.75	35.7580
10/31/06	04:45:00	36.9100	0.5310	-11.8480	368.75	35.7580
10/31/06	04:46:00	36.0420	0.5300	-11.8570	368.0555556	34.8990
10/31/06	04:47:00	35.9380	0.5310	-11.8660	368.75	34.8040
10/31/06	04:48:00	35.9380	0.5310	-11.8660	368.75	34.8040
10/31/06	04:49:00	36.8060	0.5310	-11.8930	368.75	35.6990
10/31/06	04:50:00	36.8060	0.5310	-11.8930	368.75	35.6990
10/31/06	04:51:00	36.1110	0.5300	-11.9110	368.0555556	35.0220
10/31/06	04:52:00	36.1110	0.5300	-11.9110	368.0555556	35.0220
10/31/06	04:53:00	36.2150	0.5290	-11.9110	367.3611111	35.1260

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	04:54:00	36.2150	0.5290	-11.9110	367.3611111	35.1260
10/31/06	04:55:00	36.3540	0.5290	-11.9110	367.3611111	35.2650
10/31/06	04:56:00	36.5970	0.5300	-11.9110	368.0555556	35.5080
10/31/06	04:57:00	36.5970	0.5300	-11.9110	368.0555556	35.5080
10/31/06	04:58:00	36.5630	0.5320	-11.9110	369.4444444	35.4740
10/31/06	04:59:00	36.3200	0.5310	-11.9110	368.75	35.2310
10/31/06	05:00:00	36.3200	0.5310	-11.9110	368.75	35.2310
10/31/06	05:01:00	36.4590	0.5310	-11.8840	368.75	35.3430
10/31/06	05:02:00	36.4590	0.5310	-11.8840	368.75	35.3430
10/31/06	05:03:00	36.3890	0.5310	-11.8570	368.75	35.2460
10/31/06	05:04:00	36.3890	0.5310	-11.8570	368.75	35.2460
10/31/06	05:05:00	36.4930	0.5320	-11.8120	369.4444444	35.3050
10/31/06	05:06:00	36.0420	0.5320	-11.7760	369.4444444	34.8180
10/31/06	05:07:00	36.0420	0.5320	-11.7760	369.4444444	34.8180
10/31/06	05:08:00	36.5280	0.5320	-11.7670	369.4444444	35.2950
10/31/06	05:09:00	36.5280	0.5320	-11.7670	369.4444444	35.2950
10/31/06	05:10:00	36.4240	0.5310	-11.7120	368.75	35.1360
10/31/06	05:11:00	36.2500	0.5320	-11.6940	369.4444444	34.9440
10/31/06	05:12:00	36.2500	0.5320	-11.6940	369.4444444	34.9440
10/31/06	05:13:00	36.4930	0.5300	-11.6670	368.0555556	35.1600
10/31/06	05:14:00	36.3200	0.5310	-11.6310	368.75	34.9510
10/31/06	05:15:00	36.1460	0.5310	-11.6310	368.75	34.7770
10/31/06	05:16:00	36.1460	0.5320	-11.6220	369.4444444	34.7680
10/31/06	05:17:00	36.3540	0.5320	-11.5950	369.4444444	34.9490
10/31/06	05:18:00	36.3540	0.5320	-11.5950	369.4444444	34.9490
10/31/06	05:19:00	36.6670	0.5320	-11.5320	369.4444444	35.1990
10/31/06	05:20:00	36.6670	0.5320	-11.5320	369.4444444	35.1990
10/31/06	05:21:00	37.2920	0.5380	-11.4960	373.6111111	35.7880
10/31/06	05:22:00	37.2920	0.5380	-11.4960	373.6111111	35.7880
10/31/06	05:23:00	37.0840	0.5400	-11.4420	375	35.5260
10/31/06	05:24:00	37.0840	0.5400	-11.4420	375	35.5260
10/31/06	05:25:00	37.0140	0.5410	-11.3960	375.6944444	35.4100
10/31/06	05:26:00	37.2920	0.5410	-11.3780	375.6944444	35.6700
10/31/06	05:27:00	37.2920	0.5410	-11.3780	375.6944444	35.6700
10/31/06	05:28:00	37.2570	0.5400	-11.2700	375	35.5270
10/31/06	05:29:00	37.6740	0.5420	-11.2160	376.3888889	35.8900
10/31/06	05:30:00	37.6740	0.5420	-11.2160	376.3888889	35.8900
10/31/06	05:31:00	37.4310	0.5420	-11.1980	376.3888889	35.6290
10/31/06	05:32:00	37.4310	0.5420	-11.1980	376.3888889	35.6290
10/31/06	05:33:00	37.1530	0.5420	-11.1080	376.3888889	35.2610
10/31/06	05:34:00	37.6040	0.5440	-11.0710	377.7777778	35.6750
10/31/06	05:35:00	37.6040	0.5440	-11.0710	377.7777778	35.6750
10/31/06	05:36:00	37.6040	0.5440	-11.0710	377.7777778	35.6750
10/31/06	05:37:00	37.6040	0.5390	-10.9540	374.3055556	35.5580
10/31/06	05:38:00	37.3610	0.5410	-10.8820	375.6944444	35.2430
10/31/06	05:39:00	37.3610	0.5410	-10.8820	375.6944444	35.2430
10/31/06	05:40:00	37.3610	0.5410	-10.8820	375.6944444	35.2430
10/31/06	05:41:00	37.1180	0.5410	-10.7550	375.6944444	34.8730
10/31/06	05:42:00	37.1530	0.5410	-10.6740	375.6944444	34.8270
10/31/06	05:43:00	37.1530	0.5410	-10.6740	375.6944444	34.8270
10/31/06	05:44:00	37.1880	0.5420	-10.5930	376.3888889	34.7810
10/31/06	05:45:00	37.1880	0.5420	-10.5930	376.3888889	34.7810
10/31/06	05:46:00	37.5000	0.5430	-10.5120	377.0833333	35.0120
10/31/06	05:47:00	37.2570	0.5430	-10.4490	377.0833333	34.7060
10/31/06	05:48:00	37.2570	0.5430	-10.4490	377.0833333	34.7060
10/31/06	05:49:00	37.5350	0.5420	-10.3760	376.3888889	34.9110
10/31/06	05:50:00	37.5350	0.5420	-10.3760	376.3888889	34.9110
10/31/06	05:51:00	37.9520	0.5470	-10.2770	379.8611111	35.2290
10/31/06	05:52:00	37.9520	0.5470	-10.2770	379.8611111	35.2290
10/31/06	05:53:00	44.2360	0.6060	-10.2320	420.8333333	41.4680
10/31/06	05:54:00	44.9310	0.6110	-10.2050	424.3055556	42.1360
10/31/06	05:55:00	44.9310	0.6110	-10.2050	424.3055556	42.1360
10/31/06	05:56:00	44.5840	0.6110	-10.1960	424.3055556	41.7800
10/31/06	05:57:00	44.5840	0.6110	-10.1960	424.3055556	41.7800
10/31/06	05:58:00	44.9660	0.6090	-10.1510	422.9166667	42.1170
10/31/06	05:59:00	44.9660	0.6090	-10.1510	422.9166667	42.1170
10/31/06	06:00:00	44.7920	0.6110	-10.1050	424.3055556	41.8970
10/31/06	06:01:00	45.1040	0.6140	-10.0600	426.3888889	42.1640
10/31/06	06:02:00	45.1040	0.6140	-10.0600	426.3888889	42.1640
10/31/06	06:03:00	45.1390	0.6140	-9.9880	426.3888889	42.1270
10/31/06	06:04:00	45.1390	0.6140	-9.9880	426.3888889	42.1270
10/31/06	06:05:00	45.0700	0.6140	-9.9610	426.3888889	42.0310
10/31/06	06:06:00	45.0700	0.6140	-9.9610	426.3888889	42.0310
10/31/06	06:07:00	45.1040	0.6140	-9.9250	426.3888889	42.0290

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	06:08:00	45.1040	0.6140	-9.9250	426.3888889	42.0290
10/31/06	06:09:00	44.8270	0.6140	-9.8890	426.3888889	41.7160
10/31/06	06:10:00	45.1040	0.6150	-9.8440	427.0833333	41.9480
10/31/06	06:11:00	45.1040	0.6150	-9.8440	427.0833333	41.9480
10/31/06	06:12:00	44.8610	0.6180	-9.7890	429.1666667	41.6500
10/31/06	06:13:00	44.8610	0.6180	-9.7890	429.1666667	41.6500
10/31/06	06:14:00	45.1740	0.6170	-9.7440	428.4722222	41.9180
10/31/06	06:15:00	44.9660	0.6180	-9.7080	429.1666667	41.6740
10/31/06	06:16:00	44.9660	0.6180	-9.7080	429.1666667	41.6740
10/31/06	06:17:00	45.1740	0.6180	-9.6270	429.1666667	41.8010
10/31/06	06:18:00	45.1740	0.6180	-9.6270	429.1666667	41.8010
10/31/06	06:19:00	45.1390	0.6210	-9.5820	431.25	41.7210
10/31/06	06:20:00	45.1390	0.6210	-9.5820	431.25	41.7210
10/31/06	06:21:00	45.7640	0.6240	-9.5100	433.3333333	42.2740
10/31/06	06:22:00	45.7640	0.6240	-9.5100	433.3333333	42.2740
10/31/06	06:23:00	46.2500	0.6280	-9.4370	436.1111111	42.6870
10/31/06	06:24:00	46.2500	0.6280	-9.4370	436.1111111	42.6870
10/31/06	06:25:00	46.7710	0.6290	-9.3830	436.8055556	43.1540
10/31/06	06:26:00	46.7710	0.6290	-9.3830	436.8055556	43.1540
10/31/06	06:27:00	46.7710	0.6290	-9.3830	436.8055556	43.1540
10/31/06	06:28:00	46.7710	0.6290	-9.3830	436.8055556	43.1540
10/31/06	06:29:00	46.7710	0.6290	-9.3830	436.8055556	43.1540
10/31/06	06:30:00	46.7710	0.6330	-9.1480	439.5833333	42.9190
10/31/06	06:31:00	46.7710	0.6330	-9.1480	439.5833333	42.9190
10/31/06	06:32:00	46.6670	0.6360	-9.0670	441.6666667	42.7340
10/31/06	06:33:00	46.6670	0.6360	-9.0670	441.6666667	42.7340
10/31/06	06:34:00	46.6670	0.6340	-8.9770	440.2777778	42.6440
10/31/06	06:35:00	46.6670	0.6340	-8.9770	440.2777778	42.6440
10/31/06	06:36:00	46.8750	0.6320	-8.9140	438.8888889	42.7890
10/31/06	06:37:00	46.8750	0.6320	-8.9140	438.8888889	42.7890
10/31/06	06:38:00	46.8060	0.6350	-8.8330	440.9722222	42.6390
10/31/06	06:39:00	46.8060	0.6350	-8.7780	440.9722222	42.5840
10/31/06	06:40:00	46.8060	0.6350	-8.7780	440.9722222	42.5840
10/31/06	06:41:00	47.1180	0.6370	-8.7150	442.3611111	42.8330
10/31/06	06:42:00	47.1180	0.6370	-8.7150	442.3611111	42.8330
10/31/06	06:43:00	47.1180	0.6380	-8.6700	443.0555556	42.7880
10/31/06	06:44:00	47.0840	0.6380	-8.6160	443.0555556	42.7000
10/31/06	06:45:00	47.0840	0.6380	-8.6160	443.0555556	42.7000
10/31/06	06:46:00	47.0840	0.6400	-8.5800	444.4444444	42.6640
10/31/06	06:47:00	47.0840	0.6400	-8.5800	444.4444444	42.6640
10/31/06	06:48:00	47.1530	0.6410	-8.5530	445.1388889	42.7060
10/31/06	06:49:00	47.2220	0.6390	-8.4800	443.75	42.7020
10/31/06	06:50:00	47.2220	0.6390	-8.4800	443.75	42.7020
10/31/06	06:51:00	47.2570	0.6410	-8.4350	445.1388889	42.6920
10/31/06	06:52:00	47.2570	0.6410	-8.4350	445.1388889	42.6920
10/31/06	06:53:00	47.2570	0.6410	-8.4350	445.1388889	42.6920
10/31/06	06:54:00	47.2220	0.6420	-8.3630	445.8333333	42.5850
10/31/06	06:55:00	47.5350	0.6440	-8.3180	447.2222222	42.8530
10/31/06	06:56:00	47.5350	0.6440	-8.3180	447.2222222	42.8530
10/31/06	06:57:00	47.5700	0.6450	-8.2820	447.9166667	42.8520
10/31/06	06:58:00	47.5700	0.6450	-8.2820	447.9166667	42.8520
10/31/06	06:59:00	47.4660	0.6440	-8.2190	447.2222222	42.6850
10/31/06	07:00:00	47.4660	0.6440	-8.2190	447.2222222	42.6850
10/31/06	07:01:00	47.8470	0.6450	-8.1730	447.9166667	43.0200
10/31/06	07:02:00	47.7780	0.6450	-8.1370	447.9166667	42.9150
10/31/06	07:03:00	47.7780	0.6450	-8.1370	447.9166667	42.9150
10/31/06	07:04:00	48.0210	0.6490	-7.9300	450.6944444	42.9510
10/31/06	07:05:00	48.0210	0.6490	-7.9300	450.6944444	42.9510
10/31/06	07:06:00	48.0560	0.6500	-7.7400	451.3888889	42.7960
10/31/06	07:07:00	48.0560	0.6500	-7.7400	451.3888889	42.7960
10/31/06	07:08:00	48.0210	0.6520	-7.5140	452.7777778	42.5350
10/31/06	07:09:00	48.2640	0.6550	-7.3430	454.8611111	42.6070
10/31/06	07:10:00	48.2640	0.6550	-7.3430	454.8611111	42.6070
10/31/06	07:11:00	48.5420	0.6540	-7.2710	454.1666667	42.8130
10/31/06	07:12:00	48.5420	0.6540	-7.2710	454.1666667	42.8130
10/31/06	07:13:00	48.6460	0.6560	-7.1800	455.5555556	42.8260
10/31/06	07:14:00	48.8890	0.6580	-7.0630	456.9444444	42.9520
10/31/06	07:15:00	48.8890	0.6580	-7.0630	456.9444444	42.9520
10/31/06	07:16:00	49.0280	0.6580	-6.9820	456.9444444	43.0100
10/31/06	07:17:00	49.0280	0.6580	-6.9820	456.9444444	43.0100
10/31/06	07:18:00	49.2020	0.6600	-6.8280	458.3333333	43.0300
10/31/06	07:19:00	49.2020	0.6600	-6.8280	458.3333333	43.0300
10/31/06	07:20:00	49.2710	0.6600	-6.7110	458.3333333	42.9820
10/31/06	07:21:00	49.2710	0.6600	-6.7110	458.3333333	42.9820



**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	07:22:00	49.5490	0.6640	-6.6120	461.1111111	43.1610
10/31/06	07:23:00	49.5490	0.6640	-6.6120	461.1111111	43.1610
10/31/06	07:24:00	49.6880	0.6640	-6.5120	461.1111111	43.2000
10/31/06	07:25:00	49.7570	0.6650	-6.4400	461.8055556	43.1970
10/31/06	07:26:00	49.7570	0.6650	-6.4400	461.8055556	43.1970
10/31/06	07:27:00	49.5840	0.6640	-6.3680	461.1111111	42.9520
10/31/06	07:28:00	49.8270	0.6670	-6.2960	463.1944444	43.1230
10/31/06	07:29:00	49.8270	0.6670	-6.2960	463.1944444	43.1230
10/31/06	07:30:00	50.3470	0.6680	-6.2140	463.8888889	43.5610
10/31/06	07:31:00	50.3470	0.6680	-6.2140	463.8888889	43.5610
10/31/06	07:32:00	50.5560	0.6720	-6.1510	466.6666667	43.7070
10/31/06	07:33:00	50.5560	0.6720	-6.1510	466.6666667	43.7070
10/31/06	07:34:00	50.4520	0.6720	-6.0610	466.6666667	43.5130
10/31/06	07:35:00	50.4520	0.6720	-6.0610	466.6666667	43.5130
10/31/06	07:36:00	50.6250	0.6740	-5.9980	468.0555556	43.6230
10/31/06	07:37:00	50.6250	0.6740	-5.9980	468.0555556	43.6230
10/31/06	07:38:00	50.7290	0.6730	-5.9710	467.3611111	43.7000
10/31/06	07:39:00	50.7290	0.6730	-5.9710	467.3611111	43.7000
10/31/06	07:40:00	50.7990	0.6770	-5.9350	470.1388889	43.7340
10/31/06	07:41:00	50.9380	0.6770	-5.9170	470.1388889	43.8550
10/31/06	07:42:00	50.9380	0.6770	-5.9170	470.1388889	43.8550
10/31/06	07:43:00	51.0420	0.6770	-5.8620	470.1388889	43.9040
10/31/06	07:44:00	51.0420	0.6770	-5.8620	470.1388889	43.9040
10/31/06	07:45:00	50.8680	0.6770	-5.8080	470.1388889	43.6760
10/31/06	07:46:00	51.0420	0.6790	-5.7810	471.5277778	43.8230
10/31/06	07:47:00	51.0420	0.6790	-5.7810	471.5277778	43.8230
10/31/06	07:48:00	51.1110	0.6780	-5.7360	470.8333333	43.8470
10/31/06	07:49:00	51.1110	0.6780	-5.7360	470.8333333	43.8470
10/31/06	07:50:00	51.1460	0.6800	-5.6820	472.2222222	43.8280
10/31/06	07:51:00	51.1460	0.6800	-5.6820	472.2222222	43.8280
10/31/06	07:52:00	51.2160	0.6810	-5.6280	472.9166667	43.8440
10/31/06	07:53:00	51.2160	0.6810	-5.6280	472.9166667	43.8440
10/31/06	07:54:00	51.0420	0.6800	-5.5550	472.2222222	43.5970
10/31/06	07:55:00	51.0420	0.6800	-5.5550	472.2222222	43.5970
10/31/06	07:56:00	51.1810	0.6810	-5.5010	472.9166667	43.6820
10/31/06	07:57:00	51.1460	0.6810	-5.4380	472.9166667	43.5840
10/31/06	07:58:00	51.1460	0.6810	-5.4380	472.9166667	43.5840
10/31/06	07:59:00	51.3540	0.6800	-5.3840	472.2222222	43.7380
10/31/06	08:00:00	51.3540	0.6800	-5.3840	472.2222222	43.7380
10/31/06	08:01:00	50.9380	0.6810	-5.3390	472.9166667	43.2770
10/31/06	08:02:00	51.0070	0.6840	-5.2850	475	43.2920
10/31/06	08:03:00	51.0070	0.6840	-5.2850	475	43.2920
10/31/06	08:04:00	51.3200	0.6850	-5.1940	475.6944444	43.5140
10/31/06	08:05:00	51.3200	0.6850	-5.1940	475.6944444	43.5140
10/31/06	08:06:00	51.3200	0.6850	-5.1940	475.6944444	43.5140
10/31/06	08:07:00	51.3890	0.6870	-5.0860	477.0833333	43.4750
10/31/06	08:08:00	51.3890	0.6870	-5.0860	477.0833333	43.4750
10/31/06	08:09:00	51.2160	0.6850	-5.0770	475.6944444	43.2930
10/31/06	08:10:00	51.2160	0.6850	-5.0770	475.6944444	43.2930
10/31/06	08:11:00	51.3890	0.6870	-5.0500	477.0833333	43.4390
10/31/06	08:12:00	51.3890	0.6870	-5.0500	477.0833333	43.4390
10/31/06	08:13:00	51.3890	0.6870	-5.0500	477.0833333	43.4390
10/31/06	08:14:00	51.3890	0.6870	-5.0500	477.0833333	43.4390
10/31/06	08:15:00	51.8750	0.6870	-4.9690	477.0833333	43.8440
10/31/06	08:16:00	51.8750	0.6870	-4.9690	477.0833333	43.8440
10/31/06	08:17:00	51.4930	0.6890	-4.9140	478.4722222	43.4070
10/31/06	08:18:00	51.8060	0.6900	-4.8600	479.1666667	43.6660
10/31/06	08:19:00	51.8060	0.6900	-4.8600	479.1666667	43.6660
10/31/06	08:20:00	51.8060	0.6900	-4.8600	479.1666667	43.6660
10/31/06	08:21:00	51.5970	0.6910	-4.7970	479.8611111	43.3940
10/31/06	08:22:00	51.8410	0.6920	-4.7160	480.5555556	43.5570
10/31/06	08:23:00	51.8410	0.6920	-4.7160	480.5555556	43.5570
10/31/06	08:24:00	52.0490	0.6940	-4.6440	481.9444444	43.6930
10/31/06	08:25:00	52.0490	0.6940	-4.6440	481.9444444	43.6930
10/31/06	08:26:00	51.9450	0.6950	-4.6170	482.6388889	43.5620
10/31/06	08:27:00	52.1530	0.6950	-4.5620	482.6388889	43.7150
10/31/06	08:28:00	52.1530	0.6950	-4.5620	482.6388889	43.7150
10/31/06	08:29:00	52.3610	0.6960	-4.5260	483.3333333	43.8870
10/31/06	08:30:00	52.4310	0.6970	-4.4900	484.0277778	43.9210
10/31/06	08:31:00	52.4310	0.6970	-4.4900	484.0277778	43.9210
10/31/06	08:32:00	52.6740	0.6980	-4.4000	484.7222222	44.0740
10/31/06	08:33:00	52.6740	0.6980	-4.4000	484.7222222	44.0740
10/31/06	08:34:00	52.3610	0.6980	-4.3010	484.7222222	43.6620
10/31/06	08:35:00	52.3610	0.6980	-4.3010	484.7222222	43.6620

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	08:36:00	52.4660	0.7000	-4.1920	486.1111111	43.6580
10/31/06	08:37:00	52.4660	0.7000	-4.1920	486.1111111	43.6580
10/31/06	08:38:00	52.7090	0.7010	-4.0840	486.8055556	43.7930
10/31/06	08:39:00	52.7090	0.7010	-4.0840	486.8055556	43.7930
10/31/06	08:40:00	52.4660	0.7010	-4.0300	486.8055556	43.4960
10/31/06	08:41:00	52.5000	0.7030	-4.0120	488.1944444	43.5120
10/31/06	08:42:00	52.5000	0.7030	-4.0120	488.1944444	43.5120
10/31/06	08:43:00	52.6040	0.7010	-3.9940	486.8055556	43.5980
10/31/06	08:44:00	52.5700	0.7020	-3.9940	487.5	43.5640
10/31/06	08:45:00	52.5700	0.7020	-3.9940	487.5	43.5640
10/31/06	08:46:00	52.3960	0.7020	-3.9940	487.5	43.3900
10/31/06	08:47:00	52.8130	0.7020	-3.9850	487.5	43.7980
10/31/06	08:48:00	52.8130	0.7020	-3.9850	487.5	43.7980
10/31/06	08:49:00	52.7430	0.7030	-3.9850	488.1944444	43.7280
10/31/06	08:50:00	52.7430	0.7030	-3.9850	488.1944444	43.7280
10/31/06	08:51:00	52.6390	0.7040	-3.9670	488.8888889	43.6060
10/31/06	08:52:00	52.6390	0.7040	-3.9670	488.8888889	43.6060
10/31/06	08:53:00	52.5350	0.7040	-3.9670	488.8888889	43.5020
10/31/06	08:54:00	52.5350	0.7040	-3.9670	488.8888889	43.5020
10/31/06	08:55:00	52.7430	0.7040	-3.9670	488.8888889	43.7100
10/31/06	08:56:00	52.7430	0.7040	-3.9670	488.8888889	43.7100
10/31/06	08:57:00	52.5700	0.7040	-3.9570	488.8888889	43.5270
10/31/06	08:58:00	52.6040	0.7030	-3.9480	488.1944444	43.5520
10/31/06	08:59:00	52.6040	0.7030	-3.9480	488.1944444	43.5520
10/31/06	09:00:00	52.3270	0.7040	-3.9390	488.8888889	43.2660
10/31/06	09:01:00	52.3270	0.7040	-3.9390	488.8888889	43.2660
10/31/06	09:02:00	52.3960	0.7040	-3.9480	488.8888889	43.3440
10/31/06	09:03:00	52.3960	0.7040	-3.9480	488.8888889	43.3440
10/31/06	09:04:00	52.5000	0.7040	-3.9570	488.8888889	43.4570
10/31/06	09:05:00	52.5000	0.7040	-3.9570	488.8888889	43.4570
10/31/06	09:06:00	52.6740	0.7050	-3.9570	489.5833333	43.6310
10/31/06	09:07:00	52.4310	0.7040	-3.9570	488.8888889	43.3880
10/31/06	09:08:00	52.5700	0.7040	-3.9570	488.8888889	43.5270
10/31/06	09:09:00	52.4660	0.7050	-3.9390	489.5833333	43.4050
10/31/06	09:10:00	52.4660	0.7050	-3.9390	489.5833333	43.4050
10/31/06	09:11:00	52.3960	0.7030	-3.9390	488.1944444	43.3350
10/31/06	09:12:00	52.3270	0.7040	-3.9390	488.8888889	43.2660
10/31/06	09:13:00	52.3270	0.7040	-3.9390	488.8888889	43.2660
10/31/06	09:14:00	52.3960	0.7040	-3.9390	488.8888889	43.3350
10/31/06	09:15:00	52.3960	0.7040	-3.9390	488.8888889	43.3350
10/31/06	09:16:00	52.5350	0.7050	-3.9390	489.5833333	43.4740
10/31/06	09:17:00	52.5350	0.7050	-3.9390	489.5833333	43.4740
10/31/06	09:18:00	52.4660	0.7040	-3.9390	488.8888889	43.4050
10/31/06	09:19:00	52.4660	0.7040	-3.9390	488.8888889	43.4050
10/31/06	09:20:00	52.6740	0.7050	-3.9390	489.5833333	43.6130
10/31/06	09:21:00	52.6740	0.7050	-3.9390	489.5833333	43.6130
10/31/06	09:22:00	52.6740	0.7060	-3.9390	490.2777778	43.6130
10/31/06	09:23:00	52.6740	0.7060	-3.9390	490.2777778	43.6130
10/31/06	09:24:00	52.4660	0.7050	-3.9390	489.5833333	43.4050
10/31/06	09:25:00	52.4660	0.7050	-3.9390	489.5833333	43.4050
10/31/06	09:26:00	52.2220	0.7050	-3.9300	489.5833333	43.1520
10/31/06	09:27:00	52.6390	0.7050	-3.9300	489.5833333	43.5690
10/31/06	09:28:00	52.6390	0.7050	-3.9300	489.5833333	43.5690
10/31/06	09:29:00	52.5000	0.7070	-3.9300	490.9722222	43.4300
10/31/06	09:30:00	52.6040	0.7060	-3.9030	490.2777778	43.5070
10/31/06	09:31:00	52.6040	0.7060	-3.9030	490.2777778	43.5070
10/31/06	09:32:00	52.6740	0.7070	-3.8670	490.9722222	43.5410
10/31/06	09:33:00	52.5700	0.7070	-3.8310	490.9722222	43.4010
10/31/06	09:34:00	52.5700	0.7070	-3.8310	490.9722222	43.4010
10/31/06	09:35:00	52.6390	0.7070	-3.8130	490.9722222	43.4520
10/31/06	09:36:00	52.6390	0.7050	-3.8130	489.5833333	43.4520
10/31/06	09:37:00	52.2570	0.7070	-3.7860	490.9722222	43.0430
10/31/06	09:38:00	52.2570	0.7070	-3.7860	490.9722222	43.0430
10/31/06	09:39:00	52.6740	0.7070	-3.7770	490.9722222	43.4510
10/31/06	09:40:00	52.6740	0.7070	-3.7770	490.9722222	43.4510
10/31/06	09:41:00	52.9860	0.7090	-3.7050	492.3611111	43.6910
10/31/06	09:42:00	52.5350	0.7090	-3.6780	492.3611111	43.2130
10/31/06	09:43:00	52.5350	0.7090	-3.6780	492.3611111	43.2130
10/31/06	09:44:00	52.5700	0.7090	-3.6600	492.3611111	43.2300
10/31/06	09:45:00	52.9170	0.7090	-3.6510	492.3611111	43.5680
10/31/06	09:46:00	52.9170	0.7090	-3.6510	492.3611111	43.5680
10/31/06	09:47:00	52.9520	0.7110	-3.5600	493.75	43.5120
10/31/06	09:48:00	52.9520	0.7110	-3.5600	493.75	43.5120
10/31/06	09:49:00	52.8470	0.7120	-3.4790	494.4444444	43.3260

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	09:50:00	52.8820	0.7130	-3.4520	495.1388889	43.3340
10/31/06	09:51:00	52.8820	0.7130	-3.4520	495.1388889	43.3340
10/31/06	09:52:00	52.7430	0.7120	-3.4520	494.4444444	43.1950
10/31/06	09:53:00	52.7430	0.7120	-3.4520	494.4444444	43.1950
10/31/06	09:54:00	52.8820	0.7120	-3.4520	494.4444444	43.3340
10/31/06	09:55:00	52.8820	0.7120	-3.4520	494.4444444	43.3340
10/31/06	09:56:00	52.8130	0.7120	-3.4520	494.4444444	43.2650
10/31/06	09:57:00	52.8130	0.7120	-3.4520	494.4444444	43.2650
10/31/06	09:58:00	52.9170	0.7130	-3.4520	495.1388889	43.3690
10/31/06	09:59:00	52.9170	0.7130	-3.4520	495.1388889	43.3690
10/31/06	10:00:00	52.8470	0.7140	-3.4520	495.8333333	43.2990
10/31/06	10:01:00	52.8470	0.7140	-3.4520	495.8333333	43.2990
10/31/06	10:02:00	52.7090	0.7130	-3.4250	495.1388889	43.1340
10/31/06	10:03:00	52.7090	0.7130	-3.4250	495.1388889	43.1340
10/31/06	10:04:00	52.8820	0.7130	-3.4070	495.1388889	43.2890
10/31/06	10:05:00	52.8820	0.7130	-3.4070	495.1388889	43.2890
10/31/06	10:06:00	52.8470	0.7150	-3.4070	496.5277778	43.2540
10/31/06	10:07:00	52.8470	0.7150	-3.4070	496.5277778	43.2540
10/31/06	10:08:00	53.0210	0.7140	-3.4070	495.8333333	43.4280
10/31/06	10:09:00	53.0210	0.7140	-3.4070	495.8333333	43.4280
10/31/06	10:10:00	52.7090	0.7130	-3.3980	495.1388889	43.1070
10/31/06	10:11:00	52.7090	0.7130	-3.3980	495.1388889	43.1070
10/31/06	10:12:00	52.8130	0.7130	-3.3980	495.1388889	43.2110
10/31/06	10:13:00	52.8820	0.7140	-3.3710	495.8333333	43.2530
10/31/06	10:14:00	52.8820	0.7140	-3.3710	495.8333333	43.2530
10/31/06	10:15:00	52.8470	0.7160	-3.3710	497.2222222	43.2180
10/31/06	10:16:00	52.8470	0.7160	-3.3710	497.2222222	43.2180
10/31/06	10:17:00	53.0210	0.7150	-3.3070	496.5277778	43.3280
10/31/06	10:18:00	53.0210	0.7150	-3.3070	496.5277778	43.3280
10/31/06	10:19:00	52.9520	0.7150	-3.2890	496.5277778	43.2410
10/31/06	10:20:00	52.9520	0.7150	-3.2890	496.5277778	43.2410
10/31/06	10:21:00	52.9860	0.7160	-3.2530	497.2222222	43.2390
10/31/06	10:22:00	52.8470	0.7160	-3.2530	497.2222222	43.1000
10/31/06	10:23:00	52.8470	0.7160	-3.2620	497.2222222	43.1090
10/31/06	10:24:00	52.8470	0.7170	-3.2530	497.9166667	43.1000
10/31/06	10:25:00	52.8470	0.7170	-3.2530	497.9166667	43.1000
10/31/06	10:26:00	52.9170	0.7180	-3.2260	498.6111111	43.1430
10/31/06	10:27:00	52.9520	0.7170	-3.2260	497.9166667	43.1780
10/31/06	10:28:00	52.9520	0.7170	-3.2260	497.9166667	43.1780
10/31/06	10:29:00	53.1950	0.7180	-3.1990	498.6111111	43.3940
10/31/06	10:30:00	53.1950	0.7180	-3.1990	498.6111111	43.3940
10/31/06	10:31:00	53.1950	0.7190	-3.1720	499.3055556	43.3670
10/31/06	10:32:00	53.1250	0.7180	-3.1720	498.6111111	43.2970
10/31/06	10:33:00	53.1250	0.7180	-3.1720	498.6111111	43.2970
10/31/06	10:34:00	53.0560	0.7180	-3.1720	498.6111111	43.2280
10/31/06	10:35:00	53.0560	0.7180	-3.1720	498.6111111	43.2280
10/31/06	10:36:00	53.0560	0.7180	-3.1720	498.6111111	43.2280
10/31/06	10:37:00	52.9520	0.7170	-3.1540	497.9166667	43.1060
10/31/06	10:38:00	52.9520	0.7170	-3.1540	497.9166667	43.1060
10/31/06	10:39:00	53.1950	0.7170	-3.1540	497.9166667	43.3490
10/31/06	10:40:00	53.1950	0.7170	-3.1540	497.9166667	43.3490
10/31/06	10:41:00	53.0210	0.7180	-3.1540	498.6111111	43.1750
10/31/06	10:42:00	52.9520	0.7190	-3.1540	499.3055556	43.1060
10/31/06	10:43:00	52.9520	0.7190	-3.1540	499.3055556	43.1060
10/31/06	10:44:00	52.8470	0.7180	-3.1540	498.6111111	43.0010
10/31/06	10:45:00	52.8470	0.7180	-3.1540	498.6111111	43.0010
10/31/06	10:46:00	52.8470	0.7200	-3.1450	500	42.9920
10/31/06	10:47:00	53.1600	0.7200	-3.1450	500	43.3050
10/31/06	10:48:00	53.1600	0.7200	-3.1450	500	43.3050
10/31/06	10:49:00	53.1600	0.7210	-3.1450	500.6944444	43.3050
10/31/06	10:50:00	53.1600	0.7210	-3.1450	500.6944444	43.3050
10/31/06	10:51:00	53.1950	0.7210	-3.1450	500.6944444	43.3400
10/31/06	10:52:00	53.1950	0.7210	-3.1450	500.6944444	43.3400
10/31/06	10:53:00	53.1950	0.7200	-3.1450	500	43.3400
10/31/06	10:54:00	53.2290	0.7220	-3.1450	501.3888889	43.3740
10/31/06	10:55:00	53.2290	0.7220	-3.1450	501.3888889	43.3740
10/31/06	10:56:00	53.1600	0.7220	-3.1450	501.3888889	43.3050
10/31/06	10:57:00	53.1600	0.7220	-3.1450	501.3888889	43.3050
10/31/06	10:58:00	53.2290	0.7220	-3.1450	501.3888889	43.3740
10/31/06	10:59:00	52.9860	0.7220	-3.1450	501.3888889	43.1310
10/31/06	11:00:00	52.9860	0.7210	-3.1450	500.6944444	43.1310
10/31/06	11:01:00	53.1250	0.7220	-3.1450	501.3888889	43.2700
10/31/06	11:02:00	53.1250	0.7220	-3.1450	501.3888889	43.2700
10/31/06	11:03:00	53.0560	0.7220	-3.1450	501.3888889	43.2010

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	11:04:00	53.0560	0.7220	-3.1450	501.3888889	43.2010
10/31/06	11:05:00	53.1250	0.7220	-3.1450	501.3888889	43.2700
10/31/06	11:06:00	53.1250	0.7220	-3.1450	501.3888889	43.2700
10/31/06	11:07:00	53.0210	0.7220	-3.1360	501.3888889	43.1570
10/31/06	11:08:00	52.9170	0.7210	-3.1360	500.6944444	43.0530
10/31/06	11:09:00	52.9170	0.7210	-3.1360	500.6944444	43.0530
10/31/06	11:10:00	52.8820	0.7210	-3.1360	500.6944444	43.0180
10/31/06	11:11:00	52.8820	0.7210	-3.1360	500.6944444	43.0180
10/31/06	11:12:00	52.9170	0.7220	-3.1360	501.3888889	43.0530
10/31/06	11:13:00	52.9170	0.7230	-3.1360	502.0833333	43.0530
10/31/06	11:14:00	52.9170	0.7230	-3.1360	502.0833333	43.0530
10/31/06	11:15:00	52.8470	0.7220	-3.1360	501.3888889	42.9830
10/31/06	11:16:00	52.8470	0.7220	-3.1360	501.3888889	42.9830
10/31/06	11:17:00	52.9170	0.7240	-3.1360	502.7777778	43.0530
10/31/06	11:18:00	52.7430	0.7250	-3.1360	503.4722222	42.8790
10/31/06	11:19:00	52.7430	0.7250	-3.1360	503.4722222	42.8790
10/31/06	11:20:00	52.6040	0.7250	-3.1360	503.4722222	42.7400
10/31/06	11:21:00	52.6040	0.7250	-3.1360	503.4722222	42.7400
10/31/06	11:22:00	52.8470	0.7250	-3.1360	503.4722222	42.9830
10/31/06	11:23:00	52.8470	0.7250	-3.1360	503.4722222	42.9830
10/31/06	11:24:00	52.7090	0.7250	-3.1180	503.4722222	42.8270
10/31/06	11:25:00	52.8130	0.7260	-3.1180	504.1666667	42.9310
10/31/06	11:26:00	52.8130	0.7260	-3.1180	504.1666667	42.9310
10/31/06	11:27:00	53.0560	0.7250	-3.1180	503.4722222	43.1740
10/31/06	11:28:00	53.0560	0.7250	-3.1180	503.4722222	43.1740
10/31/06	11:29:00	52.9170	0.7280	-3.1180	505.5555556	43.0350
10/31/06	11:30:00	52.9170	0.7260	-3.1270	504.1666667	43.0440
10/31/06	11:31:00	52.9170	0.7260	-3.1270	504.1666667	43.0440
10/31/06	11:32:00	52.9520	0.7260	-3.1180	504.1666667	43.0700
10/31/06	11:33:00	52.8470	0.7270	-3.1180	504.8611111	42.9650
10/31/06	11:34:00	52.8470	0.7270	-3.1180	504.8611111	42.9650
10/31/06	11:35:00	52.7090	0.7280	-3.1180	505.5555556	42.8270
10/31/06	11:36:00	52.7090	0.7280	-3.1180	505.5555556	42.8270
10/31/06	11:37:00	52.8820	0.7280	-3.1180	505.5555556	43.0000
10/31/06	11:38:00	52.8820	0.7280	-3.1180	505.5555556	43.0000
10/31/06	11:39:00	52.8470	0.7270	-3.1180	504.8611111	42.9650
10/31/06	11:40:00	52.8470	0.7270	-3.1180	504.8611111	42.9650
10/31/06	11:41:00	52.9170	0.7270	-3.1180	504.8611111	43.0350
10/31/06	11:42:00	52.9860	0.7280	-3.1180	505.5555556	43.1040
10/31/06	11:43:00	52.9860	0.7280	-3.1180	505.5555556	43.1040
10/31/06	11:44:00	52.8130	0.7280	-3.1180	505.5555556	42.9310
10/31/06	11:45:00	53.0910	0.7280	-3.1180	505.5555556	43.2090
10/31/06	11:46:00	53.0910	0.7280	-3.1180	505.5555556	43.2090
10/31/06	11:47:00	53.0210	0.7270	-3.1180	504.8611111	43.1390
10/31/06	11:48:00	52.9860	0.7280	-3.1180	505.5555556	43.1040
10/31/06	11:49:00	52.9860	0.7280	-3.1180	505.5555556	43.1040
10/31/06	11:50:00	52.9170	0.7290	-3.1180	506.25	43.0350
10/31/06	11:51:00	52.9170	0.7290	-3.1180	506.25	43.0350
10/31/06	11:52:00	53.0210	0.7300	-3.1180	506.9444444	43.1390
10/31/06	11:53:00	53.0210	0.7300	-3.1180	506.9444444	43.1390
10/31/06	11:54:00	52.9860	0.7320	-3.1180	508.3333333	43.1040
10/31/06	11:55:00	52.8130	0.7300	-3.1180	506.9444444	42.9310
10/31/06	11:56:00	52.8130	0.7300	-3.1180	506.9444444	42.9310
10/31/06	11:57:00	52.8470	0.7300	-3.1180	506.9444444	42.9650
10/31/06	11:58:00	52.8470	0.7300	-3.1180	506.9444444	42.9650
10/31/06	11:59:00	52.9860	0.7300	-3.1180	506.9444444	43.1040
10/31/06	12:00:00	52.9860	0.7300	-3.1180	506.9444444	43.1040
10/31/06	12:01:00	52.9860	0.7310	-3.1180	507.6388889	43.1040
10/31/06	12:02:00	52.9860	0.7310	-3.1180	507.6388889	43.1040
10/31/06	12:03:00	53.0910	0.7300	-3.1180	506.9444444	43.2090
10/31/06	12:04:00	53.0910	0.7300	-3.1180	506.9444444	43.2090
10/31/06	12:05:00	52.8470	0.7310	-3.1180	507.6388889	42.9650
10/31/06	12:06:00	52.8470	0.7310	-3.1180	507.6388889	42.9650
10/31/06	12:07:00	53.1250	0.7320	-3.1180	508.3333333	43.2430
10/31/06	12:08:00	53.1250	0.7330	-3.1180	509.0277778	43.2430
10/31/06	12:09:00	53.1250	0.7330	-3.1180	509.0277778	43.2430
10/31/06	12:10:00	52.9520	0.7310	-3.1180	507.6388889	43.0700
10/31/06	12:11:00	52.8820	0.7320	-3.1180	508.3333333	43.0000
10/31/06	12:12:00	52.8820	0.7320	-3.1180	508.3333333	43.0000
10/31/06	12:13:00	52.7780	0.7330	-3.1180	509.0277778	42.8960
10/31/06	12:14:00	53.0560	0.7340	-3.1180	509.7222222	43.1740
10/31/06	12:15:00	53.0560	0.7340	-3.1180	509.7222222	43.1740
10/31/06	12:16:00	53.0560	0.7320	-3.1180	508.3333333	43.1740
10/31/06	12:17:00	53.0560	0.7320	-3.1180	508.3333333	43.1740

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	12:18:00	53.0210	0.7320	-3.1180	508.3333333	43.1390
10/31/06	12:19:00	53.0210	0.7320	-3.1180	508.3333333	43.1390
10/31/06	12:20:00	52.8820	0.7320	-3.1180	508.3333333	43.0000
10/31/06	12:21:00	52.8820	0.7320	-3.1180	508.3333333	43.0000
10/31/06	12:22:00	52.9170	0.7320	-3.1180	508.3333333	43.0350
10/31/06	12:23:00	52.9170	0.7320	-3.1180	508.3333333	43.0350
10/31/06	12:24:00	52.9520	0.7310	-3.1180	507.6388889	43.0700
10/31/06	12:25:00	52.5000	0.7320	-3.1180	508.3333333	42.6180
10/31/06	12:26:00	52.5000	0.7320	-3.1180	508.3333333	42.6180
10/31/06	12:27:00	52.6740	0.7340	-3.1180	509.7222222	42.7920
10/31/06	12:28:00	52.6740	0.7340	-3.1180	509.7222222	42.7920
10/31/06	12:29:00	52.8820	0.7340	-3.1180	509.7222222	43.0000
10/31/06	12:30:00	52.8130	0.7340	-3.1180	509.7222222	42.9310
10/31/06	12:31:00	52.8130	0.7340	-3.1180	509.7222222	42.9310
10/31/06	12:32:00	52.6040	0.7340	-3.1180	509.7222222	42.7220
10/31/06	12:33:00	52.8130	0.7340	-3.1270	509.7222222	42.9400
10/31/06	12:34:00	52.8130	0.7340	-3.1270	509.7222222	42.9400
10/31/06	12:35:00	52.7090	0.7350	-3.1360	510.4166667	42.8450
10/31/06	12:36:00	52.7090	0.7350	-3.1360	510.4166667	42.8450
10/31/06	12:37:00	52.7430	0.7350	-3.1450	510.4166667	42.8880
10/31/06	12:38:00	52.7430	0.7350	-3.1450	510.4166667	42.8880
10/31/06	12:39:00	52.6740	0.7330	-3.1450	509.0277778	42.8190
10/31/06	12:40:00	52.8820	0.7360	-3.1450	511.1111111	43.0270
10/31/06	12:41:00	52.8820	0.7360	-3.1450	511.1111111	43.0270
10/31/06	12:42:00	52.4660	0.7350	-3.1450	510.4166667	42.6110
10/31/06	12:43:00	52.4660	0.7350	-3.1450	510.4166667	42.6110
10/31/06	12:44:00	52.4660	0.7340	-3.1450	509.7222222	42.6110
10/31/06	12:45:00	52.7430	0.7360	-3.1450	511.1111111	42.8880
10/31/06	12:46:00	52.9860	0.7360	-3.1450	511.1111111	43.1310
10/31/06	12:47:00	52.9860	0.7360	-3.1450	511.1111111	43.1310
10/31/06	12:48:00	53.0210	0.7370	-3.1450	511.8055556	43.1660
10/31/06	12:49:00	53.0210	0.7370	-3.1450	511.8055556	43.1660
10/31/06	12:50:00	52.5700	0.7350	-3.1450	510.4166667	42.7150
10/31/06	12:51:00	52.5700	0.7350	-3.1450	510.4166667	42.7150
10/31/06	12:52:00	52.6040	0.7340	-3.1450	509.7222222	42.7490
10/31/06	12:53:00	52.6040	0.7370	-3.1450	511.8055556	42.7490
10/31/06	12:54:00	52.6040	0.7370	-3.1450	511.8055556	42.7490
10/31/06	12:55:00	52.7780	0.7360	-3.1450	511.1111111	42.9230
10/31/06	12:56:00	52.7780	0.7360	-3.1450	511.1111111	42.9230
10/31/06	12:57:00	52.5000	0.7370	-3.1450	511.8055556	42.6450
10/31/06	12:58:00	52.5350	0.7380	-3.1450	512.5	42.6800
10/31/06	12:59:00	52.5350	0.7380	-3.1450	512.5	42.6800
10/31/06	13:00:00	52.7780	0.7370	-3.1450	511.8055556	42.9230
10/31/06	13:01:00	52.6740	0.7380	-3.1450	512.5	42.8190
10/31/06	13:02:00	52.6740	0.7380	-3.1450	512.5	42.8190
10/31/06	13:03:00	52.5700	0.7360	-3.1450	511.1111111	42.7150
10/31/06	13:04:00	52.5700	0.7360	-3.1450	511.1111111	42.7150
10/31/06	13:05:00	52.6040	0.7380	-3.1450	512.5	42.7490
10/31/06	13:06:00	52.6040	0.7380	-3.1450	512.5	42.7490
10/31/06	13:07:00	52.7090	0.7370	-3.1450	511.8055556	42.8540
10/31/06	13:08:00	52.7090	0.7370	-3.1450	511.8055556	42.8540
10/31/06	13:09:00	52.6740	0.7390	-3.1450	513.1944444	42.8190
10/31/06	13:10:00	52.7780	0.7400	-3.1450	513.8888889	42.9230
10/31/06	13:11:00	52.7780	0.7400	-3.1450	513.8888889	42.9230
10/31/06	13:12:00	52.5350	0.7380	-3.1450	512.5	42.6800
10/31/06	13:13:00	52.7090	0.7390	-3.1450	513.1944444	42.8540
10/31/06	13:14:00	52.7090	0.7390	-3.1450	513.1944444	42.8540
10/31/06	13:15:00	52.5350	0.7380	-3.1450	512.5	42.6800
10/31/06	13:16:00	52.5350	0.7380	-3.1450	512.5	42.6800
10/31/06	13:17:00	52.6740	0.7400	-3.1450	513.8888889	42.8190
10/31/06	13:18:00	52.7430	0.7400	-3.1450	513.8888889	42.8880
10/31/06	13:19:00	52.7430	0.7400	-3.1450	513.8888889	42.8880
10/31/06	13:20:00	52.9170	0.7410	-3.0640	514.5833333	42.9810
10/31/06	13:21:00	52.9170	0.7410	-3.0640	514.5833333	42.9810
10/31/06	13:22:00	52.7780	0.7420	-2.9730	515.2777778	42.7510
10/31/06	13:23:00	52.7780	0.7420	-2.9730	515.2777778	42.7510
10/31/06	13:24:00	52.9170	0.7420	-2.9190	515.2777778	42.8360
10/31/06	13:25:00	53.2990	0.7440	-2.9190	516.6666667	43.2180
10/31/06	13:26:00	53.2990	0.7440	-2.9190	516.6666667	43.2180
10/31/06	13:27:00	53.2640	0.7430	-2.8740	515.9722222	43.1380
10/31/06	13:28:00	53.2640	0.7430	-2.8740	515.9722222	43.1380
10/31/06	13:29:00	53.2290	0.7450	-2.8380	517.3611111	43.0670
10/31/06	13:30:00	53.0910	0.7440	-2.8380	516.6666667	42.9290
10/31/06	13:31:00	53.0910	0.7440	-2.8380	516.6666667	42.9290

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	13:32:00	53.0210	0.7430	-2.8290	515.9722222	42.8500
10/31/06	13:33:00	53.1600	0.7440	-2.8200	516.6666667	42.9800
10/31/06	13:34:00	53.1600	0.7440	-2.8200	516.6666667	42.9800
10/31/06	13:35:00	52.9860	0.7450	-2.7840	517.3611111	42.7700
10/31/06	13:36:00	52.9860	0.7450	-2.7840	517.3611111	42.7700
10/31/06	13:37:00	53.1950	0.7450	-2.7840	517.3611111	42.9790
10/31/06	13:38:00	53.1950	0.7450	-2.7840	517.3611111	42.9790
10/31/06	13:39:00	53.1950	0.7440	-2.7840	516.6666667	42.9790
10/31/06	13:40:00	52.9860	0.7460	-2.7840	518.0555556	42.7700
10/31/06	13:41:00	52.9860	0.7460	-2.7840	518.0555556	42.7700
10/31/06	13:42:00	53.0910	0.7470	-2.7840	518.75	42.8750
10/31/06	13:43:00	53.0910	0.7470	-2.7840	518.75	42.8750
10/31/06	13:44:00	52.9170	0.7470	-2.7840	518.75	42.7010
10/31/06	13:45:00	53.2290	0.7450	-2.7840	517.3611111	43.0130
10/31/06	13:46:00	53.0210	0.7450	-2.7840	517.3611111	42.8050
10/31/06	13:47:00	53.0210	0.7450	-2.7840	517.3611111	42.8050
10/31/06	13:48:00	52.8130	0.7460	-2.7840	518.0555556	42.5970
10/31/06	13:49:00	52.8130	0.7460	-2.7840	518.0555556	42.5970
10/31/06	13:50:00	53.0210	0.7450	-2.7840	517.3611111	42.8050
10/31/06	13:51:00	53.0210	0.7450	-2.7840	517.3611111	42.8050
10/31/06	13:52:00	52.9860	0.7500	-2.7840	520.8333333	42.7700
10/31/06	13:53:00	52.9860	0.7500	-2.7840	520.8333333	42.7700
10/31/06	13:54:00	53.0210	0.7460	-2.7840	518.0555556	42.8050
10/31/06	13:55:00	53.0210	0.7490	-2.7840	520.1388889	42.8050
10/31/06	13:56:00	53.0210	0.7490	-2.7840	520.1388889	42.8050
10/31/06	13:57:00	53.0910	0.7480	-2.7840	519.4444444	42.8750
10/31/06	13:58:00	53.0910	0.7480	-2.7840	519.4444444	42.8750
10/31/06	13:59:00	53.1600	0.7480	-2.7480	519.4444444	42.9080
10/31/06	14:00:00	53.0210	0.7500	-2.6940	520.8333333	42.7150
10/31/06	14:01:00	53.0210	0.7500	-2.6940	520.8333333	42.7150
10/31/06	14:02:00	53.3340	0.7530	-2.6120	522.9166667	42.9460
10/31/06	14:03:00	53.3340	0.7530	-2.6120	522.9166667	42.9460
10/31/06	14:04:00	53.4380	0.7510	-2.5310	521.5277778	42.9690
10/31/06	14:05:00	53.4380	0.7510	-2.5310	521.5277778	42.9690
10/31/06	14:06:00	53.5770	0.7520	-2.4770	522.2222222	43.0540
10/31/06	14:07:00	53.4720	0.7530	-2.4230	522.9166667	42.8950
10/31/06	14:08:00	53.4720	0.7530	-2.4230	522.9166667	42.8950
10/31/06	14:09:00	53.7850	0.7530	-2.3870	522.9166667	43.1720
10/31/06	14:10:00	53.7850	0.7530	-2.3870	522.9166667	43.1720
10/31/06	14:11:00	53.7850	0.7540	-2.3600	523.6111111	43.1450
10/31/06	14:12:00	53.6460	0.7550	-2.3600	524.3055556	43.0060
10/31/06	14:13:00	53.6460	0.7550	-2.3600	524.3055556	43.0060
10/31/06	14:14:00	53.8540	0.7550	-2.3320	524.3055556	43.1860
10/31/06	14:15:00	53.8540	0.7560	-2.3140	525	43.1680
10/31/06	14:16:00	53.8540	0.7560	-2.3140	525	43.1680
10/31/06	14:17:00	53.7160	0.7540	-2.3050	523.6111111	43.0210
10/31/06	14:18:00	53.7160	0.7540	-2.3050	523.6111111	43.0210
10/31/06	14:19:00	53.8540	0.7550	-2.2960	524.3055556	43.1500
10/31/06	14:20:00	53.8540	0.7550	-2.2960	524.3055556	43.1500
10/31/06	14:21:00	53.7160	0.7550	-2.2780	524.3055556	42.9940
10/31/06	14:22:00	53.7160	0.7550	-2.2780	524.3055556	42.9940
10/31/06	14:23:00	53.7500	0.7550	-2.2780	524.3055556	43.0280
10/31/06	14:24:00	53.7160	0.7560	-2.2690	525	42.9850
10/31/06	14:25:00	53.7160	0.7560	-2.2690	525	42.9850
10/31/06	14:26:00	53.6110	0.7570	-2.2600	525.6944444	42.8710
10/31/06	14:27:00	53.6110	0.7570	-2.2600	525.6944444	42.8710
10/31/06	14:28:00	53.6110	0.7570	-2.2510	525.6944444	42.8620
10/31/06	14:29:00	53.7500	0.7580	-2.2510	526.3888889	43.0010
10/31/06	14:30:00	53.7500	0.7580	-2.2510	526.3888889	43.0010
10/31/06	14:31:00	53.8540	0.7580	-2.2510	526.3888889	43.1050
10/31/06	14:32:00	53.8540	0.7580	-2.2510	526.3888889	43.1050
10/31/06	14:33:00	53.7500	0.7570	-2.2420	525.6944444	42.9920
10/31/06	14:34:00	53.7500	0.7580	-2.2330	526.3888889	42.9830
10/31/06	14:35:00	53.7500	0.7580	-2.2330	526.3888889	42.9830
10/31/06	14:36:00	53.6810	0.7590	-2.2330	527.0833333	42.9140
10/31/06	14:37:00	53.6810	0.7590	-2.2330	527.0833333	42.9140
10/31/06	14:38:00	53.7850	0.7590	-2.2240	527.0833333	43.0090
10/31/06	14:39:00	53.7850	0.7590	-2.2240	527.0833333	43.0090
10/31/06	14:40:00	53.6460	0.7590	-2.2240	527.0833333	42.8700
10/31/06	14:41:00	53.7850	0.7590	-2.2240	527.0833333	43.0090
10/31/06	14:42:00	53.7850	0.7590	-2.2240	527.0833333	43.0090
10/31/06	14:43:00	53.8200	0.7590	-2.2240	527.0833333	43.0440
10/31/06	14:44:00	53.8200	0.7590	-2.2240	527.0833333	43.0440
10/31/06	14:45:00	53.6110	0.7590	-2.2150	527.0833333	42.8260

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	14:46:00	53.8200	0.7590	-2.2240	527.0833333	43.0440
10/31/06	14:47:00	53.6810	0.7590	-2.2240	527.0833333	42.9050
10/31/06	14:48:00	53.6810	0.7590	-2.2240	527.0833333	42.9050
10/31/06	14:49:00	53.7160	0.7590	-2.2240	527.0833333	42.9400
10/31/06	14:50:00	53.7160	0.7590	-2.2240	527.0833333	42.9400
10/31/06	14:51:00	53.6810	0.7590	-2.2240	527.0833333	42.9050
10/31/06	14:52:00	53.6810	0.7590	-2.2240	527.0833333	42.9050
10/31/06	14:53:00	53.4720	0.7590	-2.2240	527.0833333	42.6960
10/31/06	14:54:00	53.4720	0.7590	-2.2240	527.0833333	42.6960
10/31/06	14:55:00	53.7500	0.7610	-2.2240	528.4722222	42.9740
10/31/06	14:56:00	53.7500	0.7610	-2.2240	528.4722222	42.9740
10/31/06	14:57:00	53.7850	0.7610	-2.2240	528.4722222	43.0090
10/31/06	14:58:00	53.5420	0.7590	-2.2240	527.0833333	42.7660
10/31/06	14:59:00	53.5420	0.7590	-2.2240	527.0833333	42.7660
10/31/06	15:00:00	53.7500	0.7610	-2.2240	528.4722222	42.9740
10/31/06	15:01:00	53.4720	0.7610	-2.2240	528.4722222	42.6960
10/31/06	15:02:00	53.4720	0.7610	-2.2240	528.4722222	42.6960
10/31/06	15:03:00	53.4380	0.7610	-2.2240	528.4722222	42.6620
10/31/06	15:04:00	53.4380	0.7610	-2.2240	528.4722222	42.6620
10/31/06	15:05:00	53.6110	0.7610	-2.2150	528.4722222	42.8260
10/31/06	15:06:00	53.6110	0.7610	-2.2150	528.4722222	42.8260
10/31/06	15:07:00	53.5420	0.7610	-2.2240	528.4722222	42.7660
10/31/06	15:08:00	53.5420	0.7610	-2.2240	528.4722222	42.7660
10/31/06	15:09:00	53.5420	0.7620	-2.2240	529.1666667	42.7660
10/31/06	15:10:00	53.4720	0.7620	-2.2240	529.1666667	42.6960
10/31/06	15:11:00	53.4720	0.7620	-2.2240	529.1666667	42.6960
10/31/06	15:12:00	53.2640	0.7620	-2.2240	529.1666667	42.4880
10/31/06	15:13:00	53.5420	0.7610	-2.2240	528.4722222	42.7660
10/31/06	15:14:00	53.5420	0.7610	-2.2240	528.4722222	42.7660
10/31/06	15:15:00	53.5070	0.7620	-2.2240	529.1666667	42.7310
10/31/06	15:16:00	53.6810	0.7600	-2.2240	527.7777778	42.9050
10/31/06	15:17:00	53.6810	0.7600	-2.2240	527.7777778	42.9050
10/31/06	15:18:00	53.5420	0.7630	-2.2240	529.8611111	42.7660
10/31/06	15:19:00	53.5420	0.7630	-2.2240	529.8611111	42.7660
10/31/06	15:20:00	53.4030	0.7630	-2.2240	529.8611111	42.6270
10/31/06	15:21:00	53.4030	0.7630	-2.2240	529.8611111	42.6270
10/31/06	15:22:00	53.4030	0.7610	-2.2240	528.4722222	42.6270
10/31/06	15:23:00	53.4030	0.7610	-2.2240	528.4722222	42.6270
10/31/06	15:24:00	53.5420	0.7640	-2.2240	530.5555556	42.7660
10/31/06	15:25:00	53.5420	0.7640	-2.2240	530.5555556	42.7660
10/31/06	15:26:00	53.6110	0.7640	-2.2150	530.5555556	42.8260
10/31/06	15:27:00	53.4030	0.7630	-2.2150	529.8611111	42.6180
10/31/06	15:28:00	53.4030	0.7630	-2.2150	529.8611111	42.6180
10/31/06	15:29:00	53.3680	0.7630	-2.2150	529.8611111	42.5830
10/31/06	15:30:00	53.4030	0.7640	-2.2150	530.5555556	42.6180
10/31/06	15:31:00	53.4030	0.7640	-2.2150	530.5555556	42.6180
10/31/06	15:32:00	53.4380	0.7630	-2.2150	529.8611111	42.6530
10/31/06	15:33:00	53.4030	0.7630	-2.2150	529.8611111	42.6180
10/31/06	15:34:00	53.4030	0.7630	-2.2150	529.8611111	42.6180
10/31/06	15:35:00	53.4380	0.7610	-2.2150	528.4722222	42.6530
10/31/06	15:36:00	53.4380	0.7610	-2.2150	528.4722222	42.6530
10/31/06	15:37:00	53.1950	0.7620	-2.2150	529.1666667	42.4100
10/31/06	15:38:00	53.1950	0.7620	-2.2150	529.1666667	42.4100
10/31/06	15:39:00	53.4380	0.7610	-2.2150	528.4722222	42.6530
10/31/06	15:40:00	53.4720	0.7610	-2.2150	528.4722222	42.6870
10/31/06	15:41:00	53.3340	0.7620	-2.2150	529.1666667	42.5490
10/31/06	15:42:00	53.3340	0.7620	-2.2150	529.1666667	42.5490
10/31/06	15:43:00	53.3340	0.7620	-2.2150	529.1666667	42.5490
10/31/06	15:44:00	53.4030	0.7640	-2.2150	530.5555556	42.6180
10/31/06	15:45:00	53.4030	0.7620	-2.2150	529.1666667	42.6180
10/31/06	15:46:00	53.4030	0.7620	-2.2150	529.1666667	42.6180
10/31/06	15:47:00	53.3340	0.7630	-2.2060	529.8611111	42.5400
10/31/06	15:48:00	53.3340	0.7630	-2.2060	529.8611111	42.5400
10/31/06	15:49:00	53.3680	0.7630	-2.1970	529.8611111	42.5650
10/31/06	15:50:00	53.4720	0.7650	-2.1970	531.25	42.6690
10/31/06	15:51:00	53.4720	0.7650	-2.1970	531.25	42.6690
10/31/06	15:52:00	53.4720	0.7650	-2.1970	531.25	42.6690
10/31/06	15:53:00	53.2290	0.7630	-2.1970	529.8611111	42.4260
10/31/06	15:54:00	53.2290	0.7630	-2.1970	529.8611111	42.4260
10/31/06	15:55:00	53.5070	0.7640	-2.1970	530.5555556	42.7040
10/31/06	15:56:00	53.4720	0.7640	-2.1970	530.5555556	42.6690
10/31/06	15:57:00	53.4720	0.7640	-2.1970	530.5555556	42.6690
10/31/06	15:58:00	53.5070	0.7640	-2.1970	530.5555556	42.7040
10/31/06	15:59:00	53.5070	0.7640	-2.1970	530.5555556	42.7040

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	16:00:00	53.3340	0.7640	-2.1970	530.5555556	42.5310
10/31/06	16:01:00	53.4720	0.7650	-2.1970	531.25	42.6690
10/31/06	16:02:00	53.4720	0.7650	-2.1970	531.25	42.6690
10/31/06	16:03:00	53.2290	0.7640	-2.1970	530.5555556	42.4260
10/31/06	16:04:00	53.2290	0.7640	-2.1970	530.5555556	42.4260
10/31/06	16:05:00	53.3680	0.7650	-2.1970	531.25	42.5650
10/31/06	16:06:00	53.3680	0.7650	-2.1970	531.25	42.5650
10/31/06	16:07:00	53.3680	0.7640	-2.1880	530.5555556	42.5560
10/31/06	16:08:00	53.3680	0.7640	-2.1880	530.5555556	42.5560
10/31/06	16:09:00	53.4380	0.7650	-2.1700	531.25	42.6080
10/31/06	16:10:00	53.5070	0.7660	-2.1610	531.9444444	42.6680
10/31/06	16:11:00	37.2220	0.5630	-12.9580	390.9722222	37.1800
10/31/06	16:12:00	53.5070	0.7660	-2.1610	531.9444444	42.6680
10/31/06	16:13:00	53.5070	0.7660	-2.1610	531.9444444	42.6680
10/31/06	16:14:00	53.4380	0.7650	-2.1520	531.25	42.5900
10/31/06	16:15:00	53.4380	0.7650	-2.1520	531.25	42.5900
10/31/06	16:16:00	53.4380	0.7650	-2.1520	531.25	42.5900
10/31/06	16:17:00	53.4380	0.7650	-2.1520	531.25	42.5900
10/31/06	16:18:00	53.5770	0.7650	-2.1610	531.25	42.7380
10/31/06	16:19:00	53.5770	0.7650	-2.1610	531.25	42.7380
10/31/06	16:20:00	53.2990	0.7650	-2.1610	531.25	42.4600
10/31/06	16:21:00	53.2990	0.7650	-2.1610	531.25	42.4600
10/31/06	16:22:00	53.4030	0.7650	-2.1610	531.25	42.5640
10/31/06	16:23:00	53.1950	0.7650	-2.1610	531.25	42.3560
10/31/06	16:24:00	53.1950	0.7650	-2.1610	531.25	42.3560
10/31/06	16:25:00	53.4030	0.7650	-2.1610	531.25	42.5640
10/31/06	16:26:00	53.4030	0.7650	-2.1610	531.25	42.5640
10/31/06	16:27:00	53.2640	0.7660	-2.1610	531.9444444	42.4250
10/31/06	16:28:00	53.1600	0.7660	-2.1610	531.9444444	42.3210
10/31/06	16:29:00	53.1600	0.7660	-2.1610	531.9444444	42.3210
10/31/06	16:30:00	53.2290	0.7660	-2.1610	531.9444444	42.3900
10/31/06	16:31:00	53.2290	0.7660	-2.1610	531.9444444	42.3900
10/31/06	16:32:00	53.2990	0.7650	-2.1610	531.25	42.4600
10/31/06	16:33:00	53.2640	0.7660	-2.1610	531.9444444	42.4250
10/31/06	16:34:00	53.2640	0.7660	-2.1610	531.9444444	42.4250
10/31/06	16:35:00	53.5070	0.7660	-2.1610	531.9444444	42.6680
10/31/06	16:36:00	53.5070	0.7660	-2.1610	531.9444444	42.6680
10/31/06	16:37:00	53.2290	0.7660	-2.1610	531.9444444	42.3900
10/31/06	16:38:00	53.2290	0.7660	-2.1610	531.9444444	42.3900
10/31/06	16:39:00	53.2290	0.7660	-2.1700	531.9444444	42.3990
10/31/06	16:40:00	53.0560	0.7650	-2.1700	531.25	42.2260
10/31/06	16:41:00	53.0560	0.7650	-2.1700	531.25	42.2260
10/31/06	16:42:00	53.0560	0.7670	-2.1610	532.6388889	42.2170
10/31/06	16:43:00	53.0560	0.7670	-2.1610	532.6388889	42.2170
10/31/06	16:44:00	53.1950	0.7660	-2.1700	531.9444444	42.3650
10/31/06	16:45:00	53.2290	0.7680	-2.1700	533.3333333	42.3990
10/31/06	16:46:00	53.2290	0.7680	-2.1700	533.3333333	42.3990
10/31/06	16:47:00	53.1600	0.7680	-2.1610	533.3333333	42.3210
10/31/06	16:48:00	53.1600	0.7680	-2.1610	533.3333333	42.3210
10/31/06	16:49:00	53.1950	0.7670	-2.1610	532.6388889	42.3560
10/31/06	16:50:00	53.0910	0.7670	-2.1610	532.6388889	42.2520
10/31/06	16:51:00	53.0910	0.7670	-2.1610	532.6388889	42.2520
10/31/06	16:52:00	53.0210	0.7670	-2.1700	532.6388889	42.1910
10/31/06	16:53:00	53.0210	0.7670	-2.1700	532.6388889	42.1910
10/31/06	16:54:00	53.0210	0.7670	-2.1700	532.6388889	42.1910
10/31/06	16:55:00	53.0210	0.7670	-2.1700	532.6388889	42.1910
10/31/06	16:56:00	52.9860	0.7680	-2.1700	533.3333333	42.1560
10/31/06	16:57:00	53.0560	0.7680	-2.1700	533.3333333	42.2260
10/31/06	16:58:00	53.0560	0.7680	-2.1700	533.3333333	42.2260
10/31/06	16:59:00	53.1950	0.7680	-2.1700	533.3333333	42.3650
10/31/06	17:00:00	53.1950	0.7680	-2.1700	533.3333333	42.3650
10/31/06	17:01:00	53.2640	0.7680	-2.1700	533.3333333	42.4340
10/31/06	17:02:00	53.2640	0.7690	-2.1700	534.0277778	42.4340
10/31/06	17:03:00	53.2640	0.7690	-2.1700	534.0277778	42.4340
10/31/06	17:04:00	53.0210	0.7680	-2.1700	533.3333333	42.1910
10/31/06	17:05:00	53.0210	0.7680	-2.1700	533.3333333	42.1910
10/31/06	17:06:00	52.9860	0.7680	-2.1700	533.3333333	42.1560
10/31/06	17:07:00	52.9860	0.7680	-2.1700	533.3333333	42.1560
10/31/06	17:08:00	53.0560	0.7680	-2.1700	533.3333333	42.2260
10/31/06	17:09:00	53.0560	0.7680	-2.1700	533.3333333	42.2260
10/31/06	17:10:00	52.8820	0.7680	-2.1700	533.3333333	42.0520
10/31/06	17:11:00	52.7430	0.7670	-2.1700	532.6388889	41.9130
10/31/06	17:12:00	52.7430	0.7670	-2.1700	532.6388889	41.9130
10/31/06	17:13:00	52.7780	0.7680	-2.1700	533.3333333	41.9480



**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	17:14:00	52.7780	0.7680	-2.1700	533.3333333	41.9480
10/31/06	17:15:00	53.1250	0.7690	-2.1700	534.0277778	42.2950
10/31/06	17:16:00	52.9860	0.7680	-2.1700	533.3333333	42.1560
10/31/06	17:17:00	52.9860	0.7680	-2.1700	533.3333333	42.1560
10/31/06	17:18:00	52.8470	0.7680	-2.1700	533.3333333	42.0170
10/31/06	17:19:00	52.8470	0.7680	-2.1700	533.3333333	42.0170
10/31/06	17:20:00	52.8470	0.7670	-2.1700	532.6388889	42.0170
10/31/06	17:21:00	52.8470	0.7670	-2.1700	532.6388889	42.0170
10/31/06	17:22:00	52.8130	0.7700	-2.1700	534.7222222	41.9830
10/31/06	17:23:00	52.8130	0.7700	-2.1700	534.7222222	41.9830
10/31/06	17:24:00	52.7780	0.7670	-2.1700	532.6388889	41.9480
10/31/06	17:25:00	52.8130	0.7690	-2.1700	534.0277778	41.9830
10/31/06	17:26:00	52.8130	0.7690	-2.1700	534.0277778	41.9830
10/31/06	17:27:00	52.8130	0.7690	-2.1700	534.0277778	41.9830
10/31/06	17:28:00	52.7430	0.7680	-2.1700	533.3333333	41.9130
10/31/06	17:29:00	52.7430	0.7680	-2.1700	533.3333333	41.9130
10/31/06	17:30:00	52.6390	0.7680	-2.1700	533.3333333	41.8090
10/31/06	17:31:00	52.6390	0.7680	-2.1700	533.3333333	41.8090
10/31/06	17:32:00	52.8130	0.7680	-2.1700	533.3333333	41.9830
10/31/06	17:33:00	52.7090	0.7680	-2.1700	533.3333333	41.8790
10/31/06	17:34:00	52.7090	0.7680	-2.1700	533.3333333	41.8790
10/31/06	17:35:00	52.5350	0.7690	-2.1700	534.0277778	41.7050
10/31/06	17:36:00	52.5350	0.7690	-2.1700	534.0277778	41.7050
10/31/06	17:37:00	52.7780	0.7680	-2.1700	533.3333333	41.9480
10/31/06	17:38:00	52.7780	0.7680	-2.1700	533.3333333	41.9480
10/31/06	17:39:00	52.6740	0.7680	-2.1700	533.3333333	41.8440
10/31/06	17:40:00	52.7090	0.7680	-2.1700	533.3333333	41.8790
10/31/06	17:41:00	52.7090	0.7680	-2.1700	533.3333333	41.8790
10/31/06	17:42:00	52.8130	0.7680	-2.1700	533.3333333	41.9830
10/31/06	17:43:00	52.8130	0.7680	-2.1700	533.3333333	41.9830
10/31/06	17:44:00	52.8470	0.7680	-2.1700	533.3333333	42.0170
10/31/06	17:45:00	52.5350	0.7700	-2.1700	534.7222222	41.7050
10/31/06	17:46:00	52.5350	0.7700	-2.1700	534.7222222	41.7050
10/31/06	17:47:00	52.5700	0.7690	-2.1700	534.0277778	41.7400
10/31/06	17:48:00	52.5700	0.7690	-2.1700	534.0277778	41.7400
10/31/06	17:49:00	52.6040	0.7690	-2.1700	534.0277778	41.7740
10/31/06	17:50:00	52.6040	0.7690	-2.1700	534.0277778	41.7740
10/31/06	17:51:00	52.8130	0.7700	-2.1790	534.7222222	41.9920
10/31/06	17:52:00	52.8130	0.7700	-2.1790	534.7222222	41.9920
10/31/06	17:53:00	52.5700	0.7690	-2.1970	534.0277778	41.7670
10/31/06	17:54:00	52.7090	0.7690	-2.1970	534.0277778	41.9060
10/31/06	17:55:00	52.7090	0.7690	-2.1970	534.0277778	41.9060
10/31/06	17:56:00	52.6390	0.7690	-2.1970	534.0277778	41.8360
10/31/06	17:57:00	52.6390	0.7690	-2.1970	534.0277778	41.8360
10/31/06	17:58:00	52.6040	0.7690	-2.1970	534.0277778	41.8010
10/31/06	17:59:00	52.8130	0.7700	-2.1970	534.7222222	42.0100
10/31/06	18:00:00	52.8130	0.7700	-2.1970	534.7222222	42.0100
10/31/06	18:01:00	52.9170	0.7700	-2.1970	534.7222222	42.1140
10/31/06	18:02:00	52.7780	0.7700	-2.1970	534.7222222	41.9750
10/31/06	18:03:00	52.7780	0.7700	-2.1970	534.7222222	41.9750
10/31/06	18:04:00	52.7780	0.7700	-2.1970	534.7222222	41.9750
10/31/06	18:05:00	52.7430	0.7700	-2.1970	534.7222222	41.9400
10/31/06	18:06:00	52.4660	0.7700	-2.1970	534.7222222	41.6630
10/31/06	18:07:00	52.4660	0.7700	-2.1970	534.7222222	41.6630
10/31/06	18:08:00	52.5350	0.7710	-2.2060	535.4166667	41.7410
10/31/06	18:09:00	52.4660	0.7710	-2.2060	535.4166667	41.6720
10/31/06	18:10:00	52.6390	0.7680	-2.2060	533.3333333	41.8450
10/31/06	18:11:00	52.5700	0.7700	-2.2060	534.7222222	41.7760
10/31/06	18:12:00	52.5700	0.7700	-2.2060	534.7222222	41.7760
10/31/06	18:13:00	52.6740	0.7700	-2.2060	534.7222222	41.8800
10/31/06	18:14:00	52.5000	0.7700	-2.2060	534.7222222	41.7060
10/31/06	18:15:00	52.5000	0.7700	-2.2060	534.7222222	41.7060
10/31/06	18:16:00	52.8470	0.7710	-2.2060	535.4166667	42.0530
10/31/06	18:17:00	52.8470	0.7710	-2.2060	535.4166667	42.0530
10/31/06	18:18:00	52.6740	0.7720	-2.2060	536.1111111	41.8800
10/31/06	18:19:00	52.6740	0.7720	-2.2060	536.1111111	41.8800
10/31/06	18:20:00	52.3270	0.7720	-2.2060	536.1111111	41.5330
10/31/06	18:21:00	52.3270	0.7720	-2.2060	536.1111111	41.5330
10/31/06	18:22:00	52.5350	0.7720	-2.2060	536.1111111	41.7410
10/31/06	18:23:00	52.5700	0.7720	-2.2060	536.1111111	41.7760
10/31/06	18:24:00	52.5700	0.7720	-2.2060	536.1111111	41.7760
10/31/06	18:25:00	52.3960	0.7720	-2.2240	536.1111111	41.6200
10/31/06	18:26:00	52.3960	0.7720	-2.2240	536.1111111	41.6200
10/31/06	18:27:00	52.5000	0.7710	-2.2240	535.4166667	41.7240

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	18:28:00	52.2570	0.7720	-2.2240	536.1111111	41.4810
10/31/06	18:29:00	52.2570	0.7720	-2.2240	536.1111111	41.4810
10/31/06	18:30:00	52.8130	0.7720	-2.2510	536.1111111	42.0640
10/31/06	18:31:00	52.4660	0.7730	-2.2510	536.8055556	41.7170
10/31/06	18:32:00	52.4660	0.7730	-2.2510	536.8055556	41.7170
10/31/06	18:33:00	52.5700	0.7710	-2.2510	535.4166667	41.8210
10/31/06	18:34:00	52.5700	0.7710	-2.2510	535.4166667	41.8210
10/31/06	18:35:00	52.3610	0.7700	-2.2510	534.7222222	41.6120
10/31/06	18:36:00	52.3610	0.7700	-2.2510	534.7222222	41.6120
10/31/06	18:37:00	52.7090	0.7710	-2.2780	535.4166667	41.9870
10/31/06	18:38:00	52.7090	0.7710	-2.2780	535.4166667	41.9870
10/31/06	18:39:00	52.6040	0.7710	-2.2780	535.4166667	41.8820
10/31/06	18:40:00	52.3610	0.7700	-2.2780	534.7222222	41.6390
10/31/06	18:41:00	52.3610	0.7700	-2.2780	534.7222222	41.6390
10/31/06	18:42:00	52.3610	0.7740	-2.2870	537.5	41.6480
10/31/06	18:43:00	52.4310	0.7720	-2.3050	536.1111111	41.7360
10/31/06	18:44:00	52.4310	0.7720	-2.3050	536.1111111	41.7360
10/31/06	18:45:00	52.4310	0.7720	-2.3140	536.1111111	41.7450
10/31/06	18:46:00	52.5000	0.7710	-2.3140	535.4166667	41.8140
10/31/06	18:47:00	52.5000	0.7710	-2.3140	535.4166667	41.8140
10/31/06	18:48:00	52.3960	0.7710	-2.3320	535.4166667	41.7280
10/31/06	18:49:00	52.3960	0.7710	-2.3320	535.4166667	41.7280
10/31/06	18:50:00	52.0490	0.7710	-2.3320	535.4166667	41.3810
10/31/06	18:51:00	52.0490	0.7710	-2.3320	535.4166667	41.3810
10/31/06	18:52:00	52.1530	0.7700	-2.3420	534.7222222	41.4950
10/31/06	18:53:00	52.1530	0.7700	-2.3420	534.7222222	41.4950
10/31/06	18:54:00	52.2570	0.7710	-2.3420	535.4166667	41.5990
10/31/06	18:55:00	52.6390	0.7710	-2.3600	535.4166667	41.9990
10/31/06	18:56:00	52.6390	0.7710	-2.3600	535.4166667	41.9990
10/31/06	18:57:00	52.4310	0.7720	-2.3600	536.1111111	41.7910
10/31/06	18:58:00	52.4310	0.7720	-2.3600	536.1111111	41.7910
10/31/06	18:59:00	52.5700	0.7710	-2.3690	535.4166667	41.9390
10/31/06	19:00:00	52.4310	0.7710	-2.3690	535.4166667	41.8000
10/31/06	19:01:00	52.4310	0.7710	-2.3690	535.4166667	41.8000
10/31/06	19:02:00	52.3270	0.7710	-2.3870	535.4166667	41.7140
10/31/06	19:03:00	52.3270	0.7710	-2.3870	535.4166667	41.7140
10/31/06	19:04:00	52.5350	0.7730	-2.3960	536.8055556	41.9310
10/31/06	19:05:00	52.5350	0.7730	-2.3960	536.8055556	41.9310
10/31/06	19:06:00	52.2570	0.7710	-2.3960	535.4166667	41.6530
10/31/06	19:07:00	52.2570	0.7710	-2.3960	535.4166667	41.6530
10/31/06	19:08:00	52.4660	0.7710	-2.3960	535.4166667	41.8620
10/31/06	19:09:00	52.5700	0.7710	-2.3960	535.4166667	41.9660
10/31/06	19:10:00	52.5700	0.7710	-2.3960	535.4166667	41.9660
10/31/06	19:11:00	52.4310	0.7720	-2.4050	536.1111111	41.8360
10/31/06	19:12:00	52.4310	0.7720	-2.4050	536.1111111	41.8360
10/31/06	19:13:00	52.4660	0.7730	-2.4230	536.8055556	41.8890
10/31/06	19:14:00	52.3270	0.7720	-2.4230	536.1111111	41.7500
10/31/06	19:15:00	52.2920	0.7720	-2.4230	536.1111111	41.7150
10/31/06	19:16:00	52.2920	0.7720	-2.4230	536.1111111	41.7150
10/31/06	19:17:00	52.2920	0.7710	-2.4410	535.4166667	41.7330
10/31/06	19:18:00	52.2920	0.7710	-2.4410	535.4166667	41.7330
10/31/06	19:19:00	52.5000	0.7720	-2.4500	536.1111111	41.9500
10/31/06	19:20:00	52.5000	0.7720	-2.4500	536.1111111	41.9500
10/31/06	19:21:00	52.2570	0.7720	-2.4500	536.1111111	41.7070
10/31/06	19:22:00	52.2570	0.7720	-2.4500	536.1111111	41.7070
10/31/06	19:23:00	52.4310	0.7730	-2.4500	536.8055556	41.8810
10/31/06	19:24:00	52.4310	0.7730	-2.4500	536.8055556	41.8810
10/31/06	19:25:00	52.3270	0.7710	-2.4500	535.4166667	41.7770
10/31/06	19:26:00	52.3270	0.7710	-2.4500	535.4166667	41.7770
10/31/06	19:27:00	52.2570	0.7720	-2.4410	536.1111111	41.6980
10/31/06	19:28:00	52.0140	0.7710	-2.4500	535.4166667	41.4640
10/31/06	19:29:00	52.0140	0.7710	-2.4500	535.4166667	41.4640
10/31/06	19:30:00	51.9790	0.7720	-2.4590	536.1111111	41.4380
10/31/06	19:31:00	51.9790	0.7720	-2.4590	536.1111111	41.4380
10/31/06	19:32:00	52.1530	0.7720	-2.5310	536.1111111	41.6840
10/31/06	19:33:00	51.9450	0.7710	-2.5310	535.4166667	41.4760
10/31/06	19:34:00	51.9450	0.7710	-2.5310	535.4166667	41.4760
10/31/06	19:35:00	52.2220	0.7720	-2.5310	536.1111111	41.7530
10/31/06	19:36:00	52.2220	0.7720	-2.5310	536.1111111	41.7530
10/31/06	19:37:00	52.3270	0.7740	-2.5310	537.5	41.8580
10/31/06	19:38:00	52.3270	0.7740	-2.5310	537.5	41.8580
10/31/06	19:39:00	52.2570	0.7710	-2.5310	535.4166667	41.7880
10/31/06	19:40:00	52.2570	0.7710	-2.5310	535.4166667	41.7880
10/31/06	19:41:00	52.1880	0.7730	-2.5310	536.8055556	41.7190

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	19:42:00	52.2570	0.7710	-2.5310	535.4166667	41.7880
10/31/06	19:43:00	52.2570	0.7710	-2.5310	535.4166667	41.7880
10/31/06	19:44:00	52.0840	0.7720	-2.5310	536.1111111	41.6150
10/31/06	19:45:00	52.1880	0.7730	-2.5310	536.8055556	41.7190
10/31/06	19:46:00	52.1880	0.7730	-2.5310	536.8055556	41.7190
10/31/06	19:47:00	52.3610	0.7720	-2.5310	536.1111111	41.8920
10/31/06	19:48:00	52.3610	0.7720	-2.5310	536.1111111	41.8920
10/31/06	19:49:00	52.1880	0.7720	-2.5310	536.1111111	41.7190
10/31/06	19:50:00	52.1880	0.7720	-2.5310	536.1111111	41.7190
10/31/06	19:51:00	52.2570	0.7720	-2.5310	536.1111111	41.7880
10/31/06	19:52:00	52.2570	0.7720	-2.5310	536.1111111	41.7880
10/31/06	19:53:00	52.3610	0.7710	-2.5310	535.4166667	41.8920
10/31/06	19:54:00	52.2920	0.7720	-2.5310	536.1111111	41.8230
10/31/06	19:55:00	52.2920	0.7720	-2.5310	536.1111111	41.8230
10/31/06	19:56:00	52.2220	0.7720	-2.5310	536.1111111	41.7530
10/31/06	19:57:00	52.2220	0.7720	-2.5310	536.1111111	41.7530
10/31/06	19:58:00	52.2570	0.7730	-2.5310	536.8055556	41.7880
10/31/06	19:59:00	52.2570	0.7730	-2.5310	536.8055556	41.7880
10/31/06	20:00:00	52.2920	0.7720	-2.5400	536.1111111	41.8320
10/31/06	20:01:00	52.2920	0.7740	-2.5580	537.5	41.8500
10/31/06	20:02:00	52.2920	0.7740	-2.5580	537.5	41.8500
10/31/06	20:03:00	52.3610	0.7720	-2.5760	536.1111111	41.9370
10/31/06	20:04:00	52.3610	0.7720	-2.5760	536.1111111	41.9370
10/31/06	20:05:00	52.3270	0.7720	-2.5850	536.1111111	41.9120
10/31/06	20:06:00	52.3270	0.7720	-2.5850	536.1111111	41.9120
10/31/06	20:07:00	52.2570	0.7720	-2.5940	536.1111111	41.8510
10/31/06	20:08:00	52.0140	0.7710	-2.6120	535.4166667	41.6260
10/31/06	20:09:00	52.0140	0.7710	-2.6120	535.4166667	41.6260
10/31/06	20:10:00	52.0490	0.7700	-2.6210	534.7222222	41.6700
10/31/06	20:11:00	52.1530	0.7720	-2.6120	536.1111111	41.7650
10/31/06	20:12:00	52.1530	0.7720	-2.6120	536.1111111	41.7650
10/31/06	20:13:00	52.2570	0.7720	-2.6210	536.1111111	41.8780
10/31/06	20:14:00	51.9450	0.7710	-2.6390	535.4166667	41.5840
10/31/06	20:15:00	51.9450	0.7710	-2.6390	535.4166667	41.5840
10/31/06	20:16:00	52.0490	0.7720	-2.6390	536.1111111	41.6880
10/31/06	20:17:00	51.9790	0.7720	-2.6390	536.1111111	41.6180
10/31/06	20:18:00	51.9790	0.7720	-2.6480	536.1111111	41.6270
10/31/06	20:19:00	51.9790	0.7720	-2.6480	536.1111111	41.6270
10/31/06	20:20:00	51.9790	0.7730	-2.6390	536.8055556	41.6180
10/31/06	20:21:00	51.9790	0.7730	-2.6390	536.8055556	41.6180
10/31/06	20:22:00	52.0490	0.7740	-2.6480	537.5	41.6970
10/31/06	20:23:00	52.1180	0.7730	-2.6760	536.8055556	41.7940
10/31/06	20:24:00	52.1180	0.7730	-2.6760	536.8055556	41.7940
10/31/06	20:25:00	52.1880	0.7720	-2.6670	536.1111111	41.8550
10/31/06	20:26:00	52.1880	0.7720	-2.6670	536.1111111	41.8550
10/31/06	20:27:00	52.0140	0.7720	-2.6760	536.1111111	41.6900
10/31/06	20:28:00	52.0140	0.7720	-2.6760	536.1111111	41.6900
10/31/06	20:29:00	52.1180	0.7720	-2.7030	536.1111111	41.8210
10/31/06	20:30:00	52.1530	0.7720	-2.7030	536.1111111	41.8560
10/31/06	20:31:00	52.1180	0.7740	-2.7030	537.5	41.8210
10/31/06	20:32:00	52.1180	0.7740	-2.7030	537.5	41.8210
10/31/06	20:33:00	52.1880	0.7730	-2.7210	536.8055556	41.9090
10/31/06	20:34:00	52.1880	0.7730	-2.7210	536.8055556	41.9090
10/31/06	20:35:00	52.1180	0.7720	-2.7300	536.1111111	41.8480
10/31/06	20:36:00	52.1180	0.7720	-2.7300	536.1111111	41.8480
10/31/06	20:37:00	51.9790	0.7740	-2.7300	537.5	41.7090
10/31/06	20:38:00	51.9790	0.7740	-2.7300	537.5	41.7090
10/31/06	20:39:00	51.8750	0.7700	-2.7300	534.7222222	41.6050
10/31/06	20:40:00	52.0490	0.7710	-2.7300	535.4166667	41.7790
10/31/06	20:41:00	52.0490	0.7710	-2.7300	535.4166667	41.7790
10/31/06	20:42:00	52.2570	0.7720	-2.7390	536.1111111	41.9960
10/31/06	20:43:00	52.2570	0.7720	-2.7390	536.1111111	41.9960
10/31/06	20:44:00	52.3610	0.7720	-2.7390	536.1111111	42.1000
10/31/06	20:45:00	52.3610	0.7720	-2.7300	536.1111111	42.0910
10/31/06	20:46:00	52.3610	0.7720	-2.7300	536.1111111	42.0910
10/31/06	20:47:00	52.3270	0.7750	-2.7300	538.1944444	42.0570
10/31/06	20:48:00	52.4660	0.7730	-2.7300	536.8055556	42.1960
10/31/06	20:49:00	52.4660	0.7730	-2.7300	536.8055556	42.1960
10/31/06	20:50:00	52.0840	0.7710	-2.7300	535.4166667	41.8140
10/31/06	20:51:00	52.0840	0.7710	-2.7300	535.4166667	41.8140
10/31/06	20:52:00	52.2920	0.7730	-2.7390	536.8055556	42.0310
10/31/06	20:53:00	52.2920	0.7730	-2.7390	536.8055556	42.0310
10/31/06	20:54:00	52.1880	0.7720	-2.7480	536.1111111	41.9360
10/31/06	20:55:00	52.0840	0.7730	-2.7570	536.8055556	41.8410

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	20:56:00	52.0840	0.7730	-2.7570	536.8055556	41.8410
10/31/06	20:57:00	52.0840	0.7720	-2.7570	536.1111111	41.8410
10/31/06	20:58:00	52.0840	0.7720	-2.7570	536.1111111	41.8410
10/31/06	20:59:00	52.1180	0.7760	-2.7750	538.8888889	41.8930
10/31/06	21:00:00	52.2220	0.7750	-2.7750	538.1944444	41.9970
10/31/06	21:01:00	52.2220	0.7750	-2.7840	538.1944444	42.0060
10/31/06	21:02:00	52.0840	0.7720	-2.7840	536.1111111	41.8680
10/31/06	21:03:00	52.0840	0.7720	-2.7840	536.1111111	41.8680
10/31/06	21:04:00	52.0840	0.7720	-2.7840	536.1111111	41.8680
10/31/06	21:05:00	52.0840	0.7720	-2.7840	536.1111111	41.8680
10/31/06	21:06:00	52.0840	0.7720	-2.7840	536.1111111	41.8680
10/31/06	21:07:00	51.9790	0.7720	-2.7840	536.1111111	41.7630
10/31/06	21:08:00	52.0490	0.7710	-2.7840	535.4166667	41.8330
10/31/06	21:09:00	52.0490	0.7710	-2.7840	535.4166667	41.8330
10/31/06	21:10:00	52.0140	0.7740	-2.7840	537.5	41.7980
10/31/06	21:11:00	52.0140	0.7740	-2.7840	537.5	41.7980
10/31/06	21:12:00	52.2570	0.7720	-2.7930	536.1111111	42.0500
10/31/06	21:13:00	52.1180	0.7710	-2.8110	535.4166667	41.9290
10/31/06	21:14:00	52.1180	0.7710	-2.8110	535.4166667	41.9290
10/31/06	21:15:00	52.0140	0.7750	-2.8110	538.1944444	41.8250
10/31/06	21:16:00	52.0140	0.7750	-2.8110	538.1944444	41.8250
10/31/06	21:17:00	52.2920	0.7740	-2.8110	537.5	42.1030
10/31/06	21:18:00	52.0490	0.7740	-2.8200	537.5	41.8690
10/31/06	21:19:00	52.0490	0.7740	-2.8200	537.5	41.8690
10/31/06	21:20:00	52.1180	0.7730	-2.8380	536.8055556	41.9560
10/31/06	21:21:00	52.1180	0.7730	-2.8380	536.8055556	41.9560
10/31/06	21:22:00	52.1180	0.7740	-2.8380	537.5	41.9560
10/31/06	21:23:00	52.0840	0.7740	-2.8380	537.5	41.9220
10/31/06	21:24:00	52.0840	0.7740	-2.8380	537.5	41.9220
10/31/06	21:25:00	52.0490	0.7730	-2.8560	536.8055556	41.9050
10/31/06	21:26:00	52.0490	0.7730	-2.8560	536.8055556	41.9050
10/31/06	21:27:00	52.0140	0.7740	-2.8650	537.5	41.8790
10/31/06	21:28:00	52.0140	0.7730	-2.8650	536.8055556	41.8790
10/31/06	21:29:00	52.0140	0.7730	-2.8650	536.8055556	41.8790
10/31/06	21:30:00	51.9790	0.7740	-2.8650	537.5	41.8440
10/31/06	21:31:00	52.1880	0.7730	-2.8650	536.8055556	42.0530
10/31/06	21:32:00	52.1880	0.7730	-2.8650	536.8055556	42.0530
10/31/06	21:33:00	51.9450	0.7750	-2.8740	538.1944444	41.8190
10/31/06	21:34:00	51.9450	0.7750	-2.8740	538.1944444	41.8190
10/31/06	21:35:00	52.0490	0.7740	-2.8740	537.5	41.9230
10/31/06	21:36:00	52.0490	0.7740	-2.8740	537.5	41.9230
10/31/06	21:37:00	52.1530	0.7750	-2.8740	538.1944444	42.0270
10/31/06	21:38:00	52.1530	0.7750	-2.8740	538.1944444	42.0270
10/31/06	21:39:00	52.2220	0.7740	-2.8830	537.5	42.1050
10/31/06	21:40:00	52.2220	0.7740	-2.8830	537.5	42.1050
10/31/06	21:41:00	52.1180	0.7730	-2.8920	536.8055556	42.0100
10/31/06	21:42:00	51.9790	0.7730	-2.8920	536.8055556	41.8710
10/31/06	21:43:00	51.9790	0.7730	-2.8920	536.8055556	41.8710
10/31/06	21:44:00	52.1180	0.7740	-2.9010	537.5	42.0190
10/31/06	21:45:00	51.8750	0.7720	-2.8920	536.1111111	41.7670
10/31/06	21:46:00	51.8750	0.7720	-2.8920	536.1111111	41.7670
10/31/06	21:47:00	51.9790	0.7740	-2.8920	537.5	41.8710
10/31/06	21:48:00	51.9790	0.7740	-2.8920	537.5	41.8710
10/31/06	21:49:00	52.0490	0.7740	-2.9100	537.5	41.9590
10/31/06	21:50:00	51.9790	0.7740	-2.9190	537.5	41.8980
10/31/06	21:51:00	51.9790	0.7740	-2.9190	537.5	41.8980
10/31/06	21:52:00	52.1180	0.7740	-2.9190	537.5	42.0370
10/31/06	21:53:00	52.1180	0.7740	-2.9190	537.5	42.0370
10/31/06	21:54:00	51.9100	0.7760	-2.9280	538.8888889	41.8380
10/31/06	21:55:00	51.9100	0.7760	-2.9280	538.8888889	41.8380
10/31/06	21:56:00	51.9450	0.7750	-2.9190	538.1944444	41.8640
10/31/06	21:57:00	51.9450	0.7750	-2.9190	538.1944444	41.8640
10/31/06	21:58:00	51.8410	0.7730	-2.9190	536.8055556	41.7600
10/31/06	21:59:00	51.9100	0.7730	-2.9190	536.8055556	41.8290
10/31/06	22:00:00	51.9100	0.7730	-2.9190	536.8055556	41.8290
10/31/06	22:01:00	51.8750	0.7740	-2.9190	537.5	41.7940
10/31/06	22:02:00	52.1880	0.7780	-2.9190	540.2777778	42.1070
10/31/06	22:03:00	52.1880	0.7780	-2.9190	540.2777778	42.1070
10/31/06	22:04:00	52.1880	0.7780	-2.9190	540.2777778	42.1070
10/31/06	22:05:00	52.0840	0.7780	-2.9280	540.2777778	42.0120
10/31/06	22:06:00	52.2920	0.7790	-2.9190	540.9722222	42.2110
10/31/06	22:07:00	52.2920	0.7790	-2.9190	540.9722222	42.2110
10/31/06	22:08:00	52.2220	0.7760	-2.9190	538.8888889	42.1410
10/31/06	22:09:00	52.2220	0.7760	-2.9190	538.8888889	42.1410

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	22:10:00	52.0140	0.7750	-2.9190	538.1944444	41.9330
10/31/06	22:11:00	52.0140	0.7750	-2.9190	538.1944444	41.9330
10/31/06	22:12:00	51.8750	0.7750	-2.9190	538.1944444	41.7940
10/31/06	22:13:00	51.7020	0.7740	-2.9280	537.5	41.6300
10/31/06	22:14:00	51.7020	0.7740	-2.9280	537.5	41.6300
10/31/06	22:15:00	51.9100	0.7750	-2.9550	538.1944444	41.8650
10/31/06	22:16:00	52.0140	0.7740	-2.9460	537.5	41.9600
10/31/06	22:17:00	52.0140	0.7740	-2.9460	537.5	41.9600
10/31/06	22:18:00	51.8750	0.7730	-2.9460	536.8055556	41.8210
10/31/06	22:19:00	51.8750	0.7730	-2.9460	536.8055556	41.8210
10/31/06	22:20:00	51.5970	0.7710	-2.9460	535.4166667	41.5430
10/31/06	22:21:00	51.5970	0.7710	-2.9460	535.4166667	41.5430
10/31/06	22:22:00	51.9100	0.7740	-2.9550	537.5	41.8650
10/31/06	22:23:00	51.9100	0.7740	-2.9550	537.5	41.8650
10/31/06	22:24:00	51.5970	0.7720	-2.9820	536.1111111	41.5790
10/31/06	22:25:00	51.5280	0.7700	-2.9730	534.7222222	41.5010
10/31/06	22:26:00	51.5280	0.7700	-2.9730	534.7222222	41.5010
10/31/06	22:27:00	51.5970	0.7710	-2.9820	535.4166667	41.5790
10/31/06	22:28:00	51.5970	0.7710	-2.9820	535.4166667	41.5790
10/31/06	22:29:00	51.5630	0.7700	-2.9820	534.7222222	41.5450
10/31/06	22:30:00	51.4240	0.7710	-2.9820	535.4166667	41.4060
10/31/06	22:31:00	51.4240	0.7710	-2.9820	535.4166667	41.4060
10/31/06	22:32:00	51.4240	0.7730	-2.9920	536.8055556	41.4160
10/31/06	22:33:00	51.5280	0.7720	-3.0100	536.1111111	41.5380
10/31/06	22:34:00	51.5280	0.7720	-3.0100	536.1111111	41.5380
10/31/06	22:35:00	51.6670	0.7740	-3.0010	537.5	41.6680
10/31/06	22:36:00	51.6670	0.7740	-3.0010	537.5	41.6680
10/31/06	22:37:00	51.4590	0.7720	-3.0100	536.1111111	41.4690
10/31/06	22:38:00	51.4590	0.7720	-3.0100	536.1111111	41.4690
10/31/06	22:39:00	51.4240	0.7730	-3.0100	536.8055556	41.4340
10/31/06	22:40:00	51.4240	0.7730	-3.0100	536.8055556	41.4340
10/31/06	22:41:00	51.3890	0.7720	-3.0280	536.1111111	41.4170
10/31/06	22:42:00	51.4240	0.7730	-3.0370	536.8055556	41.4610
10/31/06	22:43:00	51.4240	0.7730	-3.0370	536.8055556	41.4610
10/31/06	22:44:00	51.6320	0.7740	-3.0370	537.5	41.6690
10/31/06	22:45:00	51.7360	0.7730	-3.0550	536.8055556	41.7910
10/31/06	22:46:00	51.7360	0.7730	-3.0550	536.8055556	41.7910
10/31/06	22:47:00	51.7360	0.7740	-3.0640	537.5	41.8000
10/31/06	22:48:00	51.7360	0.7740	-3.0640	537.5	41.8000
10/31/06	22:49:00	51.4930	0.7720	-3.0640	536.1111111	41.5570
10/31/06	22:50:00	51.3890	0.7700	-3.0640	534.7222222	41.4530
10/31/06	22:51:00	51.3890	0.7700	-3.0640	534.7222222	41.4530
10/31/06	22:52:00	51.5280	0.7710	-3.0910	535.4166667	41.6190
10/31/06	22:53:00	51.5280	0.7710	-3.0910	535.4166667	41.6190
10/31/06	22:54:00	51.5970	0.7720	-3.0910	536.1111111	41.6880
10/31/06	22:55:00	51.5970	0.7720	-3.0910	536.1111111	41.6880
10/31/06	22:56:00	51.7360	0.7730	-3.0910	536.8055556	41.8270
10/31/06	22:57:00	51.7360	0.7730	-3.0910	536.8055556	41.8270
10/31/06	22:58:00	50.3470	0.7760	-3.0910	538.8888889	40.4380
10/31/06	22:59:00	50.5910	0.7750	-3.0910	538.1944444	40.6820
10/31/06	23:00:00	50.5910	0.7750	-3.0910	538.1944444	40.6820
10/31/06	23:01:00	50.3820	0.7730	-3.0910	536.8055556	40.4730
10/31/06	23:02:00	50.3820	0.7730	-3.0910	536.8055556	40.4730
10/31/06	23:03:00	50.4170	0.7720	-3.1180	536.1111111	40.5350
10/31/06	23:04:00	50.4170	0.7720	-3.1180	536.1111111	40.5350
10/31/06	23:05:00	50.6950	0.7740	-3.1180	537.5	40.8130
10/31/06	23:06:00	50.6950	0.7740	-3.1180	537.5	40.8130
10/31/06	23:07:00	50.6250	0.7740	-3.1180	537.5	40.7430
10/31/06	23:08:00	50.7990	0.7740	-3.1180	537.5	40.9170
10/31/06	23:09:00	50.7990	0.7740	-3.1180	537.5	40.9170
10/31/06	23:10:00	50.7990	0.7730	-3.1270	536.8055556	40.9260
10/31/06	23:11:00	50.7990	0.7730	-3.1270	536.8055556	40.9260
10/31/06	23:12:00	50.7990	0.7750	-3.1450	538.1944444	40.9440
10/31/06	23:13:00	50.7290	0.7750	-3.1450	538.1944444	40.8740
10/31/06	23:14:00	50.7290	0.7750	-3.1450	538.1944444	40.8740
10/31/06	23:15:00	50.6250	0.7750	-3.1450	538.1944444	40.7700
10/31/06	23:16:00	50.6250	0.7750	-3.1450	538.1944444	40.7700
10/31/06	23:17:00	50.6250	0.7740	-3.1450	537.5	40.7700
10/31/06	23:18:00	50.9030	0.7740	-3.1450	537.5	41.0480
10/31/06	23:19:00	50.9030	0.7740	-3.1450	537.5	41.0480
10/31/06	23:20:00	50.9030	0.7740	-3.1450	537.5	41.0480
10/31/06	23:21:00	50.7290	0.7740	-3.1450	537.5	40.8740
10/31/06	23:22:00	50.7640	0.7740	-3.1450	537.5	40.9090
10/31/06	23:23:00	50.7640	0.7740	-3.1450	537.5	40.9090

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

10/31/06	23:24:00	50.9720	0.7760	-3.1450	538.8888889	41.1170
10/31/06	23:25:00	50.9720	0.7760	-3.1450	538.8888889	41.1170
10/31/06	23:26:00	50.7990	0.7760	-3.1450	538.8888889	40.9440
10/31/06	23:27:00	50.8340	0.7770	-3.1450	539.5833333	40.9790
10/31/06	23:28:00	50.8340	0.7770	-3.1450	539.5833333	40.9790
10/31/06	23:29:00	50.7990	0.7760	-3.1540	538.8888889	40.9530
10/31/06	23:30:00	51.0070	0.7770	-3.1720	539.5833333	41.1790
10/31/06	23:31:00	51.0070	0.7770	-3.1720	539.5833333	41.1790
10/31/06	23:32:00	50.7990	0.7760	-3.1720	538.8888889	40.9710
10/31/06	23:33:00	50.7990	0.7760	-3.1720	538.8888889	40.9710
10/31/06	23:34:00	50.7990	0.7760	-3.1720	538.8888889	40.9710
10/31/06	23:35:00	50.7640	0.7760	-3.1720	538.8888889	40.9360
10/31/06	23:36:00	50.7640	0.7760	-3.1720	538.8888889	40.9360
10/31/06	23:37:00	50.6600	0.7740	-3.1810	537.5	40.8410
10/31/06	23:38:00	50.6600	0.7740	-3.1810	537.5	40.8410
10/31/06	23:39:00	50.8340	0.7730	-3.1810	536.8055556	41.0150
10/31/06	23:40:00	50.8340	0.7730	-3.1810	536.8055556	41.0150
10/31/06	23:41:00	50.7290	0.7740	-3.1990	537.5	40.9280
10/31/06	23:42:00	50.6950	0.7750	-3.1990	538.1944444	40.8940
10/31/06	23:43:00	50.6950	0.7750	-3.1990	538.1944444	40.8940
10/31/06	23:44:00	50.8680	0.7760	-3.1990	538.8888889	41.0670
10/31/06	23:45:00	50.8340	0.7750	-3.1990	538.1944444	41.0330
10/31/06	23:46:00	50.8340	0.7750	-3.1990	538.1944444	41.0330
10/31/06	23:47:00	50.7290	0.7730	-3.2170	536.8055556	40.9460
10/31/06	23:48:00	50.7290	0.7730	-3.2170	536.8055556	40.9460
10/31/06	23:49:00	50.6600	0.7730	-3.2260	536.8055556	40.8860
10/31/06	23:50:00	50.7990	0.7740	-3.2260	537.5	41.0250
10/31/06	23:51:00	50.7990	0.7740	-3.2260	537.5	41.0250
10/31/06	23:52:00	50.7990	0.7750	-3.2260	538.1944444	41.0250
10/31/06	23:53:00	50.7990	0.7750	-3.2260	538.1944444	41.0250
10/31/06	23:54:00	50.9030	0.7740	-3.2260	537.5	41.1290
10/31/06	23:55:00	50.9030	0.7740	-3.2260	537.5	41.1290
10/31/06	23:56:00	50.8680	0.7750	-3.2260	538.1944444	41.0940
10/31/06	23:57:00	50.8680	0.7750	-3.2350	538.1944444	41.1030
10/31/06	23:58:00	50.8680	0.7750	-3.2350	538.1944444	41.1030
10/31/06	23:59:00	50.8340	0.7750	-3.2440	538.1944444	41.0780
11/01/06	00:00:00	50.8340	0.7750	-3.2440	538.1944444	41.0780
11/01/06	00:01:00	50.8340	0.7750	-3.2530	538.1944444	41.0870
11/01/06	00:02:00	50.7290	0.7750	-3.2620	538.1944444	40.9910
11/01/06	00:03:00	50.7290	0.7750	-3.2620	538.1944444	40.9910
11/01/06	00:04:00	50.9030	0.7760	-3.2530	538.8888889	41.1560
11/01/06	00:05:00	50.9030	0.7760	-3.2530	538.8888889	41.1560
11/01/06	00:06:00	50.8340	0.7750	-3.2530	538.1944444	41.0870
11/01/06	00:07:00	50.8340	0.7750	-3.2530	538.1944444	41.0870
11/01/06	00:08:00	50.9720	0.7760	-3.2530	538.8888889	41.2250
11/01/06	00:09:00	50.9380	0.7750	-3.2620	538.1944444	41.2000
11/01/06	00:10:00	50.9380	0.7750	-3.2620	538.1944444	41.2000
11/01/06	00:11:00	33.1950	0.5390	-12.9670	374.3055556	33.1620
11/01/06	00:12:00	50.9380	0.7750	-3.2620	538.1944444	41.2000
11/01/06	00:13:00	50.9380	0.7750	-3.2620	538.1944444	41.2000
11/01/06	00:14:00	50.9030	0.7760	-3.2890	538.8888889	41.1920
11/01/06	00:15:00	50.9030	0.7750	-3.2890	538.1944444	41.1920
11/01/06	00:16:00	50.9030	0.7750	-3.2890	538.1944444	41.1920
11/01/06	00:17:00	50.9030	0.7750	-3.2890	538.1944444	41.1920
11/01/06	00:18:00	50.9030	0.7750	-3.2890	538.1944444	41.1920
11/01/06	00:19:00	50.9380	0.7760	-3.2980	538.8888889	41.2360
11/01/06	00:20:00	50.9380	0.7760	-3.2980	538.8888889	41.2360
11/01/06	00:21:00	50.9030	0.7750	-3.3070	538.1944444	41.2100
11/01/06	00:22:00	50.9720	0.7760	-3.3070	538.8888889	41.2790
11/01/06	00:23:00	50.9720	0.7760	-3.3070	538.8888889	41.2790
11/01/06	00:24:00	51.0420	0.7770	-3.3070	539.5833333	41.3490
11/01/06	00:25:00	51.0420	0.7770	-3.3070	539.5833333	41.3490
11/01/06	00:26:00	50.7990	0.7760	-3.3170	538.8888889	41.1160
11/01/06	00:27:00	50.9380	0.7770	-3.3170	539.5833333	41.2550
11/01/06	00:28:00	50.9380	0.7770	-3.3170	539.5833333	41.2550
11/01/06	00:29:00	50.9380	0.7760	-3.3260	538.8888889	41.2640
11/01/06	00:30:00	50.8340	0.7760	-3.3440	538.8888889	41.1780
11/01/06	00:31:00	50.8340	0.7760	-3.3440	538.8888889	41.1780
11/01/06	00:32:00	50.7290	0.7760	-3.3440	538.8888889	41.0730
11/01/06	00:33:00	50.9030	0.7750	-3.3440	538.1944444	41.2470
11/01/06	00:34:00	50.9030	0.7750	-3.3440	538.1944444	41.2470
11/01/06	00:35:00	50.9380	0.7770	-3.3440	539.5833333	41.2820
11/01/06	00:36:00	50.9380	0.7770	-3.3440	539.5833333	41.2820
11/01/06	00:37:00	50.7990	0.7750	-3.3440	538.1944444	41.1430

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	00:38:00	50.7990	0.7750	-3.3440	538.1944444	41.1430
11/01/06	00:39:00	50.7990	0.7740	-3.3620	537.5	41.1610
11/01/06	00:40:00	50.9380	0.7770	-3.3710	539.5833333	41.3090
11/01/06	00:41:00	50.9380	0.7770	-3.3710	539.5833333	41.3090
11/01/06	00:42:00	50.7290	0.7770	-3.3710	539.5833333	41.1000
11/01/06	00:43:00	50.7290	0.7770	-3.3710	539.5833333	41.1000
11/01/06	00:44:00	50.7990	0.7750	-3.3710	538.1944444	41.1700
11/01/06	00:45:00	50.9720	0.7750	-3.3710	538.1944444	41.3430
11/01/06	00:46:00	50.9720	0.7750	-3.3710	538.1944444	41.3430
11/01/06	00:47:00	50.6950	0.7770	-3.3800	539.5833333	41.0750
11/01/06	00:48:00	50.7990	0.7760	-3.3980	538.8888889	41.1970
11/01/06	00:49:00	50.7990	0.7760	-3.3980	538.8888889	41.1970
11/01/06	00:50:00	50.7640	0.7760	-3.3980	538.8888889	41.1620
11/01/06	00:51:00	50.7640	0.7760	-3.3980	538.8888889	41.1620
11/01/06	00:52:00	50.8340	0.7770	-3.3980	539.5833333	41.2320
11/01/06	00:53:00	50.8340	0.7770	-3.3980	539.5833333	41.2320
11/01/06	00:54:00	50.7640	0.7760	-3.3980	538.8888889	41.1620
11/01/06	00:55:00	50.7640	0.7760	-3.3980	538.8888889	41.1620
11/01/06	00:56:00	51.0070	0.7770	-3.3980	539.5833333	41.4050
11/01/06	00:57:00	50.5910	0.7760	-3.4070	538.8888889	40.9980
11/01/06	00:58:00	50.5910	0.7760	-3.4070	538.8888889	40.9980
11/01/06	00:59:00	50.6950	0.7770	-3.4160	539.5833333	41.1110
11/01/06	01:00:00	50.7640	0.7770	-3.4250	539.5833333	41.1890
11/01/06	01:01:00	50.7640	0.7770	-3.4250	539.5833333	41.1890
11/01/06	01:02:00	50.5560	0.7770	-3.4250	539.5833333	40.9810
11/01/06	01:03:00	50.5560	0.7770	-3.4250	539.5833333	40.9810
11/01/06	01:04:00	50.7290	0.7770	-3.4250	539.5833333	41.1540
11/01/06	01:05:00	50.7290	0.7770	-3.4250	539.5833333	41.1540
11/01/06	01:06:00	50.7640	0.7770	-3.4250	539.5833333	41.1890
11/01/06	01:07:00	50.7640	0.7770	-3.4250	539.5833333	41.1890
11/01/06	01:08:00	50.9030	0.7760	-3.4250	538.8888889	41.3280
11/01/06	01:09:00	50.7990	0.7780	-3.4250	540.2777778	41.2240
11/01/06	01:10:00	50.7990	0.7780	-3.4250	540.2777778	41.2240
11/01/06	01:11:00	50.6950	0.7760	-3.4340	538.8888889	41.1290
11/01/06	01:12:00	50.9380	0.7780	-3.4340	540.2777778	41.3720
11/01/06	01:13:00	50.9380	0.7780	-3.4340	540.2777778	41.3720
11/01/06	01:14:00	50.9380	0.7760	-3.4520	538.8888889	41.3900
11/01/06	01:15:00	50.8680	0.7770	-3.4520	539.5833333	41.3200
11/01/06	01:16:00	50.8680	0.7770	-3.4520	539.5833333	41.3200
11/01/06	01:17:00	50.7640	0.7760	-3.4520	538.8888889	41.2160
11/01/06	01:18:00	50.7640	0.7760	-3.4520	538.8888889	41.2160
11/01/06	01:19:00	50.8340	0.7760	-3.4520	538.8888889	41.2860
11/01/06	01:20:00	50.8340	0.7760	-3.4520	538.8888889	41.2860
11/01/06	01:21:00	51.0070	0.7760	-3.4520	538.8888889	41.4590
11/01/06	01:22:00	51.0070	0.7760	-3.4520	538.8888889	41.4590
11/01/06	01:23:00	50.7990	0.7770	-3.4520	539.5833333	41.2510
11/01/06	01:24:00	50.7990	0.7770	-3.4520	539.5833333	41.2510
11/01/06	01:25:00	50.7640	0.7760	-3.4520	538.8888889	41.2160
11/01/06	01:26:00	50.7290	0.7770	-3.4700	539.5833333	41.1990
11/01/06	01:27:00	50.7290	0.7770	-3.4700	539.5833333	41.1990
11/01/06	01:28:00	50.7640	0.7770	-3.4790	539.5833333	41.2430
11/01/06	01:29:00	50.6950	0.7750	-3.4790	538.1944444	41.1740
11/01/06	01:30:00	50.6950	0.7750	-3.4790	538.1944444	41.1740
11/01/06	01:31:00	50.7640	0.7760	-3.4790	538.8888889	41.2430
11/01/06	01:32:00	50.7640	0.7760	-3.4790	538.8888889	41.2430
11/01/06	01:33:00	50.7290	0.7770	-3.4790	539.5833333	41.2080
11/01/06	01:34:00	50.6600	0.7770	-3.4790	539.5833333	41.1390
11/01/06	01:35:00	50.6600	0.7770	-3.4790	539.5833333	41.1390
11/01/06	01:36:00	50.6600	0.7780	-3.4790	540.2777778	41.1390
11/01/06	01:37:00	50.6600	0.7780	-3.4790	540.2777778	41.1390
11/01/06	01:38:00	50.7990	0.7770	-3.4970	539.5833333	41.2960
11/01/06	01:39:00	50.7990	0.7770	-3.4970	539.5833333	41.2960
11/01/06	01:40:00	50.8340	0.7770	-3.5060	539.5833333	41.3400
11/01/06	01:41:00	50.8680	0.7770	-3.5060	539.5833333	41.3740
11/01/06	01:42:00	50.8680	0.7770	-3.5060	539.5833333	41.3740
11/01/06	01:43:00	50.7290	0.7760	-3.5150	538.8888889	41.2440
11/01/06	01:44:00	50.7640	0.7760	-3.5150	538.8888889	41.2790
11/01/06	01:45:00	50.7640	0.7760	-3.5150	538.8888889	41.2790
11/01/06	01:46:00	50.8680	0.7760	-3.5240	538.8888889	41.3920
11/01/06	01:47:00	50.7640	0.7770	-3.5330	539.5833333	41.2970
11/01/06	01:48:00	50.7640	0.7770	-3.5330	539.5833333	41.2970
11/01/06	01:49:00	50.5210	0.7760	-3.5330	538.8888889	41.0540
11/01/06	01:50:00	50.5210	0.7760	-3.5330	538.8888889	41.0540
11/01/06	01:51:00	50.7290	0.7780	-3.5330	540.2777778	41.2620

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	01:52:00	50.7290	0.7780	-3.5330	540.2777778	41.2620
11/01/06	01:53:00	50.6600	0.7770	-3.5510	539.5833333	41.2110
11/01/06	01:54:00	50.6600	0.7770	-3.5510	539.5833333	41.2110
11/01/06	01:55:00	50.6600	0.7770	-3.5600	539.5833333	41.2200
11/01/06	01:56:00	50.7640	0.7770	-3.5600	539.5833333	41.3240
11/01/06	01:57:00	50.7640	0.7770	-3.5600	539.5833333	41.3240
11/01/06	01:58:00	50.6250	0.7780	-3.5690	540.2777778	41.1940
11/01/06	01:59:00	50.4170	0.7750	-3.5690	538.1944444	40.9860
11/01/06	02:00:00	50.4170	0.7750	-3.5690	538.1944444	40.9860
11/01/06	02:01:00	50.6950	0.7770	-3.5780	539.5833333	41.2730
11/01/06	02:02:00	50.6950	0.7770	-3.5780	539.5833333	41.2730
11/01/06	02:03:00	50.8340	0.7770	-3.5870	539.5833333	41.4210
11/01/06	02:04:00	50.8340	0.7770	-3.5870	539.5833333	41.4210
11/01/06	02:05:00	50.6250	0.7750	-3.5870	538.1944444	41.2120
11/01/06	02:06:00	50.7640	0.7760	-3.5960	538.8888889	41.3600
11/01/06	02:07:00	50.7640	0.7760	-3.5960	538.8888889	41.3600
11/01/06	02:08:00	50.5560	0.7770	-3.6050	539.5833333	41.1610
11/01/06	02:09:00	50.5560	0.7770	-3.6050	539.5833333	41.1610
11/01/06	02:10:00	50.6600	0.7760	-3.6140	538.8888889	41.2740
11/01/06	02:11:00	50.5910	0.7760	-3.6230	538.8888889	41.2140
11/01/06	02:12:00	50.5910	0.7760	-3.6230	538.8888889	41.2140
11/01/06	02:13:00	50.5560	0.7740	-3.6140	537.5	41.1700
11/01/06	02:14:00	50.6600	0.7760	-3.6140	538.8888889	41.2740
11/01/06	02:15:00	50.6600	0.7760	-3.6140	538.8888889	41.2740
11/01/06	02:16:00	50.6250	0.7750	-3.6140	538.1944444	41.2390
11/01/06	02:17:00	50.5910	0.7750	-3.6230	538.1944444	41.2140
11/01/06	02:18:00	50.5910	0.7750	-3.6230	538.1944444	41.2140
11/01/06	02:19:00	50.5560	0.7770	-3.6420	539.5833333	41.1980
11/01/06	02:20:00	50.5560	0.7770	-3.6420	539.5833333	41.1980
11/01/06	02:21:00	50.6250	0.7750	-3.6510	538.1944444	41.2760
11/01/06	02:22:00	50.6250	0.7750	-3.6510	538.1944444	41.2760
11/01/06	02:23:00	50.5560	0.7750	-3.6510	538.1944444	41.2070
11/01/06	02:24:00	50.5560	0.7750	-3.6510	538.1944444	41.2070
11/01/06	02:25:00	50.5560	0.7750	-3.6510	538.1944444	41.2070
11/01/06	02:26:00	50.6600	0.7740	-3.6690	537.5	41.3290
11/01/06	02:27:00	50.6600	0.7740	-3.6690	537.5	41.3290
11/01/06	02:28:00	50.5910	0.7750	-3.6780	538.1944444	41.2690
11/01/06	02:29:00	50.5910	0.7750	-3.6780	538.1944444	41.2690
11/01/06	02:30:00	50.6250	0.7760	-3.6780	538.8888889	41.3030
11/01/06	02:31:00	50.5560	0.7750	-3.6780	538.1944444	41.2340
11/01/06	02:32:00	50.5560	0.7750	-3.6780	538.1944444	41.2340
11/01/06	02:33:00	50.6950	0.7750	-3.6780	538.1944444	41.3730
11/01/06	02:34:00	50.6950	0.7750	-3.6780	538.1944444	41.3730
11/01/06	02:35:00	50.6950	0.7750	-3.6780	538.1944444	41.3730
11/01/06	02:36:00	50.6950	0.7750	-3.6780	538.1944444	41.3730
11/01/06	02:37:00	50.6950	0.7750	-3.6780	538.1944444	41.3730
11/01/06	02:38:00	50.6950	0.7750	-3.6780	538.1944444	41.3730
11/01/06	02:39:00	50.6950	0.7750	-3.6780	538.1944444	41.3730
11/01/06	02:40:00	50.6950	0.7750	-3.6780	538.1944444	41.3730
11/01/06	02:41:00	50.3130	0.7750	-3.7050	538.1944444	41.0180
11/01/06	02:42:00	50.3130	0.7750	-3.7050	538.1944444	41.0180
11/01/06	02:43:00	50.3470	0.7740	-3.7050	537.5	41.0520
11/01/06	02:44:00	50.3470	0.7740	-3.7050	537.5	41.0520
11/01/06	02:45:00	50.3470	0.7750	-3.7050	538.1944444	41.0520
11/01/06	02:46:00	50.2090	0.7720	-3.7140	536.1111111	40.9230
11/01/06	02:47:00	50.2090	0.7720	-3.7140	536.1111111	40.9230
11/01/06	02:48:00	50.3820	0.7740	-3.7140	537.5	41.0960
11/01/06	02:49:00	50.5910	0.7750	-3.7140	538.1944444	41.3050
11/01/06	02:50:00	50.5910	0.7750	-3.7140	538.1944444	41.3050
11/01/06	02:51:00	50.3470	0.7750	-3.7320	538.1944444	41.0790
11/01/06	02:52:00	50.3470	0.7750	-3.7320	538.1944444	41.0790
11/01/06	02:53:00	50.2780	0.7740	-3.7230	537.5	41.0010
11/01/06	02:54:00	50.2780	0.7740	-3.7230	537.5	41.0010
11/01/06	02:55:00	50.3820	0.7740	-3.7320	537.5	41.1140
11/01/06	02:56:00	50.4520	0.7740	-3.7410	537.5	41.1930
11/01/06	02:57:00	50.4520	0.7740	-3.7410	537.5	41.1930
11/01/06	02:58:00	50.4170	0.7720	-3.7590	536.1111111	41.1760
11/01/06	02:59:00	50.4170	0.7720	-3.7590	536.1111111	41.1760
11/01/06	03:00:00	50.2430	0.7730	-3.7590	536.8055556	41.0020
11/01/06	03:01:00	50.3820	0.7750	-3.7590	538.1944444	41.1410
11/01/06	03:02:00	50.3820	0.7750	-3.7590	538.1944444	41.1410
11/01/06	03:03:00	50.5560	0.7750	-3.7680	538.1944444	41.3240
11/01/06	03:04:00	50.5560	0.7750	-3.7680	538.1944444	41.3240
11/01/06	03:05:00	50.3820	0.7740	-3.7680	537.5	41.1500



**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	03:06:00	50.3820	0.7740	-3.7680	537.5	41.1500
11/01/06	03:07:00	50.3130	0.7750	-3.7860	538.1944444	41.0990
11/01/06	03:08:00	50.3470	0.7750	-3.7860	538.1944444	41.1330
11/01/06	03:09:00	50.3470	0.7750	-3.7860	538.1944444	41.1330
11/01/06	03:10:00	50.2430	0.7750	-3.7860	538.1944444	41.0290
11/01/06	03:11:00	50.2430	0.7750	-3.7860	538.1944444	41.0290
11/01/06	03:12:00	50.2090	0.7740	-3.7860	537.5	40.9950
11/01/06	03:13:00	50.4170	0.7750	-3.7860	538.1944444	41.2030
11/01/06	03:14:00	50.4170	0.7750	-3.7860	538.1944444	41.2030
11/01/06	03:15:00	50.4170	0.7750	-3.7860	538.1944444	41.2030
11/01/06	03:16:00	50.5210	0.7740	-3.7950	537.5	41.3160
11/01/06	03:17:00	50.5210	0.7740	-3.7950	537.5	41.3160
11/01/06	03:18:00	50.2430	0.7770	-3.8130	539.5833333	41.0560
11/01/06	03:19:00	50.2430	0.7770	-3.8130	539.5833333	41.0560
11/01/06	03:20:00	50.3820	0.7750	-3.8130	538.1944444	41.1950
11/01/06	03:21:00	50.3820	0.7750	-3.8130	538.1944444	41.1950
11/01/06	03:22:00	50.4520	0.7740	-3.8130	537.5	41.2650
11/01/06	03:23:00	50.4170	0.7760	-3.8130	538.8888889	41.2300
11/01/06	03:24:00	50.4170	0.7760	-3.8130	538.8888889	41.2300
11/01/06	03:25:00	50.2430	0.7730	-3.8130	536.8055556	41.0560
11/01/06	03:26:00	50.2430	0.7730	-3.8130	536.8055556	41.0560
11/01/06	03:27:00	50.3470	0.7740	-3.8220	537.5	41.1690
11/01/06	03:28:00	50.2780	0.7740	-3.8220	537.5	41.1000
11/01/06	03:29:00	50.2780	0.7740	-3.8220	537.5	41.1000
11/01/06	03:30:00	50.2090	0.7740	-3.8130	537.5	41.0220
11/01/06	03:31:00	50.2430	0.7760	-3.8130	538.8888889	41.0560
11/01/06	03:32:00	50.2430	0.7760	-3.8130	538.8888889	41.0560
11/01/06	03:33:00	50.2090	0.7740	-3.8220	537.5	41.0310
11/01/06	03:34:00	50.2090	0.7740	-3.8220	537.5	41.0310
11/01/06	03:35:00	50.2430	0.7740	-3.8400	537.5	41.0830
11/01/06	03:36:00	50.2430	0.7740	-3.8400	537.5	41.0830
11/01/06	03:37:00	50.2780	0.7730	-3.8400	536.8055556	41.1180
11/01/06	03:38:00	50.2430	0.7740	-3.8490	537.5	41.0920
11/01/06	03:39:00	50.2430	0.7740	-3.8490	537.5	41.0920
11/01/06	03:40:00	50.1740	0.7740	-3.8670	537.5	41.0410
11/01/06	03:41:00	50.1740	0.7740	-3.8670	537.5	41.0410
11/01/06	03:42:00	50.1390	0.7740	-3.8670	537.5	41.0060
11/01/06	03:43:00	50.1740	0.7740	-3.8670	537.5	41.0410
11/01/06	03:44:00	50.1740	0.7740	-3.8670	537.5	41.0410
11/01/06	03:45:00	50.1390	0.7760	-3.8760	538.8888889	41.0150
11/01/06	03:46:00	50.1040	0.7740	-3.8850	537.5	40.9890
11/01/06	03:47:00	50.1040	0.7740	-3.8850	537.5	40.9890
11/01/06	03:48:00	50.3130	0.7750	-3.8850	538.1944444	41.1980
11/01/06	03:49:00	50.2090	0.7740	-3.9030	537.5	41.1120
11/01/06	03:50:00	50.2090	0.7740	-3.9030	537.5	41.1120
11/01/06	03:51:00	50.2430	0.7750	-3.9120	538.1944444	41.1550
11/01/06	03:52:00	50.2430	0.7750	-3.9120	538.1944444	41.1550
11/01/06	03:53:00	50.2430	0.7740	-3.9120	537.5	41.1550
11/01/06	03:54:00	50.2430	0.7740	-3.9120	537.5	41.1550
11/01/06	03:55:00	50.1040	0.7740	-3.9300	537.5	41.0340
11/01/06	03:56:00	50.0700	0.7720	-3.9300	536.1111111	41.0000
11/01/06	03:57:00	50.0700	0.7720	-3.9300	536.1111111	41.0000
11/01/06	03:58:00	49.9310	0.7740	-3.9300	537.5	40.8610
11/01/06	03:59:00	49.9310	0.7740	-3.9300	537.5	40.8610
11/01/06	04:00:00	50.1040	0.7730	-3.9300	536.8055556	41.0340
11/01/06	04:01:00	49.9660	0.7740	-3.9390	537.5	40.9050
11/01/06	04:02:00	49.9660	0.7740	-3.9390	537.5	40.9050
11/01/06	04:03:00	49.8270	0.7710	-3.9390	535.4166667	40.7660
11/01/06	04:04:00	49.8270	0.7710	-3.9390	535.4166667	40.7660
11/01/06	04:05:00	50.0350	0.7720	-3.9390	536.1111111	40.9740
11/01/06	04:06:00	50.0350	0.7720	-3.9390	536.1111111	40.9740
11/01/06	04:07:00	49.9660	0.7720	-3.9570	536.1111111	40.9230
11/01/06	04:08:00	49.9660	0.7720	-3.9570	536.1111111	40.9230
11/01/06	04:09:00	49.9660	0.7720	-3.9570	536.1111111	40.9230
11/01/06	04:10:00	50.1390	0.7720	-3.9570	536.1111111	41.0960
11/01/06	04:11:00	50.1390	0.7720	-3.9570	536.1111111	41.0960
11/01/06	04:12:00	50.1390	0.7750	-3.9570	538.1944444	41.0960
11/01/06	04:13:00	50.0700	0.7740	-3.9670	537.5	41.0370
11/01/06	04:14:00	50.0700	0.7740	-3.9670	537.5	41.0370
11/01/06	04:15:00	49.9660	0.7710	-3.9760	535.4166667	40.9420
11/01/06	04:16:00	49.8610	0.7710	-3.9850	535.4166667	40.8460
11/01/06	04:17:00	49.8610	0.7710	-3.9850	535.4166667	40.8460
11/01/06	04:18:00	49.9310	0.7740	-3.9850	537.5	40.9160
11/01/06	04:19:00	49.9310	0.7740	-3.9850	537.5	40.9160

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	04:20:00	49.9660	0.7730	-3.9850	536.805556	40.9510
11/01/06	04:21:00	49.9660	0.7730	-3.9850	536.805556	40.9510
11/01/06	04:22:00	50.0350	0.7720	-3.9850	536.111111	41.0200
11/01/06	04:23:00	50.0350	0.7720	-3.9850	536.111111	41.0200
11/01/06	04:24:00	49.8610	0.7720	-3.9850	536.111111	40.8460
11/01/06	04:25:00	50.0350	0.7720	-3.9850	536.111111	41.0200
11/01/06	04:26:00	50.0350	0.7720	-3.9850	536.111111	41.0200
11/01/06	04:27:00	49.8960	0.7720	-3.9850	536.111111	40.8810
11/01/06	04:28:00	49.8960	0.7720	-3.9850	536.111111	40.8810
11/01/06	04:29:00	49.7920	0.7720	-3.9850	536.111111	40.7770
11/01/06	04:30:00	49.9310	0.7720	-3.9850	536.111111	40.9160
11/01/06	04:31:00	49.9310	0.7720	-3.9850	536.111111	40.9160
11/01/06	04:32:00	49.8960	0.7740	-3.9940	537.5	40.8900
11/01/06	04:33:00	50.0350	0.7720	-4.0030	536.111111	41.0380
11/01/06	04:34:00	50.0350	0.7720	-4.0030	536.111111	41.0380
11/01/06	04:35:00	49.9660	0.7740	-4.0120	537.5	40.9780
11/01/06	04:36:00	49.9660	0.7740	-4.0120	537.5	40.9780
11/01/06	04:37:00	49.9310	0.7730	-4.0120	536.805556	40.9430
11/01/06	04:38:00	49.9310	0.7730	-4.0120	536.805556	40.9430
11/01/06	04:39:00	49.8610	0.7720	-4.0120	536.111111	40.8730
11/01/06	04:40:00	49.8610	0.7720	-4.0120	536.111111	40.8730
11/01/06	04:41:00	49.9660	0.7710	-4.0120	535.416667	40.9780
11/01/06	04:42:00	49.9310	0.7720	-4.0120	536.111111	40.9430
11/01/06	04:43:00	49.9310	0.7720	-4.0120	536.111111	40.9430
11/01/06	04:44:00	49.8270	0.7710	-4.0210	535.416667	40.8480
11/01/06	04:45:00	49.7920	0.7710	-4.0210	535.416667	40.8130
11/01/06	04:46:00	49.7920	0.7710	-4.0210	535.416667	40.8130
11/01/06	04:47:00	49.7920	0.7730	-4.0300	536.805556	40.8220
11/01/06	04:48:00	50.0000	0.7740	-4.0390	537.5	41.0390
11/01/06	04:49:00	50.0000	0.7740	-4.0390	537.5	41.0390
11/01/06	04:50:00	49.8960	0.7740	-4.0390	537.5	40.9350
11/01/06	04:51:00	49.8960	0.7740	-4.0390	537.5	40.9350
11/01/06	04:52:00	49.8960	0.7720	-4.0390	536.111111	40.9350
11/01/06	04:53:00	49.8960	0.7720	-4.0390	536.111111	40.9350
11/01/06	04:54:00	49.7920	0.7720	-4.0480	536.111111	40.8400
11/01/06	04:55:00	49.7920	0.7720	-4.0480	536.111111	40.8400
11/01/06	04:56:00	49.7570	0.7720	-4.0480	536.111111	40.8050
11/01/06	04:57:00	49.8270	0.7730	-4.0660	536.805556	40.8930
11/01/06	04:58:00	49.8270	0.7730	-4.0660	536.805556	40.8930
11/01/06	04:59:00	49.7220	0.7710	-4.0660	535.416667	40.7880
11/01/06	05:00:00	49.8270	0.7730	-4.0660	536.805556	40.8930
11/01/06	05:01:00	49.8270	0.7730	-4.0660	536.805556	40.8930
11/01/06	05:02:00	49.6880	0.7710	-4.0660	535.416667	40.7540
11/01/06	05:03:00	49.6880	0.7710	-4.0660	535.416667	40.7540
11/01/06	05:04:00	50.1390	0.7740	-4.0750	537.5	41.2140
11/01/06	05:05:00	50.1390	0.7740	-4.0750	537.5	41.2140
11/01/06	05:06:00	49.8960	0.7710	-4.0840	535.416667	40.9800
11/01/06	05:07:00	49.9310	0.7720	-4.0840	536.111111	41.0150
11/01/06	05:08:00	49.9310	0.7720	-4.0840	536.111111	41.0150
11/01/06	05:09:00	49.8270	0.7730	-4.0930	536.805556	40.9200
11/01/06	05:10:00	49.8270	0.7730	-4.0930	536.805556	40.9200
11/01/06	05:11:00	49.8270	0.7710	-4.0930	535.416667	40.9200
11/01/06	05:12:00	50.0700	0.7720	-4.0930	536.111111	41.1630
11/01/06	05:13:00	50.0700	0.7720	-4.0930	536.111111	41.1630
11/01/06	05:14:00	49.9310	0.7720	-4.0930	536.111111	41.0240
11/01/06	05:15:00	49.8960	0.7710	-4.1020	535.416667	40.9980
11/01/06	05:16:00	49.8960	0.7710	-4.1020	535.416667	40.9980
11/01/06	05:17:00	49.6880	0.7710	-4.1020	535.416667	40.7900
11/01/06	05:18:00	49.6880	0.7710	-4.1020	535.416667	40.7900
11/01/06	05:19:00	49.9310	0.7710	-4.1110	535.416667	41.0420
11/01/06	05:20:00	49.9310	0.7710	-4.1110	535.416667	41.0420
11/01/06	05:21:00	49.6880	0.7710	-4.1110	535.416667	40.7990
11/01/06	05:22:00	49.8960	0.7720	-4.1110	536.111111	41.0070
11/01/06	05:23:00	49.8960	0.7720	-4.1110	536.111111	41.0070
11/01/06	05:24:00	49.9660	0.7730	-4.1200	536.805556	41.0860
11/01/06	05:25:00	49.9660	0.7730	-4.1200	536.805556	41.0860
11/01/06	05:26:00	49.9660	0.7720	-4.1200	536.111111	41.0860
11/01/06	05:27:00	49.9310	0.7720	-4.1200	536.111111	41.0510
11/01/06	05:28:00	49.9310	0.7720	-4.1200	536.111111	41.0510
11/01/06	05:29:00	49.7920	0.7730	-4.1200	536.805556	40.9120
11/01/06	05:30:00	49.9310	0.7710	-4.1290	535.416667	41.0600
11/01/06	05:31:00	49.9310	0.7710	-4.1290	535.416667	41.0600
11/01/06	05:32:00	49.8270	0.7700	-4.1380	534.722222	40.9650
11/01/06	05:33:00	49.9660	0.7720	-4.1470	536.111111	41.1130

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	05:34:00	49.9660	0.7720	-4.1470	536.1111111	41.1130
11/01/06	05:35:00	49.9310	0.7720	-4.1470	536.1111111	41.0780
11/01/06	05:36:00	49.9310	0.7720	-4.1470	536.1111111	41.0780
11/01/06	05:37:00	49.6880	0.7720	-4.1470	536.1111111	40.8350
11/01/06	05:38:00	49.6880	0.7720	-4.1470	536.1111111	40.8350
11/01/06	05:39:00	49.9660	0.7710	-4.1470	535.4166667	41.1130
11/01/06	05:40:00	49.9310	0.7710	-4.1470	535.4166667	41.0780
11/01/06	05:41:00	49.9310	0.7710	-4.1470	535.4166667	41.0780
11/01/06	05:42:00	49.7570	0.7710	-4.1560	535.4166667	40.9130
11/01/06	05:43:00	49.7570	0.7710	-4.1560	535.4166667	40.9130
11/01/06	05:44:00	49.7220	0.7740	-4.1560	537.5	40.8780
11/01/06	05:45:00	49.8270	0.7710	-4.1740	535.4166667	41.0010
11/01/06	05:46:00	49.8270	0.7710	-4.1740	535.4166667	41.0010
11/01/06	05:47:00	49.8610	0.7710	-4.1740	535.4166667	41.0350
11/01/06	05:48:00	49.8270	0.7690	-4.1830	534.0277778	41.0100
11/01/06	05:49:00	49.8270	0.7690	-4.1830	534.0277778	41.0100
11/01/06	05:50:00	49.7570	0.7700	-4.1830	534.7222222	40.9400
11/01/06	05:51:00	49.7570	0.7700	-4.1830	534.7222222	40.9400
11/01/06	05:52:00	49.7570	0.7710	-4.1920	535.4166667	40.9490
11/01/06	05:53:00	49.7570	0.7710	-4.1920	535.4166667	40.9490
11/01/06	05:54:00	49.8960	0.7720	-4.1830	536.1111111	41.0790
11/01/06	05:55:00	49.8960	0.7720	-4.1830	536.1111111	41.0790
11/01/06	05:56:00	49.7570	0.7710	-4.1920	535.4166667	40.9490
11/01/06	05:57:00	49.7570	0.7710	-4.1920	535.4166667	40.9490
11/01/06	05:58:00	49.7220	0.7720	-4.2010	536.1111111	40.9230
11/01/06	05:59:00	49.7220	0.7720	-4.2100	536.1111111	40.9320
11/01/06	06:00:00	49.7220	0.7720	-4.2100	536.1111111	40.9320
11/01/06	06:01:00	49.6880	0.7700	-4.2100	534.7222222	40.8980
11/01/06	06:02:00	49.6530	0.7710	-4.2190	535.4166667	40.8720
11/01/06	06:03:00	49.6530	0.7710	-4.2190	535.4166667	40.8720
11/01/06	06:04:00	49.7570	0.7710	-4.2100	535.4166667	40.9670
11/01/06	06:05:00	49.7570	0.7710	-4.2100	535.4166667	40.9670
11/01/06	06:06:00	49.6880	0.7700	-4.2190	534.7222222	40.9070
11/01/06	06:07:00	49.6880	0.7700	-4.2190	534.7222222	40.9070
11/01/06	06:08:00	49.8270	0.7710	-4.2100	535.4166667	41.0370
11/01/06	06:09:00	49.8610	0.7710	-4.2100	535.4166667	41.0710
11/01/06	06:10:00	49.8610	0.7710	-4.2100	535.4166667	41.0710
11/01/06	06:11:00	49.7570	0.7720	-4.2100	536.1111111	40.9670
11/01/06	06:12:00	49.7570	0.7720	-4.2100	536.1111111	40.9670
11/01/06	06:13:00	49.9310	0.7700	-4.2190	534.7222222	41.1500
11/01/06	06:14:00	49.7920	0.7710	-4.2010	535.4166667	40.9930
11/01/06	06:15:00	49.7570	0.7720	-4.2010	536.1111111	40.9580
11/01/06	06:16:00	49.7570	0.7720	-4.2010	536.1111111	40.9580
11/01/06	06:17:00	49.8270	0.7710	-4.2010	535.4166667	41.0280
11/01/06	06:18:00	49.8270	0.7710	-4.2010	535.4166667	41.0280
11/01/06	06:19:00	49.8960	0.7720	-4.1920	536.1111111	41.0880
11/01/06	06:20:00	49.8960	0.7720	-4.1920	536.1111111	41.0880
11/01/06	06:21:00	49.8610	0.7700	-4.1920	534.7222222	41.0530
11/01/06	06:22:00	49.8610	0.7700	-4.1920	534.7222222	41.0530
11/01/06	06:23:00	49.8610	0.7720	-4.1740	536.1111111	41.0350
11/01/06	06:24:00	49.8270	0.7720	-4.1470	536.1111111	40.9740
11/01/06	06:25:00	49.8270	0.7720	-4.1470	536.1111111	40.9740
11/01/06	06:26:00	49.8270	0.7720	-4.1470	536.1111111	40.9740
11/01/06	06:27:00	50.3820	0.7750	-4.1200	538.1944444	41.5020
11/01/06	06:28:00	50.3820	0.7750	-4.1200	538.1944444	41.5020
11/01/06	06:29:00	50.4170	0.7750	-4.0930	538.1944444	41.5100
11/01/06	06:30:00	50.1390	0.7750	-4.0750	538.1944444	41.2140
11/01/06	06:31:00	50.1390	0.7750	-4.0750	538.1944444	41.2140
11/01/06	06:32:00	50.2430	0.7730	-4.0750	536.8055556	41.3180
11/01/06	06:33:00	50.0700	0.7720	-4.0660	536.1111111	41.1360
11/01/06	06:34:00	50.0700	0.7720	-4.0660	536.1111111	41.1360
11/01/06	06:35:00	50.1390	0.7740	-4.0660	537.5	41.2050
11/01/06	06:36:00	50.1390	0.7740	-4.0660	537.5	41.2050
11/01/06	06:37:00	50.0000	0.7720	-4.0570	536.1111111	41.0570
11/01/06	06:38:00	50.0000	0.7720	-4.0570	536.1111111	41.0570
11/01/06	06:39:00	50.2430	0.7730	-4.0750	536.8055556	41.3180
11/01/06	06:40:00	50.1740	0.7710	-4.0750	535.4166667	41.2490
11/01/06	06:41:00	50.1740	0.7710	-4.0750	535.4166667	41.2490
11/01/06	06:42:00	50.2430	0.7720	-4.0750	536.1111111	41.3180
11/01/06	06:43:00	50.2430	0.7720	-4.0750	536.1111111	41.3180
11/01/06	06:44:00	50.1740	0.7710	-4.0840	535.4166667	41.2580
11/01/06	06:45:00	50.1040	0.7710	-4.0930	535.4166667	41.1970
11/01/06	06:46:00	50.1040	0.7710	-4.0930	535.4166667	41.1970
11/01/06	06:47:00	50.1740	0.7710	-4.1110	535.4166667	41.2850

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	06:48:00	50.1740	0.7710	-4.1110	535.4166667	41.2850
11/01/06	06:49:00	50.2090	0.7730	-4.1290	536.8055556	41.3380
11/01/06	06:50:00	50.2090	0.7730	-4.1290	536.8055556	41.3380
11/01/06	06:51:00	50.3130	0.7740	-4.1380	537.5	41.4510
11/01/06	06:52:00	50.3130	0.7740	-4.1380	537.5	41.4510
11/01/06	06:53:00	50.0700	0.7700	-4.1470	534.7222222	41.2170
11/01/06	06:54:00	50.1740	0.7720	-4.1560	536.1111111	41.3300
11/01/06	06:55:00	50.1740	0.7720	-4.1560	536.1111111	41.3300
11/01/06	06:56:00	50.1740	0.7720	-4.1650	536.1111111	41.3390
11/01/06	06:57:00	50.1740	0.7720	-4.1650	536.1111111	41.3390
11/01/06	06:58:00	50.2430	0.7700	-4.1650	534.7222222	41.4080
11/01/06	06:59:00	50.2430	0.7700	-4.1740	534.7222222	41.4170
11/01/06	07:00:00	50.2430	0.7700	-4.1740	534.7222222	41.4170
11/01/06	07:01:00	50.2090	0.7720	-4.1740	536.1111111	41.3830
11/01/06	07:02:00	50.2430	0.7730	-4.1470	536.8055556	41.3900
11/01/06	07:03:00	50.2430	0.7730	-4.1470	536.8055556	41.3900
11/01/06	07:04:00	50.1040	0.7720	-4.1380	536.1111111	41.2420
11/01/06	07:05:00	50.1040	0.7720	-4.1380	536.1111111	41.2420
11/01/06	07:06:00	50.2090	0.7710	-4.1110	535.4166667	41.3200
11/01/06	07:07:00	50.2090	0.7710	-4.1110	535.4166667	41.3200
11/01/06	07:08:00	50.3820	0.7740	-4.1020	537.5	41.4840
11/01/06	07:09:00	50.3820	0.7740	-4.1020	537.5	41.4840
11/01/06	07:10:00	50.3470	0.7740	-4.0750	537.5	41.4220
11/01/06	07:11:00	50.2090	0.7730	-4.0660	536.8055556	41.2750
11/01/06	07:12:00	50.2090	0.7730	-4.0660	536.8055556	41.2750
11/01/06	07:13:00	50.2430	0.7720	-4.0480	536.1111111	41.2910
11/01/06	07:14:00	50.2090	0.7740	-4.0390	537.5	41.2480
11/01/06	07:15:00	50.2090	0.7740	-4.0390	537.5	41.2480
11/01/06	07:16:00	50.2430	0.7740	-4.0300	537.5	41.2730
11/01/06	07:17:00	50.3470	0.7740	-4.0300	537.5	41.3770
11/01/06	07:18:00	50.3470	0.7740	-4.0300	537.5	41.3770
11/01/06	07:19:00	50.3470	0.7740	-4.0300	537.5	41.3770
11/01/06	07:20:00	50.1740	0.7750	-4.0300	538.1944444	41.2040
11/01/06	07:21:00	50.1740	0.7750	-4.0300	538.1944444	41.2040
11/01/06	07:22:00	50.5210	0.7760	-4.0300	538.8888889	41.5510
11/01/06	07:23:00	50.3820	0.7750	-4.0300	538.1944444	41.4120
11/01/06	07:24:00	50.3820	0.7750	-4.0300	538.1944444	41.4120
11/01/06	07:25:00	50.5910	0.7760	-4.0210	538.8888889	41.6120
11/01/06	07:26:00	50.4520	0.7740	-4.0300	537.5	41.4820
11/01/06	07:27:00	50.4520	0.7740	-4.0300	537.5	41.4820
11/01/06	07:28:00	50.2090	0.7750	-4.0300	538.1944444	41.2390
11/01/06	07:29:00	50.2780	0.7740	-4.0210	537.5	41.2990
11/01/06	07:30:00	50.2780	0.7740	-4.0210	537.5	41.2990
11/01/06	07:31:00	50.3470	0.7750	-3.9850	538.1944444	41.3320
11/01/06	07:32:00	50.3470	0.7750	-3.9850	538.1944444	41.3320
11/01/06	07:33:00	50.4860	0.7760	-3.9760	538.8888889	41.4620
11/01/06	07:34:00	50.4860	0.7760	-3.9760	538.8888889	41.4620
11/01/06	07:35:00	50.3820	0.7750	-3.9670	538.1944444	41.3490
11/01/06	07:36:00	50.3820	0.7750	-3.9670	538.1944444	41.3490
11/01/06	07:37:00	50.3820	0.7760	-3.9760	538.8888889	41.3580
11/01/06	07:38:00	50.2430	0.7750	-3.9570	538.1944444	41.2000
11/01/06	07:39:00	50.2430	0.7750	-3.9570	538.1944444	41.2000
11/01/06	07:40:00	50.3820	0.7760	-3.9570	538.8888889	41.3390
11/01/06	07:41:00	50.3820	0.7760	-3.9570	538.8888889	41.3390
11/01/06	07:42:00	50.4520	0.7770	-3.9570	539.5833333	41.4090
11/01/06	07:43:00	50.4860	0.7770	-3.9390	539.5833333	41.4250
11/01/06	07:44:00	50.4860	0.7770	-3.9390	539.5833333	41.4250
11/01/06	07:45:00	50.3470	0.7770	-3.9390	539.5833333	41.2860
11/01/06	07:46:00	50.3820	0.7760	-3.9300	538.8888889	41.3120
11/01/06	07:47:00	50.3820	0.7760	-3.9300	538.8888889	41.3120
11/01/06	07:48:00	50.5210	0.7760	-3.8670	538.8888889	41.3880
11/01/06	07:49:00	50.5210	0.7760	-3.8670	538.8888889	41.3880
11/01/06	07:50:00	50.4860	0.7770	-3.8220	539.5833333	41.3080
11/01/06	07:51:00	50.4860	0.7770	-3.8220	539.5833333	41.3080
11/01/06	07:52:00	50.4520	0.7770	-3.8130	539.5833333	41.2650
11/01/06	07:53:00	50.4520	0.7770	-3.8130	539.5833333	41.2650
11/01/06	07:54:00	50.6950	0.7780	-3.7860	540.2777778	41.4810
11/01/06	07:55:00	50.3130	0.7760	-3.7680	538.8888889	41.0810
11/01/06	07:56:00	50.3130	0.7760	-3.7680	538.8888889	41.0810
11/01/06	07:57:00	50.4860	0.7780	-3.7590	540.2777778	41.2450
11/01/06	07:58:00	50.4860	0.7780	-3.7590	540.2777778	41.2450
11/01/06	07:59:00	50.4520	0.7770	-3.7590	539.5833333	41.2110
11/01/06	08:00:00	50.7290	0.7780	-3.6960	540.2777778	41.4250
11/01/06	08:01:00	50.7290	0.7780	-3.6960	540.2777778	41.4250

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	08:02:00	50.7990	0.7790	-3.6230	540.9722222	41.4220
11/01/06	08:03:00	50.7990	0.7790	-3.6230	540.9722222	41.4220
11/01/06	08:04:00	50.7990	0.7790	-3.6230	540.9722222	41.4220
11/01/06	08:05:00	50.7290	0.7800	-3.5060	541.6666667	41.2350
11/01/06	08:06:00	51.0070	0.7800	-3.4250	541.6666667	41.4320
11/01/06	08:07:00	51.0070	0.7800	-3.4250	541.6666667	41.4320
11/01/06	08:08:00	50.7990	0.7800	-3.3980	541.6666667	41.1970
11/01/06	08:09:00	50.7990	0.7800	-3.3980	541.6666667	41.1970
11/01/06	08:10:00	50.8680	0.7810	-3.3710	542.3611111	41.2390
11/01/06	08:11:00	50.9380	0.7810	-3.3710	542.3611111	41.3090
11/01/06	08:12:00	50.9380	0.7810	-3.3710	542.3611111	41.3090
11/01/06	08:13:00	51.2160	0.7830	-3.3440	543.75	41.5600
11/01/06	08:14:00	51.0770	0.7830	-3.3170	543.75	41.3940
11/01/06	08:15:00	51.0770	0.7830	-3.3170	543.75	41.3940
11/01/06	08:16:00	51.2160	0.7840	-3.2890	544.4444444	41.5050
11/01/06	08:17:00	51.1460	0.7840	-3.2890	544.4444444	41.4350
11/01/06	08:18:00	51.1460	0.7840	-3.2890	544.4444444	41.4350
11/01/06	08:19:00	51.1460	0.7840	-3.2800	544.4444444	41.4260
11/01/06	08:20:00	51.1460	0.7840	-3.2800	544.4444444	41.4260
11/01/06	08:21:00	50.9720	0.7810	-3.2800	542.3611111	41.2520
11/01/06	08:22:00	50.9720	0.7810	-3.2800	542.3611111	41.2520
11/01/06	08:23:00	51.2500	0.7860	-3.2620	545.8333333	41.5120
11/01/06	08:24:00	51.3540	0.7860	-3.2530	545.8333333	41.6070
11/01/06	08:25:00	51.3540	0.7860	-3.2530	545.8333333	41.6070
11/01/06	08:26:00	51.2160	0.7840	-3.2530	544.4444444	41.4690
11/01/06	08:27:00	51.2160	0.7840	-3.2530	544.4444444	41.4690
11/01/06	08:28:00	51.1110	0.7840	-3.2530	544.4444444	41.3640
11/01/06	08:29:00	51.3540	0.7830	-3.2620	543.75	41.6160
11/01/06	08:30:00	51.2160	0.7830	-3.2620	543.75	41.4780
11/01/06	08:31:00	51.2160	0.7830	-3.2620	543.75	41.4780
11/01/06	08:32:00	51.3200	0.7840	-3.2350	544.4444444	41.5550
11/01/06	08:33:00	51.3200	0.7840	-3.2350	544.4444444	41.5550
11/01/06	08:34:00	51.4240	0.7860	-3.2260	545.8333333	41.6500
11/01/06	08:35:00	51.4240	0.7860	-3.2260	545.8333333	41.6500
11/01/06	08:36:00	51.2850	0.7820	-3.2260	543.0555556	41.5110
11/01/06	08:37:00	51.2160	0.7850	-3.1990	545.1388889	41.4150
11/01/06	08:38:00	51.2160	0.7850	-3.1990	545.1388889	41.4150
11/01/06	08:39:00	51.2160	0.7840	-3.1720	544.4444444	41.3880
11/01/06	08:40:00	51.2160	0.7840	-3.1720	544.4444444	41.3880
11/01/06	08:41:00	51.3890	0.7850	-3.1450	545.1388889	41.5340
11/01/06	08:42:00	51.2160	0.7860	-3.1270	545.8333333	41.3430
11/01/06	08:43:00	51.2160	0.7860	-3.1270	545.8333333	41.3430
11/01/06	08:44:00	51.3540	0.7860	-3.1270	545.8333333	41.4810
11/01/06	08:45:00	51.3540	0.7860	-3.1270	545.8333333	41.4810
11/01/06	08:46:00	51.3200	0.7860	-3.1270	545.8333333	41.4470
11/01/06	08:47:00	51.3200	0.7860	-3.1270	545.8333333	41.4470
11/01/06	08:48:00	51.3540	0.7870	-3.1180	546.5277778	41.4720
11/01/06	08:49:00	51.3540	0.7870	-3.1180	546.5277778	41.4720
11/01/06	08:50:00	51.1460	0.7860	-3.1180	545.8333333	41.2640
11/01/06	08:51:00	51.1460	0.7860	-3.1180	545.8333333	41.2640
11/01/06	08:52:00	51.1460	0.7870	-3.0910	546.5277778	41.2370
11/01/06	08:53:00	51.1460	0.7870	-3.0910	546.5277778	41.2370
11/01/06	08:54:00	51.0770	0.7850	-3.0820	545.1388889	41.1590
11/01/06	08:55:00	50.9380	0.7850	-3.0640	545.1388889	41.0020
11/01/06	08:56:00	50.9380	0.7850	-3.0640	545.1388889	41.0020
11/01/06	08:57:00	50.9720	0.7870	-3.0640	546.5277778	41.0360
11/01/06	08:58:00	51.1110	0.7860	-3.0370	545.8333333	41.1480
11/01/06	08:59:00	51.1110	0.7860	-3.0370	545.8333333	41.1480
11/01/06	09:00:00	51.3200	0.7850	-3.0190	545.1388889	41.3390
11/01/06	09:01:00	51.3540	0.7870	-3.0010	546.5277778	41.3550
11/01/06	09:02:00	51.3540	0.7870	-3.0010	546.5277778	41.3550
11/01/06	09:03:00	51.3540	0.7870	-2.9730	546.5277778	41.3270
11/01/06	09:04:00	51.3540	0.7870	-2.9730	546.5277778	41.3270
11/01/06	09:05:00	51.2160	0.7860	-2.9820	545.8333333	41.1980
11/01/06	09:06:00	51.2160	0.7860	-2.9820	545.8333333	41.1980
11/01/06	09:07:00	51.2160	0.7840	-2.9820	544.4444444	41.1980
11/01/06	09:08:00	51.2160	0.7840	-2.9820	544.4444444	41.1980
11/01/06	09:09:00	51.2500	0.7870	-2.9820	546.5277778	41.2320
11/01/06	09:10:00	51.2500	0.7870	-2.9820	546.5277778	41.2320
11/01/06	09:11:00	51.3890	0.7860	-2.9730	545.8333333	41.3620
11/01/06	09:12:00	51.4590	0.7860	-2.9460	545.8333333	41.4050
11/01/06	09:13:00	51.4590	0.7860	-2.9460	545.8333333	41.4050
11/01/06	09:14:00	51.4240	0.7860	-2.9460	545.8333333	41.3700
11/01/06	09:15:00	51.4590	0.7860	-2.9190	545.8333333	41.3780

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	09:16:00	51.4590	0.7860	-2.9190	545.8333333	41.3780
11/01/06	09:17:00	51.5280	0.7870	-2.8920	546.5277778	41.4200
11/01/06	09:18:00	51.5280	0.7870	-2.8920	546.5277778	41.4200
11/01/06	09:19:00	51.4930	0.7870	-2.8920	546.5277778	41.3850
11/01/06	09:20:00	51.4930	0.7870	-2.8920	546.5277778	41.3850
11/01/06	09:21:00	51.4930	0.7870	-2.9010	546.5277778	41.3940
11/01/06	09:22:00	51.4930	0.7870	-2.9010	546.5277778	41.3940
11/01/06	09:23:00	51.3890	0.7880	-2.8920	547.2222222	41.2810
11/01/06	09:24:00	51.3890	0.7880	-2.8920	547.2222222	41.2810
11/01/06	09:25:00	51.5630	0.7870	-2.8740	546.5277778	41.4370
11/01/06	09:26:00	51.4930	0.7880	-2.8650	547.2222222	41.3580
11/01/06	09:27:00	51.4930	0.7880	-2.8650	547.2222222	41.3580
11/01/06	09:28:00	51.5630	0.7880	-2.8650	547.2222222	41.4280
11/01/06	09:29:00	51.5630	0.7880	-2.8650	547.2222222	41.4280
11/01/06	09:30:00	51.4930	0.7870	-2.8650	546.5277778	41.3580
11/01/06	09:31:00	51.4240	0.7890	-2.8650	547.9166667	41.2890
11/01/06	09:32:00	51.4240	0.7890	-2.8650	547.9166667	41.2890
11/01/06	09:33:00	51.3200	0.7870	-2.8470	546.5277778	41.1670
11/01/06	09:34:00	51.3200	0.7870	-2.8470	546.5277778	41.1670
11/01/06	09:35:00	51.4590	0.7880	-2.8380	547.2222222	41.2970
11/01/06	09:36:00	51.4590	0.7880	-2.8380	547.2222222	41.2970
11/01/06	09:37:00	51.4590	0.7890	-2.8290	547.9166667	41.2880
11/01/06	09:38:00	51.4590	0.7890	-2.8290	547.9166667	41.2880
11/01/06	09:39:00	51.4240	0.7890	-2.8200	547.9166667	41.2440
11/01/06	09:40:00	51.4930	0.7880	-2.8110	547.2222222	41.3040
11/01/06	09:41:00	51.4930	0.7880	-2.8110	547.2222222	41.3040
11/01/06	09:42:00	51.4930	0.7900	-2.8110	548.6111111	41.3040
11/01/06	09:43:00	51.4930	0.7900	-2.8110	548.6111111	41.3040
11/01/06	09:44:00	51.4590	0.7890	-2.8110	547.9166667	41.2700
11/01/06	09:45:00	51.5630	0.7890	-2.8110	547.9166667	41.3740
11/01/06	09:46:00	51.5630	0.7890	-2.8110	547.9166667	41.3740
11/01/06	09:47:00	51.3890	0.7890	-2.8110	547.9166667	41.2000
11/01/06	09:48:00	51.5280	0.7880	-2.7840	547.2222222	41.3120
11/01/06	09:49:00	51.5280	0.7880	-2.7840	547.2222222	41.3120
11/01/06	09:50:00	51.4590	0.7880	-2.7840	547.2222222	41.2430
11/01/06	09:51:00	51.4590	0.7880	-2.7840	547.2222222	41.2430
11/01/06	09:52:00	51.5970	0.7860	-2.7840	545.8333333	41.3810
11/01/06	09:53:00	51.5970	0.7860	-2.7840	545.8333333	41.3810
11/01/06	09:54:00	51.5280	0.7870	-2.7840	546.5277778	41.3120
11/01/06	09:55:00	51.5630	0.7870	-2.7840	546.5277778	41.3470
11/01/06	09:56:00	51.5630	0.7870	-2.7840	546.5277778	41.3470
11/01/06	09:57:00	51.5630	0.7870	-2.7840	546.5277778	41.3470
11/01/06	09:58:00	51.5630	0.7870	-2.7840	546.5277778	41.3470
11/01/06	09:59:00	51.5970	0.7880	-2.7840	547.2222222	41.3810
11/01/06	10:00:00	51.6670	0.7880	-2.7840	547.2222222	41.4510
11/01/06	10:01:00	51.4930	0.7880	-2.7840	547.2222222	41.2770
11/01/06	10:02:00	51.4930	0.7880	-2.7660	547.2222222	41.2590
11/01/06	10:03:00	51.4930	0.7880	-2.7660	547.2222222	41.2590
11/01/06	10:04:00	51.5970	0.7880	-2.7570	547.2222222	41.3540
11/01/06	10:05:00	51.5970	0.7880	-2.7570	547.2222222	41.3540
11/01/06	10:06:00	51.6320	0.7860	-2.7300	545.8333333	41.3620
11/01/06	10:07:00	51.6320	0.7860	-2.7300	545.8333333	41.3620
11/01/06	10:08:00	51.5280	0.7890	-2.7300	547.9166667	41.2580
11/01/06	10:09:00	51.6320	0.7870	-2.7300	546.5277778	41.3620
11/01/06	10:10:00	51.6320	0.7870	-2.7300	546.5277778	41.3620
11/01/06	10:11:00	51.8060	0.7870	-2.7300	546.5277778	41.5360
11/01/06	10:12:00	51.8060	0.7870	-2.7300	546.5277778	41.5360
11/01/06	10:13:00	51.7020	0.7870	-2.7300	546.5277778	41.4320
11/01/06	10:14:00	51.5970	0.7880	-2.7210	547.2222222	41.3180
11/01/06	10:15:00	51.6320	0.7880	-2.7210	547.2222222	41.3530
11/01/06	10:16:00	51.6320	0.7880	-2.7300	547.2222222	41.3620
11/01/06	10:17:00	51.7020	0.7890	-2.7300	547.9166667	41.4320
11/01/06	10:18:00	51.7020	0.7890	-2.7300	547.9166667	41.4320
11/01/06	10:19:00	51.7020	0.7870	-2.7300	546.5277778	41.4320
11/01/06	10:20:00	51.7020	0.7870	-2.7300	546.5277778	41.4320
11/01/06	10:21:00	51.8410	0.7890	-2.7300	547.9166667	41.5710
11/01/06	10:22:00	51.8410	0.7890	-2.7300	547.9166667	41.5710
11/01/06	10:23:00	51.5970	0.7900	-2.7210	548.6111111	41.3180
11/01/06	10:24:00	51.5970	0.7900	-2.7210	548.6111111	41.3180
11/01/06	10:25:00	51.5970	0.7890	-2.7120	547.9166667	41.3090
11/01/06	10:26:00	51.6670	0.7900	-2.6940	548.6111111	41.3610
11/01/06	10:27:00	51.6670	0.7900	-2.6940	548.6111111	41.3610
11/01/06	10:28:00	51.7020	0.7900	-2.6480	548.6111111	41.3500
11/01/06	10:29:00	51.7360	0.7900	-2.5940	548.6111111	41.3300

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	10:30:00	51.7360	0.7890	-2.5940	547.9166667	41.3300
11/01/06	10:31:00	51.8750	0.7910	-2.5310	549.3055556	41.4060
11/01/06	10:32:00	51.8750	0.7910	-2.5310	549.3055556	41.4060
11/01/06	10:33:00	51.8750	0.7920	-2.4320	550	41.3070
11/01/06	10:34:00	51.8750	0.7920	-2.4320	550	41.3070
11/01/06	10:35:00	52.1880	0.7930	-2.3960	550.6944444	41.5840
11/01/06	10:36:00	52.1880	0.7930	-2.3960	550.6944444	41.5840
11/01/06	10:37:00	52.0840	0.7910	-2.3690	549.3055556	41.4530
11/01/06	10:38:00	52.0840	0.7910	-2.3690	549.3055556	41.4530
11/01/06	10:39:00	52.0840	0.7910	-2.3690	549.3055556	41.4530
11/01/06	10:40:00	52.1880	0.7910	-2.3870	549.3055556	41.5750
11/01/06	10:41:00	52.1880	0.7910	-2.3870	549.3055556	41.5750
11/01/06	10:42:00	52.1180	0.7910	-2.3870	549.3055556	41.5050
11/01/06	10:43:00	51.9790	0.7900	-2.3870	548.6111111	41.3660
11/01/06	10:44:00	51.9790	0.7900	-2.3870	548.6111111	41.3660
11/01/06	10:45:00	51.9790	0.7900	-2.3870	548.6111111	41.3660
11/01/06	10:46:00	52.0140	0.7900	-2.3870	548.6111111	41.4010
11/01/06	10:47:00	52.0140	0.7900	-2.3870	548.6111111	41.4010
11/01/06	10:48:00	52.0140	0.7910	-2.3870	549.3055556	41.4010
11/01/06	10:49:00	52.0140	0.7910	-2.3870	549.3055556	41.4010
11/01/06	10:50:00	52.0840	0.7910	-2.3870	549.3055556	41.4710
11/01/06	10:51:00	52.0840	0.7910	-2.3870	549.3055556	41.4710
11/01/06	10:52:00	52.0840	0.7910	-2.3870	549.3055556	41.4710
11/01/06	10:53:00	52.0840	0.7910	-2.3870	549.3055556	41.4710
11/01/06	10:54:00	51.7710	0.7890	-2.3870	547.9166667	41.1580
11/01/06	10:55:00	51.7710	0.7890	-2.3870	547.9166667	41.1580
11/01/06	10:56:00	52.0140	0.7900	-2.3870	548.6111111	41.4010
11/01/06	10:57:00	52.0140	0.7900	-2.3870	548.6111111	41.4010
11/01/06	10:58:00	52.0490	0.7900	-2.3870	548.6111111	41.4360
11/01/06	10:59:00	51.9790	0.7910	-2.3870	549.3055556	41.3660
11/01/06	11:00:00	51.9790	0.7910	-2.3870	549.3055556	41.3660
11/01/06	11:01:00	52.0140	0.7900	-2.3870	548.6111111	41.4010
11/01/06	11:02:00	52.0140	0.7900	-2.3870	548.6111111	41.4010
11/01/06	11:03:00	52.2220	0.7910	-2.3870	549.3055556	41.6090
11/01/06	11:04:00	52.2220	0.7910	-2.3870	549.3055556	41.6090
11/01/06	11:05:00	52.0840	0.7910	-2.3600	549.3055556	41.4440
11/01/06	11:06:00	52.0840	0.7910	-2.3600	549.3055556	41.4440
11/01/06	11:07:00	52.2220	0.7920	-2.3600	550	41.5820
11/01/06	11:08:00	52.2220	0.7920	-2.3600	550	41.5820
11/01/06	11:09:00	52.1880	0.7910	-2.3320	549.3055556	41.5200
11/01/06	11:10:00	51.9450	0.7890	-2.3320	547.9166667	41.2770
11/01/06	11:11:00	51.9450	0.7890	-2.3320	547.9166667	41.2770
11/01/06	11:12:00	51.9100	0.7900	-2.3230	548.6111111	41.2330
11/01/06	11:13:00	52.0840	0.7900	-2.3050	548.6111111	41.3890
11/01/06	11:14:00	52.0840	0.7900	-2.3050	548.6111111	41.3890
11/01/06	11:15:00	52.0490	0.7910	-2.3050	549.3055556	41.3540
11/01/06	11:16:00	52.0840	0.7900	-2.3050	548.6111111	41.3890
11/01/06	11:17:00	52.0840	0.7900	-2.3050	548.6111111	41.3890
11/01/06	11:18:00	52.1880	0.7920	-2.3050	550	41.4930
11/01/06	11:19:00	52.1880	0.7920	-2.3050	550	41.4930
11/01/06	11:20:00	52.2570	0.7910	-2.2780	549.3055556	41.5350
11/01/06	11:21:00	52.2570	0.7910	-2.2780	549.3055556	41.5350
11/01/06	11:22:00	52.1530	0.7900	-2.2780	548.6111111	41.4310
11/01/06	11:23:00	52.1880	0.7910	-2.2510	549.3055556	41.4390
11/01/06	11:24:00	52.1880	0.7910	-2.2510	549.3055556	41.4390
11/01/06	11:25:00	52.2220	0.7920	-2.2420	550	41.4640
11/01/06	11:26:00	52.2220	0.7920	-2.2420	550	41.4640
11/01/06	11:27:00	52.1180	0.7910	-2.2330	549.3055556	41.3510
11/01/06	11:28:00	52.1880	0.7910	-2.2240	549.3055556	41.4120
11/01/06	11:29:00	52.1880	0.7910	-2.2240	549.3055556	41.4120
11/01/06	11:30:00	52.2920	0.7900	-2.2240	548.6111111	41.5160
11/01/06	11:31:00	52.2570	0.7900	-2.2240	548.6111111	41.4810
11/01/06	11:32:00	52.2570	0.7900	-2.2240	548.6111111	41.4810
11/01/06	11:33:00	52.1530	0.7910	-2.2240	549.3055556	41.3770
11/01/06	11:34:00	52.1530	0.7910	-2.2240	549.3055556	41.3770
11/01/06	11:35:00	52.1880	0.7910	-2.2240	549.3055556	41.4120
11/01/06	11:36:00	52.1880	0.7910	-2.2240	549.3055556	41.4120
11/01/06	11:37:00	52.1880	0.7910	-2.2240	549.3055556	41.4120
11/01/06	11:38:00	52.1880	0.7910	-2.2240	549.3055556	41.4120
11/01/06	11:39:00	52.1880	0.7920	-2.2150	550	41.4030
11/01/06	11:40:00	52.1880	0.7920	-2.2150	550	41.4030
11/01/06	11:41:00	52.1880	0.7920	-2.2060	550	41.3940
11/01/06	11:42:00	52.2220	0.7910	-2.1970	549.3055556	41.4190
11/01/06	11:43:00	52.2220	0.7910	-2.1970	549.3055556	41.4190

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	11:44:00	52.1180	0.7920	-2.1970	550	41.3150
11/01/06	11:45:00	52.1180	0.7920	-2.1970	550	41.3150
11/01/06	11:46:00	52.1530	0.7910	-2.1970	549.3055556	41.3500
11/01/06	11:47:00	52.3270	0.7910	-2.1970	549.3055556	41.5240
11/01/06	11:48:00	52.3270	0.7910	-2.1970	549.3055556	41.5240
11/01/06	11:49:00	52.2570	0.7920	-2.1970	550	41.4540
11/01/06	11:50:00	52.2570	0.7920	-2.1970	550	41.4540
11/01/06	11:51:00	52.3610	0.7930	-2.1880	550.6944444	41.5490
11/01/06	11:52:00	52.3610	0.7930	-2.1880	550.6944444	41.5490
11/01/06	11:53:00	52.3610	0.7920	-2.1790	550	41.5400
11/01/06	11:54:00	52.3610	0.7920	-2.1790	550	41.5400
11/01/06	11:55:00	52.2220	0.7920	-2.1700	550	41.3920
11/01/06	11:56:00	52.3270	0.7920	-2.1700	550	41.4970
11/01/06	11:57:00	52.3270	0.7920	-2.1700	550	41.4970
11/01/06	11:58:00	52.2920	0.7920	-2.1610	550	41.4530
11/01/06	11:59:00	52.3270	0.7920	-2.1520	550	41.4790
11/01/06	12:00:00	52.3270	0.7920	-2.1520	550	41.4790
11/01/06	12:01:00	52.3610	0.7920	-2.1340	550	41.4950
11/01/06	12:02:00	52.3610	0.7920	-2.1340	550	41.4950
11/01/06	12:03:00	52.3270	0.7920	-2.1430	550	41.4700
11/01/06	12:04:00	52.3270	0.7920	-2.1430	550	41.4700
11/01/06	12:05:00	52.2570	0.7900	-2.1430	548.6111111	41.4000
11/01/06	12:06:00	52.2570	0.7900	-2.1430	548.6111111	41.4000
11/01/06	12:07:00	52.3270	0.7910	-2.1430	549.3055556	41.4700
11/01/06	12:08:00	52.2220	0.7940	-2.1430	551.3888889	41.3650
11/01/06	12:09:00	52.2220	0.7940	-2.1430	551.3888889	41.3650
11/01/06	12:10:00	52.3610	0.7920	-2.1430	550	41.5040
11/01/06	12:11:00	52.3270	0.7920	-2.1430	550	41.4700
11/01/06	12:12:00	52.3270	0.7920	-2.1430	550	41.4700
11/01/06	12:13:00	52.3270	0.7930	-2.1430	550.6944444	41.4700
11/01/06	12:14:00	52.3960	0.7910	-2.1430	549.3055556	41.5390
11/01/06	12:15:00	52.3960	0.7910	-2.1430	549.3055556	41.5390
11/01/06	12:16:00	52.2220	0.7920	-2.1430	550	41.3650
11/01/06	12:17:00	52.4310	0.7920	-2.1340	550	41.5650
11/01/06	12:18:00	52.4310	0.7920	-2.1340	550	41.5650
11/01/06	12:19:00	52.2920	0.7920	-2.1430	550	41.4350
11/01/06	12:20:00	52.2920	0.7920	-2.1430	550	41.4350
11/01/06	12:21:00	52.2570	0.7920	-2.1340	550	41.3910
11/01/06	12:22:00	52.2570	0.7920	-2.1340	550	41.3910
11/01/06	12:23:00	52.3270	0.7910	-2.1340	549.3055556	41.4610
11/01/06	12:24:00	52.3270	0.7910	-2.1340	549.3055556	41.4610
11/01/06	12:25:00	52.3270	0.7930	-2.1340	550.6944444	41.4610
11/01/06	12:26:00	52.2570	0.7910	-2.1340	549.3055556	41.3910
11/01/06	12:27:00	52.2570	0.7910	-2.1340	549.3055556	41.3910
11/01/06	12:28:00	52.2570	0.7940	-2.1250	551.3888889	41.3820
11/01/06	12:29:00	52.3610	0.7920	-2.1070	550	41.4680
11/01/06	12:30:00	52.3610	0.7920	-2.1070	550	41.4680
11/01/06	12:31:00	52.4660	0.7920	-2.0890	550	41.5550
11/01/06	12:32:00	52.5000	0.7920	-2.0620	550	41.5620
11/01/06	12:33:00	52.5000	0.7920	-2.0620	550	41.5620
11/01/06	12:34:00	52.5350	0.7930	-2.0440	550.6944444	41.5790
11/01/06	12:35:00	52.5350	0.7930	-2.0440	550.6944444	41.5790
11/01/06	12:36:00	52.4660	0.7930	-2.0260	550.6944444	41.4920
11/01/06	12:37:00	52.4660	0.7930	-2.0260	550.6944444	41.4920
11/01/06	12:38:00	52.5000	0.7940	-1.9980	551.3888889	41.4980
11/01/06	12:39:00	52.5350	0.7940	-1.9710	551.3888889	41.5060
11/01/06	12:40:00	52.5350	0.7940	-1.9710	551.3888889	41.5060
11/01/06	12:41:00	52.5350	0.7940	-1.9440	551.3888889	41.4790
11/01/06	12:42:00	52.5350	0.7940	-1.9440	551.3888889	41.4790
11/01/06	12:43:00	52.5700	0.7950	-1.9170	552.0833333	41.4870
11/01/06	12:44:00	52.5350	0.7950	-1.8900	552.0833333	41.4250
11/01/06	12:45:00	52.5350	0.7950	-1.8900	552.0833333	41.4250
11/01/06	12:46:00	52.6040	0.7930	-1.8900	550.6944444	41.4940
11/01/06	12:47:00	52.4310	0.7940	-1.8720	551.3888889	41.3030
11/01/06	12:48:00	52.4310	0.7940	-1.8720	551.3888889	41.3030
11/01/06	12:49:00	52.5700	0.7950	-1.8630	552.0833333	41.4330
11/01/06	12:50:00	52.5700	0.7950	-1.8630	552.0833333	41.4330
11/01/06	12:51:00	52.5350	0.7940	-1.8630	551.3888889	41.3980
11/01/06	12:52:00	52.5350	0.7940	-1.8630	551.3888889	41.3980
11/01/06	12:53:00	52.7430	0.7950	-1.8360	552.0833333	41.5790
11/01/06	12:54:00	52.7430	0.7950	-1.8090	552.0833333	41.5520
11/01/06	12:55:00	52.7430	0.7950	-1.8090	552.0833333	41.5520
11/01/06	12:56:00	52.7780	0.7940	-1.7820	551.3888889	41.5600
11/01/06	12:57:00	52.7780	0.7940	-1.7820	551.3888889	41.5600



**KAHANAHOU WWPS SCADA DATA  
OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	12:58:00	52.8130	0.7970	-1.7550	553.4722222	41.5680
11/01/06	12:59:00	52.7430	0.7950	-1.7190	552.0833333	41.4620
11/01/06	13:00:00	52.7430	0.7950	-1.7190	552.0833333	41.4620
11/01/06	13:01:00	53.0210	0.7970	-1.6640	553.4722222	41.6850
11/01/06	13:02:00	53.0210	0.7970	-1.6640	553.4722222	41.6850
11/01/06	13:03:00	52.9520	0.7980	-1.6100	554.1666667	41.5620
11/01/06	13:04:00	52.9520	0.7980	-1.6100	554.1666667	41.5620
11/01/06	13:05:00	53.0560	0.7980	-1.5830	554.1666667	41.6390
11/01/06	13:06:00	53.0210	0.7990	-1.5830	554.8611111	41.6040
11/01/06	13:07:00	53.0210	0.7990	-1.5830	554.8611111	41.6040
11/01/06	13:08:00	52.9520	0.7980	-1.5560	554.1666667	41.5080
11/01/06	13:09:00	52.9520	0.7980	-1.5560	554.1666667	41.5080
11/01/06	13:10:00	53.0910	0.8000	-1.5020	555.5555556	41.5930
11/01/06	13:11:00	53.0210	0.7980	-1.5020	554.1666667	41.5230
11/01/06	13:12:00	53.0210	0.7980	-1.5020	554.1666667	41.5230
11/01/06	13:13:00	52.8470	0.7990	-1.5020	554.8611111	41.3490
11/01/06	13:14:00	52.8470	0.7990	-1.5020	554.8611111	41.3490
11/01/06	13:15:00	52.9520	0.7990	-1.4750	554.8611111	41.4270
11/01/06	13:16:00	53.1600	0.7990	-1.4750	554.8611111	41.6350
11/01/06	13:17:00	53.1600	0.7990	-1.4750	554.8611111	41.6350
11/01/06	13:18:00	53.1600	0.7990	-1.4750	554.8611111	41.6350
11/01/06	13:19:00	53.1600	0.7990	-1.4750	554.8611111	41.6350
11/01/06	13:20:00	52.9520	0.7960	-1.4750	552.7777778	41.4270
11/01/06	13:21:00	52.9520	0.7960	-1.4750	552.7777778	41.4270
11/01/06	13:22:00	52.9520	0.7960	-1.4480	552.7777778	41.4000
11/01/06	13:23:00	53.0910	0.7980	-1.4480	554.1666667	41.5390
11/01/06	13:24:00	53.0910	0.7980	-1.4480	554.1666667	41.5390
11/01/06	13:25:00	53.0560	0.7990	-1.4210	554.8611111	41.4770
11/01/06	13:26:00	53.0560	0.7990	-1.4210	554.8611111	41.4770
11/01/06	13:27:00	53.1600	0.7990	-1.4210	554.8611111	41.5810
11/01/06	13:28:00	53.1600	0.7990	-1.4210	554.8611111	41.5810
11/01/06	13:29:00	53.0910	0.7990	-1.4210	554.8611111	41.5120
11/01/06	13:30:00	53.0560	0.8020	-1.4210	556.9444444	41.4770
11/01/06	13:31:00	53.1250	0.7990	-1.4210	554.8611111	41.5460
11/01/06	13:32:00	53.1250	0.7990	-1.4210	554.8611111	41.5460
11/01/06	13:33:00	53.1250	0.8000	-1.4210	555.5555556	41.5460
11/01/06	13:34:00	53.1250	0.8000	-1.4210	555.5555556	41.5460
11/01/06	13:35:00	53.2990	0.7990	-1.4210	554.8611111	41.7200
11/01/06	13:36:00	53.2990	0.7990	-1.4210	554.8611111	41.7200
11/01/06	13:37:00	52.9170	0.7990	-1.4120	554.8611111	41.3290
11/01/06	13:38:00	52.9170	0.7990	-1.4120	554.8611111	41.3290
11/01/06	13:39:00	53.0210	0.7990	-1.4210	554.8611111	41.4420
11/01/06	13:40:00	52.9860	0.7990	-1.4210	554.8611111	41.4070
11/01/06	13:41:00	52.9860	0.7990	-1.4210	554.8611111	41.4070
11/01/06	13:42:00	53.0210	0.7980	-1.4210	554.1666667	41.4420
11/01/06	13:43:00	53.0210	0.7980	-1.4210	554.1666667	41.4420
11/01/06	13:44:00	53.1250	0.7980	-1.3940	554.1666667	41.5190
11/01/06	13:45:00	53.0910	0.7990	-1.3850	554.8611111	41.4760
11/01/06	13:46:00	53.0910	0.7990	-1.3850	554.8611111	41.4760
11/01/06	13:47:00	53.1250	0.7980	-1.3940	554.1666667	41.5190
11/01/06	13:48:00	52.9860	0.8000	-1.3940	555.5555556	41.3800
11/01/06	13:49:00	52.9860	0.8000	-1.3940	555.5555556	41.3800
11/01/06	13:50:00	53.1600	0.8000	-1.3850	555.5555556	41.5450
11/01/06	13:51:00	53.1600	0.8000	-1.3850	555.5555556	41.5450
11/01/06	13:52:00	53.0910	0.8010	-1.3850	556.25	41.4760
11/01/06	13:53:00	53.0910	0.8010	-1.3850	556.25	41.4760
11/01/06	13:54:00	53.3340	0.8000	-1.3850	555.5555556	41.7190
11/01/06	13:55:00	53.3340	0.8000	-1.3850	555.5555556	41.7190
11/01/06	13:56:00	52.9170	0.7980	-1.3940	554.1666667	41.3110
11/01/06	13:57:00	52.9170	0.7980	-1.3940	554.1666667	41.3110
11/01/06	13:58:00	53.2290	0.8000	-1.3940	555.5555556	41.6230
11/01/06	13:59:00	53.2290	0.8000	-1.3940	555.5555556	41.6230
11/01/06	14:00:00	53.1250	0.8000	-1.3850	555.5555556	41.5100
11/01/06	14:01:00	53.2640	0.8000	-1.3940	555.5555556	41.6580
11/01/06	14:02:00	53.2640	0.8000	-1.3940	555.5555556	41.6580
11/01/06	14:03:00	53.3340	0.8000	-1.3940	555.5555556	41.7280
11/01/06	14:04:00	53.3340	0.8000	-1.3940	555.5555556	41.7280
11/01/06	14:05:00	53.1600	0.8000	-1.3660	555.5555556	41.5260
11/01/06	14:06:00	53.1600	0.8000	-1.3660	555.5555556	41.5260
11/01/06	14:07:00	53.2990	0.8010	-1.3570	556.25	41.6560
11/01/06	14:08:00	53.1600	0.8000	-1.3570	555.5555556	41.5170
11/01/06	14:09:00	53.1600	0.8000	-1.3570	555.5555556	41.5170
11/01/06	14:10:00	53.2990	0.8010	-1.3570	556.25	41.6560
11/01/06	14:11:00	53.3340	0.8010	-1.3570	556.25	41.6910

**KAHANAHOU WWPS SCADA DATA  
OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	14:12:00	53.3340	0.8010	-1.3660	556.25	41.7000
11/01/06	14:13:00	53.1600	0.8000	-1.3570	555.5555556	41.5170
11/01/06	14:14:00	53.2640	0.8000	-1.3570	555.5555556	41.6210
11/01/06	14:15:00	53.2640	0.8000	-1.3570	555.5555556	41.6210
11/01/06	14:16:00	53.2990	0.8000	-1.3570	555.5555556	41.6560
11/01/06	14:17:00	53.2990	0.8000	-1.3570	555.5555556	41.6560
11/01/06	14:18:00	53.2290	0.8010	-1.3660	556.25	41.5950
11/01/06	14:19:00	53.2290	0.8010	-1.3660	556.25	41.5950
11/01/06	14:20:00	53.1600	0.8010	-1.3570	556.25	41.5170
11/01/06	14:21:00	53.1600	0.8010	-1.3570	556.25	41.5170
11/01/06	14:22:00	53.1950	0.7990	-1.3570	554.8611111	41.5520
11/01/06	14:23:00	53.1950	0.7990	-1.3570	554.8611111	41.5520
11/01/06	14:24:00	53.2640	0.8000	-1.3660	555.5555556	41.6300
11/01/06	14:25:00	53.2640	0.8000	-1.3660	555.5555556	41.6300
11/01/06	14:26:00	53.2640	0.8000	-1.3660	555.5555556	41.6300
11/01/06	14:27:00	53.1950	0.8020	-1.3570	556.9444444	41.5520
11/01/06	14:28:00	53.1950	0.8020	-1.3570	556.9444444	41.5520
11/01/06	14:29:00	53.1600	0.8010	-1.3570	556.25	41.5170
11/01/06	14:30:00	53.1600	0.7990	-1.3660	554.8611111	41.5260
11/01/06	14:31:00	53.1250	0.7980	-1.3570	554.1666667	41.4820
11/01/06	14:32:00	53.1250	0.7980	-1.3570	554.1666667	41.4820
11/01/06	14:33:00	53.0910	0.8000	-1.3660	555.5555556	41.4570
11/01/06	14:34:00	53.0910	0.8000	-1.3660	555.5555556	41.4570
11/01/06	14:35:00	53.0910	0.8000	-1.3660	555.5555556	41.4570
11/01/06	14:36:00	53.0910	0.8000	-1.3660	555.5555556	41.4570
11/01/06	14:37:00	53.0910	0.7990	-1.3660	554.8611111	41.4570
11/01/06	14:38:00	53.0910	0.7990	-1.3660	554.8611111	41.4570
11/01/06	14:39:00	53.0560	0.8000	-1.3760	555.5555556	41.4320
11/01/06	14:40:00	53.1600	0.7990	-1.3850	554.8611111	41.5450
11/01/06	14:41:00	53.1600	0.7990	-1.3850	554.8611111	41.5450
11/01/06	14:42:00	53.1950	0.8010	-1.3850	556.25	41.5800
11/01/06	14:43:00	53.1950	0.8010	-1.3850	556.25	41.5800
11/01/06	14:44:00	53.1600	0.8000	-1.3940	555.5555556	41.5540
11/01/06	14:45:00	53.2990	0.8000	-1.3940	555.5555556	41.6930
11/01/06	14:46:00	53.2990	0.8000	-1.3940	555.5555556	41.6930
11/01/06	14:47:00	53.0210	0.8010	-1.3940	556.25	41.4150
11/01/06	14:48:00	52.9860	0.8010	-1.3850	556.25	41.3710
11/01/06	14:49:00	52.9860	0.8010	-1.3850	556.25	41.3710
11/01/06	14:50:00	53.1600	0.8000	-1.3850	555.5555556	41.5450
11/01/06	14:51:00	53.1600	0.8000	-1.3850	555.5555556	41.5450
11/01/06	14:52:00	53.1250	0.8010	-1.3940	556.25	41.5190
11/01/06	14:53:00	53.1250	0.8010	-1.3940	556.25	41.5190
11/01/06	14:54:00	53.2290	0.8010	-1.3850	556.25	41.6140
11/01/06	14:55:00	53.2290	0.8010	-1.3850	556.25	41.6140
11/01/06	14:56:00	53.0910	0.7990	-1.3940	554.8611111	41.4850
11/01/06	14:57:00	53.2290	0.8010	-1.3850	556.25	41.6140
11/01/06	14:58:00	53.2290	0.8010	-1.3850	556.25	41.6140
11/01/06	14:59:00	53.1250	0.8010	-1.3850	556.25	41.5100
11/01/06	15:00:00	53.0910	0.7990	-1.3850	554.8611111	41.4760
11/01/06	15:01:00	53.0910	0.7990	-1.3850	554.8611111	41.4760
11/01/06	15:02:00	53.0560	0.7990	-1.3940	554.8611111	41.4500
11/01/06	15:03:00	53.0560	0.7990	-1.3940	554.8611111	41.4500
11/01/06	15:04:00	53.2290	0.8000	-1.3940	555.5555556	41.6230
11/01/06	15:05:00	53.2290	0.8000	-1.3940	555.5555556	41.6230
11/01/06	15:06:00	53.1600	0.8010	-1.4120	556.25	41.5720
11/01/06	15:07:00	53.0210	0.7990	-1.4210	554.8611111	41.4420
11/01/06	15:08:00	53.0210	0.7990	-1.4210	554.8611111	41.4420
11/01/06	15:09:00	52.8130	0.7990	-1.4210	554.8611111	41.2340
11/01/06	15:10:00	52.8130	0.7990	-1.4210	554.8611111	41.2340
11/01/06	15:11:00	52.8470	0.7990	-1.4120	554.8611111	41.2590
11/01/06	15:12:00	52.8470	0.7990	-1.4120	554.8611111	41.2590
11/01/06	15:13:00	52.8820	0.7970	-1.4210	553.4722222	41.3030
11/01/06	15:14:00	52.8470	0.8000	-1.4210	555.5555556	41.2680
11/01/06	15:15:00	52.8470	0.8000	-1.4210	555.5555556	41.2680
11/01/06	15:16:00	52.8820	0.7990	-1.4120	554.8611111	41.2940
11/01/06	15:17:00	52.7780	0.7970	-1.4210	553.4722222	41.1990
11/01/06	15:18:00	52.7780	0.7970	-1.4210	553.4722222	41.1990
11/01/06	15:19:00	52.8820	0.7990	-1.4210	554.8611111	41.3030
11/01/06	15:20:00	52.8820	0.7990	-1.4210	554.8611111	41.3030
11/01/06	15:21:00	52.7090	0.7990	-1.4210	554.8611111	41.1300
11/01/06	15:22:00	52.7090	0.7990	-1.4210	554.8611111	41.1300
11/01/06	15:23:00	52.7780	0.7970	-1.4120	553.4722222	41.1900
11/01/06	15:24:00	52.8130	0.7970	-1.4210	553.4722222	41.2340
11/01/06	15:25:00	52.8130	0.7970	-1.4210	553.4722222	41.2340

**KAHANAHOU WWPS SCADA DATA  
OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	15:26:00	52.9520	0.7980	-1.4210	554.1666667	41.3730
11/01/06	15:27:00	52.9520	0.7980	-1.4210	554.1666667	41.3730
11/01/06	15:28:00	52.8470	0.7970	-1.4210	553.4722222	41.2680
11/01/06	15:29:00	52.8470	0.7980	-1.4210	554.1666667	41.2680
11/01/06	15:30:00	52.8470	0.7980	-1.4210	554.1666667	41.2680
11/01/06	15:31:00	52.7430	0.7980	-1.4210	554.1666667	41.1640
11/01/06	15:32:00	52.9170	0.8000	-1.4390	555.5555556	41.3560
11/01/06	15:33:00	52.9170	0.8000	-1.4390	555.5555556	41.3560
11/01/06	15:34:00	52.8820	0.7980	-1.4480	554.1666667	41.3300
11/01/06	15:35:00	52.8820	0.7980	-1.4480	554.1666667	41.3300
11/01/06	15:36:00	52.8820	0.7980	-1.4480	554.1666667	41.3300
11/01/06	15:37:00	52.7780	0.7990	-1.4480	554.8611111	41.2260
11/01/06	15:38:00	52.8130	0.7990	-1.4480	554.8611111	41.2610
11/01/06	15:39:00	52.8130	0.7990	-1.4480	554.8611111	41.2610
11/01/06	15:40:00	52.8470	0.7980	-1.4750	554.1666667	41.3220
11/01/06	15:41:00	52.8470	0.7980	-1.4750	554.1666667	41.3220
11/01/06	15:42:00	52.8130	0.7990	-1.4750	554.8611111	41.2880
11/01/06	15:43:00	52.8820	0.8000	-1.4750	555.5555556	41.3570
11/01/06	15:44:00	52.8820	0.8000	-1.4750	555.5555556	41.3570
11/01/06	15:45:00	52.8470	0.7980	-1.4750	554.1666667	41.3220
11/01/06	15:46:00	52.8820	0.7990	-1.4750	554.8611111	41.3570
11/01/06	15:47:00	52.8820	0.7990	-1.4750	554.8611111	41.3570
11/01/06	15:48:00	52.7430	0.7990	-1.4750	554.8611111	41.2180
11/01/06	15:49:00	52.7430	0.7990	-1.4750	554.8611111	41.2180
11/01/06	15:50:00	52.7430	0.7990	-1.4750	554.8611111	41.2180
11/01/06	15:51:00	52.8820	0.8000	-1.4750	555.5555556	41.3570
11/01/06	15:52:00	52.8820	0.8000	-1.4750	555.5555556	41.3570
11/01/06	15:53:00	52.8470	0.7990	-1.4750	554.8611111	41.3220
11/01/06	15:54:00	52.8470	0.7990	-1.4750	554.8611111	41.3220
11/01/06	15:55:00	52.7430	0.7980	-1.4750	554.1666667	41.2180
11/01/06	15:56:00	52.8820	0.8000	-1.4750	555.5555556	41.3570
11/01/06	15:57:00	52.8820	0.8000	-1.4750	555.5555556	41.3570
11/01/06	15:58:00	52.9860	0.7990	-1.4750	554.8611111	41.4610
11/01/06	15:59:00	52.9860	0.7990	-1.4750	554.8611111	41.4610
11/01/06	16:00:00	52.8820	0.7970	-1.4750	553.4722222	41.3570
11/01/06	16:01:00	52.9170	0.7990	-1.4840	554.8611111	41.4010
11/01/06	16:02:00	52.9170	0.7990	-1.4840	554.8611111	41.4010
11/01/06	16:03:00	52.9860	0.7990	-1.4750	554.8611111	41.4610
11/01/06	16:04:00	52.9860	0.7990	-1.4750	554.8611111	41.4610
11/01/06	16:05:00	52.8820	0.7990	-1.4750	554.8611111	41.3570
11/01/06	16:06:00	52.8820	0.7990	-1.4750	554.8611111	41.3570
11/01/06	16:07:00	52.8820	0.8000	-1.4930	555.5555556	41.3750
11/01/06	16:08:00	52.8820	0.8000	-1.4930	555.5555556	41.3750
11/01/06	16:09:00	52.9170	0.7990	-1.4930	554.8611111	41.4100
11/01/06	16:10:00	52.9170	0.7990	-1.4930	554.8611111	41.4100
11/01/06	16:11:00	52.9520	0.8000	-1.5020	555.5555556	41.4540
11/01/06	16:12:00	52.9520	0.8000	-1.5020	555.5555556	41.4540
11/01/06	16:13:00	52.9170	0.7970	-1.5020	553.4722222	41.4190
11/01/06	16:14:00	52.9520	0.7990	-1.5020	554.8611111	41.4540
11/01/06	16:15:00	52.9520	0.7980	-1.5020	554.1666667	41.4540
11/01/06	16:16:00	52.9520	0.7980	-1.5020	554.1666667	41.4540
11/01/06	16:17:00	52.8470	0.7990	-1.5020	554.8611111	41.3490
11/01/06	16:18:00	52.8470	0.7990	-1.5020	554.8611111	41.3490
11/01/06	16:19:00	52.9170	0.7980	-1.5020	554.1666667	41.4190
11/01/06	16:20:00	52.9170	0.7980	-1.5020	554.1666667	41.4190
11/01/06	16:21:00	53.0560	0.7970	-1.5290	553.4722222	41.5850
11/01/06	16:22:00	53.0560	0.7970	-1.5290	553.4722222	41.5850
11/01/06	16:23:00	52.8130	0.7990	-1.5290	554.8611111	41.3420
11/01/06	16:24:00	52.8130	0.7990	-1.5290	554.8611111	41.3420
11/01/06	16:25:00	52.9860	0.7990	-1.5290	554.8611111	41.5150
11/01/06	16:26:00	52.7780	0.7980	-1.5290	554.1666667	41.3070
11/01/06	16:27:00	52.7780	0.7980	-1.5290	554.1666667	41.3070
11/01/06	16:28:00	52.8130	0.7960	-1.5290	552.7777778	41.3420
11/01/06	16:29:00	52.7430	0.7990	-1.5290	554.8611111	41.2720
11/01/06	16:30:00	52.7430	0.7990	-1.5290	554.8611111	41.2720
11/01/06	16:31:00	52.7430	0.7970	-1.5560	553.4722222	41.2990
11/01/06	16:32:00	52.7430	0.7970	-1.5560	553.4722222	41.2990
11/01/06	16:33:00	53.0210	0.7990	-1.5560	554.8611111	41.5770
11/01/06	16:34:00	52.9170	0.7970	-1.5560	553.4722222	41.4730
11/01/06	16:35:00	52.9170	0.7970	-1.5560	553.4722222	41.4730
11/01/06	16:36:00	52.8820	0.7980	-1.5560	554.1666667	41.4380
11/01/06	16:37:00	52.8820	0.7980	-1.5560	554.1666667	41.4380
11/01/06	16:38:00	52.9170	0.7960	-1.5560	552.7777778	41.4730
11/01/06	16:39:00	52.9170	0.7960	-1.5560	552.7777778	41.4730

**KAHANAHOU WWPS SCADA DATA  
OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	16:40:00	52.8130	0.7970	-1.5830	553.4722222	41.3960
11/01/06	16:41:00	52.8820	0.7980	-1.5830	554.1666667	41.4650
11/01/06	16:42:00	52.8820	0.7980	-1.5830	554.1666667	41.4650
11/01/06	16:43:00	52.6390	0.7950	-1.6010	552.0833333	41.2400
11/01/06	16:44:00	52.6740	0.7960	-1.6010	552.7777778	41.2750
11/01/06	16:45:00	52.8130	0.7960	-1.6100	552.7777778	41.4230
11/01/06	16:46:00	52.5350	0.7970	-1.6100	553.4722222	41.1450
11/01/06	16:47:00	52.8470	0.7970	-1.6100	553.4722222	41.4570
11/01/06	16:48:00	52.8470	0.7970	-1.6100	553.4722222	41.4570
11/01/06	16:49:00	52.8470	0.7970	-1.6100	553.4722222	41.4570
11/01/06	16:50:00	52.8470	0.7970	-1.6100	553.4722222	41.4570
11/01/06	16:51:00	52.9860	0.8010	-1.5380	556.25	41.5240
11/01/06	16:52:00	52.9860	0.8010	-1.5380	556.25	41.5240
11/01/06	16:53:00	52.8470	0.8000	-1.5020	555.5555556	41.3490
11/01/06	16:54:00	52.8470	0.8000	-1.5020	555.5555556	41.3490
11/01/06	16:55:00	53.0560	0.8000	-1.4660	555.5555556	41.5220
11/01/06	16:56:00	53.0560	0.8000	-1.4660	555.5555556	41.5220
11/01/06	16:57:00	52.6390	0.7990	-1.4750	554.8611111	41.1140
11/01/06	16:58:00	52.9520	0.7980	-1.4480	554.1666667	41.4000
11/01/06	16:59:00	52.9520	0.7980	-1.4480	554.1666667	41.4000
11/01/06	17:00:00	52.9170	0.8000	-1.4480	555.5555556	41.3650
11/01/06	17:01:00	52.9860	0.8000	-1.4480	555.5555556	41.4340
11/01/06	17:02:00	52.9860	0.8000	-1.4480	555.5555556	41.4340
11/01/06	17:03:00	53.0210	0.7990	-1.4480	554.8611111	41.4690
11/01/06	17:04:00	53.0210	0.7990	-1.4480	554.8611111	41.4690
11/01/06	17:05:00	52.8820	0.7990	-1.4480	554.8611111	41.3300
11/01/06	17:06:00	52.8820	0.7990	-1.4480	554.8611111	41.3300
11/01/06	17:07:00	53.0210	0.7990	-1.4480	554.8611111	41.4690
11/01/06	17:08:00	52.9520	0.7990	-1.4480	554.8611111	41.4000
11/01/06	17:09:00	52.9520	0.7990	-1.4480	554.8611111	41.4000
11/01/06	17:10:00	53.0910	0.7980	-1.4480	554.1666667	41.5390
11/01/06	17:11:00	53.0910	0.7980	-1.4480	554.1666667	41.5390
11/01/06	17:12:00	52.8470	0.7970	-1.4390	553.4722222	41.2860
11/01/06	17:13:00	52.7780	0.7980	-1.4480	554.1666667	41.2260
11/01/06	17:14:00	52.8820	0.7970	-1.4480	553.4722222	41.3300
11/01/06	17:15:00	52.8820	0.7970	-1.4480	553.4722222	41.3300
11/01/06	17:16:00	52.8820	0.7990	-1.4390	554.8611111	41.3210
11/01/06	17:17:00	52.8820	0.7990	-1.4390	554.8611111	41.3210
11/01/06	17:18:00	52.7090	0.7970	-1.4390	553.4722222	41.1480
11/01/06	17:19:00	52.7090	0.7970	-1.4390	553.4722222	41.1480
11/01/06	17:20:00	53.0910	0.7990	-1.4390	554.8611111	41.5300
11/01/06	17:21:00	52.8820	0.7980	-1.4480	554.1666667	41.3300
11/01/06	17:22:00	52.8820	0.7980	-1.4480	554.1666667	41.3300
11/01/06	17:23:00	52.8470	0.7990	-1.4480	554.8611111	41.2950
11/01/06	17:24:00	52.8470	0.7990	-1.4480	554.8611111	41.2950
11/01/06	17:25:00	52.8820	0.7990	-1.4480	554.8611111	41.3300
11/01/06	17:26:00	52.8820	0.8000	-1.4480	555.5555556	41.3300
11/01/06	17:27:00	52.8820	0.8000	-1.4480	555.5555556	41.3300
11/01/06	17:28:00	52.6040	0.8000	-1.4480	555.5555556	41.0520
11/01/06	17:29:00	52.6040	0.8000	-1.4480	555.5555556	41.0520
11/01/06	17:30:00	52.9520	0.7990	-1.4480	554.8611111	41.4000
11/01/06	17:31:00	52.8130	0.7990	-1.4480	554.8611111	41.2610
11/01/06	17:32:00	52.8130	0.7990	-1.4480	554.8611111	41.2610
11/01/06	17:33:00	53.0910	0.8000	-1.4480	555.5555556	41.5390
11/01/06	17:34:00	53.0910	0.8000	-1.4480	555.5555556	41.5390
11/01/06	17:35:00	52.8130	0.7980	-1.4480	554.1666667	41.2610
11/01/06	17:36:00	52.8130	0.7980	-1.4480	554.1666667	41.2610
11/01/06	17:37:00	53.0560	0.8000	-1.4480	555.5555556	41.5040
11/01/06	17:38:00	53.0210	0.7990	-1.4480	554.8611111	41.4690
11/01/06	17:39:00	53.0210	0.7990	-1.4480	554.8611111	41.4690
11/01/06	17:40:00	53.0560	0.8010	-1.4480	556.25	41.5040
11/01/06	17:41:00	53.0560	0.8010	-1.4480	556.25	41.5040
11/01/06	17:42:00	52.9170	0.7990	-1.4480	554.8611111	41.3650
11/01/06	17:43:00	52.9170	0.7990	-1.4480	554.8611111	41.3650
11/01/06	17:44:00	53.0210	0.7970	-1.4480	553.4722222	41.4690
11/01/06	17:45:00	53.0210	0.7990	-1.4480	554.8611111	41.4690
11/01/06	17:46:00	53.0210	0.7990	-1.4480	554.8611111	41.4690
11/01/06	17:47:00	52.8820	0.7990	-1.4480	554.8611111	41.3300
11/01/06	17:48:00	52.8820	0.7990	-1.4480	554.8611111	41.3300
11/01/06	17:49:00	52.8130	0.8000	-1.4480	555.5555556	41.2610
11/01/06	17:50:00	52.7430	0.8000	-1.4480	555.5555556	41.1910
11/01/06	17:51:00	52.7430	0.8000	-1.4480	555.5555556	41.1910
11/01/06	17:52:00	53.0210	0.7990	-1.4480	554.8611111	41.4690
11/01/06	17:53:00	53.0210	0.7990	-1.4480	554.8611111	41.4690

**KAHANAHOU WWPS SCADA DATA  
OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	17:54:00	52.8820	0.8000	-1.4390	555.555556	41.3210
11/01/06	17:55:00	52.8820	0.8000	-1.4390	555.555556	41.3210
11/01/06	17:56:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	17:57:00	52.8130	0.7990	-1.4480	554.861111	41.2610
11/01/06	17:58:00	52.8820	0.8010	-1.4480	556.25	41.3300
11/01/06	17:59:00	52.8820	0.7970	-1.4480	553.472222	41.3300
11/01/06	18:00:00	52.8820	0.7970	-1.4480	553.472222	41.3300
11/01/06	18:01:00	53.0560	0.7990	-1.4480	554.861111	41.5040
11/01/06	18:02:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:03:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:04:00	52.8820	0.8000	-1.4480	555.555556	41.3300
11/01/06	18:05:00	52.8820	0.8000	-1.4480	555.555556	41.3300
11/01/06	18:06:00	53.0210	0.7980	-1.4480	554.166667	41.4690
11/01/06	18:07:00	53.0210	0.7980	-1.4480	554.166667	41.4690
11/01/06	18:08:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:09:00	53.0210	0.8000	-1.4480	555.555556	41.4690
11/01/06	18:10:00	53.0210	0.8000	-1.4480	555.555556	41.4690
11/01/06	18:11:00	53.1250	0.7990	-1.4480	554.861111	41.5730
11/01/06	18:12:00	53.1250	0.7990	-1.4480	554.861111	41.5730
11/01/06	18:13:00	52.8820	0.7980	-1.4480	554.166667	41.3300
11/01/06	18:14:00	52.9520	0.8000	-1.4480	555.555556	41.4000
11/01/06	18:15:00	52.9170	0.8000	-1.4480	555.555556	41.3650
11/01/06	18:16:00	52.9170	0.8000	-1.4480	555.555556	41.3650
11/01/06	18:17:00	53.1600	0.7980	-1.4480	554.166667	41.6080
11/01/06	18:18:00	53.1600	0.7980	-1.4480	554.166667	41.6080
11/01/06	18:19:00	52.8470	0.8000	-1.4480	555.555556	41.2950
11/01/06	18:20:00	52.8470	0.8000	-1.4480	555.555556	41.2950
11/01/06	18:21:00	53.1250	0.8000	-1.4480	555.555556	41.5730
11/01/06	18:22:00	53.1250	0.8000	-1.4480	555.555556	41.5730
11/01/06	18:23:00	53.0210	0.7980	-1.4480	554.166667	41.4690
11/01/06	18:24:00	52.9520	0.8000	-1.4480	555.555556	41.4000
11/01/06	18:25:00	52.9520	0.8000	-1.4480	555.555556	41.4000
11/01/06	18:26:00	53.1950	0.7990	-1.4480	554.861111	41.6430
11/01/06	18:27:00	53.1950	0.7990	-1.4480	554.861111	41.6430
11/01/06	18:28:00	53.0910	0.8000	-1.4480	555.555556	41.5390
11/01/06	18:29:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:30:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:31:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:32:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:33:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:34:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:35:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:36:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:37:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:38:00	52.9860	0.7990	-1.4480	554.861111	41.4340
11/01/06	18:39:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	18:40:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	18:41:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	18:42:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	18:43:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	18:44:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	18:45:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	18:46:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	18:47:00	53.0210	0.0000	0.0000	0	40.0210
11/01/06	18:48:00	53.0210	0.0000	0.0000	0	40.0210
11/01/06	18:49:00	53.0210	0.0000	0.0000	0	40.0210
11/01/06	18:50:00	53.0210	0.0000	0.0000	0	40.0210
11/01/06	18:51:00	53.0210	0.0000	0.0000	0	40.0210
11/01/06	18:52:00	53.0210	0.0000	0.0000	0	40.0210
11/01/06	18:53:00	53.0210	0.0000	0.0000	0	40.0210
11/01/06	18:54:00	53.0210	0.0000	0.0000	0	40.0210
11/01/06	18:55:00	53.0210	0.0000	0.0000	0	40.0210
11/01/06	18:56:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	18:57:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	18:58:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	18:59:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:00:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:01:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:02:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:03:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:04:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:05:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:06:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:07:00	0.0000	0.0000	0.0000	0	-13.0000

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	19:08:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:09:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:10:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:11:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:12:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:13:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:14:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:15:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:16:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:17:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:18:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:19:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:20:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:21:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:22:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:23:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:24:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:25:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:26:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:27:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:28:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:29:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:30:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:31:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:32:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:33:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:34:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:35:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:36:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:37:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:38:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:39:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:40:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:41:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:42:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:43:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:44:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:45:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:46:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:47:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:48:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:49:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:50:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:51:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:52:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:53:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:54:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:55:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:56:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:57:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:58:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	19:59:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:00:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:01:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:02:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:03:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:04:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:05:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:06:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:07:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:08:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:09:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:10:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:11:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:12:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:13:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:14:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:15:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:16:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:17:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:18:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:19:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:20:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:21:00	0.0000	0.0000	0.0000	0	-13.0000

**KAHANAHOU WWPS SCADA DATA  
OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	20:22:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:23:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:24:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:25:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:26:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:27:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:28:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:29:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:30:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:31:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:32:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:33:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:34:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:35:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:36:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:37:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:38:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:39:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:40:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:41:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:42:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:43:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:44:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:45:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:46:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:47:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:48:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:49:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:50:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:51:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:52:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:53:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:54:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:55:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:56:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:57:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:58:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	20:59:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:00:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:01:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:02:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:03:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:04:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:05:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:06:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:07:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:08:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:09:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:10:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:11:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:12:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:13:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:14:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:15:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:16:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:17:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:18:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:19:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:20:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:21:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:22:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:23:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:24:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:25:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:26:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:27:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:28:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:29:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:30:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:31:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:32:00	0.0000	0.0000	0.0000	0	-13.0000
11/01/06	21:33:00	53.0210	0.0000	0.0000	0	40.0210
11/01/06	21:34:00	52.7090	0.7940	-1.8360	551.3888889	41.5450
11/01/06	21:35:00	52.7090	0.7940	-1.8360	551.3888889	41.5450

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	21:36:00	52.6390	0.7940	-1.8360	551.3888889	41.4750
11/01/06	21:37:00	52.5000	0.7930	-1.8360	550.6944444	41.3360
11/01/06	21:38:00	52.5000	0.7930	-1.8360	550.6944444	41.3360
11/01/06	21:39:00	52.5000	0.7920	-1.8360	550	41.3360
11/01/06	21:40:00	52.5350	0.7920	-1.8360	550	41.3710
11/01/06	21:41:00	52.7090	0.7920	-1.8360	550	41.5450
11/01/06	21:42:00	52.7090	0.7920	-1.8360	550	41.5450
11/01/06	21:43:00	52.7090	0.7920	-1.8360	550	41.5450
11/01/06	21:44:00	52.7090	0.7920	-1.8360	550	41.5450
11/01/06	21:45:00	52.6390	0.7920	-1.8360	550	41.4750
11/01/06	21:46:00	52.6040	0.7930	-1.8630	550.6944444	41.4670
11/01/06	21:47:00	52.6040	0.7930	-1.8630	550.6944444	41.4670
11/01/06	21:48:00	52.8470	0.7950	-1.8630	552.0833333	41.7100
11/01/06	21:49:00	52.6740	0.7940	-1.8630	551.3888889	41.5370
11/01/06	21:50:00	52.6740	0.7940	-1.8630	551.3888889	41.5370
11/01/06	21:51:00	52.7090	0.7960	-1.8630	552.7777778	41.5720
11/01/06	21:52:00	52.7090	0.7960	-1.8630	552.7777778	41.5720
11/01/06	21:53:00	52.7090	0.7960	-1.8630	552.7777778	41.5720
11/01/06	21:54:00	52.7090	0.7960	-1.8630	552.7777778	41.5720
11/01/06	21:55:00	52.8130	0.7930	-1.8630	550.6944444	41.6760
11/01/06	21:56:00	52.8130	0.7930	-1.8630	550.6944444	41.6760
11/01/06	21:57:00	52.4660	0.7930	-1.8900	550.6944444	41.3560
11/01/06	21:58:00	52.4660	0.7930	-1.8900	550.6944444	41.3560
11/01/06	21:59:00	52.4660	0.7910	-1.9170	549.3055556	41.3830
11/01/06	22:00:00	52.4660	0.7910	-1.9170	549.3055556	41.3830
11/01/06	22:01:00	52.4660	0.7910	-1.9170	549.3055556	41.3830
11/01/06	22:02:00	52.4660	0.7910	-1.9170	549.3055556	41.3830
11/01/06	22:03:00	52.3610	0.7910	-1.9170	549.3055556	41.2780
11/01/06	22:04:00	52.3610	0.7910	-1.9170	549.3055556	41.2780
11/01/06	22:05:00	52.1880	0.7900	-1.9440	548.6111111	41.1320
11/01/06	22:06:00	52.2570	0.7890	-1.9440	547.9166667	41.2010
11/01/06	22:07:00	52.2570	0.7890	-1.9440	547.9166667	41.2010
11/01/06	22:08:00	52.4310	0.7910	-1.9440	549.3055556	41.3750
11/01/06	22:09:00	52.4310	0.7910	-1.9440	549.3055556	41.3750
11/01/06	22:10:00	52.2570	0.7910	-1.9440	549.3055556	41.2010
11/01/06	22:11:00	52.1880	0.7890	-1.9440	547.9166667	41.1320
11/01/06	22:12:00	52.1880	0.7890	-1.9440	547.9166667	41.1320
11/01/06	22:13:00	52.2220	0.7890	-1.9440	547.9166667	41.1660
11/01/06	22:14:00	52.6040	0.7900	-1.9530	548.6111111	41.5570
11/01/06	22:15:00	52.6040	0.7900	-1.9530	548.6111111	41.5570
11/01/06	22:16:00	52.6040	0.7900	-1.9530	548.6111111	41.5570
11/01/06	22:17:00	52.3610	0.7920	-1.9800	550	41.3410
11/01/06	22:18:00	52.3610	0.7920	-1.9800	550	41.3410
11/01/06	22:19:00	52.3610	0.7920	-1.9800	550	41.3410
11/01/06	22:20:00	52.3610	0.7920	-1.9800	550	41.3410
11/01/06	22:21:00	52.3610	0.7920	-1.9800	550	41.3410
11/01/06	22:22:00	52.3610	0.7920	-1.9800	550	41.3410
11/01/06	22:23:00	52.3610	0.7920	-1.9800	550	41.3410
11/01/06	22:24:00	52.3610	0.7920	-1.9800	550	41.3410
11/01/06	22:25:00	52.3610	0.7900	-1.9800	548.6111111	41.3410
11/01/06	22:26:00	52.3610	0.7900	-1.9800	548.6111111	41.3410
11/01/06	22:27:00	52.3610	0.7900	-1.9800	548.6111111	41.3410
11/01/06	22:28:00	52.3610	0.7900	-1.9800	548.6111111	41.3410
11/01/06	22:29:00	52.4660	0.7900	-1.9800	548.6111111	41.4460
11/01/06	22:30:00	52.4660	0.7900	-1.9800	548.6111111	41.4460
11/01/06	22:31:00	52.5000	0.7910	-1.9800	549.3055556	41.4800
11/01/06	22:32:00	52.5000	0.7910	-1.9800	549.3055556	41.4800
11/01/06	22:33:00	52.6390	0.7920	-1.9800	550	41.6190
11/01/06	22:34:00	52.6390	0.7920	-1.9800	550	41.6190
11/01/06	22:35:00	52.6390	0.7920	-1.9800	550	41.6190
11/01/06	22:36:00	52.4660	0.7910	-2.0070	549.3055556	41.4730
11/01/06	22:37:00	52.4660	0.7910	-2.0070	549.3055556	41.4730
11/01/06	22:38:00	52.6040	0.7900	-2.0070	548.6111111	41.6110
11/01/06	22:39:00	52.1880	0.7880	-2.0260	547.2222222	41.2140
11/01/06	22:40:00	52.1880	0.7880	-2.0260	547.2222222	41.2140
11/01/06	22:41:00	52.3960	0.7910	-2.0350	549.3055556	41.4310
11/01/06	22:42:00	52.3960	0.7910	-2.0350	549.3055556	41.4310
11/01/06	22:43:00	52.4660	0.7920	-2.0260	550	41.4920
11/01/06	22:44:00	52.3270	0.7910	-2.0620	549.3055556	41.3890
11/01/06	22:45:00	52.3270	0.7910	-2.0620	549.3055556	41.3890
11/01/06	22:46:00	52.4310	0.7920	-2.0620	550	41.4930
11/01/06	22:47:00	52.3960	0.7900	-2.0620	548.6111111	41.4580
11/01/06	22:48:00	52.3960	0.7900	-2.0620	548.6111111	41.4580
11/01/06	22:49:00	52.2570	0.7890	-2.0710	547.9166667	41.3280



**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/01/06	22:50:00	52.2570	0.7890	-2.0710	547.9166667	41.3280
11/01/06	22:51:00	52.2220	0.7900	-2.0890	548.6111111	41.3110
11/01/06	22:52:00	52.2220	0.7900	-2.0890	548.6111111	41.3110
11/01/06	22:53:00	52.3270	0.7890	-2.0890	547.9166667	41.4160
11/01/06	22:54:00	52.3270	0.7920	-2.0980	550	41.4250
11/01/06	22:55:00	52.3270	0.7920	-2.0980	550	41.4250
11/01/06	22:56:00	52.3960	0.7890	-2.1160	547.9166667	41.5120
11/01/06	22:57:00	52.3960	0.7890	-2.1160	547.9166667	41.5120
11/01/06	22:58:00	52.4660	0.7910	-2.1160	549.3055556	41.5820
11/01/06	22:59:00	52.4660	0.7910	-2.1160	549.3055556	41.5820
11/01/06	23:00:00	52.4660	0.7910	-2.1160	549.3055556	41.5820
11/01/06	23:01:00	52.4660	0.7910	-2.1160	549.3055556	41.5820
11/01/06	23:02:00	52.4660	0.7910	-2.1160	549.3055556	41.5820
11/01/06	23:03:00	52.2220	0.7880	-2.1430	547.2222222	41.3650
11/01/06	23:04:00	52.2220	0.7880	-2.1430	547.2222222	41.3650
11/01/06	23:05:00	52.4660	0.7920	-2.1430	550	41.6090
11/01/06	23:06:00	52.4660	0.7920	-2.1430	550	41.6090
11/01/06	23:07:00	52.4660	0.7920	-2.1430	550	41.6090
11/01/06	23:08:00	52.2220	0.7880	-2.1430	547.2222222	41.3650
11/01/06	23:09:00	52.2220	0.7880	-2.1430	547.2222222	41.3650
11/01/06	23:10:00	52.1880	0.7880	-2.1520	547.2222222	41.3400
11/01/06	23:11:00	52.1880	0.7880	-2.1520	547.2222222	41.3400
11/01/06	23:12:00	52.4310	0.7890	-2.1700	547.9166667	41.6010
11/01/06	23:13:00	52.4310	0.7890	-2.1700	547.9166667	41.6010
11/01/06	23:14:00	52.2920	0.7890	-2.1700	547.9166667	41.4620
11/01/06	23:15:00	52.4660	0.7900	-2.1700	548.6111111	41.6360
11/01/06	23:16:00	52.4660	0.7900	-2.1700	548.6111111	41.6360
11/01/06	23:17:00	52.3270	0.7890	-2.1700	547.9166667	41.4970
11/01/06	23:18:00	52.3270	0.7890	-2.1700	547.9166667	41.4970
11/01/06	23:19:00	52.4310	0.7870	-2.1790	546.5277778	41.6100
11/01/06	23:20:00	52.4310	0.7870	-2.1790	546.5277778	41.6100
11/01/06	23:21:00	52.4310	0.7870	-2.1790	546.5277778	41.6100
11/01/06	23:22:00	52.3270	0.7880	-2.1790	547.2222222	41.5060
11/01/06	23:23:00	52.3610	0.7910	-2.1790	549.3055556	41.5400
11/01/06	23:24:00	52.3610	0.7910	-2.1790	549.3055556	41.5400
11/01/06	23:25:00	52.7430	0.7900	-2.1790	548.6111111	41.9220
11/01/06	23:26:00	52.7430	0.7900	-2.1790	548.6111111	41.9220
11/01/06	23:27:00	52.6390	0.7910	-2.1790	549.3055556	41.8180
11/01/06	23:28:00	52.4660	0.7890	-2.1970	547.9166667	41.6630
11/01/06	23:29:00	52.4660	0.7890	-2.1970	547.9166667	41.6630
11/01/06	23:30:00	52.5000	0.7900	-2.1970	548.6111111	41.6970
11/01/06	23:31:00	52.5000	0.7900	-2.1970	548.6111111	41.6970
11/01/06	23:32:00	52.5000	0.7900	-2.1970	548.6111111	41.6970
11/01/06	23:33:00	52.3270	0.7890	-2.1970	547.9166667	41.5240
11/01/06	23:34:00	52.3960	0.7900	-2.1970	548.6111111	41.5930
11/01/06	23:35:00	52.3960	0.7900	-2.1970	548.6111111	41.5930
11/01/06	23:36:00	52.2920	0.7890	-2.2060	547.9166667	41.4980
11/01/06	23:37:00	52.2920	0.7890	-2.2060	547.9166667	41.4980
11/01/06	23:38:00	52.2570	0.7890	-2.2240	547.9166667	41.4810
11/01/06	23:39:00	52.2570	0.7890	-2.2240	547.9166667	41.4810
11/01/06	23:40:00	52.6740	0.7890	-2.2240	547.9166667	41.8980
11/01/06	23:41:00	52.6390	0.7900	-2.2240	548.6111111	41.8630
11/01/06	23:42:00	52.6390	0.7900	-2.2240	548.6111111	41.8630
11/01/06	23:43:00	52.2920	0.7870	-2.2240	546.5277778	41.5160
11/01/06	23:44:00	52.2920	0.7870	-2.2240	546.5277778	41.5160
11/01/06	23:45:00	52.2570	0.7860	-2.2240	545.8333333	41.4810
11/01/06	23:46:00	52.4660	0.7880	-2.2240	547.2222222	41.6900
11/01/06	23:47:00	52.4660	0.7880	-2.2240	547.2222222	41.6900
11/01/06	23:48:00	52.2220	0.7870	-2.2240	546.5277778	41.4460
11/01/06	23:49:00	52.1880	0.7890	-2.2240	547.9166667	41.4120
11/01/06	23:50:00	52.1880	0.7890	-2.2240	547.9166667	41.4120
11/01/06	23:51:00	52.2920	0.7890	-2.2510	547.9166667	41.5430
11/01/06	23:52:00	52.2920	0.7890	-2.2510	547.9166667	41.5430
11/01/06	23:53:00	52.2920	0.7890	-2.2510	547.9166667	41.5430
11/01/06	23:54:00	52.6040	0.7880	-2.2510	547.2222222	41.8550
11/01/06	23:55:00	52.1880	0.7880	-2.2510	547.2222222	41.4390
11/01/06	23:56:00	52.1880	0.7880	-2.2510	547.2222222	41.4390
11/01/06	23:57:00	52.2920	0.7890	-2.2780	547.9166667	41.5700
11/01/06	23:58:00	52.2920	0.7890	-2.2780	547.9166667	41.5700
11/01/06	23:59:00	52.1880	0.7870	-2.2780	546.5277778	41.4660
11/02/06	00:00:00	52.1880	0.7870	-2.2780	546.5277778	41.4660
11/02/06	00:01:00	52.1880	0.7870	-2.2780	546.5277778	41.4660
11/02/06	00:02:00	52.1180	0.7880	-2.2780	547.2222222	41.3960
11/02/06	00:03:00	52.1180	0.7880	-2.2780	547.2222222	41.3960

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	00:04:00	52.0840	0.7870	-2.2780	546.5277778	41.3620
11/02/06	00:05:00	52.0840	0.7870	-2.2780	546.5277778	41.3620
11/02/06	00:06:00	52.2920	0.7890	-2.3050	547.9166667	41.5970
11/02/06	00:07:00	52.2920	0.7890	-2.3050	547.9166667	41.5970
11/02/06	00:08:00	52.0840	0.7880	-2.3050	547.2222222	41.3890
11/02/06	00:09:00	52.2220	0.7880	-2.3050	547.2222222	41.5270
11/02/06	00:10:00	52.2220	0.7880	-2.3050	547.2222222	41.5270
11/02/06	00:11:00	52.2570	0.7880	-2.3140	547.2222222	41.5710
11/02/06	00:12:00	52.2570	0.7880	-2.3140	547.2222222	41.5710
11/02/06	00:13:00	52.2220	0.7870	-2.3320	546.5277778	41.5540
11/02/06	00:14:00	52.2920	0.7880	-2.3320	547.2222222	41.6240
11/02/06	00:15:00	52.2920	0.7880	-2.3320	547.2222222	41.6240
11/02/06	00:16:00	52.3610	0.7880	-2.3420	547.2222222	41.7030
11/02/06	00:17:00	52.3610	0.7880	-2.3420	547.2222222	41.7030
11/02/06	00:18:00	52.3960	0.7880	-2.3320	547.2222222	41.7280
11/02/06	00:19:00	52.3960	0.7880	-2.3320	547.2222222	41.7280
11/02/06	00:20:00	52.3610	0.7880	-2.3420	547.2222222	41.7030
11/02/06	00:21:00	52.3610	0.7880	-2.3420	547.2222222	41.7030
11/02/06	00:22:00	52.1180	0.7860	-2.3600	545.8333333	41.4780
11/02/06	00:23:00	52.1180	0.7860	-2.3600	545.8333333	41.4780
11/02/06	00:24:00	52.1180	0.7860	-2.3600	545.8333333	41.4780
11/02/06	00:25:00	52.2570	0.7890	-2.3600	547.9166667	41.6170
11/02/06	00:26:00	52.2570	0.7890	-2.3600	547.9166667	41.6170
11/02/06	00:27:00	52.1180	0.7880	-2.3690	547.2222222	41.4870
11/02/06	00:28:00	52.1180	0.7880	-2.3690	547.2222222	41.4870
11/02/06	00:29:00	52.1180	0.7880	-2.3690	547.2222222	41.4870
11/02/06	00:30:00	52.1180	0.7880	-2.3690	547.2222222	41.4870
11/02/06	00:31:00	52.1880	0.7880	-2.3600	547.2222222	41.5480
11/02/06	00:32:00	52.1880	0.7880	-2.3600	547.2222222	41.5480
11/02/06	00:33:00	51.9790	0.7860	-2.3690	545.8333333	41.3480
11/02/06	00:34:00	51.9790	0.7860	-2.3690	545.8333333	41.3480
11/02/06	00:35:00	51.9790	0.7860	-2.3690	545.8333333	41.3480
11/02/06	00:36:00	52.1530	0.7880	-2.3780	547.2222222	41.5310
11/02/06	00:37:00	52.1530	0.7880	-2.3780	547.2222222	41.5310
11/02/06	00:38:00	52.1530	0.7880	-2.3780	547.2222222	41.5310
11/02/06	00:39:00	52.0140	0.7860	-2.3870	545.8333333	41.4010
11/02/06	00:40:00	52.0140	0.7860	-2.3870	545.8333333	41.4010
11/02/06	00:41:00	52.1530	0.7860	-2.3870	545.8333333	41.5400
11/02/06	00:42:00	52.1530	0.7860	-2.3870	545.8333333	41.5400
11/02/06	00:43:00	52.1530	0.7860	-2.3870	545.8333333	41.5400
11/02/06	00:44:00	52.1180	0.7860	-2.3960	545.8333333	41.5140
11/02/06	00:45:00	52.1180	0.7860	-2.3960	545.8333333	41.5140
11/02/06	00:46:00	51.9100	0.7880	-2.3870	547.2222222	41.2970
11/02/06	00:47:00	51.9100	0.7880	-2.3870	547.2222222	41.2970
11/02/06	00:48:00	51.9100	0.7880	-2.3870	547.2222222	41.2970
11/02/06	00:49:00	52.0840	0.7860	-2.3960	545.8333333	41.4800
11/02/06	00:50:00	52.0840	0.7860	-2.3960	545.8333333	41.4800
11/02/06	00:51:00	52.0840	0.7860	-2.3960	545.8333333	41.4800
11/02/06	00:52:00	52.1880	0.7870	-2.4140	546.5277778	41.6020
11/02/06	00:53:00	52.1880	0.7870	-2.4140	546.5277778	41.6020
11/02/06	00:54:00	52.1880	0.7870	-2.4140	546.5277778	41.6020
11/02/06	00:55:00	52.1880	0.7870	-2.4140	546.5277778	41.6020
11/02/06	00:56:00	52.1880	0.7870	-2.4140	546.5277778	41.6020
11/02/06	00:57:00	52.1180	0.7880	-2.4230	547.2222222	41.5410
11/02/06	00:58:00	52.1180	0.7880	-2.4230	547.2222222	41.5410
11/02/06	00:59:00	52.0140	0.7890	-2.4230	547.9166667	41.4370
11/02/06	01:00:00	52.0140	0.7890	-2.4230	547.9166667	41.4370
11/02/06	01:01:00	52.0840	0.7890	-2.4230	547.9166667	41.5070
11/02/06	01:02:00	52.0840	0.7890	-2.4230	547.9166667	41.5070
11/02/06	01:03:00	52.0840	0.7890	-2.4230	547.9166667	41.5070
11/02/06	01:04:00	52.2220	0.7870	-2.4410	546.5277778	41.6630
11/02/06	01:05:00	52.2220	0.7870	-2.4410	546.5277778	41.6630
11/02/06	01:06:00	52.2220	0.7870	-2.4410	546.5277778	41.6630
11/02/06	01:07:00	51.9450	0.7850	-2.4500	545.1388889	41.3950
11/02/06	01:08:00	51.9450	0.7850	-2.4500	545.1388889	41.3950
11/02/06	01:09:00	51.9450	0.7850	-2.4500	545.1388889	41.3950
11/02/06	01:10:00	52.1530	0.7860	-2.4500	545.8333333	41.6030
11/02/06	01:11:00	52.1530	0.7860	-2.4500	545.8333333	41.6030
11/02/06	01:12:00	52.1530	0.7880	-2.4500	547.2222222	41.6030
11/02/06	01:13:00	52.1530	0.7880	-2.4500	547.2222222	41.6030
11/02/06	01:14:00	52.1180	0.7880	-2.4590	547.2222222	41.5770
11/02/06	01:15:00	52.1180	0.7880	-2.4590	547.2222222	41.5770
11/02/06	01:16:00	52.1180	0.7880	-2.4590	547.2222222	41.5770
11/02/06	01:17:00	51.5970	0.7870	-2.4770	546.5277778	41.0740

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	01:18:00	51.7020	0.7840	-2.4770	544.4444444	41.1790
11/02/06	01:19:00	51.7020	0.7840	-2.4770	544.4444444	41.1790
11/02/06	01:20:00	51.7020	0.7840	-2.4770	544.4444444	41.1790
11/02/06	01:21:00	51.5970	0.7810	-2.4770	542.3611111	41.0740
11/02/06	01:22:00	51.5970	0.7810	-2.4770	542.3611111	41.0740
11/02/06	01:23:00	51.5970	0.7810	-2.4770	542.3611111	41.0740
11/02/06	01:24:00	51.8410	0.7840	-2.4770	544.4444444	41.3180
11/02/06	01:25:00	51.8410	0.7840	-2.4770	544.4444444	41.3180
11/02/06	01:26:00	51.8410	0.7840	-2.4770	544.4444444	41.3180
11/02/06	01:27:00	51.8410	0.7840	-2.4770	544.4444444	41.3180
11/02/06	01:28:00	51.8410	0.7840	-2.4770	544.4444444	41.3180
11/02/06	01:29:00	51.9450	0.7850	-2.4860	545.1388889	41.4310
11/02/06	01:30:00	51.9450	0.7850	-2.4860	545.1388889	41.4310
11/02/06	01:31:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	01:32:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	01:33:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	01:34:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	01:35:00	51.8750	0.7850	-2.5040	545.1388889	41.3790
11/02/06	01:36:00	51.8750	0.7850	-2.5040	545.1388889	41.3790
11/02/06	01:37:00	51.8750	0.7850	-2.5040	545.1388889	41.3790
11/02/06	01:38:00	51.9450	0.7850	-2.5040	545.1388889	41.4490
11/02/06	01:39:00	51.9450	0.7850	-2.5040	545.1388889	41.4490
11/02/06	01:40:00	51.9450	0.7850	-2.5040	545.1388889	41.4490
11/02/06	01:41:00	51.2500	0.7780	-2.5040	540.2777778	40.7540
11/02/06	01:42:00	51.2500	0.7780	-2.5040	540.2777778	40.7540
11/02/06	01:43:00	51.2500	0.7780	-2.5040	540.2777778	40.7540
11/02/06	01:44:00	51.2500	0.7780	-2.5040	540.2777778	40.7540
11/02/06	01:45:00	51.2500	0.7780	-2.5040	540.2777778	40.7540
11/02/06	01:46:00	51.2500	0.7780	-2.5040	540.2777778	40.7540
11/02/06	01:47:00	51.4590	0.7810	-2.5040	542.3611111	40.9630
11/02/06	01:48:00	51.4590	0.7810	-2.5040	542.3611111	40.9630
11/02/06	01:49:00	51.4240	0.7790	-2.5040	540.9722222	40.9280
11/02/06	01:50:00	51.4240	0.7790	-2.5040	540.9722222	40.9280
11/02/06	01:51:00	51.4240	0.7790	-2.5040	540.9722222	40.9280
11/02/06	01:52:00	51.4930	0.7810	-2.5040	542.3611111	40.9970
11/02/06	01:53:00	51.4930	0.7810	-2.5040	542.3611111	40.9970
11/02/06	01:54:00	51.5280	0.7810	-2.5040	542.3611111	41.0320
11/02/06	01:55:00	51.5280	0.7810	-2.5040	542.3611111	41.0320
11/02/06	01:56:00	51.4930	0.7800	-2.5040	541.6666667	40.9970
11/02/06	01:57:00	51.4930	0.7800	-2.5040	541.6666667	40.9970
11/02/06	01:58:00	51.4930	0.7800	-2.5040	541.6666667	40.9970
11/02/06	01:59:00	51.4930	0.7800	-2.5040	541.6666667	40.9970
11/02/06	02:00:00	51.4930	0.7800	-2.5040	541.6666667	40.9970
11/02/06	02:01:00	51.5280	0.7810	-2.5040	542.3611111	41.0320
11/02/06	02:02:00	51.5280	0.7800	-2.5040	541.6666667	41.0320
11/02/06	02:03:00	51.5280	0.7800	-2.5040	541.6666667	41.0320
11/02/06	02:04:00	51.5280	0.7800	-2.5040	541.6666667	41.0320
11/02/06	02:05:00	51.5280	0.7800	-2.5040	541.6666667	41.0320
11/02/06	02:06:00	51.5280	0.7800	-2.5040	541.6666667	41.0320
11/02/06	02:07:00	51.5630	0.7820	-2.5310	543.0555556	41.0940
11/02/06	02:08:00	51.5630	0.7820	-2.5310	543.0555556	41.0940
11/02/06	02:09:00	51.4590	0.7800	-2.5310	541.6666667	40.9900
11/02/06	02:10:00	51.4590	0.7800	-2.5310	541.6666667	40.9900
11/02/06	02:11:00	51.4590	0.7800	-2.5310	541.6666667	40.9900
11/02/06	02:12:00	51.4930	0.7820	-2.5400	543.0555556	41.0330
11/02/06	02:13:00	51.4930	0.7820	-2.5400	543.0555556	41.0330
11/02/06	02:14:00	51.4240	0.7790	-2.5580	540.9722222	40.9820
11/02/06	02:15:00	51.4240	0.7790	-2.5580	540.9722222	40.9820
11/02/06	02:16:00	51.4240	0.7790	-2.5580	540.9722222	40.9820
11/02/06	02:17:00	51.4240	0.7790	-2.5580	540.9722222	40.9820
11/02/06	02:18:00	51.4240	0.7790	-2.5580	540.9722222	40.9820
11/02/06	02:19:00	51.4240	0.7790	-2.5580	540.9722222	40.9820
11/02/06	02:20:00	51.4930	0.7800	-2.5580	541.6666667	41.0510
11/02/06	02:21:00	51.4930	0.7800	-2.5580	541.6666667	41.0510
11/02/06	02:22:00	51.4240	0.7800	-2.5850	541.6666667	41.0090
11/02/06	02:23:00	51.4930	0.7790	-2.5850	540.9722222	41.0780
11/02/06	02:24:00	51.4930	0.7790	-2.5850	540.9722222	41.0780
11/02/06	02:25:00	51.4930	0.7790	-2.5850	540.9722222	41.0780
11/02/06	02:26:00	51.4930	0.7790	-2.5850	540.9722222	41.0780
11/02/06	02:27:00	51.4590	0.7790	-2.5850	540.9722222	41.0440
11/02/06	02:28:00	51.4590	0.7790	-2.5850	540.9722222	41.0440
11/02/06	02:29:00	51.4590	0.7790	-2.5850	540.9722222	41.0440
11/02/06	02:30:00	51.4590	0.7790	-2.5850	540.9722222	41.0440
11/02/06	02:31:00	51.4590	0.7790	-2.5850	540.9722222	41.0440

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	02:32:00	51.4590	0.7790	-2.5850	540.9722222	41.0440
11/02/06	02:33:00	51.4590	0.7790	-2.5850	540.9722222	41.0440
11/02/06	02:34:00	51.4590	0.7790	-2.5850	540.9722222	41.0440
11/02/06	02:35:00	51.4590	0.7790	-2.5850	540.9722222	41.0440
11/02/06	02:36:00	51.4590	0.7790	-2.5850	540.9722222	41.0440
11/02/06	02:37:00	51.4590	0.7790	-2.5850	540.9722222	41.0440
11/02/06	02:38:00	51.4590	0.7800	-2.6120	541.6666667	41.0710
11/02/06	02:39:00	51.4590	0.7800	-2.6120	541.6666667	41.0710
11/02/06	02:40:00	51.6320	0.7800	-2.6120	541.6666667	41.2440
11/02/06	02:41:00	51.6320	0.7800	-2.6120	541.6666667	41.2440
11/02/06	02:42:00	51.5970	0.7800	-2.6120	541.6666667	41.2090
11/02/06	02:43:00	51.4590	0.7790	-2.6210	540.9722222	41.0800
11/02/06	02:44:00	51.4590	0.7790	-2.6210	540.9722222	41.0800
11/02/06	02:45:00	51.4590	0.7790	-2.6300	540.9722222	41.0890
11/02/06	02:46:00	51.4590	0.7790	-2.6390	540.9722222	41.0980
11/02/06	02:47:00	51.4590	0.7790	-2.6390	540.9722222	41.0980
11/02/06	02:48:00	51.3890	0.7790	-2.6390	540.9722222	41.0280
11/02/06	02:49:00	51.3540	0.7780	-2.6390	540.2777778	40.9930
11/02/06	02:50:00	51.3540	0.7780	-2.6390	540.2777778	40.9930
11/02/06	02:51:00	51.3540	0.7780	-2.6390	540.2777778	40.9930
11/02/06	02:52:00	51.3200	0.7780	-2.6390	540.2777778	40.9590
11/02/06	02:53:00	51.3540	0.7800	-2.6480	541.6666667	41.0020
11/02/06	02:54:00	51.3540	0.7800	-2.6480	541.6666667	41.0020
11/02/06	02:55:00	51.3540	0.7800	-2.6480	541.6666667	41.0020
11/02/06	02:56:00	51.3200	0.7780	-2.6480	540.2777778	40.9680
11/02/06	02:57:00	51.3200	0.7780	-2.6480	540.2777778	40.9680
11/02/06	02:58:00	51.3200	0.7780	-2.6480	540.2777778	40.9680
11/02/06	02:59:00	51.3200	0.7780	-2.6480	540.2777778	40.9680
11/02/06	03:00:00	51.3200	0.7780	-2.6670	540.2777778	40.9870
11/02/06	03:01:00	51.4240	0.7800	-2.6670	541.6666667	41.0910
11/02/06	03:02:00	51.4240	0.7800	-2.6670	541.6666667	41.0910
11/02/06	03:03:00	51.4240	0.7800	-2.6670	541.6666667	41.0910
11/02/06	03:04:00	51.4240	0.7800	-2.6670	541.6666667	41.0910
11/02/06	03:05:00	51.3200	0.7780	-2.6760	540.2777778	40.9960
11/02/06	03:06:00	51.3200	0.7780	-2.6760	540.2777778	40.9960
11/02/06	03:07:00	51.3890	0.7790	-2.6760	540.9722222	41.0650
11/02/06	03:08:00	51.3890	0.7790	-2.6760	540.9722222	41.0650
11/02/06	03:09:00	51.3890	0.7790	-2.6760	540.9722222	41.0650
11/02/06	03:10:00	51.3890	0.7790	-2.6760	540.9722222	41.0650
11/02/06	03:11:00	51.2850	0.7780	-2.7030	540.2777778	40.9880
11/02/06	03:12:00	51.2850	0.7780	-2.7030	540.2777778	40.9880
11/02/06	03:13:00	51.2850	0.7780	-2.7030	540.2777778	40.9880
11/02/06	03:14:00	51.3540	0.7800	-2.7030	541.6666667	41.0570
11/02/06	03:15:00	51.3540	0.7800	-2.7030	541.6666667	41.0570
11/02/06	03:16:00	51.3540	0.7800	-2.7030	541.6666667	41.0570
11/02/06	03:17:00	51.3540	0.7800	-2.7030	541.6666667	41.0570
11/02/06	03:18:00	51.1810	0.7780	-2.7030	540.2777778	40.8840
11/02/06	03:19:00	51.1810	0.7780	-2.7030	540.2777778	40.8840
11/02/06	03:20:00	51.1810	0.7780	-2.7030	540.2777778	40.8840
11/02/06	03:21:00	51.1110	0.7750	-2.7030	538.1944444	40.8140
11/02/06	03:22:00	51.1110	0.7750	-2.7030	538.1944444	40.8140
11/02/06	03:23:00	51.1110	0.7770	-2.7030	539.5833333	40.8140
11/02/06	03:24:00	51.1110	0.7770	-2.7030	539.5833333	40.8140
11/02/06	03:25:00	51.1110	0.7760	-2.7030	538.8888889	40.8140
11/02/06	03:26:00	51.2160	0.7780	-2.7030	540.2777778	40.9190
11/02/06	03:27:00	51.2160	0.7780	-2.7030	540.2777778	40.9190
11/02/06	03:28:00	51.2160	0.7780	-2.7030	540.2777778	40.9190
11/02/06	03:29:00	51.2160	0.7780	-2.7030	540.2777778	40.9190
11/02/06	03:30:00	51.2160	0.7780	-2.7030	540.2777778	40.9190
11/02/06	03:31:00	51.2160	0.7780	-2.7030	540.2777778	40.9190
11/02/06	03:32:00	51.2160	0.7780	-2.7030	540.2777778	40.9190
11/02/06	03:33:00	51.2160	0.7780	-2.7300	540.2777778	40.9460
11/02/06	03:34:00	51.2160	0.7780	-2.7300	540.2777778	40.9460
11/02/06	03:35:00	51.2160	0.7780	-2.7300	540.2777778	40.9460
11/02/06	03:36:00	51.2500	0.7770	-2.7300	539.5833333	40.9800
11/02/06	03:37:00	51.2500	0.7770	-2.7300	539.5833333	40.9800
11/02/06	03:38:00	51.1460	0.7760	-2.7570	538.8888889	40.9030
11/02/06	03:39:00	51.1460	0.7760	-2.7570	538.8888889	40.9030
11/02/06	03:40:00	51.1460	0.7760	-2.7570	538.8888889	40.9030
11/02/06	03:41:00	51.1460	0.7760	-2.7570	538.8888889	40.9030
11/02/06	03:42:00	51.1460	0.7760	-2.7570	538.8888889	40.9030
11/02/06	03:43:00	51.1460	0.7760	-2.7570	538.8888889	40.9030
11/02/06	03:44:00	51.1810	0.7780	-2.7660	540.2777778	40.9470
11/02/06	03:45:00	51.1810	0.7780	-2.7660	540.2777778	40.9470

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	03:46:00	51.1110	0.7770	-2.7840	539.5833333	40.8950
11/02/06	03:47:00	51.1460	0.7750	-2.7840	538.1944444	40.9300
11/02/06	03:48:00	51.1460	0.7750	-2.7840	538.1944444	40.9300
11/02/06	03:49:00	51.1460	0.7760	-2.7840	538.8888889	40.9300
11/02/06	03:50:00	51.1460	0.7760	-2.7840	538.8888889	40.9300
11/02/06	03:51:00	51.1460	0.7760	-2.7840	538.8888889	40.9300
11/02/06	03:52:00	51.2160	0.7770	-2.7840	539.5833333	41.0000
11/02/06	03:53:00	51.2160	0.7770	-2.7840	539.5833333	41.0000
11/02/06	03:54:00	51.2160	0.7760	-2.7840	538.8888889	41.0000
11/02/06	03:55:00	51.2160	0.7760	-2.7840	538.8888889	41.0000
11/02/06	03:56:00	51.2850	0.7770	-2.7840	539.5833333	41.0690
11/02/06	03:57:00	51.2850	0.7770	-2.7840	539.5833333	41.0690
11/02/06	03:58:00	51.2500	0.7780	-2.7570	540.2777778	41.0070
11/02/06	03:59:00	51.2500	0.7780	-2.7570	540.2777778	41.0070
11/02/06	04:00:00	51.2500	0.7780	-2.7570	540.2777778	41.0070
11/02/06	04:01:00	51.3200	0.7780	-2.7570	540.2777778	41.0770
11/02/06	04:02:00	51.3200	0.7780	-2.7570	540.2777778	41.0770
11/02/06	04:03:00	51.2160	0.7770	-2.7570	539.5833333	40.9730
11/02/06	04:04:00	51.2160	0.7770	-2.7570	539.5833333	40.9730
11/02/06	04:05:00	51.2160	0.7770	-2.7570	539.5833333	40.9730
11/02/06	04:06:00	51.2500	0.7780	-2.7480	540.2777778	40.9980
11/02/06	04:07:00	51.2500	0.7780	-2.7480	540.2777778	40.9980
11/02/06	04:08:00	51.2850	0.7770	-2.7480	539.5833333	41.0330
11/02/06	04:09:00	51.2850	0.7770	-2.7480	539.5833333	41.0330
11/02/06	04:10:00	51.1810	0.7770	-2.7480	539.5833333	40.9290
11/02/06	04:11:00	51.1810	0.7770	-2.7480	539.5833333	40.9290
11/02/06	04:12:00	51.1460	0.7760	-2.7660	538.8888889	40.9120
11/02/06	04:13:00	51.1460	0.7760	-2.7660	538.8888889	40.9120
11/02/06	04:14:00	51.2160	0.7760	-2.7840	538.8888889	41.0000
11/02/06	04:15:00	51.2160	0.7780	-2.7840	540.2777778	41.0000
11/02/06	04:16:00	51.2160	0.7780	-2.7840	540.2777778	41.0000
11/02/06	04:17:00	51.1460	0.7760	-2.7840	538.8888889	40.9300
11/02/06	04:18:00	51.1460	0.7760	-2.7840	538.8888889	40.9300
11/02/06	04:19:00	51.1110	0.7760	-2.7660	538.8888889	40.8770
11/02/06	04:20:00	51.1110	0.7760	-2.7660	538.8888889	40.8770
11/02/06	04:21:00	51.2850	0.7770	-2.7660	539.5833333	41.0510
11/02/06	04:22:00	51.2850	0.7770	-2.7660	539.5833333	41.0510
11/02/06	04:23:00	51.3200	0.7770	-2.7120	539.5833333	41.0320
11/02/06	04:24:00	51.3200	0.7770	-2.7120	539.5833333	41.0320
11/02/06	04:25:00	51.4240	0.7760	-2.6120	538.8888889	41.0360
11/02/06	04:26:00	51.4590	0.7780	-2.5580	540.2777778	41.0170
11/02/06	04:27:00	51.4590	0.7780	-2.5580	540.2777778	41.0170
11/02/06	04:28:00	51.5970	0.7790	-2.5040	540.9722222	41.1010
11/02/06	04:29:00	51.5970	0.7790	-2.5040	540.9722222	41.1010
11/02/06	04:30:00	51.5970	0.7800	-2.4860	541.6666667	41.0830
11/02/06	04:31:00	51.5970	0.7800	-2.4500	541.6666667	41.0470
11/02/06	04:32:00	51.5970	0.7800	-2.4500	541.6666667	41.0470
11/02/06	04:33:00	51.5970	0.7800	-2.4500	541.6666667	41.0470
11/02/06	04:34:00	51.5970	0.7800	-2.4500	541.6666667	41.0470
11/02/06	04:35:00	51.5970	0.7800	-2.4500	541.6666667	41.0470
11/02/06	04:36:00	51.5970	0.7800	-2.4500	541.6666667	41.0470
11/02/06	04:37:00	51.5970	0.7800	-2.4500	541.6666667	41.0470
11/02/06	04:38:00	51.5970	0.7800	-2.4500	541.6666667	41.0470
11/02/06	04:39:00	51.5970	0.7800	-2.4500	541.6666667	41.0470
11/02/06	04:40:00	51.5970	0.7800	-2.4500	541.6666667	41.0470
11/02/06	04:41:00	51.5970	0.7800	-2.4500	541.6666667	41.0470
11/02/06	04:42:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:43:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:44:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:45:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:46:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:47:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:48:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:49:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:50:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:51:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:52:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:53:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:54:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	04:55:00	51.5630	0.7790	-2.3690	540.9722222	40.9320
11/02/06	04:56:00	51.5630	0.7790	-2.3690	540.9722222	40.9320
11/02/06	04:57:00	51.5630	0.7790	-2.3690	540.9722222	40.9320
11/02/06	04:58:00	51.5630	0.7790	-2.3690	540.9722222	40.9320
11/02/06	04:59:00	51.5630	0.7800	-2.3690	541.6666667	40.9320

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	05:00:00	51.5630	0.7800	-2.3690	541.6666667	40.9320
11/02/06	05:01:00	51.6670	0.7790	-2.3510	540.9722222	41.0180
11/02/06	05:02:00	51.6670	0.7790	-2.3510	540.9722222	41.0180
11/02/06	05:03:00	51.6670	0.7790	-2.3510	540.9722222	41.0180
11/02/06	05:04:00	51.6670	0.7790	-2.3510	540.9722222	41.0180
11/02/06	05:05:00	51.5970	0.7800	-2.3140	541.6666667	40.9110
11/02/06	05:06:00	51.5970	0.7800	-2.3140	541.6666667	40.9110
11/02/06	05:07:00	51.7020	0.7800	-2.3050	541.6666667	41.0070
11/02/06	05:08:00	51.7020	0.7800	-2.3050	541.6666667	41.0070
11/02/06	05:09:00	51.7020	0.7800	-2.3050	541.6666667	41.0070
11/02/06	05:10:00	51.6670	0.7800	-2.2780	541.6666667	40.9450
11/02/06	05:11:00	51.6670	0.7800	-2.2780	541.6666667	40.9450
11/02/06	05:12:00	51.6670	0.7800	-2.2780	541.6666667	40.9450
11/02/06	05:13:00	51.7020	0.7810	-2.2780	542.3611111	40.9800
11/02/06	05:14:00	51.7020	0.7790	-2.2600	540.9722222	40.9620
11/02/06	05:15:00	51.7020	0.7790	-2.2600	540.9722222	40.9620
11/02/06	05:16:00	51.8060	0.7810	-2.2510	542.3611111	41.0570
11/02/06	05:17:00	51.8060	0.7810	-2.2510	542.3611111	41.0570
11/02/06	05:18:00	51.8060	0.7810	-2.2510	542.3611111	41.0570
11/02/06	05:19:00	51.9450	0.7810	-2.2240	542.3611111	41.1690
11/02/06	05:20:00	51.9450	0.7810	-2.2240	542.3611111	41.1690
11/02/06	05:21:00	51.9450	0.7810	-2.2240	542.3611111	41.1690
11/02/06	05:22:00	51.9450	0.7810	-2.2240	542.3611111	41.1690
11/02/06	05:23:00	51.9450	0.7810	-2.2240	542.3611111	41.1690
11/02/06	05:24:00	51.8750	0.7800	-2.2150	541.6666667	41.0900
11/02/06	05:25:00	51.8750	0.7800	-2.2150	541.6666667	41.0900
11/02/06	05:26:00	51.8750	0.7800	-2.2150	541.6666667	41.0900
11/02/06	05:27:00	51.8750	0.7800	-2.2150	541.6666667	41.0900
11/02/06	05:28:00	51.9100	0.7810	-2.1970	542.3611111	41.1070
11/02/06	05:29:00	51.9100	0.7810	-2.1970	542.3611111	41.1070
11/02/06	05:30:00	51.9100	0.7810	-2.1970	542.3611111	41.1070
11/02/06	05:31:00	51.9100	0.7810	-2.1970	542.3611111	41.1070
11/02/06	05:32:00	51.9100	0.7810	-2.1970	542.3611111	41.1070
11/02/06	05:33:00	51.9100	0.7810	-2.1970	542.3611111	41.1070
11/02/06	05:34:00	51.9100	0.7810	-2.1970	542.3611111	41.1070
11/02/06	05:35:00	51.9100	0.7830	-2.1700	543.75	41.0800
11/02/06	05:36:00	51.9100	0.7830	-2.1700	543.75	41.0800
11/02/06	05:37:00	51.9100	0.7830	-2.1700	543.75	41.0800
11/02/06	05:38:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:39:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:40:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:41:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:42:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:43:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:44:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:45:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:46:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:47:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:48:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:49:00	51.7710	0.7810	-2.1700	542.3611111	40.9410
11/02/06	05:50:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	05:51:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	05:52:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	05:53:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	05:54:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	05:55:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	05:56:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	05:57:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	05:58:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	05:59:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:00:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:01:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:02:00	52.0140	0.7830	-2.0350	543.75	41.0490
11/02/06	06:03:00	52.0140	0.7830	-2.0350	543.75	41.0490
11/02/06	06:04:00	52.0140	0.7870	-2.0350	546.5277778	41.0490
11/02/06	06:05:00	52.0140	0.7870	-2.0350	546.5277778	41.0490
11/02/06	06:06:00	52.0140	0.7870	-2.0350	546.5277778	41.0490
11/02/06	06:07:00	52.0140	0.7830	-2.0350	543.75	41.0490
11/02/06	06:08:00	52.0140	0.7830	-2.0350	543.75	41.0490
11/02/06	06:09:00	52.0140	0.7840	-2.0070	544.4444444	41.0210
11/02/06	06:10:00	52.0140	0.7840	-2.0070	544.4444444	41.0210
11/02/06	06:11:00	52.0490	0.7830	-1.9980	543.75	41.0470
11/02/06	06:12:00	52.0490	0.7830	-1.9980	543.75	41.0470
11/02/06	06:13:00	52.1530	0.7840	-1.9980	544.4444444	41.1510

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	06:14:00	52.1530	0.7860	-1.9710	545.8333333	41.1240
11/02/06	06:15:00	52.1530	0.7860	-1.9710	545.8333333	41.1240
11/02/06	06:16:00	52.1180	0.7820	-1.9800	543.0555556	41.0980
11/02/06	06:17:00	52.1180	0.7820	-1.9800	543.0555556	41.0980
11/02/06	06:18:00	52.0840	0.7850	-1.9710	545.1388889	41.0550
11/02/06	06:19:00	52.0840	0.7850	-1.9710	545.1388889	41.0550
11/02/06	06:20:00	52.0840	0.7850	-1.9710	545.1388889	41.0550
11/02/06	06:21:00	52.0840	0.7850	-1.9710	545.1388889	41.0550
11/02/06	06:22:00	52.0840	0.7850	-1.9710	545.1388889	41.0550
11/02/06	06:23:00	52.0840	0.7850	-1.9710	545.1388889	41.0550
11/02/06	06:24:00	52.0840	0.7850	-1.9710	545.1388889	41.0550
11/02/06	06:25:00	52.0840	0.7850	-1.9710	545.1388889	41.0550
11/02/06	06:26:00	52.0840	0.7850	-1.9710	545.1388889	41.0550
11/02/06	06:27:00	52.1880	0.7830	-1.9440	543.75	41.1320
11/02/06	06:28:00	52.1880	0.7830	-1.9440	543.75	41.1320
11/02/06	06:29:00	52.1880	0.7830	-1.9440	543.75	41.1320
11/02/06	06:30:00	52.0840	0.7840	-1.9530	544.4444444	41.0370
11/02/06	06:31:00	52.0840	0.7840	-1.9530	544.4444444	41.0370
11/02/06	06:32:00	52.0840	0.7840	-1.9530	544.4444444	41.0370
11/02/06	06:33:00	52.1530	0.7860	-1.9440	545.8333333	41.0970
11/02/06	06:34:00	52.1530	0.7860	-1.9440	545.8333333	41.0970
11/02/06	06:35:00	52.1530	0.7860	-1.9440	545.8333333	41.0970
11/02/06	06:36:00	52.1530	0.7860	-1.9440	545.8333333	41.0970
11/02/06	06:37:00	52.1530	0.7860	-1.9440	545.8333333	41.0970
11/02/06	06:38:00	52.1530	0.7860	-1.9440	545.8333333	41.0970
11/02/06	06:39:00	52.1530	0.7860	-1.9440	545.8333333	41.0970
11/02/06	06:40:00	52.1530	0.7860	-1.9440	545.8333333	41.0970
11/02/06	06:41:00	52.1530	0.7860	-1.9440	545.8333333	41.0970
11/02/06	06:42:00	52.1530	0.7860	-1.9440	545.8333333	41.0970
11/02/06	06:43:00	52.1530	0.7860	-1.9440	545.8333333	41.0970
11/02/06	06:44:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:45:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:46:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:47:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:48:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:49:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:50:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:51:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:52:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:53:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:54:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:55:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:56:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:57:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:58:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	06:59:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:00:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:01:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:02:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:03:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:04:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:05:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:06:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:07:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:08:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:09:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:10:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:11:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:12:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:13:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:14:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:15:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:16:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:17:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:18:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:19:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:20:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:21:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:22:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:23:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:24:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:25:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:26:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	07:27:00	0.0000	0.0000	0.0000	0	-13.0000











**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	12:24:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	12:25:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	12:26:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	12:27:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	12:28:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	12:29:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	12:30:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	12:31:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	12:32:00	53.1950	0.7930	-1.3030	550.6944444	41.4980
11/02/06	12:33:00	53.1950	0.7930	-1.3030	550.6944444	41.4980
11/02/06	12:34:00	53.1950	0.7930	-1.3030	550.6944444	41.4980
11/02/06	12:35:00	53.1600	0.7930	-1.3120	550.6944444	41.4720
11/02/06	12:36:00	53.1600	0.7930	-1.3120	550.6944444	41.4720
11/02/06	12:37:00	53.1600	0.7930	-1.3120	550.6944444	41.4720
11/02/06	12:38:00	53.1250	0.7930	-1.2850	550.6944444	41.4100
11/02/06	12:39:00	53.1250	0.7930	-1.2850	550.6944444	41.4100
11/02/06	12:40:00	53.1600	0.7940	-1.2850	551.3888889	41.4450
11/02/06	12:41:00	53.1600	0.7940	-1.2850	551.3888889	41.4450
11/02/06	12:42:00	53.1250	0.7940	-1.2760	551.3888889	41.4010
11/02/06	12:43:00	53.1600	0.7930	-1.2760	550.6944444	41.4360
11/02/06	12:44:00	53.1600	0.7930	-1.2760	550.6944444	41.4360
11/02/06	12:45:00	53.1950	0.7940	-1.2850	551.3888889	41.4800
11/02/06	12:46:00	53.1950	0.7940	-1.2760	551.3888889	41.4710
11/02/06	12:47:00	53.1950	0.7940	-1.2760	551.3888889	41.4710
11/02/06	12:48:00	53.1950	0.7940	-1.2760	551.3888889	41.4710
11/02/06	12:49:00	53.1950	0.7940	-1.2760	551.3888889	41.4710
11/02/06	12:50:00	53.1950	0.7940	-1.2760	551.3888889	41.4710
11/02/06	12:51:00	53.1950	0.7940	-1.2760	551.3888889	41.4710
11/02/06	12:52:00	53.2290	0.7930	-1.2490	550.6944444	41.4780
11/02/06	12:53:00	53.2290	0.7930	-1.2490	550.6944444	41.4780
11/02/06	12:54:00	53.2290	0.7930	-1.2490	550.6944444	41.4780
11/02/06	12:55:00	53.1950	0.7930	-1.2490	550.6944444	41.4440
11/02/06	12:56:00	53.1250	0.7910	-1.2490	549.3055556	41.3740
11/02/06	12:57:00	53.1250	0.7910	-1.2490	549.3055556	41.3740
11/02/06	12:58:00	53.2640	0.7930	-1.2490	550.6944444	41.5130
11/02/06	12:59:00	53.2640	0.7930	-1.2490	550.6944444	41.5130
11/02/06	13:00:00	53.1250	0.7950	-1.2490	552.0833333	41.3740
11/02/06	13:01:00	53.1250	0.7930	-1.2490	550.6944444	41.3740
11/02/06	13:02:00	53.1250	0.7930	-1.2490	550.6944444	41.3740
11/02/06	13:03:00	53.1250	0.7930	-1.2490	550.6944444	41.3740
11/02/06	13:04:00	53.1600	0.7930	-1.2490	550.6944444	41.4090
11/02/06	13:05:00	53.1600	0.7930	-1.2490	550.6944444	41.4090
11/02/06	13:06:00	53.1950	0.7940	-1.2490	551.3888889	41.4440
11/02/06	13:07:00	53.1950	0.7940	-1.2490	551.3888889	41.4440
11/02/06	13:08:00	53.0910	0.7930	-1.2490	550.6944444	41.3400
11/02/06	13:09:00	53.1250	0.7940	-1.2490	551.3888889	41.3740
11/02/06	13:10:00	53.1250	0.7940	-1.2490	551.3888889	41.3740
11/02/06	13:11:00	53.0910	0.7910	-1.2490	549.3055556	41.3400
11/02/06	13:12:00	53.0910	0.7910	-1.2490	549.3055556	41.3400
11/02/06	13:13:00	53.1250	0.7930	-1.2490	550.6944444	41.3740
11/02/06	13:14:00	53.0910	0.7920	-1.2490	550	41.3400
11/02/06	13:15:00	53.0910	0.7920	-1.2490	550	41.3400
11/02/06	13:16:00	53.1600	0.7940	-1.2490	551.3888889	41.4090
11/02/06	13:17:00	53.1600	0.7940	-1.2490	551.3888889	41.4090
11/02/06	13:18:00	53.1950	0.7950	-1.2490	552.0833333	41.4440
11/02/06	13:19:00	53.1950	0.7950	-1.2490	552.0833333	41.4440
11/02/06	13:20:00	53.1600	0.7940	-1.2490	551.3888889	41.4090
11/02/06	13:21:00	53.1600	0.7940	-1.2490	551.3888889	41.4090
11/02/06	13:22:00	53.1950	0.7960	-1.2490	552.7777778	41.4440
11/02/06	13:23:00	53.1950	0.7960	-1.2490	552.7777778	41.4440
11/02/06	13:24:00	53.1950	0.7960	-1.2490	552.7777778	41.4440
11/02/06	13:25:00	53.1600	0.7940	-1.2490	551.3888889	41.4090
11/02/06	13:26:00	53.1250	0.7930	-1.2760	550.6944444	41.4010
11/02/06	13:27:00	53.1250	0.7930	-1.2760	550.6944444	41.4010
11/02/06	13:28:00	53.0910	0.7950	-1.2850	552.0833333	41.3760
11/02/06	13:29:00	53.0910	0.7950	-1.2850	552.0833333	41.3760
11/02/06	13:30:00	53.1250	0.7950	-1.2850	552.0833333	41.4100
11/02/06	13:31:00	53.1250	0.7950	-1.2940	552.0833333	41.4190
11/02/06	13:32:00	53.1250	0.7950	-1.2940	552.0833333	41.4190
11/02/06	13:33:00	53.0910	0.7930	-1.3030	550.6944444	41.3940
11/02/06	13:34:00	53.0910	0.7930	-1.3030	550.6944444	41.3940
11/02/06	13:35:00	53.0560	0.7950	-1.3030	552.0833333	41.3590
11/02/06	13:36:00	53.0560	0.7950	-1.3030	552.0833333	41.3590
11/02/06	13:37:00	53.0210	0.7950	-1.3120	552.0833333	41.3330

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	13:38:00	53.0210	0.7950	-1.3120	552.0833333	41.3330
11/02/06	13:39:00	53.0210	0.7930	-1.3120	550.6944444	41.3330
11/02/06	13:40:00	53.0210	0.7930	-1.3120	550.6944444	41.3330
11/02/06	13:41:00	53.0210	0.7940	-1.3120	551.3888889	41.3330
11/02/06	13:42:00	53.0210	0.7940	-1.3120	551.3888889	41.3330
11/02/06	13:43:00	52.9860	0.7930	-1.3120	550.6944444	41.2980
11/02/06	13:44:00	52.9860	0.7930	-1.3120	550.6944444	41.2980
11/02/06	13:45:00	53.0910	0.7940	-1.3120	551.3888889	41.4030
11/02/06	13:46:00	53.0910	0.7940	-1.3120	551.3888889	41.4030
11/02/06	13:47:00	53.0910	0.7930	-1.3030	550.6944444	41.3940
11/02/06	13:48:00	52.6390	0.7910	-1.3120	549.3055556	40.9510
11/02/06	13:49:00	52.6390	0.7910	-1.3120	549.3055556	40.9510
11/02/06	13:50:00	52.7090	0.7910	-1.3120	549.3055556	41.0210
11/02/06	13:51:00	52.7090	0.7910	-1.3120	549.3055556	41.0210
11/02/06	13:52:00	52.6740	0.7920	-1.3120	550	40.9860
11/02/06	13:53:00	52.6740	0.7920	-1.3120	550	40.9860
11/02/06	13:54:00	52.6740	0.7920	-1.3120	550	40.9860
11/02/06	13:55:00	52.6390	0.7920	-1.3120	550	40.9510
11/02/06	13:56:00	52.6390	0.7910	-1.3030	549.3055556	40.9420
11/02/06	13:57:00	52.6390	0.7910	-1.3030	549.3055556	40.9420
11/02/06	13:58:00	52.7430	0.7930	-1.3120	550.6944444	41.0550
11/02/06	13:59:00	52.7430	0.7930	-1.3120	550.6944444	41.0550
11/02/06	14:00:00	52.7780	0.7920	-1.3120	550	41.0900
11/02/06	14:01:00	52.7430	0.7940	-1.3300	551.3888889	41.0730
11/02/06	14:02:00	52.7430	0.7940	-1.3300	551.3888889	41.0730
11/02/06	14:03:00	52.6740	0.7910	-1.3480	549.3055556	41.0220
11/02/06	14:04:00	52.6740	0.7910	-1.3480	549.3055556	41.0220
11/02/06	14:05:00	52.6740	0.7910	-1.3480	549.3055556	41.0220
11/02/06	14:06:00	52.6740	0.7920	-1.3660	550	41.0400
11/02/06	14:07:00	52.6740	0.7920	-1.3660	550	41.0400
11/02/06	14:08:00	52.6390	0.7920	-1.3940	550	41.0330
11/02/06	14:09:00	52.6740	0.7930	-1.3940	550.6944444	41.0680
11/02/06	14:10:00	52.6740	0.7930	-1.3940	550.6944444	41.0680
11/02/06	14:11:00	52.6740	0.7930	-1.3940	550.6944444	41.0680
11/02/06	14:12:00	52.6740	0.7930	-1.3940	550.6944444	41.0680
11/02/06	14:13:00	52.6390	0.7930	-1.3940	550.6944444	41.0330
11/02/06	14:14:00	52.7090	0.7910	-1.3940	549.3055556	41.1030
11/02/06	14:15:00	52.7090	0.7910	-1.3940	549.3055556	41.1030
11/02/06	14:16:00	52.6390	0.7920	-1.3940	550	41.0330
11/02/06	14:17:00	52.6390	0.7920	-1.3940	550	41.0330
11/02/06	14:18:00	52.7090	0.7920	-1.3940	550	41.1030
11/02/06	14:19:00	52.7090	0.7920	-1.3940	550	41.1030
11/02/06	14:20:00	52.6390	0.7930	-1.3940	550.6944444	41.0330
11/02/06	14:21:00	52.6390	0.7930	-1.3940	550.6944444	41.0330
11/02/06	14:22:00	52.7430	0.7940	-1.3850	551.3888889	41.1280
11/02/06	14:23:00	52.7430	0.7940	-1.3850	551.3888889	41.1280
11/02/06	14:24:00	52.7090	0.7930	-1.3940	550.6944444	41.1030
11/02/06	14:25:00	52.7090	0.7930	-1.3940	550.6944444	41.1030
11/02/06	14:26:00	52.7430	0.7940	-1.3940	551.3888889	41.1370
11/02/06	14:27:00	52.7430	0.7940	-1.3940	551.3888889	41.1370
11/02/06	14:28:00	52.7430	0.7940	-1.3940	551.3888889	41.1370
11/02/06	14:29:00	52.7090	0.7940	-1.3940	551.3888889	41.1030
11/02/06	14:30:00	52.7090	0.7940	-1.4210	551.3888889	41.1300
11/02/06	14:31:00	52.7090	0.7940	-1.4210	551.3888889	41.1300
11/02/06	14:32:00	52.6040	0.7930	-1.4750	550.6944444	41.0790
11/02/06	14:33:00	52.6040	0.7930	-1.4750	550.6944444	41.0790
11/02/06	14:34:00	52.5700	0.7910	-1.4750	549.3055556	41.0450
11/02/06	14:35:00	52.5700	0.7910	-1.4750	549.3055556	41.0450
11/02/06	14:36:00	52.6040	0.7940	-1.5020	551.3888889	41.1060
11/02/06	14:37:00	52.6040	0.7940	-1.5020	551.3888889	41.1060
11/02/06	14:38:00	52.6040	0.7920	-1.5020	550	41.1060
11/02/06	14:39:00	52.6390	0.7930	-1.5020	550.6944444	41.1410
11/02/06	14:40:00	52.6390	0.7930	-1.5020	550.6944444	41.1410
11/02/06	14:41:00	52.5700	0.7900	-1.5290	548.6111111	41.0990
11/02/06	14:42:00	52.5700	0.7900	-1.5290	548.6111111	41.0990
11/02/06	14:43:00	52.5000	0.7920	-1.5560	550	41.0560
11/02/06	14:44:00	52.5000	0.7920	-1.5560	550	41.0560
11/02/06	14:45:00	52.5000	0.7910	-1.5830	549.3055556	41.0830
11/02/06	14:46:00	52.5000	0.7910	-1.5830	549.3055556	41.0830
11/02/06	14:47:00	52.5000	0.7920	-1.5830	550	41.0830
11/02/06	14:48:00	52.5000	0.7920	-1.5830	550	41.0830
11/02/06	14:49:00	52.5350	0.7930	-1.5830	550.6944444	41.1180
11/02/06	14:50:00	52.5000	0.7930	-1.5830	550.6944444	41.0830
11/02/06	14:51:00	52.5000	0.7930	-1.5830	550.6944444	41.0830

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	14:52:00	52.5000	0.7930	-1.5830	550.6944444	41.0830
11/02/06	14:53:00	52.5350	0.7920	-1.5830	550	41.1180
11/02/06	14:54:00	52.5350	0.7920	-1.5830	550	41.1180
11/02/06	14:55:00	52.5350	0.7920	-1.5830	550	41.1180
11/02/06	14:56:00	52.5000	0.7940	-1.5650	551.3888889	41.0650
11/02/06	14:57:00	52.5000	0.7940	-1.5650	551.3888889	41.0650
11/02/06	14:58:00	52.5000	0.7940	-1.5650	551.3888889	41.0650
11/02/06	14:59:00	52.5000	0.7940	-1.5650	551.3888889	41.0650
11/02/06	15:00:00	52.5000	0.7940	-1.5650	551.3888889	41.0650
11/02/06	15:01:00	52.5000	0.7940	-1.5650	551.3888889	41.0650
11/02/06	15:02:00	52.5000	0.7940	-1.5650	551.3888889	41.0650
11/02/06	15:03:00	52.5000	0.7940	-1.5650	551.3888889	41.0650
11/02/06	15:04:00	52.2570	0.7890	-1.5560	547.9166667	40.8130
11/02/06	15:05:00	52.2570	0.7890	-1.5560	547.9166667	40.8130
11/02/06	15:06:00	52.2220	0.7900	-1.5560	548.6111111	40.7780
11/02/06	15:07:00	52.1880	0.7900	-1.5560	548.6111111	40.7440
11/02/06	15:08:00	52.1880	0.7900	-1.5560	548.6111111	40.7440
11/02/06	15:09:00	52.1880	0.7900	-1.5560	548.6111111	40.7440
11/02/06	15:10:00	52.1880	0.7900	-1.5560	548.6111111	40.7440
11/02/06	15:11:00	52.2220	0.7890	-1.5830	547.9166667	40.8050
11/02/06	15:12:00	52.2220	0.7890	-1.5830	547.9166667	40.8050
11/02/06	15:13:00	52.1180	0.7890	-1.6190	547.9166667	40.7370
11/02/06	15:14:00	52.0490	0.7880	-1.6640	547.2222222	40.7130
11/02/06	15:15:00	52.0490	0.7880	-1.6640	547.2222222	40.7130
11/02/06	15:16:00	52.0490	0.7880	-1.6640	547.2222222	40.7130
11/02/06	15:17:00	52.0490	0.7880	-1.6640	547.2222222	40.7130
11/02/06	15:18:00	52.0490	0.7880	-1.6640	547.2222222	40.7130
11/02/06	15:19:00	52.0490	0.7880	-1.6640	547.2222222	40.7130
11/02/06	15:20:00	52.0490	0.7880	-1.6640	547.2222222	40.7130
11/02/06	15:21:00	52.0490	0.7880	-1.6640	547.2222222	40.7130
11/02/06	15:22:00	51.9450	0.7890	-1.7550	547.9166667	40.7000
11/02/06	15:23:00	51.9450	0.7890	-1.7550	547.9166667	40.7000
11/02/06	15:24:00	51.9790	0.7880	-1.7550	547.2222222	40.7340
11/02/06	15:25:00	51.9790	0.7880	-1.7550	547.2222222	40.7340
11/02/06	15:26:00	51.9790	0.7880	-1.7550	547.2222222	40.7340
11/02/06	15:27:00	51.8750	0.7880	-1.7550	547.2222222	40.6300
11/02/06	15:28:00	51.8750	0.7880	-1.7550	547.2222222	40.6300
11/02/06	15:29:00	51.8750	0.7880	-1.7550	547.2222222	40.6300
11/02/06	15:30:00	51.8750	0.7880	-1.7550	547.2222222	40.6300
11/02/06	15:31:00	51.5630	0.7840	-1.7550	544.4444444	40.3180
11/02/06	15:32:00	51.7360	0.7880	-1.7280	547.2222222	40.4640
11/02/06	15:33:00	51.7360	0.7880	-1.7280	547.2222222	40.4640
11/02/06	15:34:00	51.7360	0.7880	-1.7280	547.2222222	40.4640
11/02/06	15:35:00	51.7020	0.7870	-1.7280	546.5277778	40.4300
11/02/06	15:36:00	51.7020	0.7870	-1.7280	546.5277778	40.4300
11/02/06	15:37:00	51.7020	0.7870	-1.7280	546.5277778	40.4300
11/02/06	15:38:00	51.7710	0.7870	-1.7280	546.5277778	40.4990
11/02/06	15:39:00	51.7360	0.7860	-1.7190	545.8333333	40.4550
11/02/06	15:40:00	51.7360	0.7860	-1.7190	545.8333333	40.4550
11/02/06	15:41:00	51.7020	0.7870	-1.7280	546.5277778	40.4300
11/02/06	15:42:00	51.7020	0.7870	-1.7280	546.5277778	40.4300
11/02/06	15:43:00	51.8750	0.7870	-1.7280	546.5277778	40.6030
11/02/06	15:44:00	51.8750	0.7870	-1.7280	546.5277778	40.6030
11/02/06	15:45:00	51.8750	0.7870	-1.7280	546.5277778	40.6030
11/02/06	15:46:00	51.8750	0.7870	-1.7280	546.5277778	40.6030
11/02/06	15:47:00	51.8750	0.7870	-1.7280	546.5277778	40.6030
11/02/06	15:48:00	51.8750	0.7870	-1.7280	546.5277778	40.6030
11/02/06	15:49:00	51.7020	0.7860	-1.8090	545.8333333	40.5110
11/02/06	15:50:00	51.7020	0.7860	-1.8090	545.8333333	40.5110
11/02/06	15:51:00	51.7360	0.7870	-1.8090	546.5277778	40.5450
11/02/06	15:52:00	51.7360	0.7870	-1.8090	546.5277778	40.5450
11/02/06	15:53:00	51.7020	0.7860	-1.8360	545.8333333	40.5380
11/02/06	15:54:00	51.7020	0.7860	-1.8360	545.8333333	40.5380
11/02/06	15:55:00	51.7360	0.7850	-1.8360	545.1388889	40.5720
11/02/06	15:56:00	51.7360	0.7850	-1.8360	545.1388889	40.5720
11/02/06	15:57:00	51.7020	0.7850	-1.8360	545.1388889	40.5380
11/02/06	15:58:00	51.7020	0.7850	-1.8360	545.1388889	40.5380
11/02/06	15:59:00	51.7710	0.7870	-1.8360	546.5277778	40.6070
11/02/06	16:00:00	51.7710	0.7870	-1.8360	546.5277778	40.6070
11/02/06	16:01:00	51.8410	0.7890	-1.8360	547.9166667	40.6770
11/02/06	16:02:00	51.8410	0.7890	-1.8360	547.9166667	40.6770
11/02/06	16:03:00	52.0490	0.7900	-1.8360	548.6111111	40.8850
11/02/06	16:04:00	52.0490	0.7900	-1.8360	548.6111111	40.8850
11/02/06	16:05:00	52.0490	0.7900	-1.8360	548.6111111	40.8850

**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	16:06:00	52.0490	0.7900	-1.8360	548.6111111	40.8850
11/02/06	16:07:00	51.9450	0.7880	-1.8630	547.2222222	40.8080
11/02/06	16:08:00	51.9450	0.7880	-1.8630	547.2222222	40.8080
11/02/06	16:09:00	51.9450	0.7880	-1.8630	547.2222222	40.8080
11/02/06	16:10:00	51.9790	0.7910	-1.8630	549.3055556	40.8420
11/02/06	16:11:00	51.9790	0.7910	-1.8630	549.3055556	40.8420
11/02/06	16:12:00	51.9790	0.7910	-1.8630	549.3055556	40.8420
11/02/06	16:13:00	51.9790	0.7910	-1.8630	549.3055556	40.8420
11/02/06	16:14:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:15:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:16:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:17:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:18:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:19:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:20:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:21:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:22:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:23:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:24:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:25:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:26:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	16:27:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:28:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:29:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:30:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:31:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:32:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:33:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:34:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:35:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:36:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:37:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:38:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:39:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:40:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:41:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:42:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:43:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:44:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:45:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:46:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:47:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:48:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:49:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:50:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:51:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:52:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:53:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:54:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:55:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:56:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:57:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:58:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	16:59:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:00:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:01:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:02:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:03:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:04:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:05:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:06:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:07:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:08:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:09:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:10:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:11:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:12:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:13:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:14:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:15:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:16:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:17:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:18:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	17:19:00	0.0000	0.0000	0.0000	0	-13.0000







**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	19:48:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	19:49:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	19:50:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	19:51:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	19:52:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	19:53:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	19:54:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	19:55:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	19:56:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	19:57:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	19:58:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	19:59:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:00:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:01:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:02:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:03:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:04:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:05:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:06:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:07:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:08:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:09:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:10:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:11:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:12:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:13:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:14:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:15:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:16:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:17:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:18:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:19:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:20:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:21:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:22:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:23:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:24:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:25:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:26:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:27:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:28:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:29:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:30:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:31:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:32:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:33:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:34:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:35:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:36:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:37:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:38:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:39:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:40:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:41:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:42:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:43:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:44:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:45:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:46:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:47:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:48:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:49:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:50:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:51:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:52:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:53:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:54:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:55:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:56:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:57:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:58:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	20:59:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	21:00:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	21:01:00	0.0000	0.0000	0.0000	0	-13.0000





**KAHANAHOU WWPS SCADA DATA**  
**OCT. 31, 2006 ~ NOV. 2 2006**

11/02/06	23:30:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	23:31:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	23:32:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	23:33:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	23:34:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	23:35:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	23:36:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	23:37:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	23:38:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	23:39:00	51.8750	0.7870	-1.9170	546.5277778	40.7920
11/02/06	23:40:00	50.8680	0.7840	-3.1000	544.4444444	40.9680
11/02/06	23:41:00	50.8680	0.7840	-3.1000	544.4444444	40.9680
11/02/06	23:42:00	50.8680	0.7860	-3.1000	545.8333333	40.9680
11/02/06	23:43:00	50.8680	0.7860	-3.1000	545.8333333	40.9680
11/02/06	23:44:00	50.8680	0.7860	-3.1000	545.8333333	40.9680
11/02/06	23:45:00	50.9030	0.7850	-3.0910	545.1388889	40.9940
11/02/06	23:46:00	50.9030	0.7850	-3.0910	545.1388889	40.9940
11/02/06	23:47:00	50.7990	0.7860	-3.0910	545.8333333	40.8900
11/02/06	23:48:00	50.7990	0.7860	-3.0910	545.8333333	40.8900
11/02/06	23:49:00	50.7990	0.7860	-3.0910	545.8333333	40.8900
11/02/06	23:50:00	50.7990	0.7860	-3.0910	545.8333333	40.8900
11/02/06	23:51:00	50.7990	0.7860	-3.0910	545.8333333	40.8900
11/02/06	23:52:00	50.7990	0.7860	-3.0910	545.8333333	40.8900
11/02/06	23:53:00	50.7640	0.7840	-3.0910	544.4444444	40.8550
11/02/06	23:54:00	50.7640	0.7840	-3.0910	544.4444444	40.8550
11/02/06	23:55:00	50.7640	0.7840	-3.0910	544.4444444	40.8550
11/02/06	23:56:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	23:57:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	23:58:00	0.0000	0.0000	0.0000	0	-13.0000
11/02/06	23:59:00	0.0000	0.0000	0.0000	0	-13.0000

# **APPENDIX C INFIX PUMP STATION REPORT**

AREA : KANEOHE BASIN

PREPARED BY : CITY & COUNTY OF HONOLULU

Date : 01/06/11

PLANT/ STATION	TRIBUTARY AREA  (ACRES)	TRIBUTARY EQUIVALENT POPULATION			WASTEWATER FLOW COMPUTATION							
		RES.	OTHER	TOTAL	AVE.	MAX	MAX	DRY	DESIGN	DESIGN	WET	DESIGN
					Q	FF	Q	I/I	AVE	Q MAX	I/I	Q PEAK
(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	
KK 20	619.7	8267	3006	11273	0.9018	3.08	2.7777	0.0695	0.9713	2.8472	0.8198	3.6670
KK 21	16.2	373	12	385	0.0308	5.00	0.1541	0.0019	0.0327	0.1560	0.0202	0.1762
KK 22	195.2	2040	135	2176	0.1740	4.28	0.7449	0.0240	0.1981	0.7690	0.2891	1.0581
KK 23	171.6	1900	62	1963	0.1570	4.37	0.6860	0.0221	0.1791	0.7080	0.2554	0.9634
KK 24	103.6	1154	17	1171	0.0936	4.84	0.4537	0.0128	0.1064	0.4665	0.1493	0.6158
KK 30	4151.8	51276	40850	92126	7.3700	2.02	14.9129	0.6261	7.9960	15.5389	6.1627	21.7016
KK 31	9.0	88	24	112	0.0090	5.00	0.0449	0.0006	0.0095	0.0454	0.0113	0.0567
KK 32	68.6	832	22	854	0.0684	5.00	0.3418	0.0149	0.0832	0.3567	0.1218	0.4784
KK 33	42.4	674	226	900	0.0720	5.00	0.3598	0.0095	0.0815	0.3694	0.0731	0.4424
KK 34	142.5	2364	0	2364	0.1891	4.21	0.7961	0.0118	0.2009	0.8079	0.1781	0.9861
KK 35	425.5	743	931	1674	0.1339	4.51	0.6041	0.0084	0.1423	0.6124	1.1111	1.7235
KK 36	165.5	2354	2105	4459	0.3567	3.71	1.3226	0.0329	0.3896	1.3555	0.2251	1.5806
KK 37	181.1	2695	277	2972	0.2377	4.02	0.9560	0.0459	0.2837	1.0019	0.3231	1.3251
KK 45	27.7	442	61	503	0.0402	5.00	0.2012	0.0025	0.0428	0.2037	0.0346	0.2383
KK 48	4.2	68	0	68	0.0054	5.00	0.0272	0.0003	0.0058	0.0275	0.0053	0.0328
KK 50	464.4	4724	1078	5802	0.4642	3.52	1.6328	0.0869	0.5511	1.7197	0.7669	2.4866
KK 51	280.9	2658	797	3455	0.2764	3.90	1.0784	0.0610	0.3374	1.1394	0.4651	1.6045
KK 52	175.7	1763	776	2538	0.2031	4.15	0.8428	0.0536	0.2567	0.8964	0.3193	1.2157
KK 53	42.0	392	19	411	0.0329	5.00	0.1645	0.0061	0.0390	0.1706	0.0815	0.2521

AREA : KANEOHE BASIN

PREPARED BY : CITY & COUNTY OF HONOLULU

Date : 01/06/11

PLANT/ STATION	TRIBUTARY AREA  (ACRES)	TRIBUTARY EQUIVALENT POPULATION			WASTEWATER FLOW COMPUTATION							
		RES.	OTHER	TOTAL	AVE. Q  (MGD)	MAX FF	MAX Q  (MGD)	DRY I/I  (MGD)	DESIGN AVE  (MGD)	DESIGN Q MAX  (MGD)	WET I/I  (MGD)	DESIGN Q PEAK  (MGD)
KK 20	892.7	18101	4398	22500	1.8001	2.68	4.8286	0.2966	2.0967	5.1252	1.5703	6.6955
KK 21	162.4	2780	12	2792	0.2234	4.07	0.9095	0.0858	0.3091	0.9953	0.4223	1.4176
KK 22	313.0	4721	1314	6035	0.4829	3.49	1.6853	0.1343	0.6172	1.8196	0.6130	2.4326
KK 23	178.2	2943	56	2999	0.2400	4.01	0.9631	0.0363	0.2762	0.9994	0.2736	1.2730
KK 24	110.3	1747	17	1763	0.1411	4.46	0.6298	0.0202	0.1613	0.6500	0.1675	0.8176
KK 30	4470.7	83082	46631	129713	10.3771	1.89	19.6087	1.0568	11.4339	20.6655	7.0392	27.7047
KK 31	9.0	88	97	185	0.0148	5.00	0.0739	0.0009	0.0157	0.0748	0.0113	0.0861
KK 32	76.0	1123	18	1141	0.0913	4.87	0.4447	0.0206	0.1120	0.4653	0.1422	0.6075
KK 33	42.4	757	261	1018	0.0814	4.98	0.4055	0.0113	0.0927	0.4168	0.0731	0.4899
KK 34	142.5	2643	0	2643	0.2115	4.12	0.8705	0.0132	0.2247	0.8837	0.1781	1.0618
KK 35	425.5	811	931	1742	0.1394	4.47	0.6236	0.0087	0.1481	0.6323	1.1111	1.7434
KK 36	170.9	3850	2177	6027	0.4822	3.49	1.6833	0.0440	0.5262	1.7274	0.2398	1.9671
KK 37	188.5	3260	405	3665	0.2932	3.86	1.1306	0.0567	0.3499	1.1874	0.3436	1.5310
KK 45	27.7	530	61	591	0.0473	5.00	0.2365	0.0030	0.0503	0.2395	0.0346	0.2740
KK 48	4.2	92	0	92	0.0074	5.00	0.0369	0.0005	0.0078	0.0373	0.0053	0.0426
KK 50	464.4	7198	1145	8343	0.6675	3.27	2.1834	0.1114	0.7788	2.2947	0.7669	3.0616
KK 51	280.9	4637	831	5468	0.4375	3.56	1.5572	0.0824	0.5198	1.6395	0.4651	2.1046
KK 52	175.7	2983	776	3759	0.3007	3.84	1.1536	0.0692	0.3699	1.2228	0.3193	1.5421
KK 53	42.0	643	19	662	0.0529	5.00	0.2647	0.0122	0.0651	0.2769	0.0815	0.3584



## **APPENDIX D HISTORICAL FLOW RATES AND POWER USE**

**TABLE D-1: KAHANAHOU WWPS  
HISTORICAL FLOW RATES AND POWER USE**

(Sheet 1 of 3)

Month	Total Flow <sup>a</sup> (MGM)	Daily Flow Rate <sup>a</sup> (MGD)			Total Energy <sup>a</sup> (1,000 KWH/Month)	Flow/KWH <sup>a</sup> (1,000 gal/KWH)	Monthly Precipitation <sup>b</sup> (Inches)
		Monthly Maximum	Monthly Average	Monthly Minimum			
Jan-00	9.0750	0.4400	0.2927	0.2150	3.3970	2.6715	4.49
Feb-00	7.1250	0.3000	0.2457	0.1950	2.6730	2.6655	0.39
Mar-00	7.6600	0.3050	0.2471	0.2150	2.9620	2.5861	2.11
Apr-00	7.7000	0.3300	0.2567	0.2050	3.0540	2.5213	3.40
May-00	8.2450	0.3600	0.2660	0.1900	3.2030	2.5741	1.48
Jun-00	8.4500	0.3400	0.2817	0.2100	3.1830	2.6547	1.28
Jul-00	9.1300	0.4150	0.2945	0.2350	3.4380	2.6556	1.81
Aug-00	8.5600	0.3400	0.2761	0.2150	3.3390	2.5636	3.01
Sep-00	8.5000	0.3400	0.2833	0.2350	3.3020	2.5742	5.56
Oct-00	8.5100	0.4200	0.2745	0.2250	3.3090	2.5718	2.93
Nov-00	8.4650	0.3550	0.2822	0.2200	3.2870	2.5753	3.42
Dec-00	9.1250	0.3850	0.2944	0.2250	3.5340	2.5821	1.22
Jan-01	8.9300	0.3650	0.2881	0.2250	3.4860	2.5617	0.63
Feb-01	10.1200	0.5000	0.3614	0.2600	3.6270	2.7902	5.73
Mar-01	9.5850	0.4000	0.3092	0.2200	3.3010	2.9037	2.63
Apr-01	7.6150	0.2850	0.2538	0.2000	3.1520	2.4159	2.19
May-01	8.5300	0.3350	0.2752	0.2300	3.4320	2.4854	3.36
Jun-01	8.9300	0.3600	0.2977	0.2400	3.3760	2.6451	2.88
Jul-01	10.2500	0.4100	0.3306	0.2600	3.9460	2.5976	0.98
Aug-01	9.6700	0.4200	0.3119	0.2400	3.7000	2.6135	2.61
Sep-01	9.8700	0.3900	0.3290	0.2450	3.6940	2.6719	1.17
Oct-01	8.5300	0.3200	0.2752	0.2200	3.3920	2.5147	3.38
Nov-01	9.5300	0.6000	0.3177	0.2300	3.6140	2.6370	6.66
Dec-01	9.1600	0.4500	0.2955	0.1900	3.6540	2.5068	4.10
Jan-02	11.2250	0.6650	0.3621	0.2550	3.8740	2.8975	7.17
Feb-02	9.4750	0.5900	0.3384	0.2400	3.0650	3.0914	3.63
Mar-02	8.9800	0.3600	0.2897	0.2300	3.0670	2.9279	7.95
Apr-02	9.1100	0.3700	0.3037	0.2400	3.0790	2.9588	2.93
May-02	11.0400	0.6200	0.3561	0.2600	3.5550	3.1055	7.05
Jun-02	8.9100	0.3600	0.2970	0.2350	2.9260	3.0451	0.99
Jul-02	9.3100	0.4000	0.3003	0.2394	2.9600	3.1453	3.62
Aug-02	8.1400	0.3100	0.2626	0.2100	2.8340	2.8723	1.72
Sep-02	10.4200	0.4500	0.3473	0.2600	3.4230	3.0441	1.05
Oct-02	12.5900	0.4800	0.4061	0.3250	4.0020	3.1459	4.17
Nov-02	10.3800	0.4500	0.3460	0.2200	3.5610	2.9149	2.70
Dec-02	9.6500	0.4200	0.3113	0.2350	3.5410	2.7252	1.18
Jan-03	10.4900	0.5000	0.3384	0.2700	3.8120	2.7518	4.13
Feb-03	8.8600	0.5650	0.3164	0.2300	3.0790	2.8776	5.94
Mar-03	10.2800	0.4050	0.3316	0.2700	3.4980	2.9388	4.93
Apr-03	9.5200	0.3900	0.3173	0.2400	3.3790	2.8174	2.52
May-03	10.9800	0.4300	0.3542	0.2700	3.7770	2.9071	0.94
Jun-03	12.7700	0.5200	0.4257	0.3500	4.8160	2.6516	2.52
Jul-03	12.2300	0.5000	0.3945	0.3200	4.1680	2.9343	2.86
Aug-03	13.3250	0.5250	0.4298	0.3200	4.5160	2.9506	1.55
Sep-03	16.2550	0.6200	0.5418	0.4600	5.7290	2.8373	2.95
Oct-03	15.6200	0.6000	0.5039	0.4100	5.2260	2.9889	1.62
Nov-03	12.0100	0.6000	0.4003	0.2900	4.1700	2.8801	9.09

**TABLE D-1: KAHANAHOU WWPS  
HISTORICAL FLOW RATES AND POWER USE**  
(Sheet 2 of 3)

Month	Total Flow <sup>a</sup> (MGM)	Daily Flow Rate <sup>a</sup> (MGD)			Total Energy <sup>a</sup> (1,000 KWH/Month)	Flow/KWH <sup>a</sup> (1,000 gal/KWH)	Monthly Precipitation <sup>b</sup> (Inches)
		Monthly Maximum	Monthly Average	Monthly Minimum			
Dec-03	12.9100	0.7200	0.4165	0.2800	4.5140	2.8600	11.70
Jan-04	14.6200	0.6700	0.4716	0.3300	5.0070	2.9199	12.86
Feb-04	12.8100	0.7700	0.4417	0.3700	4.3890	2.9187	13.89
Mar-04	15.0000	0.7700	0.4839	0.3700	5.1750	2.8986	8.42
Apr-04	10.8400	0.4200	0.3613	0.2900	3.5950	3.0153	2.91
May-04	15.0000	0.6900	0.4839	0.3200	5.4980	2.7283	6.71
Jun-04	12.3400	0.5000	0.4113	0.2700	4.4460	2.7755	3.08
Jul-04	11.0400	0.5500	0.3561	0.2500	3.7400	2.9519	1.98
Aug-04	12.7200	0.7100	0.4103	0.2100	4.3160	2.9472	7.59
Sep-04	12.1000	0.6700	0.4033	0.2100	4.0350	2.9988	2.87
Oct-04	13.3800	0.7900	0.4316	0.1900	4.5830	2.9195	6.59
Nov-04	16.3600	1.0000	0.5453	0.2300	5.8570	2.7932	9.60
Dec-04	14.0500	0.7300	0.4532	0.2700	5.0360	2.7899	4.76
Jan-05	14.0600	0.8300	0.4535	0.2200	4.9870	2.8193	7.99
Feb-05	12.9900	1.0700	0.4639	0.2000	4.7490	2.7353	8.42
Mar-05	12.4200	0.7100	0.4006	0.1800	4.4640	2.7823	6.44
Apr-05	9.7200	0.6100	0.3240	0.1100	3.5740	2.7196	1.14
May-05	10.8200	0.4600	0.3490	0.2800	3.7840	2.8594	2.83
Jun-05	10.5700	0.4900	0.3523	0.2900	3.4630	3.0523	1.54
Jul-05	9.9300	0.4700	0.3203	0.1900	3.4400	2.8866	2.22
Aug-05	10.7000	0.5100	0.3452	0.2100	3.4880	3.0677	0.85
Sep-05	11.9500	0.7500	0.3983	0.2700	4.0060	2.9830	10.36
Oct-05	11.4700	0.6300	0.3700	0.1500	3.8410	2.9862	10.02
Nov-05	11.8600	0.8300	0.3953	0.2300	3.9820	2.9784	3.61
Dec-05	12.8400	0.6100	0.4142	0.2400	4.4610	2.8783	2.82
Jan-06	12.4900	0.7000	0.4029	0.1300	4.4840	2.7855	4.32
Feb-06	13.5000	0.9500	0.4821	0.2200	4.7710	2.8296	18.70
Mar-06	18.6200	0.8600	0.6006	0.3300	7.2010	2.5858	26.40
Apr-06	14.1200	0.8700	0.4707	0.2300	4.9640	2.8445	4.85
May-06	11.2500	0.5100	0.3629	0.2300	3.7420	3.0064	3.26
Jun-06	11.9700	0.6000	0.3990	0.2200	4.0360	2.9658	0.83
Jul-06	15.8700	0.9300	0.5119	0.2200	4.9290	3.2197	0.65
Aug-06	16.0300	0.7800	0.5171	0.2400	5.7540	2.7859	1.67
Sep-06	13.3100	0.6500	0.4437	0.2500	4.6140	2.8847	2.50
Oct-06	14.7100	0.7500	0.4745	0.2500	5.3310	2.7593	5.13
Nov-06	18.4300	1.0700	0.6143	0.2500	7.5430	2.4433	11.19
Dec-06	13.5700	0.7200	0.4377	0.2300	4.3290	3.1347	1.78
Jan-07	13.2300	0.6500	0.4268	0.2200	4.3930	3.0116	3.64
Feb-07	10.8500	0.5900	0.3875	0.2100	3.6780	2.9500	2.16
Mar-07	10.7300	0.5900	0.3461	0.1700	3.8180	2.8104	5.10
Apr-07	9.2800	0.4800	0.3093	0.1400	3.1650	2.9321	1.22
May-07	10.1500	0.4700	0.3274	0.1700	3.3190	3.0582	1.18
Jun-07	10.0200	0.5300	0.3340	0.1800	3.1480	3.1830	1.15
Jul-07	11.2200	0.5300	0.3619	0.2200	3.7440	2.9968	2.12
Aug-07	11.8200	0.5500	0.3813	0.2200	4.1470	2.8503	1.56
Sep-07	10.6700	0.5200	0.3557	0.1900	3.5140	3.0364	1.56
Oct-07	10.1500	0.5500	0.3274	0.1800	3.3610	3.0199	1.40

**TABLE D-1: KAHANAHOU WWPS  
HISTORICAL FLOW RATES AND POWER USE**  
(Sheet 3 of 3)

Month	Total Flow <sup>a</sup> (MGM)	Daily Flow Rate <sup>a</sup> (MGD)			Total Energy <sup>a</sup> (1,000 KWH/Month)	Flow/KWH <sup>a</sup> (1,000 gal/KWH)	Monthly Precipitation <sup>b</sup> (Inches)
		Monthly Maximum	Monthly Average	Monthly Minimum			
Nov-07	13.8200	0.8000	0.4607	0.1800	5.4560	2.5330	10.83
Dec-07	16.1200	0.7600	0.5200	0.2500	6.6730	2.4157	13.27
Jan-08	13.3200	0.6900	0.4297	0.2000	5.1670	2.5779	3.26
Feb-08	9.8100	0.5300	0.3383	0.1900	3.8570	2.5434	2.00
Mar-08	9.5600	0.4400	0.3084	0.1700	3.7510	2.5487	0.30
Apr-08	8.7700	0.4500	0.2923	0.1500	3.5400	2.4774	2.39
May-08	9.7000	0.4500	0.3129	0.1500	3.8570	2.5149	1.84
Jun-08	11.5300	0.6200	0.3843	0.1800	4.4190	2.6092	7.80
Jul-08	9.9300	0.5800	0.3203	0.1500	3.7690	2.6347	2.67
Aug-08	7.3700	0.4400	0.2377	0.9000	2.8110	2.6218	2.35
Sep-08	6.2200	0.3100	0.2073	0.1100	2.2790	2.7293	3.01
Oct-08	6.3200	0.3100	0.2039	0.1000	2.2740	2.7792	3.38
Nov-08	6.4300	0.4500	0.2143	0.1200	2.4570	2.6170	6.65
Dec-08	8.7700	0.7900	0.2829	0.1300	3.4940	2.5100	12.41
Jan-09	6.2600	0.3300	0.2019	0.1400	2.3850	2.6247	3.20
Feb-09	4.8200	0.2900	0.1721	0.1100	1.8950	2.5435	1.98
Mar-09	6.6500	0.5900	0.2145	0.0900	2.6740	2.4869	9.05
Apr-09	6.3900	0.4700	0.2130	0.0900	2.5350	2.5207	8.15
May-09	5.3300	0.2700	0.1719	0.1000	1.9410	2.7460	2.58
Jun-09	4.9400	0.2500	0.1647	0.1000	1.8750	2.6347	1.17
Jul-09	5.8000	0.2900	0.1871	0.1000	2.1440	2.7052	1.58
Aug-09	6.7200	0.4000	0.2168	0.1100	2.5020	2.6859	7.26
Sep-09	5.3800	0.2400	0.1793	0.0900	2.0200	2.6634	1.25
Oct-09	6.9000	0.5300	0.2226	0.0900	2.5950	2.6590	9.86
Nov-09	5.2300	0.2800	0.1743	0.0800	1.8930	2.7628	4.29
Dec-09	5.5400	0.2700	0.1787	0.1200	1.9620	2.8236	2.13
Jan-10	5.2600	0.2600	0.1697	0.1200	1.8960	2.7743	3.25

<sup>a</sup>Flow and Power Data based on City records.

<sup>b</sup>Precipitation Data based on U.S. Department of Commerce, National Oceanic & Atmospheric Administration Annual Climatological records for Station 513117/99999, Kaneohe 838.1, Hawaii.

# **APPENDIX E HISTORICAL RAINFALL DATA**

U.S. Department of Commerce  
National Oceanic & Atmospheric Administration

# ANNUAL CLIMATOLOGICAL SUMMARY (2000)

National Climatic Data Center  
Federal Building  
151 Patton Avenue  
Asheville, North Carolina 28801

Station: **513117/99999, KANEOHE 838.1, Hawaii**

Elev. 60 ft. above sea level

Lat. 21°25'N, Lon. 157°48'W

Date		Temperature (° F)													Precipitation (inches)									
Elem->	MMXT	MMNT	MNTM	DPNT	HTDD	CLDD	EMXT		EMNP		DT90	DX32	DT32	DT00	TPCP	DPNP	EMXP		TSNW	MXSD		DP01	DP05	DP10
2000 Month	Mean Max.	Mean Min.	Mean	Depart. from Normal	Heating Degree Days	Cooling Degree Days	Highest	High Date	Lowest	Low Date	Number of Days				Total	Depart. from Normal	Greatest Observed		Snow, Sleet			Number of Days		
											Max >=90°	Max <=32°	Min <=32°	Min <=0°			Day	Date	Total Fall	Max Depth	Max Date	>= .10	>= .50	>= 1.0
1	77.2X	66.9X	72.1X		0B	225B	81	4	62	26	0	0	0	0	4.49		1.74	20	0.0	0		11	2	1
2	81.1	67.4	74.3		0	275	84	7	64	8	0	0	0	0	0.39		0.17	1	0.0	0		1	0	0
3	82.0X	69.3X	75.7X		0B	338B	87	11	65	9	0	0	0	0	2.11		0.48	27	0.0	0		6	0	0
4	79.1X	68.7X	73.9X		0B	278B	83	26	63	9	0	0	0	0	3.40		1.31	1	0.0	0		6	2	1
5	83.3	71.4	77.4		0	394	85	28	69	16	0	0	0	0	1.48		0.61	17	0.0	0		2	1	0
6	86.0	73.6	79.8		0	450	89	21	71	8	0	0	0	0	1.28		0.20	7	0.0	0		3	0	0
7	84.8	74.3	79.6		0	461	87	31	72	4	0	0	0	0	1.81		0.38	21	0.0	0		6	0	0
8	85.8	74.9	80.4		0	484	89	2	72	21	0	0	0	0	3.01		1.50	21	0.0	0		10	1	1
9	84.7	73.7	79.2		0	434	87	30	70	28	0	0	0	0	5.56		2.07	28	0.0	0		10	2	2
10	84.4	74.2	79.3		0	451	87	5	70	30	0	0	0	0	2.93		1.33	30	0.0	0		5	1	1
11	81.4	72.1	76.8		0	362	85	5	69	30	0	0	0	0	3.42		0.75	3	0.0	0		13	1	0
12	81.5	68.4	75.0		0	316	84	5	65	31	0	0	0	0	1.22		0.24	9	0.0	0		4	0	0
Annual	82.6X	71.2X	77.0X		0	4468	89	Aug	62	Jan	0	0	0	0	31.10		2.07	Sep	0.0	0		77	10	6

### Notes

(blank) Not reported.

+ Occurred on one or more previous dates during the month. The date in the Date field is the last day of occurrence. Used through December 1983 only.

A Accumulated amount. This value is a total that may include data from a previous month or months or year (for annual value).

B Adjusted Total. Monthly value totals based on proportional available data across the entire month.

E An estimated monthly or annual total.

X Monthly means or totals based on incomplete time series. 1 to 9 days are missing. Annual means or totals include one or more months which had 1 to 9 days that were missing.

M Used to indicate data element missing.

T Trace of precipitation, snowfall, or snowdepth. The precipitation data value will = zero.

Elem- Element Types are included to provide cross-reference for > users of the NCDC CDO System.

Station Station is identified by: CoopID/WBAN, Station Name, State.

S Precipitation amount is continuing to be accumulated. Total will be included in a subsequent monthly or yearly value. Example: Days 1-20 had 1.35 inches of precipitation, then a period of accumulation began. The element TPCP would then be 00135S and the total accumulated amount value appears in a subsequent monthly value. If TPCP = "M" there was no precipitation measured during the month. Flag is set to "S" and the total accumulated amount appears in a subsequent monthly value.

Dynamically generated Tue Sep 14 21:16:22 EDT 2010 via <http://hurricane.ncdc.noaa.gov/ancsum/ACS>

Data provided from the NCDC CDO System

Additional documentation can be found at <http://cdo.ncdc.noaa.gov/cdo/3220doc.txt>

U.S. Department of Commerce  
National Oceanic & Atmospheric Administration**ANNUAL  
CLIMATOLOGICAL SUMMARY  
(2001)**National Climatic Data Center  
Federal Building  
151 Patton Avenue  
Asheville, North Carolina 28801

Station: 513117/99999, KANEOHE 838.1, Hawaii

Elev. 60 ft. above sea level

Lat. 21°25'N, Lon. 157°48'W

Date	Temperature (° F)													Precipitation (inches)											
Elem->	MMXT	MMNT	MNTM	DPNT	HTDD	CLDD	EMXT		EMNP		DT90	DX32	DT32	DT00	TPCP	DPNP	EMXP		TSNW	MXSD		DP01	DP05	DP10	
2001 Month	Mean Max.	Mean Min.	Mean	Depart. from Normal	Heating Degree Days	Cooling Degree Days	Highest	High Date	Lowest	Low Date	Number of Days				Total	Depart. from Normal	Greatest Observed		Snow, Sleet			Number of Days			
											Max >=90°	Max <=32°	Min <=32°	Min <=0°			Day	Date	Total Fall	Max Depth	Max Date	>= .10	>= .50	>= 1.0	
1	83.3X	70.1X	76.7X		0B	368B	91	20	65	1	1	0	0	0	0.63		0.14	14	0.0	0		7	2	0	0
2	81.2	68.7	75.0		0	288	86	27	62	8	0	0	0	0	5.73		2.51	9	0.0	0		7	2	2	2
3	81.1	68.4	74.8		0	309	86	26	61	21	0	0	0	0	2.63		0.85	18	0.0	0		7	2	0	0
4	81.2	70.0	75.6		0	325	84	23	66	17	0	0	0	0	2.19		0.42	29	0.0	0		7	0	0	0
5	82.6	71.1	76.9		0	374	88	31	68	6	0	0	0	0	3.36		1.49	19	0.0	0		8	1	1	1
6	83.5X	72.7X	78.1X		0B	398B	85	30	69	5	0	0	0	0	2.88		0.68	5	0.0	0		8	1	0	0
7	86.2	74.5	80.4		0	484	87	31	72	18	0	0	0	0	0.98		0.17	31	0.0	0		4	0	0	0
8	85.9X	74.7	80.3X		0B	482B	91	28	71	26	1	0	0	0	2.61		0.61	27	0.0	0		9	1	0	0
9	86.8	75.2	81.0		0	490	89	12	73	30	0	0	0	0	1.17		0.39	30	0.0	0		3	0	0	0
10	83.5	73.0	78.3		0	419	87	5	68	24	0	0	0	0	3.38		0.45	28	0.0	0		10	0	0	0
11	83.3X	70.9X	77.1X		0B	370B	90	27	67	18	1	0	0	0	6.66		3.68	27	0.0	0		8	2	2	2
12	80.2X	71.0	75.6X		0B	336B	85	29	65	27	0	0	0	0	4.10		1.42	24	0.0	0		9	2	1	1
Annual	83.2X	71.7X	77.5X		0	4643	91	Aug	61	Mar	3	0	0	0	36.32		3.68	Nov	0.0	0		82	11	6	6

## Notes

(blank) Not reported.

+ Occurred on one or more previous dates during the month.  
The date in the Date field is the last day of occurrence.  
Used through December 1983 only.

A Accumulated amount. This value is a total that may include data from a previous month or months or year (for annual value).

B Adjusted Total. Monthly value totals based on proportional available data across the entire month.

E An estimated monthly or annual total.

X Monthly means or totals based on incomplete time series. 1 to 9 days are missing. Annual means or totals include one or more months which had 1 to 9 days that were missing.

M Used to indicate data element missing.

T Trace of precipitation, snowfall, or snowdepth. The precipitation data value will = zero.

Elem- Element Types are included to provide cross-reference for &gt; users of the NCDC CDO System.

Station Station is identified by: CoopID/WBAN, Station Name, State.

S Precipitation amount is continuing to be accumulated. Total will be included in a subsequent monthly or yearly value. Example: Days 1-20 had 1.35 inches of precipitation, then a period of accumulation began. The element TPCP would then be 00135S and the total accumulated amount value appears in a subsequent monthly value. If TPCP = "M" there was no precipitation measured during the month. Flag is set to "S" and the total accumulated amount appears in a subsequent monthly value.

Dynamically generated Tue Sep 14 21:16:06 EDT 2010 via <http://hurricane.ncdc.noaa.gov/ancsum/ACS>

Data provided from the NCDC CDO System

Additional documentation can be found at <http://cdo.ncdc.noaa.gov/cdo/3220doc.txt>

U.S. Department of Commerce  
National Oceanic & Atmospheric Administration

# ANNUAL CLIMATOLOGICAL SUMMARY (2002)

National Climatic Data Center  
Federal Building  
151 Patton Avenue  
Asheville, North Carolina 28801

Station: **513117/99999, KANEOHE 838.1, Hawaii**

Elev. 60 ft. above sea level

Lat. 21°25'N, Lon. 157°48'W

Date Elem->	Temperature (° F)														Precipitation (inches)									
	MMXT	MMNT	MNTM	DPNT	HTDD	CLDD	EMXT		EMNP		DT90	DX32	DT32	DT00	TPCP	DPNP	EMXP		TSNW	MXSD		DP01	DP05	DP10
	Mean Max.	Mean Min.	Mean	Depart. from Normal	Heating Degree Days	Cooling Degree Days	Highest	High Date	Lowest	Low Date	Max >=90°	Max <=32°	Min <=32°	Min <=0°	Total	Depart. from Normal	Greatest Observed		Snow, Sleet			Number of Days		
2002 Month																Day	Date	Total Fall	Max Depth	Max Date	>= .10	>= .50	>= 1.0	
1	79.5X	68.2	73.9X		0B	283B	86	9	63	2	0	0	0	0	7.17	1.40	2.27	27	0.0	0		9	4	3
2	77.6	67.4	72.5		0	217	82	20	62	9	0	0	0	0	3.63	-0.98	1.92	9	0.0	0		8	2	1
3	79.5	67.8	73.7		0	277	84	24	63	4	0	0	0	0	7.95	2.56	2.16	17	0.0	0		9	4	3
4	83.3	69.6	76.5		0	349	92	11	63	3	1	0	0	0	2.93	-1.21	0.99	21	0.0	0		5	2	0
5	83.3	72.0X	77.7X		0B	405B	87	31	69	22	0	0	0	0	7.05	3.82	4.92	7	0.0	0		7	3	1
6	85.0X	73.4	79.2X		0B	434B	87	5	69	15	0	0	0	0	0.99	-1.52	0.18	22	0.0	0		4	0	0
7	84.6	72.8	78.7		0	435	88	31	65	26	0	0	0	0	3.62	0.92	1.45	30	0.0	0		8	1	1
8	85.0	74.8X	79.9X		0B	469B	88	26	72	20	0	0	0	0	1.72	-1.14	0.25	30	0.0	0		5	0	0
9	86.6X	72.9X	79.8X		0B	452B	89	27	70	24	0	0	0	0	1.05	-2.46	0.20	12	0.0	0		3	0	0
10	85.5	73.7	79.6		0	463	90	16	70	28	3	0	0	0	4.17	-0.25	2.45	15	0.0	0		6	2	1
11	82.6X	70.5	76.6X		0B	354B	89	10	69	30	0	0	0	0	2.70	-3.65	0.46	13	0.0	0		9	0	0
12	80.9X	68.1X	74.5X		0B	300B	84	20	65	31	0	0	0	0	1.18	-4.26	0.31	28	0.0	0		4	0	0
Annual	82.8X	70.9X	76.9X		0	443B	92	Apr	62	Feb	4	0	0	0	44.16	-6.77	4.92	May	0.0	0		77	18	10

### Notes

(blank) Not reported.

+ Occurred on one or more previous dates during the month. The date in the Date field is the last day of occurrence. Used through December 1983 only.

A Accumulated amount. This value is a total that may include data from a previous month or months or year (for annual value).

B Adjusted Total. Monthly value totals based on proportional available data across the entire month.

E An estimated monthly or annual total.

X Monthly means or totals based on incomplete time series. 1 to 9 days are missing. Annual means or totals include one or more months which had 1 to 9 days that were missing.

M Used to indicate data element missing.

T Trace of precipitation, snowfall, or snowdepth. The precipitation data value will = zero.

Elem- Element Types are included to provide cross-reference for > users of the NCDC CDO System.

Station Station is identified by: CoopID/WBAN, Station Name, State.

S Precipitation amount is continuing to be accumulated. Total will be included in a subsequent monthly or yearly value. Example: Days 1-20 had 1.35 inches of precipitation, then a period of accumulation began. The element TPCP would then be 00135S and the total accumulated amount value appears in a subsequent monthly value. If TPCP = "M" there was no precipitation measured during the month. Flag is set to "S" and the total accumulated amount appears in a subsequent monthly value.

Dynamically generated Tue Sep 14 21:15:48 EDT 2010 via <http://hurricane.ncdc.noaa.gov/ancsum/ACS>

Data provided from the NCDC CDO System

Additional documentation can be found at <http://cdo.ncdc.noaa.gov/cdo/3220doc.txt>



U.S. Department of Commerce  
National Oceanic & Atmospheric Administration

# ANNUAL CLIMATOLOGICAL SUMMARY (2003)

National Climatic Data Center  
Federal Building  
151 Patton Avenue  
Asheville, North Carolina 28801

Station: **513117/99999, KANEOHE 838.1, Hawaii**

Elev. 60 ft. above sea level

Lat. 21°25'N, Lon. 157°48'W

Date		Temperature (° F)											Precipitation (inches)											
Elem->	MMXT	MMNT	MNTM	DPNT	HTDD	CLDD	EMXT		EMNP		DT90	DX32	DT32	DT00	TPCP	DPNP	EMXP		TSNW	MXSD		DP01	DP05	DP10
2003 Month	Mean Max.	Mean Min.	Mean	Depart. from Normal	Heating Degree Days	Cooling Degree Days	Highest	High Date	Lowest	Low Date	Number of Days				Total	Depart. from Normal	Greatest Observed		Snow, Sleet			Number of Days		
											Max >=90°	Max <=32°	Min <=32°	Min <=0°			Day	Date	Total Fall	Max Depth	Max Date	>= .10	>= .50	>= 1.0
1	80.5X	65.3	72.9X		0B	254B	86	2	58	18	0	0	0	0	4.13	-1.64	0.94	20	0.0	0		8	4	0
2	78.6	67.1	72.9		0	227	85	6	62	14	0	0	0	0	5.94	1.33	3.48	14	0.0	0		9	2	1
3	82.5X	68.0	75.3X		0B	327B	87	27	65	11	0	0	0	0	4.93	-0.46	1.35	8	0.0	0		7	4	2
4	81.6	69.5	75.6		0	324	85	4	67	30	0	0	0	0	2.52	-1.62	0.38	11	0.0	0		9	0	0
5	83.8	72.2	78.0		0	412	86	30	68	1	0	0	0	0	0.94	-2.29	0.70	1	0.0	0		1	1	0
6	84.9X	72.6	78.8X		0B	421B	87	9	70	5	0	0	0	0	2.52	0.01	0.54	5	0.0	0		11	1	0
7	85.3X	74.6	80.0X		0B	470B	88	29	71	9	0	0	0	0	2.86	0.16	0.73	27	0.0	0		6	3	0
8	85.7X	74.4	80.1X		0B	475B	88	31	71	6	0	0	0	0	1.55	-1.31	0.34	6	0.0	0		5	0	0
9	86.9	73.5	80.2		0	464	93	25	71	28	3	0	0	0	2.95	-0.56	0.96	11	0.0	0		6	1	0
10	87.5	73.4	80.5		0	489	92	26	70	20	7	0	0	0	1.62	-2.80	0.33	7	0.0	0		6	0	0
11	82.6X	71.7X	77.2X		0B	371B	88	27	67	28	0	0	0	0	9.09	2.74	7.82	30	0.0	0		6	1	1
12	79.4	68.9	74.2		0	291	85	31	64	28	0	0	0	0	11.70	6.26	4.33	2	0.0	0		12	6	3
Annual	83.3X	70.9X	77.1X		0	4525	93	Sep	58	Jan	10	0	0	0	50.75	-0.18	7.82	Nov	0.0	0		86	23	7

### Notes

(blank) Not reported.

+ Occurred on one or more previous dates during the month. The date in the Date field is the last day of occurrence. Used through December 1983 only.

A Accumulated amount. This value is a total that may include data from a previous month or months or year (for annual value).

B Adjusted Total. Monthly value totals based on proportional available data across the entire month.

E An estimated monthly or annual total.

X Monthly means or totals based on incomplete time series. 1 to 9 days are missing. Annual means or totals include one or more months which had 1 to 9 days that were missing.

M Used to indicate data element missing.

T Trace of precipitation, snowfall, or snowdepth. The precipitation data value will = zero.

Elem- Element Types are included to provide cross-reference for > users of the NCDC CDO System.

Station Station is identified by: CoopID/WBAN, Station Name, State.

S Precipitation amount is continuing to be accumulated. Total will be included in a subsequent monthly or yearly value. Example: Days 1-20 had 1.35 inches of precipitation, then a period of accumulation began. The element TPCP would then be 00135S and the total accumulated amount value appears in a subsequent monthly value. If TPCP = "M" there was no precipitation measured during the month. Flag is set to "S" and the total accumulated amount appears in a subsequent monthly value.

Dynamically generated Tue Sep 14 21:15:34 EDT 2010 via <http://hurricane.ncdc.noaa.gov/ancsum/ACS>

Data provided from the NCDC CDO System

Additional documentation can be found at <http://cdo.ncdc.noaa.gov/cdo/3220doc.txt>

U.S. Department of Commerce  
National Oceanic & Atmospheric Administration

# ANNUAL CLIMATOLOGICAL SUMMARY (2004)

National Climatic Data Center  
Federal Building  
151 Patton Avenue  
Asheville, North Carolina 28801

Station: 513117/99999, KANEOHE 838.1, Hawaii

Elev. 60 ft. above sea level

Lat. 21°25'N, Lon. 157°48'W

Date	Temperature (° F)													Precipitation (inches)										
	Elem->	MMXT	MMNT	MNTM	DPNT	HTDD	CLDD	EMXT		EMNP		DT90	DX32	DT32	DT00	TPCP	DPNP	EMXP		TSNW	MXSD		DP01	DP05
2004 Month	Mean Max.	Mean Min.	Mean	Depart. from Normal	Heating Degree Days	Cooling Degree Days	Highest	High Date	Lowest	Low Date	Number of Days				Total	Depart. from Normal	Greatest Observed		Snow, Sleet			Number of Days		
											Max >=90°	Max <=32°	Min <=32°	Min <=0°			Day	Date	Total Fall	Max Depth	Max Date	>= .10	>= .50	>= 1.0
1	80.3X	66.7	73.5X		0B	272B	83	20	63	8	0	0	0	0	12.86	7.09	4.89	3	0.0	0		14	6	5
2	80.6X	69.1	74.9X		0B	294B	85	16	62	28	0	0	0	0	13.89	9.28	7.61	28	0.0	0		8	5	2
3	77.8	67.2	72.5		0	238	84	28	61	19	0	0	0	0	8.42	3.03	1.85	2	0.0	0		19	5	2
4	79.9X	69.1	74.5X		0B	289B	83	26	63	29	0	0	0	0	2.91	-1.23	0.85	21	0.0	0		8	1	0
5	82.3	71.0	76.7		0	368	89	21	66	17	0	0	0	0	6.71	3.48	1.96	16	0.0	0		7	4	3
6	83.6	73.2X	78.4X		0B	410B	87	27	71	15	0	0	0	0	3.08	0.57	0.31	24	0.0	0		12	0	0
7	87.3	75.1	81.2		0	511	89	24	73	27	0	0	0	0	1.98	-0.72	0.43	26	0.0	0		6	0	0
8	86.5	74.9	80.7		0	492	89	19	71	5	0	0	0	0	7.59	4.73	3.32	4	0.0	0		11	3	2
9	87.7X	74.9	81.3X		0B	497B	90	9	72	27	2	0	0	0	2.87	-0.64	0.33	25	0.0	0		11	0	0
10	86.3	73.7	80.0		0	473	89	15	71	26	0	0	0	0	6.59	2.17	3.14	31	0.0	0		12	3	1
11	84.0	70.9	77.5		0	381	88	14	67	22	0	0	0	0	9.60	3.25	2.45	10	0.0	0		13	5	4
12	81.3X	69.3	75.3X		0B	326B	86	17	65	15	0	0	0	0	4.76	-0.68	2.21	23	0.0	0		4	3	2
Annual	83.1X	71.3X	77.2X		0	4551	90	Sep	61	Mar	2	0	0	0	81.26	30.33	7.61	Feb	0.0	0		125	35	21

### Notes

(blank) Not reported.

+ Occurred on one or more previous dates during the month. The date in the Date field is the last day of occurrence. Used through December 1983 only.

A Accumulated amount. This value is a total that may include data from a previous month or months or year (for annual value).

B Adjusted Total. Monthly value totals based on proportional available data across the entire month.

E An estimated monthly or annual total.

X Monthly means or totals based on incomplete time series. 1 to 9 days are missing. Annual means or totals include one or more months which had 1 to 9 days that were missing.

M Used to indicate data element missing.

T Trace of precipitation, snowfall, or snowdepth. The precipitation data value will = zero.

Elem- Element Types are included to provide cross-reference for > users of the NCDC CDO System.

Station Station is identified by: CoopID/WBAN, Station Name, State.

S Precipitation amount is continuing to be accumulated. Total will be included in a subsequent monthly or yearly value. Example: Days 1-20 had 1.35 inches of precipitation, then a period of accumulation began. The element TPCP would then be 00135S and the total accumulated amount value appears in a subsequent monthly value. If TPCP = "M" there was no precipitation measured during the month. Flag is set to "S" and the total accumulated amount appears in a subsequent monthly value.

Dynamically generated Tue Sep 14 21:15:22 EDT 2010 via <http://hurricane.ncdc.noaa.gov/ancsum/ACS>

Data provided from the NCDC CDO System

Additional documentation can be found at <http://cdo.ncdc.noaa.gov/cdo/3220doc.txt>

U.S. Department of Commerce  
National Oceanic & Atmospheric Administration**ANNUAL  
CLIMATOLOGICAL SUMMARY  
(2005)**National Climatic Data Center  
Federal Building  
151 Patton Avenue  
Asheville, North Carolina 28801Station: **513117/99999, KANEOHE 838.1, Hawaii**

Elev. 60 ft. above sea level

Lat. 21°25'N, Lon. 157°48'W

Date	Temperature (° F)													Precipitation (inches)										
Elem->	MMXT	MMNT	MNTM	DPNT	HTDD	CLDD	EMXT		EMNP		DT90	DX32	DT32	DT00	TPCP	DPNP	EMXP		TSNW	MXSD		DP01	DP05	DP10
2005 Month	Mean Max.	Mean Min.	Mean	Depart. from Normal	Heating Degree Days	Cooling Degree Days	Highest	High Date	Lowest	Low Date	Number of Days				Total	Depart. from Normal	Greatest Observed		Snow, Sleet			Number of Days		
											Max >=90°	Max <=32°	Min <=32°	Min <=0°			Day	Date	Total Fall	Max Depth	Max Date	>= .10	>= .50	>= 1.0
1	80.9	67.8X	74.4X		0B	299B	86	24	63	13	0	0	0	0	7.99	2.22	2.86	2	0.0	0		8	5	4
2	79.1	67.9	73.5		0	244	83	7	62	12	0	0	0	0	8.42	3.81	2.64	12	0.0	0		10	5	4
3	79.7	66.6	73.2		0	263	87	10	61	16	0	0	0	0	6.44	1.05	1.89	9	0.0	0		11	4	2
4	81.6	71.0	76.3		0	344	88	28	66	29	0	0	0	0	1.14	-3.00	0.18	1	0.0	0		4	0	0
5	84.9	72.5	78.7		0	432	87	11	65	2	0	0	0	0	2.83	-0.40	1.10	21	0.0	0		6	2	1
6	85.0	74.2	79.6		0	444	87	14	72	11	0	0	0	0	1.54	-0.97	0.24	29	0.0	0		7	0	0
7	84.9	74.8	79.9		0	469	87	17	72	23	0	0	0	0	2.22	-0.48	0.44	23	0.0	0		7	0	0
8	87.5	74.8	81.2		0	508	90	28	71	12	2	0	0	0	0.85	-2.01	0.17	9	0.0	0		2	0	0
9	85.9	74.8	80.4		0	467	89	26	72	20	0	0	0	0	10.36	6.85	5.85	24	0.0	0		15	2	1
10	83.8	73.6	78.7		0	435	86	21	71	25	0	0	0	0	10.02	5.60	3.90	31	0.0	0		12	4	2
11	81.9X	72.0X	77.0X		0B	363B	85	26	68	14	0	0	0	0	3.61	-2.74	0.86	27	0.0	0		12	1	0
12	82.3	68.2	75.3		0	328	88	30	64	17	0	0	0	0	2.82	-2.62	2.76	5	0.0	0		1	1	1
Annual	83.1X	71.5X	77.4X		0	4596	90	Aug	61	Mar	2	0	0	0	58.24	7.31	5.85	Sep	0.0	0		95	24	15

**Notes**

(blank) Not reported.

+ Occurred on one or more previous dates during the month.  
The date in the Date field is the last day of occurrence.  
Used through December 1983 only.

A Accumulated amount. This value is a total that may include data from a previous month or months or year (for annual value).

B Adjusted Total. Monthly value totals based on proportional available data across the entire month.

E An estimated monthly or annual total.

X Monthly means or totals based on incomplete time series. 1 to 9 days are missing. Annual means or totals include one or more months which had 1 to 9 days that were missing.

M Used to indicate data element missing.

T Trace of precipitation, snowfall, or snowdepth. The precipitation data value will = zero.

Elem- Element Types are included to provide cross-reference for &gt; users of the NCDC CDO System.

Station Station is identified by: CoopID/WBAN, Station Name, State.

S Precipitation amount is continuing to be accumulated. Total will be included in a subsequent monthly or yearly value. Example: Days 1-20 had 1.35 inches of precipitation, then a period of accumulation began. The element TPCP would then be 00135S and the total accumulated amount value appears in a subsequent monthly value. If TPCP = "M" there was no precipitation measured during the month. Flag is set to "S" and the total accumulated amount appears in a subsequent monthly value.

Dynamically generated Tue Sep 14 21:15:05 EDT 2010 via <http://hurricane.ncdc.noaa.gov/ancsum/ACS>

Data provided from the NCDC CDO System

Additional documentation can be found at <http://cdo.ncdc.noaa.gov/cdo/3220doc.txt>

U.S. Department of Commerce  
National Oceanic & Atmospheric Administration

# ANNUAL CLIMATOLOGICAL SUMMARY (2006)

National Climatic Data Center  
Federal Building  
151 Patton Avenue  
Asheville, North Carolina 28801

Station: **513117/99999, KANEOHE 838.1, Hawaii**

Elev. 60 ft. above sea level

Lat. 21°25'N, Lon. 157°48'W

Date		Temperature (° F)													Precipitation (inches)									
Elem->	MMXT	MMNT	MNTM	DPNT	HTDD	CLDD	EMXT		EMNP		DT90	DX32	DT32	DT00	TPCP	DPNP	EMXP		TSNW	MXSD		DP01	DP05	DP10
2006 Month	Mean Max.	Mean Min.	Mean	Depart. from Normal	Heating Degree Days	Cooling Degree Days	Highest	High Date	Lowest	Low Date	Number of Days				Total	Depart. from Normal	Greatest Observed		Snow, Sleet			Number of Days		
											Max >=90°	Max <=32°	Min <=32°	Min <=0°			Day	Date	Total Fall	Max Depth	Max Date	>= .10	>= .50	>= 1.0
1	79.5	69.9	74.7		0	310	87	4	66	6	0	0	0	0	4.32	-1.45	1.19	23	0.0	0		8	3	1
2	77.3	66.7	72.0		0	200	85	3	61	12	0	0	0	0	18.70	14.09	5.75	19	0.0	0		13	7	5
3	79.4	69.3	74.4		0	296	87	25	65	31	0	0	0	0	26.40	21.01	6.53	3	0.0	0		19	13	6
4	79.1	69.6	74.4		0	288	83	29	67	22	0	0	0	0	4.85	0.71	2.18	1	0.0	0		9	2	1
5	81.1	69.2	75.2		0	322	87	26	63	16	0	0	0	0	3.26	0.03	0.75	5	0.0	0		9	2	0
6	85.5	73.4	79.5		0	440	88	9	71	25	0	0	0	0	0.83	-1.68	0.24	26	0.0	0		2	0	0
7	85.9X	74.5	80.2X		0B	481B	90	31	72	15	1	0	0	0	0.65	-2.05	0.16	15	0.0	0		1	0	0
8	87.4X	74.2X	80.8X		0B	498B	95	28	71	26	3	0	0	0	1.67	-1.19	0.57	1	0.0	0		3	1	0
9	86.6X	74.1X	80.4X		0B	465B	89	14	71	24	0	0	0	0	2.50	-1.01	0.45	16	0.0	0		8	0	0
10	85.1	73.3X	79.2X		0B	448B	93	10	71	18	2	0	0	0	5.13	0.71	1.91	31	0.0	0		8	3	2
11	84.0	71.5	77.8		0	388	91	6	68	30	2	0	0	0	11.19	4.84	3.73	1	0.0	0		12	3	3
12	80.7	70.5X	75.6X		0B	338B	83	28	66	24	0	0	0	0	1.78	-3.66	0.39	29	0.0	0		5	0	0
Annual	82.6X	71.4X	77.0X		0	4474	95	Aug	61	Feb	8	0	0	0	81.28	30.35	6.53	Mar	0.0	0		97	34	18

### Notes

(blank) Not reported.

+ Occurred on one or more previous dates during the month. The date in the Date field is the last day of occurrence. Used through December 1983 only.

A Accumulated amount. This value is a total that may include data from a previous month or months or year (for annual value).

B Adjusted Total. Monthly value totals based on proportional available data across the entire month.

E An estimated monthly or annual total.

X Monthly means or totals based on incomplete time series. 1 to 9 days are missing. Annual means or totals include one or more months which had 1 to 9 days that were missing.

M Used to indicate data element missing.

T Trace of precipitation, snowfall, or snowdepth. The precipitation data value will = zero.

Elem- Element Types are included to provide cross-reference for > users of the NCDC CDO System.

Station Station is identified by: CoopID/WBAN, Station Name, State.

S Precipitation amount is continuing to be accumulated. Total will be included in a subsequent monthly or yearly value. Example: Days 1-20 had 1.35 inches of precipitation, then a period of accumulation began. The element TPCP would then be 00135S and the total accumulated amount value appears in a subsequent monthly value. If TPCP = "M" there was no precipitation measured during the month. Flag is set to "S" and the total accumulated amount appears in a subsequent monthly value.

Dynamically generated Tue Sep 14 21:14:48 EDT 2010 via <http://hurricane.ncdc.noaa.gov/ancsum/ACS>

Data provided from the NCDC CDO System

Additional documentation can be found at <http://cdo.ncdc.noaa.gov/cdo/3220doc.txt>

U.S. Department of Commerce  
National Oceanic & Atmospheric Administration

# ANNUAL CLIMATOLOGICAL SUMMARY (2007)

National Climatic Data Center  
Federal Building  
151 Patton Avenue  
Asheville, North Carolina 28801

Station: 513117/99999, KANEOHE 838.1, Hawaii

Elev. 60 ft. above sea level

Lat. 21°25'N, Lon. 157°48'W

Date	Temperature (° F)											Precipitation (inches)													
	Elem->	MMXT	MMNT	MNTM	DPNT	HTDD	CLDD	EMXT		EMNP		DT90	DX32	DT32	DT00	TPCP	DPNP	EMXP		TSNW	MXSD		DP01	DP05	DP10
2007 Month	Mean Max.	Mean Min.	Mean	Depart. from Normal	Heating Degree Days	Cooling Degree Days	Highest	High Date	Lowest	Low Date	Number of Days				Total	Depart. from Normal	Greatest Observed		Snow, Sleet			Number of Days			
											Max >=90°	Max <=32°	Min <=32°	Min <=0°			Day	Date	Total Fall	Max Depth	Max Date	>= .10	>= .50	>= 1.0	
1	80.0X	69.3X	74.7X		0B	303B	82	29	64	28	0	0	0	0	3.64	-2.13	0.65	30	0.0	0	0	0	11	1	0
2	79.5	67.1	73.3		0	239	84	6	61	5	0	0	0	0	2.16	-2.45	0.71	2	0.0	0	0	6	1	0	
3	81.8	68.5	75.2		0	324	87	9	64	31	0	0	0	0	5.10	-0.29	1.41	27	0.0	0	0	12	2	1	
4	82.1	69.1	75.6		0	323	85	11	63	1	0	0	0	0	1.22	-2.92	0.19	27	0.0	0	0	5	0	0	
5	84.8X	71.4X	78.1X		0B	413B	89	22	68	11	0	0	0	0	1.18	-2.05	0.27	25	0.0	0	0	3	0	0	
6	85.1	73.4	79.3		0	434	88	4	71	8	0	0	0	0	1.15	-1.36	0.32	5	0.0	0	0	4	0	0	
7	85.5	73.5	79.5		0	458	88	31	71	28	0	0	0	0	2.12	-0.58	0.31	17	0.0	0	0	6	0	0	
8	87.1	74.6	80.9		0	502	91	30	71	21	2	0	0	0	1.56	-1.30	0.26	25	0.0	0	0	6	0	0	
9	86.8	74.5	80.7		0	479	91	8	73	27	1	0	0	0	1.56	-1.95	0.23	1	0.0	0	0	5	0	0	
10	85.2	73.5	79.4		0	454	91	22	69	22	1	0	0	0	1.40	-3.02	0.27	31	0.0	0	0	5	0	0	
11	83.1	70.9	77.0		0	366	90	3	67	21	1	0	0	0	10.83	4.48	3.95	4	0.0	0	0	11	5	2	
12	79.5	70.3	74.9		0	314	86	3	67	5	0	0	0	0	13.27	7.83	2.85	7	0.0	0	0	17	7	5	
Annual	83.4X	71.3X	77.4X		0	4609	91	Oct	61	Feb	5	0	0	0	45.19	-5.74	3.95	Nov	0.0	0	0	91	16	8	

### Notes

(blank) Not reported.

+ Occurred on one or more previous dates during the month. The date in the Date field is the last day of occurrence. Used through December 1983 only.

A Accumulated amount. This value is a total that may include data from a previous month or months or year (for annual value).

B Adjusted Total. Monthly value totals based on proportional available data across the entire month.

E An estimated monthly or annual total.

X Monthly means or totals based on incomplete time series. 1 to 9 days are missing. Annual means or totals include one or more months which had 1 to 9 days that were missing.

M Used to indicate data element missing.

T Trace of precipitation, snowfall, or snowdepth. The precipitation data value will = zero.

Elem- Element Types are included to provide cross-reference for > users of the NCDC CDO System.

Station Station is identified by: CoopID/WBAN, Station Name, State.

S Precipitation amount is continuing to be accumulated. Total will be included in a subsequent monthly or yearly value. Example: Days 1-20 had 1.35 inches of precipitation, then a period of accumulation began. The element TPCP would then be 00135S and the total accumulated amount value appears in a subsequent monthly value. If TPCP = "M" there was no precipitation measured during the month. Flag is set to "S" and the total accumulated amount appears in a subsequent monthly value.

Dynamically generated Tue Sep 14 21:14:26 EDT 2010 via <http://hurricane.ncdc.noaa.gov/ancsum/ACS>

Data provided from the NCDC CDO System

Additional documentation can be found at <http://cdo.ncdc.noaa.gov/cdo/3220doc.txt>

U.S. Department of Commerce  
National Oceanic & Atmospheric Administration

# ANNUAL CLIMATOLOGICAL SUMMARY (2008)

National Climatic Data Center  
Federal Building  
151 Patton Avenue  
Asheville, North Carolina 28801

Station: **513117/99999, KANEOHE 838.1, Hawaii**

Elev. 60 ft. above sea level

Lat. 21°25'N, Lon. 157°48'W

Date		Temperature (° F)													Precipitation (inches)									
Elem->	MMXT	MMNT	MNTM	DPNT	HTDD	CLDD	EMXT		EMNP		DT90	DX32	DT32	DT00	TPCP	DPNP	EMXP		TSNW	MXSD		DP01	DP05	DP10
2008 Month	Mean Max.	Mean Min.	Mean	Depart. from Normal	Heating Degree Days	Cooling Degree Days	Highest	High Date	Lowest	Low Date	Number of Days				Total	Depart. from Normal	Greatest Observed		Snow, Sleet			Number of Days		
											Max >=90°	Max <=32°	Min <=32°	Min <=0°			Day	Date	Total Fall	Max Depth	Max Date	>= .10	>= .50	>= 1.0
1	77.5	67.1	72.3		0	236	82	8	64	19	0	0	0	0	3.26	-2.51	0.92	12	0.0	0		11	1	0
2	80.1X	67.6X	73.9X		0B	262B	86	19	63	28	0	0	0	0	2.00	-2.61	M	0.0	0		8	0	0	
3	82.2X	70.4X	76.3X		0B	357B	85	8	66	10	0	0	0	0	0.30	-5.09	0.09	23	0.0	0		0	0	0
4	82.2	69.6	75.9		0	335	86	26	67	26	0	0	0	0	2.39	-1.75	0.96	26	0.0	0		6	1	0
5	84.6	72.2	78.4		0	424	90	16	68	14	1	0	0	0	1.84	-1.39	1.45	22	0.0	0		1	1	1
6	84.4	72.9	78.7		0	416	88	29	70	12	0	0	0	0	7.80	5.29	6.62	12	0.0	0		4	1	1
7	85.7	73.4	79.6		0	461	88	18	71	20	0	0	0	0	2.67	-0.03	0.51	1	0.0	0		11	1	0
8	85.9	73.9	79.9		0	471	88	27	71	30	0	0	0	0	2.35	-0.51	0.40	30	0.0	0		8	0	0
9	85.6	72.6	79.1		0	431	88	6	69	14	0	0	0	0	3.01	-0.50	0.31	30	0.0	0		14	0	0
10	83.8X	72.6	78.2X		0B	417B	89	9	69	28	0	0	0	0	3.38	-1.04	0.95	26	0.0	0		9	1	0
11	82.2	71.3	76.8		0	358	87	14	67	23	0	0	0	0	6.65	0.30	3.11	23	0.0	0		6	2	2
12	80.2X	70.3	75.3X		0B	323B	86	13	69	18	0	0	0	0	12.41	6.97	4.57	12	0.0	0		13	4	3
Annual	82.9X	71.2X	77.0X		0	4491	90	May	63	Feb	1	0	0	0	48.06	-2.87	M	Jun	0.0	0		91	12	7

### Notes

(blank) Not reported.

+ Occurred on one or more previous dates during the month. The date in the Date field is the last day of occurrence. Used through December 1983 only.

A Accumulated amount. This value is a total that may include data from a previous month or months or year (for annual value).

B Adjusted Total. Monthly value totals based on proportional available data across the entire month.

E An estimated monthly or annual total.

X Monthly means or totals based on incomplete time series. 1 to 9 days are missing. Annual means or totals include one or more months which had 1 to 9 days that were missing.

M Used to indicate data element missing.

T Trace of precipitation, snowfall, or snowdepth. The precipitation data value will = zero.

Elem- Element Types are included to provide cross-reference for > users of the NCDC CDO System.

Station Station is identified by: CoopID/WBAN, Station Name, State.

S Precipitation amount is continuing to be accumulated. Total will be included in a subsequent monthly or yearly value. Example: Days 1-20 had 1.35 inches of precipitation, then a period of accumulation began. The element TPCP would then be 00135S and the total accumulated amount value appears in a subsequent monthly value. If TPCP = "M" there was no precipitation measured during the month. Flag is set to "S" and the total accumulated amount appears in a subsequent monthly value.

Dynamically generated Tue Sep 14 21:14:09 EDT 2010 via <http://hurricane.ncdc.noaa.gov/ancsum/ACS>

Data provided from the NCDC CDO System

Additional documentation can be found at <http://cdo.ncdc.noaa.gov/cdo/3220doc.txt>

U.S. Department of Commerce  
National Oceanic & Atmospheric Administration

# ANNUAL CLIMATOLOGICAL SUMMARY (2009)

National Climatic Data Center  
Federal Building  
151 Patton Avenue  
Asheville, North Carolina 28801

Station: 513117/99999, KANEOHE 838.1, Hawaii

Elev. 48 ft. above sea level

Lat. 21°25'N, Lon. 157°48'W

Date		Temperature (° F)											Precipitation (inches)											
Elem->	MMXT	MMNT	MNTM	DPNT	HTDD	CLDD	EMXT		EMNP		DT90	DX32	DT32	DT00	TPCP	DPNP	EMXP		TSNW	MXSD		DP01	DP05	DP10
2009 Month	Mean Max.	Mean Min.	Mean	Depart. from Normal	Heating Degree Days	Cooling Degree Days	Highest	High Date	Lowest	Low Date	Number of Days				Total	Depart. from Normal	Greatest Observed		Snow, Sleet			Number of Days		
											Max >=90°	Max <=32°	Min <=32°	Min <=0°			Day	Date	Total Fall	Max Depth	Max Date	>= .10	>= .50	>= 1.0
1	79.0X	66.5	72.8X		0B	249B	85	11	61	19	0	0	0	0	3.20	-2.57	1.02	11	0.0	0		9	1	1
2	77.8	67.1	72.5		0	217	83	12	61	24	0	0	0	0	1.98	-2.63	0.88	10	0.0	0		4	1	0
3	77.7X	66.6	72.2X		0B	234B	82	16	58	14	0	0	0	0	9.05	3.66	4.14	15	0.0	0		9	3	3
4	78.2X	67.1	72.7X		0B	238B	87	20	63	28	0	0	0	0	8.15	4.01	4.25	21	0.0	0		5	3	3
5	84.0	69.9	77.0		0	379	86	31	66	23	0	0	0	0	2.58	-0.65	0.80	18	0.0	0		7	2	0
6	85.3	73.2	79.3		0	434	88	2	70	30	0	0	0	0	1.17	-1.34	0.20	19	0.0	0		3	0	0
7	85.2X	74.3	79.8X		0B	462B	87	27	70	1	0	0	0	0	1.58	-1.12	0.26	28	0.0	0		6	0	0
8	85.4	75.2	80.3		0	480	88	9	73	28	0	0	0	0	7.26	4.40	3.11	13	0.0	0		5	3	3
9	86.0	74.6	80.3		0	465	88	25	71	23	0	0	0	0	1.25	-2.26	0.23	25	0.0	0		6	0	0
10	85.7	73.6	79.7		0	462	89	29	70	16	0	0	0	0	9.86	5.44	5.61	5	0.0	0		9	4	2
11	81.7	72.9	77.3		0	377	85	13	68	13	0	0	0	0	4.29	-2.06	0.86	3	0.0	0		10	4	0
12	80.3	66.9	73.6		0	274	85	30	63	25	0	0	0	0	2.13	-3.31	0.92	4	0.0	0		5	1	0
Annual	82.2X	70.7	76.5X		0	4271	89	Oct	58	Mar	0	0	0	0	52.50	1.57	5.61	Oct	0.0	0		78	22	12

### Notes

(blank) Not reported.

+ Occurred on one or more previous dates during the month. The date in the Date field is the last day of occurrence. Used through December 1983 only.

A Accumulated amount. This value is a total that may include data from a previous month or months or year (for annual value).

B Adjusted Total. Monthly value totals based on proportional available data across the entire month.

E An estimated monthly or annual total.

X Monthly means or totals based on incomplete time series. 1 to 9 days are missing. Annual means or totals include one or more months which had 1 to 9 days that were missing.

M Used to indicate data element missing.

T Trace of precipitation, snowfall, or snowdepth. The precipitation data value will = zero.

Elem- Element Types are included to provide cross-reference for > users of the NCDC CDO System.

Station Station is identified by: CoopID/WBAN, Station Name, State.

S Precipitation amount is continuing to be accumulated. Total will be included in a subsequent monthly or yearly value. Example: Days 1-20 had 1.35 inches of precipitation, then a period of accumulation began. The element TPCP would then be 00135S and the total accumulated amount value appears in a subsequent monthly value. If TPCP = "M" there was no precipitation measured during the month. Flag is set to "S" and the total accumulated amount appears in a subsequent monthly value.

Dynamically generated Tue Sep 14 21:11:18 EDT 2010 via <http://hurricane.ncdc.noaa.gov/ancsum/ACS>

Data provided from the NCDC CDO System

Additional documentation can be found at <http://cdo.ncdc.noaa.gov/cdo/3220doc.txt>

U.S. Department of Commerce  
National Oceanic & Atmospheric Administration

# ANNUAL CLIMATOLOGICAL SUMMARY (2010)

National Climatic Data Center  
Federal Building  
151 Patton Avenue  
Asheville, North Carolina 28801

Station: **513117/99999, KANEOHE 838.1, Hawaii**

Elev. 48 ft. above sea level

Lat. 21°25'N, Lon. 157°48'W

Date		Temperature (° F)												Precipitation (inches)										
Elem->	MMXT	MMNT	MNTM	DPNT	HTDD	CLDD	EMXT		EMNP		DT90	DX32	DT32	DT00	TPCP	DPNP	EMXP		TSNW	MXSD		DP01	DP05	DP10
2010 Month	Mean Max.	Mean Min.	Mean	Depart. from Normal	Heating Degree Days	Cooling Degree Days	Highest	High Date	Lowest	Low Date	Number of Days				Total	Depart. from Normal	Greatest Observed		Snow, Sleet			Number of Days		
											Max >=90°	Max <=32°	Min <=32°	Min <=0°			Day	Date	Total Fall	Max Depth	Max Date	>= .10	>= .50	>= 1.0
1	80.8X	68.0	74.4X		0B	299B	87	26	63	15	0	0	0	0	3.25	-2.52	1.70	30	0.0	0		7	1	1
2	80.0X	66.0X	73.0X		0B	232B	84	25	63	20	0	0	0	0	1.78	-2.83	0.87	22	0.0	0		3	1	0
3	79.5	68.3	73.9		0	281	84	18	65	19	0	0	0	0	2.59	-2.80	0.44	18	0.0	0		7	0	0
4	79.9	69.4	74.7		0	297	83	26	64	16	0	0	0	0	1.91	-2.23	0.51	7	0.0	0		6	1	0
5	M	M	M		M	M	M		M		M	M	M	M	M	M	M		M	M		M	M	M
6	M	M	M		M	M	M		M		M	M	M	M	M	M	M		M	M		M	M	M
7	M	M	M		M	M	M		M		M	M	M	M	M	M	M		M	M		M	M	M
8	M	M	M		M	M	M		M		M	M	M	M	M	M	M		M	M		M	M	M
9	M	M	M		M	M	M		M		M	M	M	M	M	M	M		M	M		M	M	M
10	M	M	M		M	M	M		M		M	M	M	M	M	M	M		M	M		M	M	M
11	M	M	M		M	M	M		M		M	M	M	M	M	M	M		M	M		M	M	M
12	M	M	M		M	M	M		M		M	M	M	M	M	M	M		M	M		M	M	M
Annual	M	M	M		M	M	M	Jan	M	Feb	M	M	M	M	M	M	M	Jan	M	M		M	M	M

### Notes

(blank) Not reported.

+ Occurred on one or more previous dates during the month. The date in the Date field is the last day of occurrence. Used through December 1983 only.

A Accumulated amount. This value is a total that may include data from a previous month or months or year (for annual value).

B Adjusted Total. Monthly value totals based on proportional available data across the entire month.

E An estimated monthly or annual total.

X Monthly means or totals based on incomplete time series. 1 to 9 days are missing. Annual means or totals include one or more months which had 1 to 9 days that were missing.

M Used to indicate data element missing.

T Trace of precipitation, snowfall, or snowdepth. The precipitation data value will = zero.

Elem- Element Types are included to provide cross-reference for > users of the NCDC CDO System.

Station Station is identified by: CoopID/WBAN, Station Name, State.

S Precipitation amount is continuing to be accumulated. Total will be included in a subsequent monthly or yearly value. Example: Days 1-20 had 1.35 inches of precipitation, then a period of accumulation began. The element TPCP would then be 00135S and the total accumulated amount value appears in a subsequent monthly value. If TPCP = "M" there was no precipitation measured during the month. Flag is set to "S" and the total accumulated amount appears in a subsequent monthly value.

*Dynamically generated Tue Sep 14 21:10:15 EDT 2010 via <http://hurricane.ncdc.noaa.gov/ancsum/ACS>*

*Data provided from the NCDC CDO System*

*Additional documentation can be found at <http://cdo.ncdc.noaa.gov/cdo/3220doc.txt>*



# **APPENDIX F MECHANICAL CATALOG CUTS**



**The ABS EffeX range**  
The world's first premium-efficiency  
submersible sewage pumps!

# A completely new approach

At ABS we make it our business to understand wastewater, whether it is our ongoing investigation into causes of blockage, the reduction of water consumption, changing personal hygiene habits or public opinion on environmental issues.

We also closely follow changes to legislation at the global level that set higher levels of wastewater treatment, and legislation at the equipment level that sets minimum efficiency levels for all energy-using equipment. Thus we make sure we recognise the impacts on our equipment and your business.

## A time for change


The pressures on the wastewater business have increased regardless of whether you are a publicly funded municipality, privately owned water company or a private operator of a wastewater collection system.

Now we clearly see an increased focus on energy use with regard to cost and CO<sub>2</sub> footprint, and requirements for fewer blockages and the associated reduced risk of overflows and pressure to keep operator costs under control. Moreover, we must not forget the constant battle to improve service levels for your customers and the quality of treated water.

ABS firmly believes that the time is now right for advancing the design of submersible wastewater pumping equipment. What was acceptable even five years ago no longer comes close to meeting the ever-changing market needs.

## Setting new standards

The new ABS EffeX range is not a modification to an existing design but a completely fresh concept in submersible wastewater pumping equipment. Our new range pushes available technology to the limit to achieve a design



In response to numerous global, business and social drivers, ABS is the first to launch a series of premium-efficiency submersible sewage pumps – the new ABS EffeX range.

that not only satisfies today's stringent requirements, but also exceeds planned legislation\*. It focuses on delivering the utmost in reliable operation, including advanced designs with greater safety margins, and market-leading blockage resistance offering the best rag handling available on the market today with a minimum free solids passage of 75 mm.

Our ABS EffeX range also sets new standards when it comes to optimum energy efficiency. As it incorporates the first premium-efficiency IE3 motor designed and tested in accordance with IEC60034-30 together with optimised hydraulics, the new ABS EffeX range gives the best total efficiency available on the market today.

## The right choice if you want to be first

The ABS EffeX range of submersible sewage pumps offers you a complete solution for your pumping needs. It does this by a combination of much improved reliability, greater energy saving, the highest level of blockage resistance, future-proof designs and a clear commitment to achieving the highest sustainability in both manufacturing and operation.

Simply put: We now give you greater peace of mind in running your wastewater business.

\* Contact your local ABS Sales Office for more details.





Six families of ABS EffeX range models will eventually cover virtually all submersible sewage pump applications in the segments Domestic and Commercial Wastewater, Wastewater Collection Networks and Wastewater Treatment.

Now you can make the right choice if you want to be first,  
or more importantly,  
the first choice if you want to be right!

# Premium efficiency and a lot more

A premium-efficiency motor is just one of many benefits you get with the ABS EffeX range. After analysing market needs and the design of our submersible sewage pumps, we have built in a number of new features that makes our ABS EffeX range the best pumps available. The five major features we now offer you are summarised below along with their corresponding benefits. A detailed description of the features is presented when you fold out the middle spread.

## Long-term reliability

- Reduced risk of pollution from overflows
- Reduced risk of interruption to services to customers
- Reduced breakdown costs
- Reduced tankering costs
- Reduced maintenance costs

## Greater energy saving

- Reduced energy costs
- Smaller CO<sub>2</sub> footprint
- Qualification for capital allowance schemes

## Excellent rag handling

- Lowest blockage on the market
- Reduced risk of pollution from overflows
- Reduced risk of interruption to services to customers
- Reduced breakdown costs
- Reduced tankering costs

## Future-proof design

- Compliance with planned EU, US and other legislation for conventional motors
- Impeller designs based on future wastewater content
- High reliability to ensure compliance with overflow reduction targets

## Sustainable in manufacturing and operation

- Reduced CO<sub>2</sub> emissions in pump manufacturing and operation
- Prolonged pump lifecycle
- Reduced maintenance costs by adjustment rather than repair

## Optimal lifecycle operation

The sum total of these five major benefits is optimal lifecycle operation. That is, when you install an ABS EffeX range premium-efficiency pump, you know that no other similar type of pump on the market can match its benefits. ABS EffeX range pumps are designed to reduce energy costs and CO<sub>2</sub> emissions, and to ensure a prolonged lifecycle compared with competitive pumps. Moreover, they comply with forthcoming equipment motor legislation in relevant countries and contribute to sustainable development.





Our ABS Effex range has several built-in features that make them the best submersible sewage pumps available.

# Details make the best pump

When it comes to pumping wastewater you have to look at the complete picture. Simply focusing on producing a pump with the best hydraulic efficiency will not result in trouble-free operation. High hydraulic efficiency without excellent blockage resistance, rag handling and free solids passage will only result in more blockage, overflows and increased operator costs.

Similarly, products that focus merely on using low-efficiency impellers that are good for rag handling result in unacceptable much higher energy costs and a bigger CO<sub>2</sub> footprint.

Conversely, our ABS EffeX range is a complete concept that ensures that all aspects of handling wastewater are considered to provide you with several major benefits. These are discussed in detail below.

## Long-term reliability

Long-term reliability starts with understanding the application. When we discuss wastewater handling it is clear that it is not the same as pumping a clear liquid. Wastewater pumping is like handling abrasive liquids with a high content of rag and other solids in an application where regular stopping and starting are required.

This subjects equipment bearings and motors to high loads, high wear and poor cooling.

Reliability of the ABS EffeX range starts with built-in IE3 premium-efficiency motors. These give the major advantage of lower operating temperatures (NEMA Class A) along with reducing the need for cooling, considerably improving the bearing environment and reducing load on the stator.

It is also possible to operate smaller motors (PE1 & PE2 pumps) without any cooling. Add to this an increased bearing design life, reduced shaft deflection and increased shaft fatigue safety factors, and you have a highly robust and reliable submersible motor design.

## Optimum operating conditions

When it comes to hydraulic reliability, the key is blockage and wear resistance coupled with easy adjustment to maintain optimum operating conditions. The ABS EffeX range makes use of our new Contrablock Plus impeller design with adjustable bottom plate to ensure efficiency and reliability throughout the pump lifetime. Larger pumps also use optimised closed impeller designs to give the best balance between reliability and energy consumption.



## Our long-term reliability gives you:

- Reduced risk of pollution from overflows
- Reduced risk of interruption to services to customers
- Reduced breakdown costs
- Reduced tankering costs
- Reduced maintenance costs



## Greater energy saving

The impact of good energy management is twofold. Firstly, from a purely operational point of view, good energy management results in lower energy costs, particularly important with ever-increasing energy prices. Secondly, and equally important, is the impact on CO<sub>2</sub> production. Reduced energy used in pumping equipment has a direct impact on the CO<sub>2</sub> footprint of your organisation.



When we consider the energy consumption of pumping equipment, calculations must always be based on the total efficiency of the pump; that is, the sum of the efficiency of the hydraulics and the motor. To achieve the best result one must optimise both efficiencies. It is no good saying we have the best hydraulic efficiency and then fit the hydraulics to a sub-standard efficiency submersible motor.

## Highest efficiency available


The ABS EffeX range has built-in IE3 premium-efficiency motors in accordance with IEC60034-30 to optimise motor efficiency. And we are the first company in the world to offer submersible motors with such a high standard. The main benefit of using this type of motor is the highest efficiency available on the market without any impact on the risk of increased blockage often associated with hydraulic efficiency.

When we come to hydraulic efficiency, traditional thinking when designing impellers has dictated that you must always compromise between efficiency, rag handling and free solid passage. However, the ABS EffeX range boosts impeller design to the next level and achieves some of the highest hydraulic efficiencies in the market, providing the best resistance to blockage while still maintaining a minimum 75 mm free solid passage.

This is achieved by optimising impellers for efficiency using the latest CFD technology and then completing extensive testing to measure the blockage resistance of the impeller.

## Our greater energy saving gives you:

- Reduced energy costs
- Smaller CO<sub>2</sub> footprint
- Qualification for capital allowance schemes








## Excellent rag handling

On average, over 60% of the breakdown calls from a typical wastewater pumping station are a direct result of a pump problem. This is probably not surprising as pumps are the only piece of rotating equipment installed in many wastewater pumping stations. But what is most alarming is that when we look at these breakdown figures in more detail, we see that over 60% of the pump-related breakdowns are a direct result of blockage.



This situation has not improved in recent years, and even with all the improvements made to impeller design, reduced water consumption and changing personal hygiene habits still continue to increase blockage problems.

### **New impeller concept**

Our ABS EffeX range makes use of a completely new impeller concept called Contrablock Plus. This solution takes the best of the tried and tested Contrablock designs and adds new functionality to enhance the levels of blockage resistance above that of any other supplier on the market. In addition, we ensure that the free solids passage is never reduced below 75 mm to give a further level of protection against blockage.

How can we be so sure of our designs? Because ABS has invested in over 5,000 man-hours in blockage testing, understanding the content of wastewater, benchmarking available designs and optimising the impellers used in the ABS EffeX range.

### **Our excellent rag handling gives you:**

- Lowest blockage on the market
- Reduced risk of pollution from overflows
- Reduced risk of interruption to services to customers
- Reduced breakdown costs
- Reduced tankering costs

## Future-proof design

Earlier we talked about anticipating the future, trying to understand the trends and forthcoming requirements of the wastewater market. What do we see?

Firstly we can observe the changing characteristics of wastewater, driven mainly by the reduction in water consumption and changes to personal hygiene habits. Have we seen the end of this change? No, the general feeling is that water consumption will continue to reduce with the consequent increase in rag content.

We can also see legislation and other incentives push all users of energy-using products (EuP) to install higher-efficiency and explosion-proof units. There is already legislation in place controlling circulator pumps with others to follow, including submersible pumps.



Our guiding principle when looking at the manufacturing phase is to minimise the consumption of resources. This means designing products that have a long design life and which can be kept running at their optimum performance for a long period of time.

The key benefit achieved here is the optimisation of CO<sub>2</sub> used in the operating phase while significantly reducing the overall CO<sub>2</sub> footprint of the product during its lifetime.

When it comes to the operating phase, we keep the energy consumed to a minimum with the equipment running most efficiently throughout its design life.

#### Already way ahead

The ABS EffeX range looks to the future; it already more than complies with any legislation under discussion with regard to motor efficiency, hydraulic or total efficiency. With regard to rag handling, the new optimised impeller designs take into account reduced water consumption and increased rag content. The levels of reliability are again in excess of the requirements of global legislation controlling the standard of wastewater collection networks. All models have Ex-configuration as standard.

#### Our future-proof design gives you:

- Compliance with planned EU, US and other legislation for conventional motors
- Impeller designs based on future wastewater content
- High reliability to ensure compliance with overflow reduction targets

### Sustainable in manufacturing and operation

ABS believes in long-term relationships with our customers. To achieve this we must ensure that our business and that of our customers are sustainable in the long term. We also believe in looking far ahead when designing products to make sure that we minimise our impact on the environment with regard to both the manufacturing and operational phases of a product lifetime.

#### Long product lifetime

The ABS EffeX range scores highly on both counts. The models are designed with easily adjustable features that prolong the life of components while maintaining optimal performance.

Moreover, the long life of all components and the highest total efficiency available on the market ensure that the environmental impact of our premium-efficiency submersible sewage pumps is minimised without compromising operational reliability

#### Our sustainability in manufacturing and operation gives you:

- Reduced CO<sub>2</sub> emissions in pump manufacturing and operation
- Prolonged pump lifecycle
- Reduced maintenance costs by adjustment rather than repair



# A total solution supplier

It's not surprising that ABS is the first worldwide to introduce premium-efficiency submersible sewage pumps. Our long history of innovation includes being first with high-efficiency pumps, introducing our new Contrablock Plus impeller design that offers the highest available resistance to blockage on the market today, and our AquaWeb advanced alarm management system for wastewater.



## Your long-term partner

Our strength lies in the unique ability to combine products, services and application know-how into diverse solutions that satisfy a variety of application needs. When you choose us as your solution provider you get:

- A long-term partner from design to operation
- Application expertise and process know-how
- Reliable solutions that enhance process efficiency
- Strong relations through support and after-sales service
- The most complete range of products on the market

ABS solutions not only increase process efficiency, but also enhance overall process performance. Combined with our control and monitoring equipment and services, they provide peace of mind in any wastewater application.

## A wealth of expertise

Advanced R&D, backed by an engineering heritage going back over 100 years, forms the backbone of our competence and expertise in the design and installation of centrifugal pumps. This, combined with our know-how in wastewater applications, enables us to offer integrated pump solutions that are designed and sized to perfectly match the conditions of your wastewater system. We also provide installation, operational optimisation and training of a customer's own maintenance personnel.

## Service, spares and asset management

Our comprehensive range of services tailored to your needs includes:

- Planned maintenance, workshop repair, spares and spare parts kits, replacement and upgrading
- Installation, operational support, telemetry and diagnostics, equipment optimisation, asset management.

## Flexible and responsive

ABS uses high-quality materials and manufacturing techniques with all its product ranges. We have a very modern manufacturing machine park, including our own production equipment operated by highly skilled personnel.

In our efforts to offer high-performance products, we work in close cooperation with our customers to receive important feedback for continuous product improvement.



Make the right choice and choose  
ABS as your partner  
in wastewater handling.



# At the forefront of wastewater technology

ABS has a long tradition in the wastewater industry with more than 100 years of application experience and manufacturing of customer-oriented solutions based on the latest technology.

We develop and supply individual products and integrated solutions for use in the wastewater segments: Domestic and Commercial Wastewater, Wastewater Collection Networks and Wastewater Treatment. ABS is the main brand of Wastewater Technology, which is one of four divisions of the Cardo Group. Cardo is listed on NASDAQ OMX Stockholm and has its headquarters in Malmö, Sweden.

ABS Group

Phone +46 40 35 04 70 | Fax +46 40 30 50 45

info@absgroup.com | www.absgroup.com



# TECHNICAL DATA

## 4" ABS XFP PUMP

XFP 100E-CB1  
4 Pole, 3 Phase, PE2


Date: 10/10  
Dwg: DS-E01-024 Rev: 4

### Submersible Motor Specifications, PE2 Frame

<b>Motor Design</b>	NEMA design B, squirrel cage induction	
<b>Motor Type</b>	Fully enclosed Premium Efficiency submersible, IP68 protection rating	
<b>Motor Efficiency Standard and Rating</b>	IEC 60034-30, IE3 rating	
<b>Motor Efficiency Test Protocol</b>	IEC 60034-2-1	
<b>Insulation Materials</b>	Class H, 180°C (356°F), copper windings	
<b>Motor Filling Medium</b>	Air for wet pit installation, environmentally safe, non-toxic oil for dry pit installation, no cooling jacket required	
<b>Temperature Rise</b>	Class A for wet pit installation, Class B for dry pit installation	
<b>Maximum Fluid Temperature</b>	40°C (104°F) continuous, 50°C (122°F) intermittent	
<b>Motor Protection</b>	<b>Thermal</b>	Normally closed bimetallic switch in each phase, connected in series, 140°C (284°F), +/- 5 °C opening temperature
	<b>Leakage</b>	ABS Seal minder moisture detection probe in seal sensing chamber
<b>Sensing Chamber Filling Medium</b>	Environmentally safe, non-toxic oil	
<b>Bearing Type</b>	<b>Upper</b>	Single row ball permanently lubricated
	<b>Lower</b>	Double row angular contact permanently lubricated
<b>Motor Starter Types</b>	Suitable for use with across the line, electronic soft starters, and PWM type Variable Frequency Drives*	
<b>Maximum Starts per Hour</b>	15, evenly spaced	
<b>Inverter Duty Rating</b>	Motors meet NEMA MG1, part 31 requirements	
<b>Maximum Submergence</b>	20 meters (65 feet)	
<b>Available Voltages</b>	208, 230, 460, 600	
<b>Voltage Tolerance from Rated</b>	+/-10%	
<b>Agency Approvals</b>	Factory Mutual, CSA	
<b>Explosion Proof Rating</b>	NEC 500 Class 1, Division 1, Group C & D, Class T3C max surface temp	



ABS submersible sewage pump XFP  
Part of the ABS EffeX range



Premium Efficiency  
without Compromise

\*Output filters may be required on VFDs. See document DS-E00-001 for details.

### Motor Ratings, PE2 Frame

Motor Model	Input Power (P1)	Rated Power Output (P2)	Nominal RPM	Rated Voltage	Full Load Amps	Locked Rotor Amps	NEMA Code Letter	NEMA Service Factor	Motor Efficiency at % Load			Power Factor at % Load		
									100	75	50	100	75	50
PE 75/4	8.2 kW	7.5 kW 10 HP	1760	208	30.6	177.8	H	1.3**	91.7	91.9	91.6	.742	.654	.534
				230	27.7	160.8								
				460	13.8	80.4								
				600	10.6	61.6								
PE 90/4	9.8kW	9 kW 12 HP	1760	208	34.9	232	H	1.3**	91.7	91.5	88.8	.78	.7	.56
				230	31.5	210								
				460	15.8	105								
				600	12.1	80.5								
PE 105/4	11.4 kW	10.5 kW 14.1 HP	1755	208	39.1	232	G	1.3**	92.4	92.6	90.9	.806	.754	.632
				230	35.4	210								
				460	17.7	105								
				600	13.6	80.5								

\*\* For wet pit installation. Service factor is 1.15 for dry pit installation.



# TECHNICAL DATA

## 4" ABS XFP PUMP

XFP 100E-CB1  
4 Pole, 3 Phase, PE2

Date: 10/10  
Dwg: DS-E01-024 | Rev: 4

### Cable Data, PE2 Frame

	Motor	Motor Voltage	Cable Type	Cable Nominal Dia. +/- .5mm (.02")
Power Cable	PE 75/4	208 volt	SOOW 8/4+16/3	25.4mm (1.0") diameter
		230 volt	SOOW 8/4+16/3	25.4mm (1.0") diameter
		460 volt	SOOW 12/7*	18.8mm (0.74") diameter
		600 volt	SOOW 14/7	18.3mm (0.72") diameter
Control Cable		All	Included in Power Cable	
Power Cable	PE 90/4	208 volt	SOOW 8/4+16/3	25.4mm (1.0") diameter
		230 volt	SOOW 8/4+16/3	25.4mm (1.0") diameter
		460 volt	SOOW 12/7*	18.8mm (0.74") diameter
		600 volt	SOOW 14/7	18.3mm (0.72") diameter
Control Cable		All	Included in Power Cable	
Power Cable	PE 105/4	208 volt	SOOW 8/4+16/3	25.4mm (1.0") diameter
		230 volt	SOOW 8/4+16/3	25.4mm (1.0") diameter
		460 volt	SOOW 10/7*	20.7mm (0.82") diameter
		600 volt	SOOW 12/7	18.8mm (0.74") diameter
Control Cable		All	Included in Power Cable	
Cable Length	Standard: 15m (49 feet)		Optional: 20m (65 feet), 30m (98 feet) - Consult Factory for Longer Lengths	

\* Special versions ordered with cable suitable for both 230 volt and 460 volt operation will be equipped with the cable type and diameter shown in the "230 volt" section of the table

### Pump Data

Discharge Size	4" flanged, compatible with 4" class 125 ANSI flanges					
Suction Size	4" flanged, compatible with 4" class 125 ANSI flanges, threaded for 8 x 5/8-11 UNC bolts, 28mm (1.1") deep					
Volute pressure rating	10 bar (145 psi)					
Impeller Type	Semi-open, 1-vane, ContraBlock Plus w/ Seal Protection System					
Impeller Size	.1	.2	.3	.4	.5	
Solids Passage Size	80mm (3.14")	80mm (3.14")	80mm (3.14")	80mm (3.14")	80mm (3.14")	
Impeller DIA	250mm (9.4")	240mm (9.4")	225mm (8.6")	215mm (8.5")	195mm (7.7")	
Impeller Weight	9.7 Kg (21.3lb)	8.8 Kg (19.4lb)	8.4 Kg (18.5lb)	6.6 Kg (14.5 lb)	6.3 Kg (13.9 lb)	
Min Recommended Flow, GPM	160	160	160	130	130	

### Materials of Construction

	Standard	Optional
Motor Housing	Cast Iron EN-GJL-250 (ASTM A-48, Class 35B)	
Oil Chamber	Cast Iron EN-GJL-250 (ASTM A-48, Class 35B)	
Seal Plate	Cast Iron EN-GJL-250 (ASTM A-48, Class 35B)	
Impeller	Cast Iron EN-GJL-250 (ASTM A-48, Class 35B)	
Volute	Cast Iron EN-GJL-250 (ASTM A-48, Class 35B)	
Bottom Plate CB	Cast Iron EN-GJL-250 (ASTM A-48, Class 35B)	
Cable Entry Casting	Cast Iron EN-GJL-250 (ASTM A-48, Class 35B)	
Pump and Motor Shaft	Stainless Steel 1.4021 (AISI 420 SS)	
External Hardware	Stainless Steel 1.4401 (AISI 316 SS)	
Lifting Hoop	Stainless Steel 1.4401 (AISI 316 SS)	
O-Rings	Nitrile (Buna-N)	
Cable Glands	Nitrile (Buna-N)	
Tandem Mechanical Seal	Lower: Silicon Carbide on Silicon Carbide Upper: Silicon Carbide on Silicon Carbide	
Coating	Two part epoxy, black, 120µm (4.7 mil) DFT	Two part epoxy, black, 400µm (15.7 mil) DFT

### General Data

	PE 75/4	PE 90/4	PE 105/4
Overall Height	762mm (30")	762mm (30")	832mm (32.8")
Pump Weight	177 kg (390 lb)	177 kg (390 lb)	188.5 kg (415.6 lb)






# Pump performance curves XFP100E CB1 60HZ

Curve number  
Reference curve  
XFP100E CB1

Density 62.43 lb/ft <sup>3</sup>	Viscosity 1.57 cSt	Testnorm ISO 9906 Gr 2 Annex A1/A2	Discharge DN100	Frequency 60 Hz
Flow 578 US g.p.m.	Head 45.5 ft	Rated power 9.6 hp	Rated speed 1765 rpm	Date 2010-11-30
			Hydraulic efficiency 69.1 %	NPSH 10.2 ft



Impeller size 8.46 inch	N° of vanes 1	Impeller Contrabloc Plus impeller, 1 vane	Solid size 3 1/8"	Revision 2009-11-12
----------------------------	------------------	--	----------------------	------------------------

ABS reserves the right to change any data and dimensions without prior notice and can not be held responsible for the use of information contained in this software.

ABSEL PRO 1.7.2 / 2006-12-21





Massblatt XFP 100E-CB1 Trockeninstallation  
 Dimension sheet DRY-WELL Installation  
 Dimensioni Installazione a secco  
 Hoja de dimensiones instalación en seco  
 Plan d'encombrement Installation à sec

No: AN-M.22.569-01  
 Drawn: 11.05.09 / D.Wheelan  
 Issue Date: 11.05.09  
 Änderungen vorbehalten  
 Technical changes reserved  
 Con riserva di modifiche  
 Con reserva de modificaciones  
 Sous réserve de modification





**50 Hz**

**U.S.**

Typ Type Tipo	Gewicht Weight Poids Peso (lbs)	O (")	R (")
PE 60/4	367	29.5	46.4
PE 90/4	392	32.3	49.1

**60 Hz**


Typ Type Tipo	Gewicht Weight Poids Peso (lbs)	O (")	R (")
PE 35/6	326	29.5	46.4
PE 75/4	367	29.5	46.4
PE 90/4	367	29.5	46.4
PE 105/4	392	32.3	49.1



Guss-Allgemeintoleranzen nach DIN1680 - GTB16  
 General tolerances for castings in acc. to DIN1680-GTB16  
 Tolleranze generali delle fusioni secondo DIN1680-GTB16  
 Tolerancias generales para la fundición seg. de DIN1680-GTB16  
 Tolérance générale de la fonderie selon DIN1680-GTB16

# XFP100E CB1 60HZ

Testnorm  
ISO 9906 Gr 2 Annex A1/A2



2009-11-12

<b>Operating data specification</b>			
Flow	578 US g.p.m.	Head	45.5 ft
Efficiency	69.1 %	Shaft power	9.6 hp
NPSH	10.2 ft	Fluid	Water
Temperature	39 °F	Nature of system	Single head pump
No. of pumps	1		
<b>Pump data</b>			
Type	XFP100E CB1 60HZ	Make	ABS
Series	XFP PE1-PE3	Impeller	Contrabloc Plus impeller, 1 vane
N° of vanes	1	Impeller size	8.46 inch
Free passage	3 1/8"	Suction port	DN100
Discharge port	DN100		
<b>Motor data</b>			
Rated voltage	460 V	Frequency	60 Hz
Rated power P2	10.1 hp	Nominal speed	1765 rpm
Number of poles	4	Efficiency	91.7 %
Power factor	0.742	Rated current	13.8 A
Starting current	80.4 A	Rated torque	29.9 lbf ft
Starting torque	58.4 lbf ft	Degree of protection	IP68
Insulation class	H		

ABS reserves the right to change any data and dimensions without prior notice and can not be held responsible for the use of information contained in this software.




# Pump performance curves XFP100E CB1 60HZ

Curve number

Reference curve  
XFP100E CB1

Density 62.43 lb/ft <sup>3</sup>	Viscosity 1.57 cSt	Testnorm ISO 9906 Gr 2 Annex A1/A2	Discharge DN100	Frequency 60 Hz
Flow 578 US g.p.m.	Head 45.5 ft	Rated power 9.6 hp	Rated speed 1765 rpm	Date 2010-12-27
			Hydraulic efficiency 69.1 %	NPSH 10.2 ft



Impeller size 8.46 inch	N° of vanes 1	Impeller Contrabloc Plus impeller, 1 vane	Solid size 3 1/8"	Revision 2009-11-12
----------------------------	------------------	--	----------------------	------------------------

ABS reserves the right to change any data and dimensions without prior notice and can not be held responsible for the use of information contained in this software.

ABSEL PRO 1.7.2 / 2006-12-21

# **APPENDIX G STRUCTURAL CATALOG CUTS**

## PHYSICAL PROPERTIES

Application time (ASTM C-308 modified)	
Working time at 70°F	40-50 minutes
Initial set at 70°F	17 hours
Components	3 parts
Bond strength to concrete (ASTM D-4541)	Concrete failure
Coefficient of thermal expansion (ASTM C-531)	$3.5 \times 10^{-5} / \text{F}^{\circ}$ ( $1.9 \times 10^{-5} / \text{C}^{\circ}$ )
Compressive strength (ASTM C-579)	7,300 psi (513.2 kg/cm <sup>2</sup> )
Density (ASTM C-905)	113 pcf (1.81 gm/cm <sup>3</sup> )
Flexural strength (ASTM C-580)	4,900 psi (344.5 kg/cm <sup>2</sup> )
Maximum service temperature	150°F (65°C)
Modulus of elasticity (ASTM C-580)	$2.75 \times 10^5$ psi ( $1.9 \times 10^4$ kg/cm <sup>2</sup> )
Tensile strength (ASTM C-307)	2,000 psi (140.6 kg/cm <sup>2</sup> )
Thickness	1/8 inch (3.175 mm)
Water Vapor Transmission	
Moisture absorption (ASTM D-570-95)	< 0.04%
Permeance (ASTM E-96-94, A)	$6.88 \times 10^{-9}$ U.S. Perms

Physical properties were determined on specimens prepared under laboratory conditions using applicable ASTM procedures. Actual field conditions may vary and yield different results; therefore, data are subject to reasonable deviation. Data should not be used for specification purposes.

## CHARACTERISTICS

- Resistant to corrosive conditions common to the municipal wastewater treatment industry.
- Suitable for application over damp or dry concrete surfaces.
- Trowelable nonsagging consistency ensures ease of application on vertical and overhead surfaces.
- Does not require a primer.
- Prohibits water infiltration.

Sauereisen SewerGard No. 210 is an aggregate-filled epoxy material. This lining system is specifically designed to protect concrete surfaces of municipal wastewater treatment structures and collection systems from chemical attack and physical abuse. No. 210's nonsagging application properties permit economical repair and protection of vertical, horizontal and overhead surfaces of both new or rehabilitated substrates.

When cured, No. 210 provides an impermeable, high strength, corrosion-resistant lining for manholes, lift stations, grit chambers, aeration basins, and related structures subject to infiltration and attack from hydrogen sulfide and acid generated by microbiological sources.

## AREA PREPARATION

### Temperature of Working Area

Maintain a temperature of 60°-85°F on air, substrate, Liquid, Hardener, and Powder components during mixing, application, and cure.

The monolithic components should be maintained at 65°F to 80°F for 48 hours prior to beginning work.

At temperatures below 65°F, the application becomes more difficult and curing is retarded. Above 80°F, the material working time decreases.

Application in direct sunlight and rising surface temperature may result in blistering of the materials due to expansion of entrapped air or moisture in the substrate. Concrete surfaces that have been in direct sunlight must be shaded for 24 hours prior to application and remain shaded until the initial set has taken place. In rising temperatures it may be necessary to postpone the application or apply during cooler hours.

### Surface Preparation

Surfaces should be made free of oil, grease, water, and other contaminants that may inhibit bond. This can be achieved by chemical cleaning.

*Concrete* - Refer to SSPC-SP13/NACE 6 "Surface Preparation of Concrete" for detailed guidelines.

*New Concrete* - All structures must be properly designed and capable of withstanding imposed loads. Abrasive blast, high-pressure water blast, or acid etch concrete to remove laitance and obtain uniform surface texture. After surface preparation, voids left in concrete surface must be filled with Sauereisen Filler Compound No. 209.

*Old Concrete* - Concrete must be dry, firm and structurally sound as specified by the architect/engineer. Mechanical methods should be utilized to remove old paints, protective coatings, and attacked or deteriorated concrete. Abrasive blast or high-pressure water blast concrete to remove laitance and obtain uniform sound substrate.

Substrate surfaces requiring repairs in excess of 1/8 inch depth should be resurfaced with Sauereisen Underlayment No. F-120 to ensure proper rehabilitation of the substrate.

*Brick* - Abrasive blast or high-pressure water blast all foreign particles and attacked or unsound mortar from the joints. Loose brickwork or open joints should be regouted with appropriate Sauereisen mortar to ensure structural integrity.

All active hydrostatic leaks must be stopped with Sauereisen materials such as InstaPlug No. F-180 or Hydroactive Urethane Grout No. F-370 prior to SewerGard application.

If chemical cleaning is utilized to remove contaminants, substrate must be neutralized. If abrasive or high-pressure water blasting is used as the method of surface preparation, all sand and/or debris must be removed by thoroughly vacuuming the area with an industrial vacuum cleaner. If surface does not have desired conditions, repeat surface preparation procedure.

No. 210 may be applied over damp surfaces that are free of standing water; best results are achieved with dry surfaces.

## APPLICATION

### Mixing

No. 210 is packaged in pre-measured units of Powder, Liquid, and Hardener components. Mixing should be done mechanically with a "Jiffy" mixer blade chucked into a drill motor. The mixing equipment must be clean and free of Portland cement or other contaminants.

Remix both Liquid and Hardener prior to combining components. Empty contents of the Liquid into a clean, dry mixing container. Empty contents of Hardener into Liquid and mix thoroughly until blended for at least one minute. Add Powder component gradually while mixing to a uniform consistency.

Mix only complete batches. Material which has begun to set must be discarded. Do not try to retemper the material. Do not add solvent, additive or adulterant to any component or mixed material.

Remove the entire batch from the mixer when mixing is completed to prevent build-up in the equipment. While pouring one batch, another should be mixed in order to eliminate delays and to permit continuous operation.

### Installation

No. 210 is applied by trowel at a minimum 1/8 inch thickness. Theoretical coverage is 44 ft<sup>2</sup> per unit at 1/8 inch thick-ness. Actual coverage may vary, depending upon jobsite conditions. Screed bars may be used to control thickness on large surface areas.

To provide a pinhole-free surface and removal of trowel marks in No. 210, a short-nap mohair paint roller slightly dampened with water may be used. Excess water should be shaken off prior to back-rolling.

After No. 210 has achieved a hardened surface, a holiday detector should be utilized to ensure a continuous pinhole-free lining. A Sauereisen SewerGard Patch Kit may be used to conveniently repair any pinholes. Consult Sauereisen for details.

For details regarding construction joints, protrusions or penetrations through concrete, consult Sauereisen for specific recommendations.

## COVERAGE

No. 210 44 ft<sup>2</sup> per unit at 1/8 inch.

\*Coverage is theoretical and will vary depending upon surface conditions, porosity, application techniques and specific project conditions.

## SETTING/CURING

SewerGard No. 210 will take an initial set in 17 hours at 70°F. Do not allow water or chemicals on the material surface for a minimum of 24 hours. For temperatures below 70°F, cure a minimum of 48 hours prior to water or chemical exposure.

## PACKAGING

No. 210 is packaged in a premeasured unit consisting of:

Part A Hardener:  
3.2 lbs. in a 1-gal. can

Part B Liquid:  
10.1 lbs. in a 2-gal. bucket

Part C Powder:  
40 lbs. in a paper or plastic bag

\*Containers are filled by weight, not volume. Container size does not indicate volume of contents.

## CLEAN-UP

All equipment should be cleaned with MEK before material cures. If removal is required after cure consult Sauereisen for specific recommendation.

## SHELF LIFE

Sauereisen SewerGard No. 210 has a shelf life of one (1) year, when stored in unopened, tightly sealed containers in a dry location at 70°F. Avoid freezing. If there is a doubt as to the quality of the materials, consult a Sauereisen representative.

## CAUTION

Consult Material Safety Data Sheets and container label Caution Statements for hazards in handling these materials.

## WARRANTY

We warrant that our goods will conform to the description contained in the order, and that we have good title to all goods sold. WE GIVE NO WARRANTY, WHETHER OF MERCHANTABILITY, FITNESS FOR PURPOSE OR OTHERWISE, EXPRESS OR IMPLIED, OTHER THAN AS EXPRESSLY SET FORTH HEREIN. We are glad to offer suggestions or to refer you to customers using Sauereisen cements and compounds for a similar application. Users shall determine the suitability of the product for intended application before using, and users assume all risk and liability whatsoever in connection therewith regardless of any suggestions as to application or construction. In no event shall we be liable hereunder or otherwise for incidental or consequential damages. Our liability and your exclusive remedy hereunder or otherwise, in law or in equity, shall be expressly limited to our replacement of nonconforming goods at our factory or, at our sole option, to repayment of the purchase price of nonconforming goods.

- Distributors and agents in major cities throughout the world. Consult manufacturer for locations.**
- Information concerning government safety regulations available upon request.**
- Sauereisen also produces inorganic compounds for assembling, sealing, electrically insulating and grouting.**

**SAUEREISEN** ...since 1899  
160 Gamma Drive  
Pittsburgh, PA 15238-2989 USA  
Phone 412/963-0303 Fax 412/963-7620  
[www.sauereisen.com](http://www.sauereisen.com)

# **APPENDIX H ELECTRICAL CALCULATIONS AND CATALOG CUTS**



## ELECTRICAL LOAD CALCULATIONS

1. **Alternative 2 - Existing 120/240V, 1-phase, 3-wire service to remain; Provide two 15 HP pumps with variable frequency drives to limit startup current**

<u>Load Description</u>	<u>Load (KVA)</u>
15 HP lead pump	14.1
15 HP lag pump	14.1
3/4 HP exhaust fan	1.6
3/4 HP supply fan	1.6
1/2 HP sump pump	1.1
Air conditioning for electric room	2.0
General electrical loads	3.0
SCADA system electrical loads	2.0
Lighting	2.0
Spare	10.0
<b>Total</b>	<b>51.5</b>
<b>Recommended generator size</b>	<b>100KW</b>

2. **Alternative 3 - Existing 120/240V, 1-phase, 3-wire service to remain; Provide two 15 HP pumps with controls to limit operation to only 1 pump operating at any given time**

<u>Load Description</u>	<u>Load (KVA)</u>
15 HP pump	14.1
3/4 HP exhaust fan	1.6
3/4 HP supply fan	1.6
1/2 HP sump pump	1.1
Air conditioning for electric room	2.0
General electrical loads	3.0
SCADA system electrical loads	2.0

Lighting	2.0
Spare	10.0
<b>Total</b>	<b>37.4</b>

**Recommended generator size 60 KW**

**3. Alternative 4 - Existing 120/240V, 1-phase, 3-wire service to remain; Provide two 10 HP pumps**


<u>Load Description</u>	<u>Load (KVA)</u>
10 HP lead pump	11.0
10 HP lag pump	11.0
3/4 HP exhaust fan	1.6
3/4 HP supply fan	1.6
1/2 HP sump pump	1.1
Air conditioning for electric room	2.0
General electrical loads	3.0
SCADA system electrical loads	2.0
Lighting	2.0
Spare	10.0
<b>Total</b>	<b>45.3</b>

**Recommended generator size 60 KW**

**4. Alternative Option - Upgrade HECO service to 480V, 3-phase, 3-wire**

<u>Load Description</u>	<u>Load (KVA)</u>
15 HP lead pump	14.1
15 HP lag pump	14.1
3/4 HP exhaust fan	1.6
3/4 HP supply fan	1.6

1/2 HP sump pump	1.1
Air conditioning for electric room	2.0
General electrical loads	3.0
SCADA system electrical loads	2.0
Lighting	2.0
Spare	10.0
<b>Total</b>	<b>51.5</b>
<b>Recommended generator size</b>	<b>50 KW</b>



## ALTERNATIVE NO. 2

**STANDBY 80-100 kW**  
**PRIME 72-90 kW**

**60 Hz**

Model	Standby kW (kVA)	Prime kW (kVA)
D80-6	80 (100)	72 (90)
D80-2S	80 (80)	72 (72)
D100-6	100 (125)	90 (112.5)
D100-6S	100 (100)	90 (90)

Tier 3 EPA Approved, Emissions Certified

## FEATURES

### GENERATOR SET

- Complete system designed and built at ISO 9001 certified facilities
- Factory tested to design specifications at full load conditions

### ENGINE

- Governor, electronic
- Electrical system, 12 VDC
- Cartridge type filters
- Battery rack and cables
- Coolant and lube drains piped to edge of base

### GENERATOR

- Insulation system, class H
- Drip proof generator air intake (NEMA 2, IP23)
- Electrical design in accordance with BS5000 Part 99, EN61000-6, IEC60034-1, NEMA MG-1.33

### CONTROL SYSTEM

- EMCP 3.1 digital control panel
- Vibration isolated NEMA 1 enclosure with lockable hinged door
- DC and AC wiring harnesses

### MOUNTING ARRANGEMENT

- Heavy-duty fabricated steel base with lifting points
- Anti-vibration pads to ensure vibration isolation
- Complete OSHA guarding
- Stub-up pipe ready for connection to silencer pipework
- Flexible fuel lines to base with NPT connections

### COOLING SYSTEM

- Radiator and cooling fan complete with protective guards
- Standard ambient temperatures up to 50° C (122° F)

### CIRCUIT BREAKER

- UL/CSA listed
- 3-pole with solid neutral
- NEMA 1 steel enclosure, vibration isolated
- Electrical stub-up area directly below circuit breaker

### AUTOMATIC VOLTAGE REGULATOR

- Voltage within  $\pm 0.5\%$  3-phase and  $\pm 1.0\%$  single phase at steady state from no load to full load
- Provides fast recovery from transient load changes

### EQUIPMENT FINISH

- All electroplated hardware
- Anticorrosive paint protection
- High gloss polyurethane paint for durability and scuff resistance

### QUALITY STANDARDS

- BS4999, BS5000, BS5514, EN61000-6, IEC60034, NEMA MG-1.33, NFPA 110 (with optional equipment)

### DOCUMENTATION

- Operation and maintenance manuals provided
- Wiring diagrams included

### WARRANTY

- All equipment carries full manufacturer's warranty.

## **OPTIONAL EQUIPMENT\***

### **ENCLOSURE**

- B Series weather protective enclosure (includes internal silencer system)
  - Single point lift
  - Panel viewing window
  - External emergency stop pushbutton
- Sound attenuated enclosure (includes internal silencer system)

### **SILENCER SYSTEM – OPEN UNIT**

- Level 1 silencer
- Level 2 silencer
- Level 3 silencer
- Mounting kit
- Through-wall installation kits

### **ENGINE**

- Battery heater
- Lube oil drain pump
- High lube oil temperature shutdown
- Lube oil sump heater

### **CIRCUIT BREAKER**

- Auxiliary voltfree contacts
- Shunt trip (100+ amp breakers)

### **GENERATOR**

- Anti-condensation heater
- Permanent magnet generator
- AREP excitation system (3-Phase only)
- Generator upgrade 1 size (3-Phase only)

### **CONTROL SYSTEM**

- No control system
- EMCP 3.2 digital control panel

### **MOUNTING ACCESSORIES**

- Seismic (Zone 4) vibration isolators

### **FUEL SYSTEM**

- UL listed closed top-diked skid-mounted fuel tank base (12/24-hour capacity) with fuel alarm (low level/leak detected)
- Critical high fuel alarm
- Critical low fuel level shutdown

### **COOLING SYSTEM**

- Coolant heater
- Low coolant temperature alarm
- Low coolant level shutdown
- Radiator transition flange

### **REMOTE ANNUNCIATORS**

- 16-channel remote annunciator panel (supplied loose)

### **MISCELLANEOUS ACCESSORIES**

- Toolkit
- Additional operator's manual pack
- Special enclosure color
- UL listing
- CSA certification
- French or Spanish language labels

### **EXTENDED SERVICE CONTRACTS**

- Extended Service Coverage available

### **TESTING**

- Factory test and report at both 1.0 pf and 0.8 pf


\* Some options may not be available on all models.  
Not all options are listed.

STANDBY  
PRIME  
60 Hz

80-100 kW  
72-90 kW



**GENERATOR SET DIMENSIONS AND WEIGHTS**



Model	Length mm (in)	Width mm (in)	Height mm (in)	Weight kg (lb)*
D80-6	2400 (94.5)	838 (32.9)	1400 (55.1)	960 (2,116)
D80-2S	2400 (94.5)	838 (32.9)	1400 (55.1)	934 (2,059)
D100-6	2400 (94.5)	838 (32.9)	1400 (55.1)	1389 (3,062)
D100-6S	2400 (94.5)	838 (32.9)	1400 (55.1)	1066 (2,350)

**NOTE:** General configuration not to be used for installation. See specific dimensional drawings for detail.

\*Includes oil and coolant

**SPECIFICATIONS  
GENERATOR**

Voltage regulation	± 0.5% 3-phase and ± 1.0% single phase at steady state from no load to full load
Frequency	± 0.25% for constant load, no load to full load
Waveform distortion	THD < 4%, at no load
Radio interference	Compliance with EN61000-6
Telephone interference	TIF < 50, THF < 2%
Overspeed limit	2250 rpm
Insulation	Class H
Temperature rise	Within Class H limits
Available voltages	1-phase – 120/240, 115/230, 110/220 3-phase – 277/480, 266/460, 120/240, 127/220, 120/208, 347/600
Deration	Consult factory for available outputs
Ratings	At 30° C (86° F), 152.4 m (500 ft), 60% humidity, 1.0 pf (1-phase), 0.8 pf (3-phase)

**ENGINE**

Manufacturer	Caterpillar
Type	4-cycle
Bore – mm (in)	105.0 (4.13)
Stroke – mm (in)	127.0 (5.00)
Governor Type	Electronic
Class	G2
Piston speed – m/sec (ft/sec)	7.62 (25.0)
Engine speed – rpm	1800
Air cleaner type	Dry, replaceable paper element type with restriction indicator

**RATING DEFINITIONS AND CONDITIONS**

**Standby** – Applicable for supplying continuous electrical power (at variable load) in the event of a utility power failure. No overload is permitted on these ratings. The generator is peak rated (as defined in ISO8528-3).

**D80-6, D80-2S – C4.4**

Aspiration	Turbocharged
Cylinder configuration	In-line 4
Displacement – L (cu in)	4.4 (269)
Compression ratio	19.2:1
Max power at rated rpm – kW (hp)	
Standby	97 (130)
Prime	88 (118)
BMEP – kPa (psi)	
Standby	1476 (213)
Prime	1335 (194)
Regenerative power – kW (hp)	13.8 (18.5)

**D100-6, D100-6S – C4.4**

Aspiration	Turbocharged
Cylinder configuration	In-line 4
Displacement – L (cu in)	4.4 (269)
Compression ratio	19.2:1
Max power at rated rpm – kW (hp)	
Standby	117 (156.9)
Prime	106 (142.1)
BMEP – kPa (psi)	
Standby	1612 (233)
Prime	1771 (257)
Regenerative power – kW (hp)	13.8 (18.5)

**CONTROL PANEL**

- Heavy duty sheet steel enclosure with lockable hinged door
- Vibration isolated from generating set
- LCD display
- AC metering
- DC metering
- Fail to start shutdown
- Low oil pressure shutdown
- High engine temperature
- Low/high battery voltage
- Underspeed/overspeed
- Loss of engine speed detection
- 2 spare fault channels
- 20 event fault log
- 2 LED status indicators
- Lockdown emergency stop push button

**Prime** – Applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. There is no limitation to the annual hours of operation and the generator set can supply 10 percent overload power for 1 hour in 12 hours.

**D100-6S (1-Phase)**

Materials and specifications are subject to change without notice.

Generator Set Technical Data – 1800 rpm/60 Hz		Standby		Prime	
<b>Power Rating</b> (at 240V)	kW      kVA	100	100	90	90
<b>Lubricating System</b> Type: full pressure Oil filter: spin-on, full flow Oil cooler: watercooled Oil type required: API CH4 Total oil capacity Oil pan	L      U.S. gal L      U.S. gal	8      2.1 7      1.9		8      2.1 7      1.9	
<b>Fuel System</b> Generator set fuel consumption 100% load 75% load 50% load	L/hr      gal/hr L/hr      gal/hr L/hr      gal/hr	29.7      7.8 23.7      6.3 17.6      4.6		27.3      7.2 21.9      5.8 16.3      3	
<b>Engine Electrical System</b> Voltage/ground: 12/negative Battery charging generator ampere rating	amps	65		65	
<b>Cooling System</b> Water pump type: centrifugal Radiator system capacity incl. engine Maximum coolant static head Coolant flow rate Minimum temperature to engine Temperature rise across engine Heat rejected to coolant at rated power Total heat radiated to room at rated power Radiator fan load	L      U.S. gal m H <sub>2</sub> O      ft H <sub>2</sub> O L/hr      U.S. gal/hr °C      °F °C      °F kW      Btu/min kW      Btu/min kW      hp	17.0      4.5 10.2      33.5 10 140      2,679 70      158 7      44.6 61.0      3,472 18.0      1,025 4.8      6.4		17.0      4.5 10.2      33.5 10 140      2,679 70      158 7      44.6 57.0      3,244 15.0      854 4.8      6.4	
<b>Air Requirements</b> Combustion air flow Maximum air cleaner restriction Radiator cooling air (zero restriction) Generator cooling air Allowable air flow restriction (after radiator) Cooling airflow (@ rated speed) Rate with restriction	m <sup>3</sup> /min      cfm kPa      in H <sub>2</sub> O m <sup>3</sup> /min      cfm m <sup>3</sup> /min      cfm kPa      in H <sub>2</sub> O m <sup>3</sup> /min      cfm	8.4      297 8      32 230      8,135 26.4      933 0.120      0.48 192      6,780		8.5      300 8      32 230      8,135 26.4      933 0.120      0.48 192      6,780	
<b>Exhaust System</b> Maximum allowable backpressure Exhaust flow at rated kW Exhaust temperature at rated kW – Dry exhaust	kPa      in/mercury m <sup>3</sup> /min      cfm °C      °F	15      4.4 22.5      794 580      1,076		15      4.4 20.0      705 540      1,004	
<b>Generator Set Noise Rating*</b> (without attenuation) at 1 m (3 ft)	dB(A)	98		97	

Generator Technical Data		120/240V	115/230V	110/220V
<b>Motor Starting Capability:</b> (kVA) (30% voltage dip)		187	175	162
Self excited		187	175	162
PM excited**				
<b>Full Load Efficiencies:</b>	Standby	90.5	90.0	89.4
	Prime	90.9	90.4	89.4
<b>Reactances (per unit):</b>	X <sub>d</sub>	2.67	2.91	3.18
	X' <sub>d</sub>	0.21	0.23	0.25
Reactances shown	X'' <sub>d</sub>	0.127	0.138	0.151
are applicable to	X <sub>q</sub>	1.60	1.74	1.90
the standby rating.	X'' <sub>q</sub>	0.151	0.164	0.180
<b>Time Constants:</b>	t' <sub>d</sub>	165 ms	t' <sub>d</sub> 13 ms	t' <sub>do</sub> 2734 ms
				t <sub>a</sub> 20 ms

\* dB(A) levels are for guidance only  
\*\* With PMG Excited Option AVR12



# DIESEL GENERATOR SET

# CATERPILLAR®

ALTERNATIVE NO. 3 AND 4



Image shown may not reflect actual package.

## STANDBY

**60 kW 75 kVA**

**60 Hz 1800 rpm 240 Volts**

Caterpillar is leading the power generation marketplace with Power Solutions engineered to deliver unmatched flexibility, expandability, reliability, and cost-effectiveness.

## FEATURES

### Caterpillar Model D60-6 3 phase

#### FUEL/EMISSIONS STRATEGY

- EPA Tier 3

#### DESIGN CRITERIA

- The generator set accepts 100% rated load in one step per NFPA 110 and meets ISO 8528-5 transient response.

#### FULL RANGE OF ATTACHMENTS

- Wide range of bolt-on system expansion attachments, factory designed and tested
- Flexible packaging options for easy and cost effective installation

#### SINGLE-SOURCE SUPPLIER

- Fully prototype tested with certified torsional vibration analysis available

#### WORLDWIDE PRODUCT SUPPORT

- Caterpillar® dealers provide extensive post sale support including maintenance and repair agreements
- Caterpillar dealers have over 1,600 dealer branch stores operating in 200 countries
- The Cat® S•O•S<sup>SM</sup> program cost effectively detects internal engine component condition, even the presence of unwanted fluids and combustion by-products

#### CAT® C4.4 DIESEL ENGINE

- Reliable, rugged, durable design
- Field-proven in thousands of applications worldwide
- Four-stroke diesel engine combines consistent performance and excellent fuel economy with minimum weight
- Electronic engine control

#### GENERATOR SET

- Complete system designed and built at ISO 9001 certified facilities
- Factory tested to design specifications at full load conditions

#### CONTROL SYSTEM

- EMCP 3.1 digital control panel
- Vibration isolated NEMA 1 enclosure with lockable hinged door
- DC and AC wiring harnesses

# STANDBY 60 ekW 75 kVA

60 Hz 1800 rpm 240 Volts



## FACTORY INSTALLED STANDARD & OPTIONAL EQUIPMENT

System	Standard	Optional
Air Inlet	<ul style="list-style-type: none"> <li>• Dry replaceable paper element type with restriction indicator</li> </ul>	
Cooling	<ul style="list-style-type: none"> <li>• Radiator and cooling fan complete with protective guards</li> <li>• Standard ambient temperatures up to 50 degrees C (122 degrees F)</li> </ul>	<ul style="list-style-type: none"> <li>• Coolant heater</li> <li>• Low coolant temperature alarm</li> <li>• Low coolant level shutdown</li> <li>• Radiator transition flange</li> </ul>
Engine	<ul style="list-style-type: none"> <li>• Governor, mechanical</li> <li>• Electrical system, 12 VDC</li> <li>• Cartridge type filters</li> <li>• Battery rack and cables</li> <li>• Coolant and lube drains piped to edge of base</li> </ul>	<ul style="list-style-type: none"> <li>• Governor, electronic</li> <li>• Battery heater</li> <li>• Lube oil drain pump</li> <li>• High lube oil temperature shutdown</li> <li>• Lube oil sump heater</li> </ul>
Generator	<ul style="list-style-type: none"> <li>• Class H insulation</li> <li>• Drip proof generator air intake (NEMA 2,IP23)</li> <li>• Electrical design in accordance with BS5000 Part 99, EN61000-6, IEC60034-1, NEMA MG-1.33</li> <li>• IP23 Protection</li> </ul>	<ul style="list-style-type: none"> <li>• Anti-condensation space heater</li> <li>• Permanent magnet excitation</li> <li>• Internal Excitation</li> <li>• Generator upgrade 1 size</li> </ul>
Circuit Breaker	<ul style="list-style-type: none"> <li>• UL/CSA listed</li> <li>• 3-pole with solid neutral</li> <li>• NEMA 1 steel enclosure, vibration isolated</li> <li>• Electrical stub-up area directly below circuit breaker</li> </ul>	<ul style="list-style-type: none"> <li>• Auxiliary voltfree contacts</li> <li>• Shunt trip</li> </ul>
Control Panels	<ul style="list-style-type: none"> <li>• EMCP 3.1 digital control panel</li> <li>• Vibration isolated NEMA 1 enclosure with lockable hinged door</li> <li>• DC and AC Wiring harnesses</li> </ul>	<ul style="list-style-type: none"> <li>• No control system</li> <li>• EMCP 3.2 digital control panel</li> </ul>
Mounting	<ul style="list-style-type: none"> <li>• Heavy-duty fabricated steel base with lifting points</li> <li>• Anti-vibration pads to ensure vibration isolation</li> <li>• Complete OSHA guarding</li> <li>• Stub-up pipe ready for connection to silencer pipework</li> <li>• Flexible fuel lines to base with NPT connections</li> </ul>	<ul style="list-style-type: none"> <li>• Seismic (Zone 4) vibration isolators</li> </ul>
General	<ul style="list-style-type: none"> <li>• High gloss polyurethane paint, Caterpillar yellow except rails and radiators gloss black</li> <li>• Anticorrosive paint protection</li> <li>• All electroplated hardware</li> </ul>	<ul style="list-style-type: none"> <li>• Toolkit</li> <li>• Additional operator's manual pack</li> <li>• Special enclosure color</li> <li>• UL Listing, CSA Certification</li> <li>• French or Spanish language labels</li> </ul>

**SPECIFICATIONS**

---

**CAT GENERATOR**

Frame Size.....LC2014H  
 Excitation.....Self Excited  
 Pitch.....0.6667  
 Number of Poles.....4  
 Number of bearings..... Single Bearing  
 Number of Leads.....012  
 IP Rating.....IP23  
 Overspeed capability..... 125  
 Wave form deviation (Line Wave Form to Line)..... 002.00  
 Paralleling kit droop transformer..... Standard  
 Voltage regulator.3 Phase sensing with selectible volts/Hz  
 Telephone Influence Factor..... Less than 50

**CAT ENGINE**

C4.4 In-line 4, 4-cycle diesel  
 Bore - mm..... 105.00 mm (4.13 in)  
 Stroke - mm..... 127.00 mm (5.0 in)  
 Displacement-L..... 4.40 L (268.5 in<sup>3</sup>)  
 Compression ratio..... 16.2:1  
 Aspiration.....T  
 Fuel system..... Common Rail  
 Governor type..... Mechanical

**Emissions (Nominal)**

NOx g/hp-hr..... 5.40  
 CO g/hp-hr..... 1.69  
 HC g/hp-hr......32  
 PM g/hp-hr......28

**Control Panel**

Heavy duty sheet steel enclosure with lockable hinged door  
 Vibration isolated from generating set  
 LCD display  
 AC metering  
 DC metering  
 Fail to start shutdown  
 Low oil pressure shutdown  
 High engine temperature  
 Low / high battery voltage  
 Underspeed/overspeed  
 Loss of engine speed detection  
 2 spare fault channels  
 20 event fault log  
 2 LED status indicators  
 Lockdown emergency stop push button

**TECHNICAL DATA**

Open Generator Set - - 1800 rpm/60 Hz/240 Volts	PM3468	
<b>Tier 3</b>		
<b>Generator Set Package Performance</b> Genset Power rating @ 0.8 pf Genset Power rating with fan	75 kVA 60 ekW	
<b>Fuel Consumption</b> 100% load with fan	20.0 L/hr	5.3 Gal/hr
<b>Cooling System</b> <sup>1</sup> Air flow restriction (system) Air flow (max @ rated speed for radiator arrangement) Engine Coolant capacity with radiator/exp. tank Engine coolant capacity Radiator coolant capacity	0.12 kPa m <sup>3</sup> /min 6.7 L .7 L 6.0 L	0.48 in. water  1.8 gal 0.2 gal 1.6 gal
<b>Inlet Air</b> Combustion air inlet flow rate	6.0 m <sup>3</sup> /min	211.9 cfm
<b>Exhaust System</b> Exhaust stack gas temperature Exhaust gas flow rate Exhaust flange size (internal diameter)	550.0 ° C 15.1 m <sup>3</sup> /min 6.4 mm	1022.0 ° F 533.3 cfm 0.3 in
<b>Heat Rejection</b> Heat rejection to coolant (total) Heat rejection to exhaust (total) Heat rejection to atmosphere from generator	50 kW 68 kW 6.9 kW	2843 Btu/min 3867 Btu/min 392.4 Btu/min
<b>Alternator</b> <sup>2</sup> Motor starting capability @ 30% voltage dip Frame Temperature Rise	127 skVA LC2014H 150 ° C	270 ° F

<sup>1</sup> For ambient and altitude capabilities consult your Caterpillar dealer. Airflow restriction (system) is added to existing restriction from factory.

<sup>2</sup> Generator temperature rise is based on a 40 C (104 F) ambient per NEMA MG1-32.

# STANDBY 60 ekW 75 kVA

60 Hz 1800 rpm 240 Volts



## RATING DEFINITIONS AND CONDITIONS

---

**Meets or Exceeds International Specifications:** AS1359, CSA, IEC60034-1, ISO3046, ISO8528, NEMA MG 1-22, NEMA MG 1-33, UL508A, 72/23/EEC, 98/37/EC, 2004/108/EC

**Standby** - Output available with varying load for the duration of the interruption of the normal source power. Average power output is 70% of the standby power rating. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year. Standby power in accordance with ISO8528. Fuel stop power in accordance with ISO3046. Standby ambients shown indicate ambient temperature at 100% load which results in a coolant top tank temperature just below the shutdown temperature.

**Ratings** are based on SAE J1349 standard conditions. These ratings also apply at ISO3046 standard conditions. **Fuel rates** are based on fuel oil of 35° API [16° C (60° F)] gravity having an LHV of 42 780 kJ/kg (18,390 Btu/lb) when used at 29° C (85° F) and weighing 838.9 g/liter (7.001 lbs/U.S. gal.). Additional ratings may be available for specific customer requirements, contact your Caterpillar representative for details. For information regarding Low Sulfur fuel and Biodiesel capability, please consult your Caterpillar dealer.

# STANDBY 60 ekW 75 kVA

60 Hz 1800 rpm 240 Volts



## DIMENSIONS

---

Package Dimensions		
Length	2208.0 mm	86.93 in
Width	1000.0 mm	39.37 in
Height	1265.9 mm	49.84 in
Weight		

NOTE: For reference only - do not use for installation design. Please contact your local dealer for exact weight and dimensions. (General Dimension Drawing #3301889).

Performance No.: PM3468

Feature Code: NAC089P

Gen. Arr. Number: 2652661

Source: U.S. Sourced

LEHE0097 02/09

14171950

[www.CAT-ElectricPower.com](http://www.CAT-ElectricPower.com)

© 2009 Caterpillar  
All rights reserved.

Materials and specifications are subject to change without notice.  
The International System of Units (SI) is used in this publication.

CAT, CATERPILLAR, SAFETY.CAT.COM their respective logos, "Caterpillar Yellow," and the POWER EDGE trade dress, as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

# **APPENDIX I COST ESTIMATE**





ESTC  
MECHANICAL

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM

DATE: JANUARY 2011

PAGE 1 OF 3

PROJECT: Kahanahou Wastewater Pump Station Upgrade

Preliminary Design Alternatives Report

Alternative No. 2 - New 15HP C/S Submersible Pumps w/ VFD

LOCATION: Kahanahou Wastewater Pump Station

ENGINEER: OKAHARA AND ASSOCIATES, INC.

ESTIMATOR: TYSON T. TOYAMA

BASIS FOR ESTIMATE: PRELIMINARY

JOB NUMBER: 210-002

CHECKED BY: TYSON T. TOYAMA

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>CIVIL / MECHANICAL</b>								
1. DEMOLITION	1	LS					7,600.00	<b>7,600.00</b>
2. DRY PIT SUBMERSIBLE PUMPS	3	EA	15,625.50	<b>46,876.50</b>	13,086.00	<b>39,258.00</b>	28,711.50	<b>86,134.50</b>
3. VFD (15 HP)	2	EA	2,250.33	<b>4,500.66</b>	1,307.00	<b>2,614.00</b>	3,557.33	<b>7,114.66</b>
4. DRY WELL SUMP PUMP	1	EA	275.88	<b>275.88</b>	116.32	<b>116.32</b>	392.20	<b>392.20</b>
5. 6"x4" DI REDUCER	4	EA	935.20	<b>3,740.80</b>	193.89	<b>775.56</b>	1,129.09	<b>4,516.36</b>
6. 4" DI PIPE	10	FT	20.49	<b>204.90</b>	31.41	<b>314.06</b>	51.90	<b>518.96</b>
7. 6" DI PIPE	120	FT	32.88	<b>3,945.60</b>	48.49	<b>5,818.91</b>	81.37	<b>9,764.51</b>
8. 8" DI PIPE	120	FT	47.95	<b>5,754.00</b>	60.20	<b>7,223.47</b>	108.15	<b>12,977.47</b>
9. 6" DI ELBOW	6	EA	473.45	<b>2,840.70</b>	193.89	<b>1,163.35</b>	667.34	<b>4,004.05</b>
10. 8" DI ELBOW	2	EA	818.30	<b>1,636.60</b>	218.10	<b>436.20</b>	1,036.40	<b>2,072.80</b>
11. 8"x8"x6" DI WYE	2	EA	1,432.03	<b>2,864.06</b>	348.96	<b>697.92</b>	1,780.99	<b>3,561.98</b>
12. 6" GATE VALVE	6	EA	1,011.19	<b>6,067.14</b>	581.60	<b>3,489.60</b>	1,592.79	<b>9,556.74</b>
13. 8" GATE VALVE	2	EA	1,811.95	<b>3,623.90</b>	697.92	<b>1,395.84</b>	2,509.87	<b>5,019.74</b>
14. 6" CHECK VALVE	2	EA	894.29	<b>1,788.58</b>	581.60	<b>1,163.20</b>	1,475.89	<b>2,951.78</b>
15. 6" FLANGED COUPLING ADAPTER	2	EA	157.82	<b>315.64</b>	72.70	<b>145.40</b>	230.52	<b>461.04</b>
16. 4" FLANGES	1	EA	69.79	<b>69.79</b>	232.64	<b>232.64</b>	302.43	<b>302.43</b>
17. 6" FLANGES	12	EA	137.59	<b>1,651.08</b>	348.96	<b>4,187.52</b>	486.55	<b>5,838.60</b>
18. 8" FLANGES	13	EA	252.04	<b>3,276.52</b>	465.28	<b>6,048.64</b>	717.32	<b>9,325.16</b>
19. 4" GASKET & BOLT SET	2	EA	10.52	<b>21.04</b>	72.70	<b>145.40</b>	83.22	<b>166.44</b>
20. 6" GASKET & BOLT SET	12	EA	17.30	<b>207.60</b>	96.91	<b>1,162.91</b>	114.21	<b>1,370.51</b>
21. 8" GASKET & BOLT SET	7	EA	19.82	<b>138.74</b>	116.32	<b>814.24</b>	136.14	<b>952.98</b>
22. PIPE SUPPORTS	1	LS					30,000.00	<b>30,000.00</b>
23. PRESSURE (LEVEL) TRANSDUCERS	1	LS					5,000.00	<b>2,500.00</b>
24. PRESSURE TRANSDUCERS	1	LS					5,000.00	<b>2,500.00</b>
25. NEW PIPE PENETRATIONS	2	LS					5,000.00	<b>10,000.00</b>
26. PATCH PIPE PENETRATIONS	2	LS					2,500.00	<b>5,000.00</b>
27. TEMP SUMP PUMPS (PURCHASE)	2	EA	40,000.00	<b>80,000.00</b>	40,000.00	<b>80,000.00</b>	80,000.00	<b>160,000.00</b>
28. TEMP HDPE PIPING	150	LF	25.00	<b>3,750.00</b>	75.00	<b>11,250.00</b>	100.00	<b>15,000.00</b>

ALT. NO. 2 SUBTOTAL - PAGE 1

399,602.91

ESTC  
MECHANICAL

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM

DATE: JANUARY 2011

PAGE 2 OF 3

PROJECT: Kahanahou Wastewater Pump Station Upgrade

Preliminary Design Alternatives Report

Alternative No. 2 - New 15HP C/S Submersible Pumps w/ VFD

LOCATION: Kahanahou Wastewater Pump Station

ENGINEER: OKAHARA AND ASSOCIATES, INC.

ESTIMATOR: TYSON T. TOYAMA

BASIS FOR ESTIMATE: PRELIMINARY

JOB NUMBER: 210-002

CHECKED BY: TYSON T. TOYAMA

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>CIVIL / MECHANICAL CONTINUED</b>								
1. CONCRETE / REBAR	3	CYD	250.00	<b>750.00</b>	1,163.20	<b>3,489.60</b>	1,413.20	<b>4,239.60</b>
2. CONCRETE JACKET 8" SEWER	50	LF					300.00	<b>15,000.00</b>
3. COMBINATION EYE WASH/SHOWER	1	EA	719.00		290.80		1,009.80	<b>1,009.80</b>
4. 1" TYPE L COPPER	60	LF	6.96	<b>417.60</b>	8.58	<b>514.72</b>	15.54	<b>932.32</b>
5. TESTING	1	LS			11,632.00		11,632.00	<b>11,632.00</b>
6. CLEANUP	1	LS			11,632.00		11,632.00	<b>11,632.00</b>
<b>METER VAULT</b>								
1. 8" VENTURI METER	1	EA	4,180.00	<b>4,180.00</b>	1,163.20	<b>1,163.20</b>	5,343.20	<b>5,343.20</b>
2. METER VAULT	1	EA					40,000.00	<b>40,000.00</b>
3. EXCAVATION	30	CYD		<b>0.00</b>	145.40	<b>4,362.00</b>	145.40	<b>4,362.00</b>
4. CRUSHED ROCK BACKFILL	5	CYD	100.00	<b>500.00</b>	72.70	<b>363.50</b>	172.70	<b>863.50</b>
5. BASE COURSE	3	CYD	100.00	<b>300.00</b>	72.70	<b>218.10</b>	172.70	<b>518.10</b>
6. DUPLEX SUMP PUMP	1	EA	1,200.00	<b>1,200.00</b>	581.60	<b>581.60</b>	1,781.60	<b>1,781.60</b>
7. 2" DWV COPPER (INCLUDE TRENCH)	100	LF	14.67	<b>1,467.00</b>	100.00	<b>10,000.00</b>	114.67	<b>11,467.00</b>
8. DEWATERING	10	DAYS	100.00	<b>1,000.00</b>	581.60	<b>5,816.00</b>	681.60	<b>6,816.00</b>
<b>GENSET BUILDING</b>								
1. CMU BUILDING	350	SF					350.00	<b>122,500.00</b>
<b>MODIFY EXISTING GENSET ROOM INTO SCADA ROOM</b>								
1. GENSET ROOM	100	SF					100.00	<b>10,000.00</b>
<b>REFURBISH EXISTING PUMP BUILDING EXTERIOR AND INTERIOR</b>								
1. PUMP STATION	900	SF					50.00	<b>45,000.00</b>
2. WETWELL LINER	1000	SF					40.00	<b>40,000.00</b>

ALT. NO. 2 SUBTOTAL - PAGE 2

333,097.12

ESTC  
MECHANICAL

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM  
DATE: JANUARY 2011  
PAGE 3 OF 3

PROJECT: **Kahanahou Wastewater Pump Station Upgrade**  
**Preliminary Design Alternatives Report**  
**Alternative No. 2 - New 15HP C/S Submersible Pumps w/ VFD**  
LOCATION: **Kahanahou Wastewater Pump Station**  
ENGINEER: **OKAHARA AND ASSOCIATES, INC.**  
ESTIMATOR: **TYSON T. TOYAMA**

BASIS FOR ESTIMATE: **PRELIMINARY**  
JOB NUMBER: **201-029**  
CHECKED BY: **TYSON T. TOYAMA**

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>SUBTOTAL - PAGE 1</b>								<b>399,602.91</b>
<b>SUBTOTAL - PAGE 2</b>								<b>333,097.12</b>
<b>HAZARDOUS MATERIAL REMOVAL</b>								
1. ASBESTOS/LEAD	1	LS					20,000.00	<b>20,000.00</b>
2. AIR MONITORING	1	LS					10,000.00	<b>10,000.00</b>
<b>MISCELLANEOUS</b>								
1. NOISE MITIGATION MEASURES	1	LS					10,000.00	<b>10,000.00</b>
2. CONSTRUCTION TRAILER	24	MONTH					2,000.00	<b>48,000.00</b>
<b>MECHANICAL - A/C AND VENTILATION SYSTEM - See Attached</b>								<b>59,400.00</b>
<b>FUEL SYSTEM - See Attached</b>								<b>88,200.00</b>
<b>GENSET EXHAUST SYSTEM - See Attached</b>								<b>22,500.00</b>
<b>ELECTRICAL - See Attached</b>								<b>636,970.00</b>

	SUBTOTAL	<b>1,627,770.03</b>
	MOB/DEMOB/PHASING 25%	<b>406,942.51</b>
	CONTINGENCY 25%	<b>508,678.13</b>
	OVERHEAD & PROFIT 10%	<b>254,339.07</b>
	TAX 4.72%	<b>132,052.84</b>
	ESCALATION (5%/YR FOR 1 YEAR)	<b>146,489.13</b>
	<b>ALT. No. 2 TOTAL</b>	<b>3,076,271.71</b>

ESTC  
MECHANICAL

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM  
DATE: JANUARY 2011  
PAGE 1 OF 3

PROJECT: **Kahanahou Wastewater Pump Station Upgrade**  
**Preliminary Design Alternatives Report**  
**Alternative No. 3 - New 15HP C/S Submersible Pumps w/ Soft Starters**  
LOCATION: **Kahanahou Wastewater Pump Station**  
ENGINEER: **OKAHARA AND ASSOCIATES, INC.**  
ESTIMATOR: **TYSON T. TOYAMA**

BASIS FOR ESTIMATE: **PRELIMINARY**  
JOB NUMBER: **210-002**  
CHECKED BY: **TYSON T. TOYAMA**

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>CIVIL / MECHANICAL</b>								
1. DEMOLITION	1	LS					7,600.00	<b>7,600.00</b>
2. DRY PIT SUBMERSIBLE PUMPS	3	EA	15,625.50	<b>46,876.50</b>	13,086.00	<b>39,258.00</b>	28,711.50	<b>86,134.50</b>
3. SOFT STARTERS	2	EA	806.61	<b>1,613.22</b>	581.60	<b>1,163.20</b>	1,388.21	<b>2,776.42</b>
4. DRY WELL SUMP PUMP	1	EA	275.88	<b>275.88</b>	116.32	<b>116.32</b>	392.20	<b>392.20</b>
5. 6"x4" DI REDUCER	4	EA	935.20	<b>3,740.80</b>	193.89	<b>775.56</b>	1,129.09	<b>4,516.36</b>
6. 4" DI PIPE	10	FT	20.49	<b>204.90</b>	31.41	<b>314.06</b>	51.90	<b>518.96</b>
7. 6" DI PIPE	120	FT	32.88	<b>3,945.60</b>	48.49	<b>5,818.91</b>	81.37	<b>9,764.51</b>
8. 8" DI PIPE	120	FT	47.95	<b>5,754.00</b>	60.20	<b>7,223.47</b>	108.15	<b>12,977.47</b>
9. 6" DI ELBOW	6	EA	473.45	<b>2,840.70</b>	193.89	<b>1,163.35</b>	667.34	<b>4,004.05</b>
10. 8" DI ELBOW	2	EA	818.30	<b>1,636.60</b>	218.10	<b>436.20</b>	1,036.40	<b>2,072.80</b>
11. 8"x8"x6" DI WYE	2	EA	1,432.03	<b>2,864.06</b>	348.96	<b>697.92</b>	1,780.99	<b>3,561.98</b>
12. 6" GATE VALVE	6	EA	1,011.19	<b>6,067.14</b>	581.60	<b>3,489.60</b>	1,592.79	<b>9,556.74</b>
13. 8" GATE VALVE	2	EA	1,811.95	<b>3,623.90</b>	697.92	<b>1,395.84</b>	2,509.87	<b>5,019.74</b>
14. 6" CHECK VALVE	2	EA	894.29	<b>1,788.58</b>	581.60	<b>1,163.20</b>	1,475.89	<b>2,951.78</b>
15. 6" FLANGED COUPLING ADAPTER	2	EA	157.82	<b>315.64</b>	72.70	<b>145.40</b>	230.52	<b>461.04</b>
16. 4" FLANGES	1	EA	69.79	<b>69.79</b>	232.64	<b>232.64</b>	302.43	<b>302.43</b>
17. 6" FLANGES	12	EA	137.59	<b>1,651.08</b>	348.96	<b>4,187.52</b>	486.55	<b>5,838.60</b>
18. 8" FLANGES	13	EA	252.04	<b>3,276.52</b>	465.28	<b>6,048.64</b>	717.32	<b>9,325.16</b>
19. 4" GASKET & BOLT SET	2	EA	10.52	<b>21.04</b>	72.70	<b>145.40</b>	83.22	<b>166.44</b>
20. 6" GASKET & BOLT SET	12	EA	17.30	<b>207.60</b>	96.91	<b>1,162.91</b>	114.21	<b>1,370.51</b>
21. 8" GASKET & BOLT SET	7	EA	19.82	<b>138.74</b>	116.32	<b>814.24</b>	136.14	<b>952.98</b>
22. PIPE SUPPORTS	1	LS					30,000.00	<b>30,000.00</b>
23. PRESSURE (LEVEL) TRANSDUCERS	1	LS					5,000.00	<b>2,500.00</b>
24. PRESSURE TRANSDUCERS	1	LS					5,000.00	<b>2,500.00</b>
25. NEW PIPE PENETRATIONS	2	LS					5,000.00	<b>10,000.00</b>
26. PATCH PIPE PENETRATIONS	2	LS					2,500.00	<b>5,000.00</b>
27. TEMP SUMP PUMPS (PURCHASE)	2	EA	40,000.00	<b>80,000.00</b>	40,000.00	<b>80,000.00</b>	80,000.00	<b>160,000.00</b>
28. TEMP HDPE PIPING	150	LF	25.00	<b>3,750.00</b>	75.00	<b>11,250.00</b>	100.00	<b>15,000.00</b>

ALT. NO. 3 SUBTOTAL - PAGE 1

395,264.67

ESTC  
MECHANICAL

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM  
DATE: JANUARY 2011  
PAGE 2 OF 3

PROJECT: **Kahanahou Wastewater Pump Station Upgrade**  
**Preliminary Design Alternatives Report**  
**Alternative No. 3 - New 15HP C/S Submersible Pumps w/ Soft Starters**  
LOCATION: **Kahanahou Wastewater Pump Station**  
ENGINEER: **OKAHARA AND ASSOCIATES, INC.**  
ESTIMATOR: **TYSON T. TOYAMA**

BASIS FOR ESTIMATE: **PRELIMINARY**  
JOB NUMBER: **210-002**  
CHECKED BY: **TYSON T. TOYAMA**

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>CIVIL / MECHANICAL CONTINUED</b>								
1. CONCRETE / REBAR	3	CYD	250.00	<b>750.00</b>	1,163.20	<b>3,489.60</b>	1,413.20	<b>4,239.60</b>
2. CONCRETE JACKET 8" SEWER	50	LF					300.00	<b>15,000.00</b>
3. COMBINATION EYE WASH/SHOWER	1	EA	719.00		290.80		1,009.80	<b>1,009.80</b>
4. 1" TYPE L COPPER	60	LF	6.96	<b>417.60</b>	8.58	<b>514.72</b>	15.54	<b>932.32</b>
5. TESTING	1	LS			11,632.00		11,632.00	<b>11,632.00</b>
6. CLEANUP	1	LS			11,632.00		11,632.00	<b>11,632.00</b>
<b>METER VAULT</b>								
1. 8" VENTURI METER	1	EA	4,180.00	<b>4,180.00</b>	1,163.20	<b>1,163.20</b>	5,343.20	<b>5,343.20</b>
2. METER VAULT	1	EA					40,000.00	<b>40,000.00</b>
3. EXCAVATION	30	CYD		<b>0.00</b>	145.40	<b>4,362.00</b>	145.40	<b>4,362.00</b>
4. CRUSHED ROCK BACKFILL	5	CYD	100.00	<b>500.00</b>	72.70	<b>363.50</b>	172.70	<b>863.50</b>
5. BASE COURSE	3	CYD	100.00	<b>300.00</b>	72.70	<b>218.10</b>	172.70	<b>518.10</b>
6. DUPLEX SUMP PUMP	1	EA	1,200.00	<b>1,200.00</b>	581.60	<b>581.60</b>	1,781.60	<b>1,781.60</b>
7. 2" DWV COPPER (INCLUDE TRENCH)	100	LF	14.67	<b>1,467.00</b>	100.00	<b>10,000.00</b>	114.67	<b>11,467.00</b>
8. DEWATERING	10	DAYS	100.00	<b>1,000.00</b>	581.60	<b>5,816.00</b>	681.60	<b>6,816.00</b>
<b>GENSET BUILDING</b>								
1. CMU BUILDING	350	SF					350.00	<b>122,500.00</b>
<b>MODIFY EXISTING GENSET ROOM INTO SCADA ROOM</b>								
1. GENSET ROOM	100	SF					100.00	<b>10,000.00</b>
<b>REFURBISH EXISTING PUMP BUILDING EXTERIOR AND INTERIOR</b>								
1. PUMP STATION	900	SF					50.00	<b>45,000.00</b>
2. WETWELL LINER	1000	SF					40.00	<b>40,000.00</b>

ALT. NO. 3 SUBTOTAL - PAGE 2

333,097.12

ESTC  
MECHANICAL

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM  
DATE: JANUARY 2011  
PAGE 3 OF 3

PROJECT: **Kahanahou Wastewater Pump Station Upgrade**  
**Preliminary Design Alternatives Report**  
**Alternative No. 3 - New 15HP C/S Submersible Pumps w/ Soft Starters**  
LOCATION: **Kahanahou Wastewater Pump Station**  
ENGINEER: **OKAHARA AND ASSOCIATES, INC.**  
ESTIMATOR: **TYSON T. TOYAMA**

BASIS FOR ESTIMATE: **PRELIMINARY**  
  
JOB NUMBER: **201-029**  
CHECKED BY: **TYSON T. TOYAMA**

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>SUBTOTAL - PAGE 1</b>								<b>395,264.67</b>
<b>SUBTOTAL - PAGE 2</b>								<b>333,097.12</b>
<b>HAZARDOUS MATERIAL REMOVAL</b>								
1. ASBESTOS/LEAD	1	LS					20,000.00	<b>20,000.00</b>
2. AIR MONITORING	1	LS					10,000.00	<b>10,000.00</b>
<b>MISCELLANEOUS</b>								
1. NOISE MITIGATION MEASURES	1	LS					10,000.00	<b>10,000.00</b>
2. CONSTRUCTION TRAILER	24	MONTH					2,000.00	<b>48,000.00</b>
<b>MECHANICAL - A/C AND VENTILATION SYSTEM - See Attached</b>								<b>59,400.00</b>
<b>FUEL SYSTEM - See Attached</b>								<b>88,200.00</b>
<b>GENSET EXHAUST SYSTEM - See Attached</b>								<b>22,500.00</b>
<b>ELECTRICAL - See Attached</b>								<b>610,792.00</b>

	SUBTOTAL	<b>1,597,253.79</b>
	MOB/DEMOP/PHASING 25%	<b>399,313.45</b>
	CONTINGENCY 25%	<b>499,141.81</b>
	OVERHEAD & PROFIT 10%	<b>249,570.90</b>
	TAX 4.72%	<b>129,577.21</b>
	ESCALATION (5%/YR FOR 1 YEAR)	<b>143,742.86</b>
	<b>ALT. No. 3 TOTAL</b>	<b>3,018,600.02</b>

ESTC  
MECHANICAL

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM

DATE: JANUARY 2011

PAGE 1 OF 3

PROJECT: Kahanahou Wastewater Pump Station Upgrade

Preliminary Design Alternatives Report

Alternative No. 4 - New 10HP C/S Submersible Pumps w/ Soft Starters

LOCATION: Kahanahou Wastewater Pump Station

ENGINEER: OKAHARA AND ASSOCIATES, INC.

ESTIMATOR: TYSON T. TOYAMA

BASIS FOR ESTIMATE: PRELIMINARY

JOB NUMBER: 210-002

CHECKED BY: TYSON T. TOYAMA

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>CIVIL / MECHANICAL</b>								
1. DEMOLITION	1	LS					7,600.00	<b>7,600.00</b>
2. DRY PIT SUBMERSIBLE PUMPS	3	EA	14,205.00	<b>42,615.00</b>	13,086.00	<b>39,258.00</b>	27,291.00	<b>81,873.00</b>
3. SOFT STARTERS	2	EA	432.53	<b>865.06</b>	387.71	<b>775.42</b>	820.24	<b>1,640.48</b>
4. DRY WELL SUMP PUMP	1	EA	275.88	<b>275.88</b>	116.32	<b>116.32</b>	392.20	<b>392.20</b>
5. 6"x4" DI REDUCER	4	EA	935.20	<b>3,740.80</b>	193.89	<b>775.56</b>	1,129.09	<b>4,516.36</b>
6. 4" DI PIPE	10	FT	20.49	<b>204.90</b>	31.41	<b>314.06</b>	51.90	<b>518.96</b>
7. 6" DI PIPE	120	FT	32.88	<b>3,945.60</b>	48.49	<b>5,818.91</b>	81.37	<b>9,764.51</b>
8. 8" DI PIPE	120	FT	47.95	<b>5,754.00</b>	60.20	<b>7,223.47</b>	108.15	<b>12,977.47</b>
9. 6" DI ELBOW	6	EA	473.45	<b>2,840.70</b>	193.89	<b>1,163.35</b>	667.34	<b>4,004.05</b>
10. 8" DI ELBOW	2	EA	818.30	<b>1,636.60</b>	218.10	<b>436.20</b>	1,036.40	<b>2,072.80</b>
11. 8"x8"x6" DI WYE	2	EA	1,432.03	<b>2,864.06</b>	348.96	<b>697.92</b>	1,780.99	<b>3,561.98</b>
12. 6" GATE VALVE	6	EA	1,011.19	<b>6,067.14</b>	581.60	<b>3,489.60</b>	1,592.79	<b>9,556.74</b>
13. 8" GATE VALVE	2	EA	1,811.95	<b>3,623.90</b>	697.92	<b>1,395.84</b>	2,509.87	<b>5,019.74</b>
14. 6" CHECK VALVE	2	EA	894.29	<b>1,788.58</b>	581.60	<b>1,163.20</b>	1,475.89	<b>2,951.78</b>
15. 6" FLANGED COUPLING ADAPTER	2	EA	157.82	<b>315.64</b>	72.70	<b>145.40</b>	230.52	<b>461.04</b>
16. 4" FLANGES	1	EA	69.79	<b>69.79</b>	232.64	<b>232.64</b>	302.43	<b>302.43</b>
17. 6" FLANGES	12	EA	137.59	<b>1,651.08</b>	348.96	<b>4,187.52</b>	486.55	<b>5,838.60</b>
18. 8" FLANGES	13	EA	252.04	<b>3,276.52</b>	465.28	<b>6,048.64</b>	717.32	<b>9,325.16</b>
19. 4" GASKET & BOLT SET	2	EA	10.52	<b>21.04</b>	72.70	<b>145.40</b>	83.22	<b>166.44</b>
20. 6" GASKET & BOLT SET	12	EA	17.30	<b>207.60</b>	96.91	<b>1,162.91</b>	114.21	<b>1,370.51</b>
21. 8" GASKET & BOLT SET	7	EA	19.82	<b>138.74</b>	116.32	<b>814.24</b>	136.14	<b>952.98</b>
22. PIPE SUPPORTS	1	LS					30,000.00	<b>30,000.00</b>
23. PRESSURE (LEVEL) TRANSDUCERS	1	LS					5,000.00	<b>2,500.00</b>
24. PRESSURE TRANSDUCERS	1	LS					5,000.00	<b>2,500.00</b>
25. NEW PIPE PENETRATIONS	2	LS					5,000.00	<b>10,000.00</b>
26. PATCH PIPE PENETRATIONS	2	LS					2,500.00	<b>5,000.00</b>
27. TEMP SUMP PUMPS (PURCHASE)	2	EA	40,000.00	<b>80,000.00</b>	40,000.00	<b>80,000.00</b>	80,000.00	<b>160,000.00</b>
28. TEMP HDPE PIPING	150	LF	25.00	<b>3,750.00</b>	75.00	<b>11,250.00</b>	100.00	<b>15,000.00</b>

ALT. NO. 4 SUBTOTAL - PAGE 1

389,867.23

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM

DATE: JANUARY 2011

PAGE 2 OF 3

PROJECT: **Kahanahou Wastewater Pump Station Upgrade**

**Preliminary Design Alternatives Report**

**Alternative No. 4 - New 10HP C/S Submersible Pumps w/ Soft Starters**

LOCATION: **Kahanahou Wastewater Pump Station**

ENGINEER: **OKAHARA AND ASSOCIATES, INC.**

ESTIMATOR: **TYSON T. TOYAMA**

BASIS FOR ESTIMATE: **PRELIMINARY**

JOB NUMBER: **210-002**

CHECKED BY: **TYSON T. TOYAMA**

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>CIVIL / MECHANICAL CONTINUED</b>								
1. CONCRETE / REBAR	3	CYD	250.00	<b>750.00</b>	1,163.20	<b>3,489.60</b>	1,413.20	<b>4,239.60</b>
2. CONCRETE JACKET 8" SEWER	50	LF					300.00	<b>15,000.00</b>
3. COMBINATION EYE WASH/SHOWER	1	EA	719.00		290.80		1,009.80	<b>1,009.80</b>
4. 1" TYPE L COPPER	60	LF	6.96	<b>417.60</b>	8.58	<b>514.72</b>	15.54	<b>932.32</b>
5. TESTING	1	LS			11,632.00		11,632.00	<b>11,632.00</b>
6. CLEANUP	1	LS			11,632.00		11,632.00	<b>11,632.00</b>
<b>METER VAULT</b>								
1. 8" VENTURI METER	1	EA	4,180.00	<b>4,180.00</b>	1,163.20	<b>1,163.20</b>	5,343.20	<b>5,343.20</b>
2. METER VAULT	1	EA					40,000.00	<b>40,000.00</b>
3. EXCAVATION	30	CYD		<b>0.00</b>	145.40	<b>4,362.00</b>	145.40	<b>4,362.00</b>
4. CRUSHED ROCK BACKFILL	5	CYD	100.00	<b>500.00</b>	72.70	<b>363.50</b>	172.70	<b>863.50</b>
5. BASE COURSE	3	CYD	100.00	<b>300.00</b>	72.70	<b>218.10</b>	172.70	<b>518.10</b>
6. DUPLEX SUMP PUMP	1	EA	1,200.00	<b>1,200.00</b>	581.60	<b>581.60</b>	1,781.60	<b>1,781.60</b>
7. 2" DWV COPPER (INCLUDE TRENCH)	100	LF	14.67	<b>1,467.00</b>	100.00	<b>10,000.00</b>	114.67	<b>11,467.00</b>
8. DEWATERING	10	DAYS	100.00	<b>1,000.00</b>	581.60	<b>5,816.00</b>	681.60	<b>6,816.00</b>
<b>GENSET BUILDING</b>								
1. CMU BUILDING	350	SF					350.00	<b>122,500.00</b>
<b>MODIFY EXISTING GENSET ROOM INTO SCADA ROOM</b>								
1. GENSET ROOM	100	SF					100.00	<b>10,000.00</b>
<b>REFURBISH EXISTING PUMP BUILDING EXTERIOR AND INTERIOR</b>								
1. PUMP STATION	900	SF					50.00	<b>45,000.00</b>
2. WETWELL LINER	1000	SF					40.00	<b>40,000.00</b>



ESTC  
MECHANICAL

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM  
DATE: JANUARY 2011  
PAGE 3 OF 3

PROJECT: **Kahanahou Wastewater Pump Station Upgrade**  
**Preliminary Design Alternatives Report**  
**Alternative No. 4 - New 10HP C/S Submersible Pumps w/ Soft Starters**  
LOCATION: **Kahanahou Wastewater Pump Station**  
ENGINEER: **OKAHARA AND ASSOCIATES, INC.**  
ESTIMATOR: **TYSON T. TOYAMA**

BASIS FOR ESTIMATE: **PRELIMINARY**  
JOB NUMBER: **201-029**  
CHECKED BY: **TYSON T. TOYAMA**

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>SUBTOTAL - PAGE 1</b>								<b>389,867.23</b>
<b>SUBTOTAL - PAGE 2</b>								<b>333,097.12</b>
<b>HAZARDOUS MATERIAL REMOVAL</b>								
1. ASBESTOS/LEAD	1	LS					20,000.00	<b>20,000.00</b>
2. AIR MONITORING	1	LS					10,000.00	<b>10,000.00</b>
<b>MISCELLANEOUS</b>								
1. NOISE MITIGATION MEASURES	1	LS					10,000.00	<b>10,000.00</b>
2. CONSTRUCTION TRAILER	24	MONTH					2,000.00	<b>48,000.00</b>
<b>MECHANICAL - A/C AND VENTILATION SYSTEM - See Attached</b>								<b>59,400.00</b>
<b>FUEL SYSTEM - See Attached</b>								<b>88,200.00</b>
<b>GENSET EXHAUST SYSTEM - See Attached</b>								<b>22,500.00</b>
<b>ELECTRICAL - See Attached</b>								<b>584,614.00</b>

	SUBTOTAL	<b>1,565,678.35</b>
	MOB/DEMOB/PHASING 25%	<b>391,419.59</b>
	CONTINGENCY 25%	<b>489,274.48</b>
	OVERHEAD & PROFIT 10%	<b>244,637.24</b>
	TAX 4.72%	<b>127,015.66</b>
	ESCALATION (5%/YR FOR 1 YEAR)	<b>140,901.27</b>
	<b>ALT. No. 3 TOTAL</b>	<b>2,958,926.58</b>

ESTC  
MECHANICAL

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM  
DATE: JANUARY 2011  
PAGE 1 OF 1

PROJECT: **Kahanahou Wastewater Pump Station Upgrade**

**Preliminary Design Alternatives Report**

**Standby Engine Generator Fuel System**

LOCATION: **Kahanahou Wastewater Pump Station**

ENGINEER: **OKAHARA AND ASSOCIATES, INC.**

ESTIMATOR: **TYSON T. TOYAMA**

BASIS FOR ESTIMATE: **PRELIMINARY**

JOB NUMBER: **210-002**

CHECKED BY: **TYSON T. TOYAMA**

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>MECHANICAL</b>								
1. DEMOLITION	1	LS					5,100.00	<b>5,100.00</b>
2. 1000 GALLON UST	1	EA	10,603.00	<b>10,603.00</b>	714.07	<b>714.07</b>	11,317.07	<b>11,317.07</b>
3. EXCAVATION	8	CYD		<b>0.00</b>	145.40	<b>1,163.20</b>	145.40	<b>1,163.20</b>
4. BACKFILL (PEA GRAVEL)	8	CYD	150.00	<b>1,200.00</b>	72.70	<b>581.60</b>	222.70	<b>1,781.60</b>
5. CONCRETE / REBARS	4	CYD	250.00	<b>1,000.00</b>	581.60	<b>2,326.40</b>	831.60	<b>3,326.40</b>
6. 1" STAINLESS STEEL PIPE	60	LF	23.09	<b>1,385.40</b>	30.53	<b>1,832.04</b>	53.62	<b>3,217.44</b>
7. 2" FRP CONTAINMENT PIPE	80	LF	11.22	<b>897.60</b>	21.52	<b>1,721.54</b>	32.74	<b>2,619.14</b>
8. 3" FRP CONTAINMENT PIPE	40	LF	13.27	<b>530.80</b>	22.39	<b>895.66</b>	35.66	<b>1,426.46</b>
9. 1" SST SHUTOFF VALVE	10	EA	631.26	<b>6,312.60</b>	41.51	<b>415.12</b>	672.77	<b>6,727.72</b>
10. 50 GALLON DAY TANK	1	EA	7,500.00	<b>7,500.00</b>	3,750.00	<b>3,750.00</b>	11,250.00	<b>11,250.00</b>
11. TANK MONITOR CONTROL PANEL	1	EA	6,000.00	<b>6,000.00</b>	3,000.00	<b>3,000.00</b>	9,000.00	<b>9,000.00</b>
12. INVENTORY PROBE	1	EA	1,750.00	<b>1,750.00</b>	875.00	<b>875.00</b>	2,625.00	<b>2,625.00</b>
13. LIQUID LEAK SENSOR	2	EA	500.00	<b>1,000.00</b>	250.00	<b>500.00</b>	750.00	<b>1,500.00</b>
14. OIL/FUEL FILTER	1	EA	500.00	<b>500.00</b>	290.80	<b>290.80</b>	790.80	<b>790.80</b>
15. FUEL HANDLING & POLISHING	1	EA	4,000.00	<b>4,000.00</b>	2,000.00	<b>2,000.00</b>	6,000.00	<b>6,000.00</b>
16. CONDUIT AND WIRING	1	LS					1,500.00	<b>1,500.00</b>
17. TESTING AND STARTUP	1	EA			2,908.00	<b>2,908.00</b>	2,908.00	<b>2,908.00</b>
18. CLEAN UP	1	EA			2,908.00	<b>2,908.00</b>	2,908.00	<b>2,908.00</b>
19. TEMPORARY FUEL SYSTEM	1	LS	6,000.00	<b>6,000.00</b>	2,000.00	<b>2,000.00</b>	8,000.00	<b>8,000.00</b>
20. TEMPORARY CONTROLS	1	LS			5,000.00	<b>5,000.00</b>	5,000.00	<b>5,000.00</b>

**GENERATOR FUEL SYSTEM SUBTOTAL**

**88,160.82**

ESTC  
MECHANICAL

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM  
DATE: JANUARY 2011  
PAGE 1 OF 1

PROJECT: **Kahanahou Wastewater Pump Station Upgrade**  
**Standby Engine Generator Exhaust System**

BASIS FOR ESTIMATE: PRELIMINARY

LOCATION: **Kahanahou Wastewater Pump Station**

ENGINEER: **OKAHARA AND ASSOCIATES, INC.**

JOB NUMBER: 210-002

ESTIMATOR: TYSON T. TOYAMA

CHECKED BY: TYSON T. TOYAMA

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>STANDBY ENGINE GENERATOR EXHAUST SYSTEM</b>								
1. DEMOLITION	1	LS					2,000.00	<b>2,000.00</b>
2. FLEXIBLE CONNECTION	1	EA	1,000.00	<b>1,000.00</b>	290.80	<b>290.80</b>	1,290.80	<b>1,290.80</b>
3. WALL THIMBLE	1	EA	2,500.00	<b>2,500.00</b>	581.60	<b>581.60</b>	3,081.60	<b>3,081.60</b>
4. SILENCER	3	EA	2,500.00	<b>7,500.00</b>	581.60	<b>1,744.80</b>	3,081.60	<b>9,244.80</b>
5. 5" SST EXHAUST PIPE	30	LF	106.76	<b>3,202.80</b>	36.35	<b>1,090.50</b>	143.11	<b>4,293.30</b>
6. 5" INSULATION AND JACKETING	30	LF	25.72	<b>771.60</b>	21.30	<b>639.03</b>	47.02	<b>1,410.63</b>
7. CLEAN UP	1	EA			1,163.20	<b>1,163.20</b>	1,163.20	<b>1,163.20</b>

**ENGINE GENERATOR EXHAUST SYSTEM SUBTOTAL 22,484.33**

ESTC  
MECHANICAL

**CONSTRUCTION COST ESTIMATE**

OKAHARA STANDARD FORM

DATE: JANUARY 2011

PAGE 1 OF 1

PROJECT: **Kahanahou Wastewater Pump Station Upgrade**  
**Air Conditioning and Ventilation System**

BASIS FOR ESTIMATE: PRELIMINARY

LOCATION: **Kahanahou Wastewater Pump Station**

ENGINEER: **OKAHARA AND ASSOCIATES, INC.**

ESTIMATOR: **TYSON T. TOYAMA**

JOB NUMBER: 210-002

CHECKED BY: **TYSON T. TOYAMA**

DESCRIPTION	QUANTITY		MATERIAL COST		LABOR COST		ENGINEER ESTIMATE	
	no. of units	unit	unit cost	cost	unit cost	cost	unit cost	total cost
HOURLY RATE: \$72.70/HR								
<b>MECHANICAL - A/C AND VENTILATION</b>								
1. DEMOLITION	1	LS					1,250.00	<b>1,250.00</b>
2. DUCTLESS SPLIT SYSTEM	2	EA	2,279.55	<b>4,559.10</b>	796.21	<b>1,592.42</b>	3,075.76	<b>6,151.52</b>
3. SUPPLY FAN W/ FILTERS	1	EA	1,432.03	<b>1,432.03</b>	727.00	<b>727.00</b>	2,159.03	<b>2,159.03</b>
4. EXHAUST FAN	1	EA	1,432.03	<b>1,432.03</b>	727.00	<b>727.00</b>	2,159.03	<b>2,159.03</b>
5. DUCT SILENCERS (GEN. INLET)	4	EA	2,308.78	<b>9,235.12</b>	290.80	<b>1,163.20</b>	2,599.58	<b>10,398.32</b>
6. DUCT SILENCERS (GEN. OUTLET)	4	EA	2,308.78	<b>9,235.12</b>	290.80	<b>1,163.20</b>	2,599.58	<b>10,398.32</b>
7. DUCTWORK (SST)	500	LBS	4.70	<b>2,350.00</b>	13.38	<b>6,688.40</b>	18.08	<b>9,038.40</b>
8. DUCT LINER (2-INCH, 3 PCF)	250	SF	1.38	<b>345.00</b>	9.67	<b>2,417.28</b>	11.05	<b>2,762.28</b>
9. DUCT INSULATION (2-IN, 3 PCF)	50	SF	0.33	<b>16.50</b>	3.85	<b>192.66</b>	4.18	<b>209.16</b>
10. DAMPERS (16x12)	2	EA	38.00	<b>76.00</b>	34.24	<b>68.48</b>	72.24	<b>144.48</b>
11. SUPPLY AIR REGISTERS (6x18)	3	EA	96.44	<b>289.32</b>	32.28	<b>96.84</b>	128.72	<b>386.16</b>
12. EXHAUST REGISTERS (16x16)	2	EA	59.03	<b>118.06</b>	34.24	<b>68.48</b>	93.27	<b>186.54</b>
13. FAN SUPPORTS	2	EA					250.00	<b>500.00</b>
14. THERMOSTAT	2	EA	175.47	<b>350.94</b>	72.70	<b>145.40</b>	248.17	<b>496.34</b>
15. 1-1/8" DWV COPPER	40	LF	8.05	<b>322.00</b>	10.83	<b>433.29</b>	18.88	<b>755.29</b>
16. 3/8" INSULATION AND JACKET.	80	LF	2.38	<b>190.40</b>	9.81	<b>785.16</b>	12.19	<b>975.56</b>
17. 1-1/8" INSULATION	40	LF	2.95	<b>118.00</b>	5.96	<b>238.46</b>	8.91	<b>356.46</b>
18. 3-3/8" INSULATION JACKET	40	LF	1.66	<b>66.40</b>	7.42	<b>296.62</b>	9.08	<b>363.02</b>
19. CURRENT SWITCH	4	EA					500.00	<b>2,000.00</b>
20. TEMPERATURE SENSOR	1	EA					500.00	<b>500.00</b>
21. AIR BALANCING	1	LS					1,715.00	<b>1,715.00</b>
22. TESTING AND STARTUP	1	LS			1,163.20	<b>1,163.20</b>	1,163.20	<b>1,163.20</b>
23. CLEANUP	1	LS			1,163.20	<b>1,163.20</b>	1,163.20	<b>1,163.20</b>
24. MAINTENANCE	1	YR			4,071.20	<b>4,071.20</b>	4,071.20	<b>4,071.20</b>

**A/C AND VENTILATION SYSTEM SUBTOTAL**

**59,302.50**



# COST ESTIMATE

SHEET **2**  
OF 10

PROJECT: KAHANAHOU WASTEWATER PUMP STATION  
PRELIMINARY DESIGN ALTERNATIVES REPORT  
LOCATION: KANEOHE, OAHU, HAWAII

DATE: JANUARY 5, 2011  
DESIGN STATUS:  
RONALD N.S. HO & ASSOC. (BO)

DESCRIPTION	NO	UNIT	MATERIAL COST		LABOR COST		LINE TOTAL
			UNIT	TOTAL	UNIT	TOTAL	
<u>ALTERNATIVE NO. 2</u>							
<u>Demolition Work</u>							
Remove MCC	1	EA	0	0	1,000	1,000	1,000
Remove emergency generator	1	EA	0	0	1,500	1,500	1,500
Remove SCADA cabinet	1	EA	0	0	500	500	500
Disconnect station pump	2	EA	0	0	60	120	120
Disconnect exhaust fan	1	EA	0	0	45	45	45
Disconnect sump pump	1	EA	0	0	45	45	45
Remove meter socket	1	EA	0	0	150	150	150
Remove battery charger	1	EA	0	0	60	60	60
Remove electric service conductors	1	LS	0	0	2,000	2,000	2,000
Remove emergent generator feeder	1	LS	0	0	500	500	500
Miscellaneous	1	LS	500	500	3,000	3,000	3,500
Subtotal Demolition Work				500		8,920	9,420
<u>Temporary Electrical Work</u>							
Temporary MCC	1	EA	75,000	75,000	3,000	3,000	78,000
Temporary emergency generator	1	EA	80,000	80,000	0	0	80,000
Temporary electrical feeders	500	LF	5	2,500	30	15,000	17,500
Miscellaneous	1	LS	2,500	2,500	2,500	2,500	5,000
Subtotal Temporary Electrical Work				160,000		20,500	180,500

# COST ESTIMATE

SHEET **3**  
OF 10

PROJECT: KAHANAHOU WASTEWATER PUMP STATION  
PRELIMINARY DESIGN ALTERNATIVES REPORT  
LOCATION: KANEOHE, OAHU, HAWAII

DATE: JANUARY 5, 2011  
DESIGN STATUS:  
RONALD N.S. HO & ASSOC. (BO)

DESCRIPTION	NO	UNIT	MATERIAL COST		LABOR COST		LINE TOTAL
			UNIT	TOTAL	UNIT	TOTAL	
<u>ALTERNATIVE NO. 2</u>							
<u>New Electrical Work</u>							
MCC, 225A	1	EA	100,000	100,000	3,000	3,000	103,000
Emergency generator, 100kW	1	EA	60,000	60,000	4,000	4,000	64,000
SCADA cabinet	1	EA	20,000	20,000	40,000	40,000	60,000
Automatic transfer switch	1	EA	25,000	25,000	2,500	2,500	27,500
Meter socket, NEMA 3R SS	1	EA	4,000	4,000	360	360	4,360
Panelboard	1	EA	1,000	1,000	480	480	1,480
Electrical equipment connection	5	EA	20	100	60	300	400
Disconnect switch, 3P30A	2	EA	240	480	90	180	660
Duplex receptacle, 20A	5	EA	15	75	50	250	325
Smoke detector	1	EA	150	150	75	75	225
Door security device	1	EA	250	250	75	75	325
Junction box, 18"sq, NEMA 4X SS	2	EA	1,500	3,000	225	450	3,450
Underground electric service wiring	150	LF	20	3,000	50	7,500	10,500
Branch circuit wiring	700	LF	5	3,500	10	7,000	10,500
Miscellaneous	1	LS	5,000	5,000	5,000	5,000	10,000
Subtotal New Electrical Work				225,555		71,170	296,725
Subtotal							486,645
Overhead & Profit	25%						121,661
Taxes	4.712%						28,663
<b>Total Alternative No. 2</b>							<b>\$ 636,970</b>

# COST ESTIMATE

SHEET **4**  
OF 10

PROJECT: KAHANAHOU WASTEWATER PUMP STATION  
PRELIMINARY DESIGN ALTERNATIVES REPORT  
LOCATION: KANEOHE, OAHU, HAWAII

DATE: JANUARY 5, 2011  
DESIGN STATUS:  
RONALD N.S. HO & ASSOC. (BO)

DESCRIPTION	NO	UNIT	MATERIAL COST		LABOR COST		LINE TOTAL
			UNIT	TOTAL	UNIT	TOTAL	
<u>ALTERNATIVE NO. 3</u>							
<u>Demolition Work</u>							
Remove MCC	1	EA	0	0	1,000	1,000	1,000
Remove emergency generator	1	EA	0	0	1,500	1,500	1,500
Remove SCADA cabinet	1	EA	0	0	500	500	500
Disconnect station pump	2	EA	0	0	60	120	120
Disconnect exhaust fan	1	EA	0	0	45	45	45
Disconnect sump pump	1	EA	0	0	45	45	45
Remove meter socket	1	EA	0	0	150	150	150
Remove battery charger	1	EA	0	0	60	60	60
Remove electric service conductors	1	LS	0	0	2,000	2,000	2,000
Remove emergent generator feeder	1	LS	0	0	500	500	500
Miscellaneous	1	LS	500	500	3,000	3,000	3,500
Subtotal Demolition Work				500		8,920	9,420
<u>Temporary Electrical Work</u>							
Temporary MCC	1	EA	75,000	75,000	3,000	3,000	78,000
Temporary emergency generator	1	EA	80,000	80,000	0	0	80,000
Temporary electrical feeders	500	LF	5	2,500	30	15,000	17,500
Miscellaneous	1	LS	2,500	2,500	2,500	2,500	5,000
Subtotal Temporary Electrical Work				160,000		20,500	180,500



# COST ESTIMATE

SHEET **5**  
OF 10

PROJECT: KAHANAHOU WASTEWATER PUMP STATION  
PRELIMINARY DESIGN ALTERNATIVES REPORT

DATE: JANUARY 5, 2011

DESIGN STATUS:

LOCATION: KANEOHE, OAHU, HAWAII

RONALD N.S. HO & ASSOC. (BO)

DESCRIPTION	NO	UNIT	MATERIAL COST		LABOR COST		LINE TOTAL
			UNIT	TOTAL	UNIT	TOTAL	
<u>ALTERNATIVE NO. 3</u>							
<u>New Electrical Work</u>							
MCC, 225A	1	EA	100,000	100,000	3,000	3,000	103,000
Emergency generator, 60kW	1	EA	40,000	40,000	4,000	4,000	44,000
SCADA cabinet	1	EA	20,000	20,000	40,000	40,000	60,000
Automatic transfer switch	1	EA	25,000	25,000	2,500	2,500	27,500
Meter socket, NEMA 3R SS	1	EA	4,000	4,000	360	360	4,360
Panelboard	1	EA	1,000	1,000	480	480	1,480
Electrical equipment connection	5	EA	20	100	60	300	400
Disconnect switch, 3P30A	2	EA	240	480	90	180	660
Duplex receptacle, 20A	5	EA	15	75	50	250	325
Smoke detector	1	EA	150	150	75	75	225
Door security device	1	EA	250	250	75	75	325
Junction box, 18"sq, NEMA 4X SS	2	EA	1,500	3,000	225	450	3,450
Underground electric service wiring	150	LF	20	3,000	50	7,500	10,500
Branch circuit wiring	700	LF	5	3,500	10	7,000	10,500
Miscellaneous	1	LS	5,000	5,000	5,000	5,000	10,000
Subtotal New Electrical Work				205,555		71,170	276,725
Subtotal							466,645
Overhead & Profit	25%						116,661
Taxes	4.712%						27,485
<b>Total Alternative No. 3</b>							<b>\$ 610,792</b>

# COST ESTIMATE

SHEET **6**  
OF 10

PROJECT: KAHANAHOU WASTEWATER PUMP STATION PRELIMINARY DESIGN ALTERNATIVES REPORT	DATE: JANUARY 5, 2011
LOCATION: KANEOHE, OAHU, HAWAII	DESIGN STATUS: RONALD N.S. HO & ASSOC. (BO)

DESCRIPTION	NO	UNIT	MATERIAL COST		LABOR COST		LINE TOTAL
			UNIT	TOTAL	UNIT	TOTAL	
<u>ALTERNATIVE NO. 4</u>							
<u>Demolition Work</u>							
Remove MCC	1	EA	0	0	1,000	1,000	1,000
Remove emergency generator	1	EA	0	0	1,500	1,500	1,500
Remove SCADA cabinet	1	EA	0	0	500	500	500
Disconnect station pump	2	EA	0	0	60	120	120
Disconnect exhaust fan	1	EA	0	0	45	45	45
Disconnect sump pump	1	EA	0	0	45	45	45
Remove meter socket	1	EA	0	0	150	150	150
Remove battery charger	1	EA	0	0	60	60	60
Remove electric service conductors	1	LS	0	0	2,000	2,000	2,000
Remove emergent generator feeder	1	LS	0	0	500	500	500
Miscellaneous	1	LS	500	500	3,000	3,000	3,500
Subtotal Demolition Work				500		8,920	9,420
<u>Temporary Electrical Work</u>							
Temporary MCC	1	EA	75,000	75,000	3,000	3,000	78,000
Temporary emergency generator	1	EA	80,000	80,000	0	0	80,000
Temporary electrical feeders	500	LF	5	2,500	30	15,000	17,500
Miscellaneous	1	LS	2,500	2,500	2,500	2,500	5,000
Subtotal Temporary Electrical Work				160,000		20,500	180,500

# COST ESTIMATE

SHEET **7**  
OF 10

PROJECT: KAHANAHOU WASTEWATER PUMP STATION  
PRELIMINARY DESIGN ALTERNATIVES REPORT

DATE: JANUARY 5, 2011

DESIGN STATUS:

LOCATION: KANEOHE, OAHU, HAWAII

RONALD N.S. HO & ASSOC. (BO)

DESCRIPTION	NO	UNIT	MATERIAL COST		LABOR COST		LINE TOTAL
			UNIT	TOTAL	UNIT	TOTAL	
<u>ALTERNATIVE NO. 4</u>							
<u>New Electrical Work</u>							
MCC, 225A	1	EA	80,000	80,000	3,000	3,000	83,000
Emergency generator, 60kW	1	EA	40,000	40,000	4,000	4,000	44,000
SCADA cabinet	1	EA	20,000	20,000	40,000	40,000	60,000
Automatic transfer switch	1	EA	25,000	25,000	2,500	2,500	27,500
Meter socket, NEMA 3R SS	1	EA	4,000	4,000	360	360	4,360
Panelboard	1	EA	1,000	1,000	480	480	1,480
Electrical equipment connection	5	EA	20	100	60	300	400
Disconnect switch, 3P30A	2	EA	240	480	90	180	660
Duplex receptacle, 20A	5	EA	15	75	50	250	325
Smoke detector	1	EA	150	150	75	75	225
Door security device	1	EA	250	250	75	75	325
Junction box, 18"sq, NEMA 4X SS	2	EA	1,500	3,000	225	450	3,450
Underground electric service wiring	150	LF	20	3,000	50	7,500	10,500
Branch circuit wiring	700	LF	5	3,500	10	7,000	10,500
Miscellaneous	1	LS	5,000	5,000	5,000	5,000	10,000
Subtotal New Electrical Work				185,555		71,170	256,725
Subtotal							446,645
Overhead & Profit	25%						111,661
Taxes	4.712%						26,307
<b>Total Alternative No. 4</b>							<b>\$ 584,614</b>



# COST ESTIMATE

SHEET **9**  
OF 10

PROJECT: KAHANAHOU WASTEWATER PUMP STATION  
PRELIMINARY DESIGN ALTERNATIVES REPORT

DATE: JANUARY 5, 2011

DESIGN STATUS:

LOCATION: KANEOHE, OAHU, HAWAII

RONALD N.S. HO & ASSOC. (BO)

DESCRIPTION	NO	UNIT	MATERIAL COST		LABOR COST		LINE TOTAL
			UNIT	TOTAL	UNIT	TOTAL	
<u>ALTERNATIVE OPTION -</u>							
<u>UPGRADE ELECTRIC SERVICE</u>							
<u>New Electrical Work</u>							
Electric Service Feeder	150	LF	25	3,750	50	7,500	11,250
Reduction of MCC cost	1	EA	-30,000	-30,000	0	0	-30,000
Reduction of generator cost	1	EA	-5,000	-5,000	0	0	-5,000
Miscellaneous	1	LS	1,000	1,000	3,000	3,000	4,000
Subtotal							-19,750
Overhead & Profit	25%						-4,938
Taxes	4.172%						-1,030
HECO Service Charges							200,000
<b>Total Alternative Option - Upgrade Electric Service</b>							<b>\$ 174,283</b>



**APPENDIX J  
PRESENT WORTH COST ANALYSIS**

Alternative No. 1 .....J-2  
Alternative No. 2 .....J-4  
Alternative No. 3 .....J-5  
Alternative No. 4 .....J-6

**TABLE J-1 KAHANAHOU WWPS  
ALTERNATIVE NO. 1: NO ACTION  
PRESENT WORTH COST ANALYSIS**

PAGE (1 OF 2)

YEAR	COST ITEM DESCRIPTION <sup>1</sup>	COST (\$)	TOTAL DISCOUNT (%) <sup>2</sup>	PRESENT WORTH COST (\$)
0	Pump Replacement Costs <sup>3</sup>	\$100,800	0	\$100,800
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	0	\$6,185
1	Preventive Maintenance <sup>5</sup>	\$3,350	5	\$3,190
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	5	\$5,890
2	Preventive Maintenance <sup>5</sup>	\$3,350	10.3	\$3,037
	Impeller and Mechanical Seal Replacement <sup>6</sup>	\$25,660	10.3	\$23,264
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	10.3	\$5,607
3	Preventive Maintenance <sup>5</sup>	\$3,350	15.8	\$2,893
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	15.8	\$5,341
4	Preventive Maintenance <sup>5</sup>	\$3,350	21.6	\$2,755
	Impeller and Mechanical Seal Replacement <sup>6</sup>	\$25,660	21.6	\$21,102
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	21.6	\$5,086
5	Preventive Maintenance <sup>5</sup>	\$3,350	27.6	\$2,625
	Motor Rewinding <sup>7</sup>	\$10,600	27.6	\$8,307
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	27.6	\$4,847
6	Preventive Maintenance <sup>5</sup>	\$3,350	34	\$2,500
	Impeller and Mechanical Seal Replacement <sup>6</sup>	\$25,660	34	\$19,149
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	34	\$4,616
7	Preventive Maintenance <sup>5</sup>	\$3,350	40.7	\$2,381
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	40.7	\$4,396
8	Preventive Maintenance <sup>5</sup>	\$3,350	47.7	\$2,268
	Impeller and Mechanical Seal Replacement <sup>6</sup>	\$25,660	47.7	\$17,373
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	47.7	\$4,188
9	Preventive Maintenance <sup>5</sup>	\$3,350	55.1	\$2,160
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	55.1	\$3,988
10	Pump Replacement Costs <sup>3</sup>	\$100,800	62.9	\$61,878
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	62.9	\$3,797
11	Preventive Maintenance <sup>5</sup>	\$3,350	71	\$1,959
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	71	\$3,617
12	Preventive Maintenance <sup>5</sup>	\$3,350	79.6	\$1,865
	Impeller and Mechanical Seal Replacement <sup>6</sup>	\$25,660	79.6	\$14,287
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	79.6	\$3,444
13	Preventive Maintenance <sup>5</sup>	\$3,350	88.6	\$1,776
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	88.6	\$3,279
14	Preventive Maintenance <sup>5</sup>	\$3,350	98	\$1,692
	Impeller and Mechanical Seal Replacement <sup>6</sup>	\$25,660	98	\$12,960
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	98	\$3,124
15	Preventive Maintenance <sup>5</sup>	\$3,350	107.9	\$1,611
	Motor Rewinding <sup>7</sup>	\$10,600	107.9	\$5,099
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	107.9	\$2,975



**TABLE J-1 KAHANAHOU WWPS  
ALTERNATIVE NO. 1: NO ACTION  
PRESENT WORTH COST ANALYSIS**

PAGE (2 OF 2)

YEAR	COST ITEM DESCRIPTION <sup>1</sup>	COST (\$)	TOTAL DISCOUNT (%) <sup>2</sup>	PRESENT WORTH COST (\$)
16	Preventive Maintenance <sup>5</sup>	\$3,350	118.3	\$1,535
	Impeller and Mechanical Seal Replacement <sup>6</sup>	\$25,660	118.3	\$11,754
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	118.3	\$2,833
17	Preventive Maintenance <sup>5</sup>	\$3,350	129.2	\$1,462
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	129.2	\$2,699
18	Preventive Maintenance <sup>5</sup>	\$3,350	140.7	\$1,392
	Impeller and Mechanical Seal Replacement <sup>6</sup>	\$25,660	140.7	\$10,661
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	140.7	\$2,570
19	Preventive Maintenance <sup>5</sup>	\$3,350	152.7	\$1,326
	Pump Energy Consumption Costs <sup>4</sup>	\$6,185	152.7	\$2,448
<b>ALTERNATIVE NO. 1 TOTAL 20 YEAR PRESENT WORTH COST</b>				<b>\$425,991</b>

<sup>1</sup>Design costs were excluded from analysis. Fuel system maintenance costs were assumed to be similar for all of the alternatives and weren't included in the analysis.

<sup>2</sup>Discount rate of 5% per year used.

<sup>3</sup>Pump replacement costs based on \$28,000 replacement cost per pump, 25% mob/demob, 25% contingency, 10% profit, and 4.72% GE tax.

<sup>4</sup>Annual WWPS energy consumption based on 2009 energy consumption of 26,421 kwh, and an electricity rate of \$0.234 per kwh consumed.

<sup>5</sup>Preventive Maintenance based on 16 man hours of effort per pump, \$72.7 hourly rate, 25% mob/demob, 10% profit, and 4.72% GE tax.

<sup>6</sup>Impeller and Mechanical Seal Replacement includes a material cost of \$6,000 per pump, 40 man hours of effort per pump, \$72.7 hourly rate, 25% mob/demob, 10% profit, and 4.72% GE tax.

<sup>7</sup>Motor rewinding costs based on \$1,500 rewinding cost per pump, 30 man hours of effort per pump, \$72.7 hourly rate, 25% mob/demob, 10% profit, and 4.72% GE tax.

**TABLE J-4 KAHANAHOU WWPS  
ALTERNATIVE NO. 2: NEW C/S DRY PIT SUBMERSIBLE PUMPS W/ VFD  
PRESENT WORTH COST ANALYSIS**

PAGE (1 OF 1)

YEAR	COST ITEM DESCRIPTION <sup>1</sup>	COST (\$)	TOTAL DISCOUNT (%) <sup>2</sup>	PRESENT WORTH COST (\$)
0	Pump Replacement Costs <sup>3</sup>	\$3,076,000	0	\$3,076,000
	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	0	\$7,110
1	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	5	\$6,771
2	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	10.3	\$6,446
3	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	15.8	\$6,140
4	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	21.6	\$5,847
5	Pump Replacement Costs <sup>5</sup>	\$103,350	27.6	\$80,995
	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	27.6	\$5,572
6	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	34	\$5,306
7	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	40.7	\$5,053
8	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	47.7	\$4,814
9	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	55.1	\$4,584
10	Pump Replacement Costs <sup>5</sup>	\$103,350	62.9	\$63,444
	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	62.9	\$4,365
11	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	71	\$4,158
12	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	79.6	\$3,959
13	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	88.6	\$3,770
14	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	98	\$3,591
15	Pump Replacement Costs <sup>5</sup>	\$103,350	107.9	\$49,711
	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	107.9	\$3,420
16	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	118.3	\$3,257
17	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	129.2	\$3,102
18	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	140.7	\$2,954
19	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	152.7	\$2,814
<b>ALTERNATIVE NO. 2 TOTAL 20 YEAR PRESENT WORTH COST</b>				<b>\$3,363,183</b>

<sup>1</sup>Design costs were excluded from analysis. Fuel system maintenance costs were assumed to be similar for all of the alternatives and weren't included in the analysis. Assumed no preventative maintenance required for submersible pumps.

<sup>2</sup>Discount rate of 5% per year used.

<sup>3</sup>Pump replacement costs based on cost estimate.

<sup>4</sup>Annual WWPS energy consumption based on 2009 energy consumption of 26,421 kwh, an electricity rate of \$0.234 per kwh consumed, and an increase of TDH from 45 feet to 46.5 feet.

<sup>5</sup>Pump replacement costs based on \$28,710 replacement cost per pump, 25% mob/demob, 25% contingency, 10% profit, and 4.72% GE tax.

**TABLE J-4 KAHANAHOU WWPS  
ALTERNATIVE NO. 3: NEW C/S DRY PIT SUB. PUMPS W/ SOFT STARTERS  
PRESENT WORTH COST ANALYSIS**

PAGE (1 OF 1)

YEAR	COST ITEM DESCRIPTION <sup>1</sup>	COST (\$)	TOTAL DISCOUNT (%) <sup>2</sup>	PRESENT WORTH COST (\$)
0	Pump Replacement Costs <sup>3</sup>	\$3,019,000	0	\$3,019,000
	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	0	\$7,110
1	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	5	\$6,771
2	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	10.3	\$6,446
3	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	15.8	\$6,140
4	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	21.6	\$5,847
5	Pump Replacement Costs <sup>5</sup>	\$103,350	27.6	\$80,995
	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	27.6	\$5,572
6	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	34	\$5,306
7	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	40.7	\$5,053
8	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	47.7	\$4,814
9	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	55.1	\$4,584
10	Pump Replacement Costs <sup>5</sup>	\$103,350	62.9	\$63,444
	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	62.9	\$4,365
11	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	71	\$4,158
12	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	79.6	\$3,959
13	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	88.6	\$3,770
14	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	98	\$3,591
15	Pump Replacement Costs <sup>5</sup>	\$103,350	107.9	\$49,711
	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	107.9	\$3,420
16	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	118.3	\$3,257
17	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	129.2	\$3,102
18	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	140.7	\$2,954
19	Pump Energy Consumption Costs <sup>4</sup>	\$7,110	152.7	\$2,814
<b>ALTERNATIVE NO. 3 TOTAL 20 YEAR PRESENT WORTH COST</b>				<b>\$3,306,183</b>

<sup>1</sup>Design costs were excluded from analysis. Fuel system maintenance costs were assumed to be similar for all of the alternatives and weren't included in the analysis. Assumed no preventative maintenance required for submersible pumps.

<sup>2</sup>Discount rate of 5% per year used.

<sup>3</sup>Pump replacement costs based on cost estimate.

<sup>4</sup>Annual WWPS energy consumption based on 2009 energy consumption of 26,421 kwh, an electricity rate of \$0.234 per kwh consumed, and an increase of TDH from 45 feet to 46.5 feet.

<sup>5</sup>Pump replacement costs based on \$28,710 replacement cost per pump, 25% mob/demob, 25% contingency, 10% profit, and 4.72% GE tax.

**TABLE J-4 KAHANAHOU WWPS  
ALTERNATIVE NO. 4: NEW C/S DRY PIT SUB. PUMPS W/ SOFT STARTERS  
PRESENT WORTH COST ANALYSIS**

PAGE (1 OF 1)

YEAR	COST ITEM DESCRIPTION <sup>1</sup>	COST (\$)	TOTAL DISCOUNT (%) <sup>2</sup>	PRESENT WORTH COST (\$)
0	Pump Replacement Costs <sup>3</sup>	\$3,019,000	0	\$3,019,000
	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	0	\$6,365
1	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	5	\$6,062
2	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	10.3	\$5,771
3	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	15.8	\$5,497
4	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	21.6	\$5,234
5	Pump Replacement Costs <sup>5</sup>	\$103,350	27.6	\$80,995
	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	27.6	\$4,988
6	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	34	\$4,750
7	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	40.7	\$4,524
8	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	47.7	\$4,309
9	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	55.1	\$4,104
10	Pump Replacement Costs <sup>5</sup>	\$103,350	62.9	\$63,444
	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	62.9	\$3,907
11	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	71	\$3,722
12	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	79.6	\$3,544
13	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	88.6	\$3,375
14	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	98	\$3,215
15	Pump Replacement Costs <sup>5</sup>	\$103,350	107.9	\$49,711
	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	107.9	\$3,062
16	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	118.3	\$2,916
17	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	129.2	\$2,777
18	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	140.7	\$2,644
19	Pump Energy Consumption Costs <sup>4</sup>	\$6,365	152.7	\$2,519
<b>ALTERNATIVE NO. 4 TOTAL 20 YEAR PRESENT WORTH COST</b>				<b>\$3,296,435</b>

<sup>1</sup>Design costs were excluded from analysis. Fuel system maintenance costs were assumed to be similar for all of the alternatives and weren't included in the analysis. Assumed no preventative maintenance required for submersible pumps.

<sup>2</sup>Discount rate of 5% per year used.

<sup>3</sup>Pump replacement costs based on cost estimate.

<sup>4</sup>Annual WWPS energy consumption based on 2009 energy consumption of 26,421 kwh, an electricity rate of \$0.234 per kwh consumed, and an increase of TDH from 45 feet to 46.5 feet.

<sup>5</sup>Pump replacement costs based on \$28,710 replacement cost per pump, 25% mob/demob, 25% contingency, 10% profit, and 4.72% GE tax.

# **APPENDIX K PERMITS**

**TABLE K-1 KAHANAHOU WWPS  
PROJECT PERMIT LIST**

<b>PERMIT</b>	<b>AGENCY</b>	<b>PHONE</b>
HRS 103-50 Document Transmittal Form	Disability and Communication Access Board	(808) 586-8121
Form 1	Department of Health, Noise and Radiation Branch	(808) 586-4700
Building Permit	City and County of Honolulu, Department of Planning and Permitting	(808) 768-8257
Application and Permit for Tank Installation	City and County of Honolulu, Honolulu Fire Department, Fire Prevention Bureau	(808) 723-7094
Application for an Underground Storage Tank Permit	Department of Health, Solid and Hazardous Waste Branch	(808) 586-4226
Temporary Industrial Wastewater Discharge Permit	City and County of Honolulu, Department of Environmental Services	(808) 768-3249 (808) 768-3261 (808) 768-3262 (808) 768-3271
Special Management Area	City and County of Honolulu, Department of Planning and Permitting, land Use Permits Division	(808) 768-8014
Trenching Permit	City and County of Honolulu, Department of Planning and Permitting, Site Development Division, Civil Engineering Branch	(808) 768-8218 (808) 768-8219

## **APPENDIX L REFERENCES**

## REFERENCES

- Austin, Tsutsumi & Associates, Inc. (2005) "Design Alternatives Report for Kahanahou Wastewater Pump Station Force Main Reconstruction". Prepared by Austin, Tsutsumi & Associates, Inc. for City and County of Honolulu, Department of Design and Construction.
- City and County of Honolulu, Department of Wastewater Management. (1993). "Design Standards of the Department of Wastewater Management, Volume 1".
- Fukunaga and Associates, Inc. (1999) "Final Sewer I/I Plan". Prepared by Fukunaga and Associates, Inc. for City and County of Honolulu, Department of Design and Construction.
- Fukunaga and Associates, Inc. (1999) "Sewer Rehabilitation and Infiltration & Inflow Minimization Study, Volume 3 of 9, Kailua –Kaneohe I/I Engineering Report". Prepared by Fukunaga and Associates, Inc. for City and County of Honolulu, Department of Design and Construction.
- Hydraulic Institute. (1990). "Hydraulic Institute Engineering Data Book, 2nd Edition".
- Hydraulic Institute. (1998). "ANSI/HI 9.8-1998, American National Standard for Pump Intake Design".
- National Fire Protection Association. (2008). "NFPA 810, Standard for Fire Protection in Wastewater Treatment and Collection Facilities".
- R.M. Towill Corporation (1997) "Kahanahou Wastewater Pump Station O&M Manual, Volume 1 of 2". Prepared by R.M. Towill Corporation for City and County of Honolulu, Department of Wastewater Management.
- Sanks, R., Tchobanoglous, G., Bosserman II, B., Jones, G. (1998) "Pumping Station Design". Boston. Butterworth Heinemann



## **Appendix B**

Kahanahou Wastewater Pump Station Force Main Sewer Line Study, Kaneohe, Oahu, Hawaii  
Okahara and Associates, Inc., December 2013



# FINAL ENGINEERING REPORT

## KAHANAHOU WASTEWATER PUMP STATION SEWER FORCE MAIN STUDY KANEEOHE, OAHU, HAWAII

Prepared For:  
City and County of Honolulu  
Department of Design and Construction  
Wastewater Division  
650 South King Street  
Honolulu, Hawaii 96813

Prepared By:  
Okahara and Associates, Inc.  
200 Kohola Street  
Hilo, Hawaii 96720

December 2013,  
Revised June 2015

**TABLE OF CONTENTS**

EXECUTIVE SUMMARY..... 3

SECTION 1 - GENERAL INFORMATION ..... 4

    1.1 Project Description ..... 4

    1.2 Project Location ..... 4

    1.3 Project Topography ..... 5

    1.4 Future Population ..... 5

    1.5 Field Survey Data ..... 5

    1.6 Flooding ..... 6

    1.7 Permits and Clearances ..... 6

SECTION 2 - SEWER SYSTEM ..... 7

    2.1 Description of Existing Sewer System ..... 7

    2.2 Description of Proposed Sewer System ..... 10

    2.3 Basis of Design ..... 14

SECTION 3 - RECOMMENDATIONS ..... 14

    3.1 Alternatives ..... 14

    3.2 Sewer System ..... 28

    3.3 Financing ..... 28

SECTION 4 - CONSTRUCTION ..... 29

    4.1 Summary ..... 29

    4.2 Construction Sequence ..... 29

## **LIST OF FIGURES**

Figure 1-1: Project Location Map.....	5
Figure 2-1: Existing Sewer System.....	8
Figure 2-2: Existing Waikapoki WWPS Tributary Area.....	9
Figure 2-3: Proposed Sewer System.....	11
Figure 2-4: Overall Sewer System to Kaneohe WWTP.....	12
Figure 2-5: Proposed Waikapoki WWPS Tributary Area .....	13
Figure 3-1: Alternative Route 1 Map.....	16
Figure 3-2: Alternative Route 3 Map.....	17
Figure 3-3: Alternative Route 3 Photos .....	18
Figure 3-4: Alternative Route 4 Map .....	19
Figure 3-5: Alternative Route 4 Photos.....	20
Figure 3-6: Alternative Route 2 Map.....	25
Figure 3-7: Alternative Route 2 Photos.....	25

## **APPENDIX**

Attachment 1: Preliminary Plan & Profile Sheets (8 pages)
Attachment 2: INFIX Data Printout (2 pages)
Attachment 3: Boring Log Plan Sheet (1 page)
Attachment 4: FEMA Flood Zone Map (1 page)
Attachment 5: Design Flow Guidance Email (1 page)
Attachment 6: Force Main Calculations (5 pages)
Attachment 7: TMK Maps showing Route 2 Private Properties (2 pages)
Attachment 8: Budgetary Opinion of Probable Construction Cost (1 page)
Attachment 9: Construction Sequence Site Plan (1 page)
Attachment 10: SMA Exemption Letters (2 pages)
Attachment 11: October 15, 2013 Meeting Minutes (3 pages)

## EXECUTIVE SUMMARY

The City and County of Honolulu has mandated by the U.S. Government through the 2010 Consent Decree, to eliminate all sanitary sewer overflows. The Kahanahou Wastewater Pump Station with its force main was named to be assessed in the consent decree. Based on the projected 5-year flow of 1.27 MGD from the Sewer Inflow and Infiltration Assessment and Rehabilitation Program Update Project, the existing Kahanahou WWPS and FM will require upgrading.

This Final Engineering Report is for the new force main (FM) only. A Design Alternatives Report is currently being conducted for the WWPS. The FM will be 10-inch fusible HDPE pipe. Manual air relief valves and access vaults will also be installed.

The Preliminary Engineering Report studied four possible routes and recommended Route 2. See Figures 3-1, 3-2, 3-4, and 3-6 for the four routes. Route 2 is on Figure 3-6. See Figure 2-1 for the existing force main.

Route	Length (feet)	TDH (feet)	Private Parcels	Budget Estimate (\$M)	Comments
1	3500	>100	0	n/a	Over 100' on static alone. Not acceptable.
2	3240	88 <sup>1</sup>	2	1.32 <sup>3</sup>	Recommended, one narrow area, minimal private properties.
3	2940	<100 <sup>2</sup>	4	1.26 <sup>3</sup>	Most private parcels, two narrow areas.
4	3680	<100 <sup>2</sup>	2	1.38 <sup>3</sup>	Through rock wall w/pool, in Makani Kai Marina and recently paved private roads, not preferred by Marina Management.

1. Includes static head inside the pump house. The total losses due to friction within the pump house are assumed to be less than 12 feet.
2. TDH not estimated but assumed to be less than 100' since the total static head is approximately 74.5' or less for Routes 3 & 4.
3. The estimate does not include land acquisition.

A meeting was held on October 15, 2013 in which these alternate routes were presented and discussed. Route 2 was chosen. See Attachment 11 for the meeting minutes. The Consultant was given the directive to proceed with completing the Design Alternative Report for the pump station upgrade and then begin the design process.

*The following report is in accordance with Section 11 – Engineering Report of the “Design Standards” of the Department of Wastewater Management, City and County of Honolulu, State of Hawaii dated July 1993. The draft “Wastewater System Design Standards and Guidelines” of the Department of Environmental Services, City and County of Honolulu, State of Hawaii dated January 2004 has also been referenced.*

## **SECTION 1 - GENERAL INFORMATION**

### **1.1 Project Description**

The City and County of Honolulu has been mandated by the U.S. Government through the 2010 Consent Decree to eliminate all sanitary sewer overflows. The Kahanahou Wastewater Pump Station with its force main was named to be assessed in the consent decree. Based on the projected peak design flow of 1.27 mgd from “The Sewer Inflow and Infiltration Assessment and Rehabilitation Program Update Project” (hereinafter referred to as the I/I Report), the existing Kahanahou WWPS and FM will require upgrading. This Final Engineering Report is for the new force main (FM) only. A Design Alternatives Report is currently being conducted for the WWPS.

This project replaces a portion of the existing sewer force main served by the Kahanahou wastewater pump station (WWPS). The existing City and County of Honolulu sewer force main has had a history of leak problems and has been mandated to be upgraded as mentioned above. The new sewer force main will be routed along an alignment that adequately serves the affected areas and is desirable to the City and County of Honolulu.

### **1.2 Project Location**

This project is located in Kaneohe, Oahu. The existing sewer system analyzed by this project starts as a force main from the Kahanahou WWPS on Kahanahou Place (TMK 4-5-047:095). The existing force main ends at a manhole on Springer Place, where it then continues as a gravity main around the marina area (TMK 4-5-0002:001, Address: 45-995 Waialele Road) to the Waikapoki WWPS. The proposed force main also begins at the Kahanahou WWPS, continues southwest along Kahanahou Circle and through some private properties, and discharges at a sewer manhole on Makahio Street near the intersection with Waialele Road. The proposed force main bypasses the Waikapoki WWPS. See Figure 1-1 below for project location map.

**Figure 1-1: Project Location Map**



### **1.3 Project Topography**

The existing ground topography along the proposed force main alignment varies from roughly 4.6 feet to 65.6 feet in elevation. The beginning of the proposed force main on Kahanahou Place is the low point of the line (elevation 4.6 feet), thus the need for the WWPS. The existing ground generally slopes upward to a high point near the intersection of Lilipuna Road and Lilipuna Place (elevation 65.6 feet). The ground then varies up and down in slope until the end of the proposed force main along Makahio Street (elevation 64.6 feet). See Attachment 1 for the preliminary plan and profile sheets with topographic survey background.

### **1.4 Future Population**

Population data from the City and County of Honolulu's INFIX version 3.0 flow model was reviewed for this report; however this data was not utilized in the design of the proposed force main (see Section 2.3 Basis of Design for the design flow information). For reference, see Attachment 2 for INFIX data printout for the Kahanahou WWPS (designated as Plant/Station KK32).

### **1.5 Field Survey Data**

*A flow report for the Kahanahou area is from the I/I Report procured by the City. The I/I Report was unavailable at the time of the preliminary engineering report. However, the necessary information has been provided by the City to complete this final engineering report.*

No soil investigations, core borings, corrosivity studies, or noise attenuation studies have been performed specifically for this project at this time. The corrosivity study is not believed to be essential, since the proposed pipe



material is plastic and will not corrode. A reference drawing from the project entitled "Kahanahou Sewage Pumping Station & Force Main" dated March 3, 1964 provides boring log information at the Kahanahou WWPS. This boring shows the ground to consist of clayey silts, sands, and coral, with the water table approximately 4½ feet below grade. See Attachment 3 for boring log plan sheet. Geotechnical investigation will be performed during the design phase.

## **1.6 Flooding**

The entire proposed force main alignment is in FEMA FIRM Zone X, which is outside the 500-year floodplain. See Attachment 4 for FEMA flood zone map.

## **1.7 Permits and Clearances**

The following is a list of permits and clearances associated with land use restrictions. In accordance with the Revised Ordinances of Honolulu dated 1990, this project is subject to the following permits and clearances:

- Flood Hazard District - NO
- Special Management Area (SMA) Use – NO
- Shoreline Setback – CITY TO SEEK FOR VARIANCE (force main will be installed within the 40' shoreline setback)
- Special District Permit - NO
- Hawaii Coastal Zone Management Program/Hawaii Coastal Nonpoint Pollution Control Program, Federal Consistency – NO
- Conservation District Use Application – NO (urban district state land use)
- Historic and Cultural Site Review – AN ARCHAEOLOGICAL LITERATURE REVIEW AND FIELD INSPECTION REPORT HAS BEEN ORDERED BY THE CITY
- National Pollutant Discharge Elimination System (NPDES) permit for Stormwater and Dewatering - YES
- Underground Injection Control (UIC) Permit – NO
- Permit for Work in Ocean Waters – NO
- Department of Army Permits – DETERMINATION PENDING CONSULTATION WITH THE CORPS
- Stream Channel Alteration Permit - NO
- Water Quality Certification – NO
- Total Maximum Daily Load (TMDL) – NO

This project will also be subject to the following permits:

- City and County of Honolulu Trenching Permit
- City and County of Honolulu Street Usage Permit
- City and County of Honolulu Sewer Connection Application
- State DCAB HRS 130-50 Document Transmittal Form

- National Pollutant Discharge Elimination System (NPDES) permit for Stormwater and Dewatering
- State Department of Health Community Noise Permit and Noise Variance

## **SECTION 2 - SEWER SYSTEM**

### **2.1 Description of Existing Sewer System**

The existing sewer system starts at the Kahanahou WWPS and consists of approximately 800 lineal feet of an 8-inch diameter high density polyethylene (HDPE) force main. The force main discharges to a manhole located within Springer Place, where it then continues as an 8-inch and 10-inch gravity main through the marina area to the Waikapoki WWPS. The gravity main is approximately 1,900 feet in length. See Figure 2-1 below for a map of the existing sewer system.


The existing tributary areas for the Waikapoki WWPS are shown on Figure 2-2 below. The tributary areas labeled “Kahanahou Tributary”, “Waikapoki Tributary 1” and “Waikapoki Tributary 2” all currently discharge to the Waikapoki WWPS (the “Kahanahou Tributary” first discharges to the Kahanahou WWPS).

The project area is currently zoned residential district R-10. The Koolaupoko Sustainable Communities Plan dated August 2000 designates the project area as low density residential land use, and states that the area is projected to have limited future population growth.

**Figure 2-1: Existing Sewer System**



Figure 2-2: Existing Waikapoki WWPS Tributary Area



Google earth




## 2.2 Description of Proposed Sewer System

The proposed force main will replace the existing force main, with the existing force main being abandoned in place. The existing gravity main from the end of the existing force main discharging to Waikapoki WWPS is to remain in service, as it will still serve the “Waikapoki Tributary 1” area shown in light purple on Figure 2-2 via several existing sewer laterals. The proposed force main is about 3,100 lineal feet, is sized at 10 inches, and will be HDPE SDR 11 fusible pipe. Pipe SDR specification is in accordance with Section 1-2.6(h) of the Draft Wastewater System Design Standards and Guidelines of the Department of Environmental Services, dated January 2004. Equally possible is the use of fusible C900 PVC pipe. The attached plan and profile sheets are conceptual and call out HDPE pipe and are curved both horizontally and vertically at the turns where possible to reduce friction. The cold bend minimum radius for HDPE SDR 11 is 25 x OD. Mitered fused bends are also an option for HDPE and required for PVC unless using large radii. The use of tracer wire is recommended. As HDPE has high buoyancy, considerations must be made to anchor sections where the water table is high.

The proposed force main will start at the Kahanahou WWPS and discharge to an existing sewer manhole on Makahio Street, where it connects to an existing 8 inch gravity sewer line. At the point of connection, the existing 8-inch gravity sewer line has an estimated capacity of 0.463 mgd; this capacity is not sufficient to handle the peak design flow of 1.27 mgd (see next section for design flow information). However, the initial years of flows should be low enough to pass through this section. The City will determine when an upgrade is necessary. Both the existing and proposed sewer systems flow to the Kaneohe Wastewater Treatment Plant; therefore there will be no change in the amount of discharge to this downstream facility. The new force main is located within areas previously disturbed by utility lines, residential development, and/or road construction; force main construction will not disturb previously undisturbed areas. See Figures 2-3 and 2-4 below for a map of the proposed sewer system.

Since the proposed force main will no longer connect to the existing gravity main discharging to Waikapoki WWPS, the “Kahanahou Tributary” area will no longer flow to the Waikapoki WWPS; this tributary area will be diverted to the Waikalua WWPS. The total tributary area discharging to the Waikapoki WWPS will be significantly reduced with the proposed force main installation, making it possible to reduce improvement needs for the Waikapoki WWPS to that of maintenance only and not for upgrading. See Figure 2-5 below for the proposed Waikapoki WWPS tributary areas.


**Figure 2-3: Proposed Sewer System**



**Figure 2-4: Overall Sewer System to Kaneohe WWTP**



Figure 2-5: Proposed Waikapoki WWPS Tributary Area



Google earth

feet 2000  
meters 800





## 2.3 Basis of Design

The Sewer Inflow and Infiltration Assessment and Rehabilitation Program Update Project (I/I Report) developed a computer hydraulic model of the City's collection system. The following results are from the model's 2030b – 2yr network and were used in the preliminary design of the proposed force main:

- Design Period = 5-year, 24-hour storm
- Design Flow Rate = 1.27 mgd
- Pipe Slope and Elevation = varies
- Pipe Length = total of 3,195 linear feet
- Hazen-Williams Coefficient C = 150 (for new HDPE or C900 PVC pipe)

The client (City and County of Honolulu Wastewater Division) provided the directive to use the future (year 2030) 5-year 24-hour flow from the I/I Report. See Attachment 5 for the design flow guidance email.

The above design data resulted in the following force main properties (see Attachment 6 for Route 2 force main calculations):

- Pipe Size = 10 inches
- Total Dynamic Head = 88 ft (*100 ft max; losses in pump house not included but assumed to be less than 12 feet*)
- Full-Flow Velocity = 3.60 ft/s (*1.75 ft/s min, 10 ft/s max*)

See Attachment 1 for the preliminary plan and profile sheets for Route 2. The highest point of the force main will be at the discharge point in order to keep the entire pipe at full flow. A new manhole will be installed prior to the discharge manhole to keep the FM outlet submerged. The required minimum pipe cover of 4 feet will be maintained along the force main; if minimum pipe cover cannot be maintained then the main will be concrete jacketed. Concrete jacketing will also be used in areas where maintenance is a concern, such as within private properties. Due to the varying existing ground slope, manual air relief valves will be installed at the high points along the force main. The City will periodically open these valves to release any air in the force main; the City will take measures to control the odor emitted. Additionally, capped access tees will be installed in vaults for monitoring and maintenance. No manholes will be installed.

## **SECTION 3 - RECOMMENDATIONS**

### **3.1 Alternatives**

The two initial general alternatives for this project were a new force main from the Kahanahou WWPS discharging to the Waikapoki WWPS or from the Kahanahou WWPS discharging to the Waikalua WWPS. The alternative that

discharges to the Waikapoki WWPS would involve improving the existing gravity main in that area, which is located right next to the shore at some points. The City dismissed this alternative early on; therefore it is not discussed further in this report. The four alternatives discussed below all discharge to the Waikalua WWPS.

There were a total of four alternative routes examined for the proposed force main. All routes started at the Kahanahou WWPS, generally ran in the southwesterly direction and connected to a City and County of Honolulu sewer manhole either in Makahio Street or William Henry Road. The proposed routes bypass the Waikapoki WWPS (where the existing force main currently discharges) and instead discharge to the Waikalua WWPS. The following is a description of each alternative route and the reasons for dismissal or selection. A “Delayed Action” alternative and a “No Action” alternative were also considered, and are briefly described below.

#### Route 1

Route 1 consisted of a force main running west along Kahanahou Circle and Lilipuna Road. At the intersection of Lilipuna Road and Wailele Road the alignment hits its high point; thereby ending the force main and beginning a gravity main. The gravity main alignment turned south and ran down Wailele Road until Makahio Street. The alignment then turns west on Makahio Street and connects to an existing sewer manhole. This route was dismissed because the estimated total dynamic head of over 100 feet exceeds the force main requirements in the Design Standards.


**Figure 3-1: Alternative Route 1 Map**



### Route 3

Route 3 consisted of a force main running west through a number of private properties and ending at the existing sewer manhole on Makahio Street. This route was dismissed because of the narrow construction space along certain areas of the proposed alignment. One specific problem area was a narrow path between an existing fence line and house structure; see the below photos. This route also crosses through the greatest number of private properties, which is undesirable per the Design Standards (standards state to locate force mains in streets or along road right-of-ways whenever possible).

**Figure 3-2: Alternative Route 3 Map**



**Figure 3-3: Alternative Route 3 Photos**




### Route 4

Route 4 was an early version of the proposed alignment. It consisted of running the force main west along Kahanahou Circle, turning south and running through some private properties, running across a bridge on Wailele Road, and ending at the existing sewer manhole on William Henry Road. This route was dismissed because it would penetrate an existing rock wall that retains a concrete lined pond. The Makani Kai Marina manager was concerned that the wall could fail and injure residents. Also, the pond was added recently and the wall was not designed for this added surcharge.

The Wailele Road bridge crossing was another complexity with this route that contributed to its dismissal. Complexities with the bridge crossing include the following: 1) Requires obtaining permits such as DOH Section 401, Army Section 404, and DLNR Stream Channel Alteration Permit (SCAP), 2) Difficulty of construction with hanging utilities on bridge deck or burying under the stream, 3) Coordination with other utilities currently hanging on the bridge, 4) High construction cost, and 5) Potential spills during and after construction. Also, the sewer manhole connection point within William Henry Road is at a lower elevation than the manhole in Makahio Street (the connection point for the other routes); this will likely result in a very deep force main line at the high point at Lilipuna Road and Lilipuna Place in order to keep a full-flowing force main.

**Figure 3-4: Alternative Route 4 Map**



**Figure 3-5: Alternative Route 4 Photos**






Photo 4-c: Route 4  
Lower Part of Marina



Photo 4-d: Route 4  
Lower Part of Marina





Photo 4-e: Route 4  
Lower Part of Marina



Photo 4-f: Route 4  
Exiting the Marina onto  
Wailele Street



Photo 4-g: Route 4  
Wailele Rd. Bridge



Photo 4-h: Route 4  
Wailele Rd. Bridge

#### Delayed Action

As an alternative to upgrading the Kahanahou WWPS and the sewer lines servicing it, the City could delay implementation of the proposed project. However, this is undesirable, as it would not allow the Kahanahou WWPS to be in compliance with the 2010 Consent Decree, which mandates that

upgrades be completed by June 30, 2020. Delaying the proposed project could also result in sewage overflows and therefore possible fines.

#### No Action

Similarly, “No Action” is not considered a feasible alternative because it would not be in compliance with the 2010 Consent Decree, could result in sewage overflows and therefore possible fines.

#### Route 2 (Chosen Alternative)

Route 2 consists of a force main running west along Kahanahou Circle, turning south and running through some private properties, and ending at the existing sewer manhole on Makahio Street. This route has an acceptable total dynamic head of roughly 85 feet, avoids the problematic areas mentioned with Routes 3 and 4, and crosses through a lesser amount of private properties compared to Route 3. For these reasons, Route 2 is the chosen alignment for this project. See Attachment 7 for the TMK maps showing the affected private properties.

#### Route 2 Known Issues:

1. There is an existing 5' wide easement through Mr. Robert Miyazaki's parcel (TMK 4-5-057:015, Address: 45-2 Lilipuna Place) through which the new FM is to traverse. See Photo 2b of Figure 3-7. The existing easement is narrow because it is bounded by the overhang of the house car port. The owner's grandson is planning on demolishing the existing house and building a new home. It is unknown when this will take place. The City may request a wider easement from the owner in the future.
2. The Makani Kai Marina (TMK 4-5-0002:001, Address: 45-995 Wailele Road) landscaped pathway is important to the manager and residents. See Photos 2-c and 2-d of Figure 3-7. It is preferred that the existing landscaping and sidewalk layout remains the same or close to it. It is likely that sidewalks and landscaping through the marina will be significantly impacted if an open-trench type installation is utilized for force main construction. The design plans will give the contractor the option to utilize a trenchless installation method (micro-tunneling) in this area.
3. There is a high point in the FM located in the Makani Kai Marina landscaped pathway. See Sheet 2 of Attachment 1. Manual air relief valves will be installed at the high points along the force main. The City will periodically open these valves to release any air in the force main; the City will take measures to control the odor emitted.

**Figure 3-6: Alternative Route 2 Map**



**Figure 3-7: Alternative Route 2 Photos**









### 3.2 Sewer System

The proposed 10-inch HDPE force main system will replace the existing force main from the Kahanahou WWPS. The proposed system is sized to handle the design flow selected by the City and County of Honolulu, which accounts for projected future development. The City will determine when an upgrade is necessary for the existing sewer system downstream of the proposed force main. The proposed force main alignment also re-routes part of the existing Waikapoki WWPS tributary area such that less flow is directed to the Waikapoki WWPS, eliminating the need to upgrade the Waikapoki WWPS.

### 3.3 Financing

See Attachment 8 for a budgetary opinion of probable construction cost. The total estimated construction cost is roughly \$1.27M, and is subject to change as design progresses.

## **SECTION 4 - CONSTRUCTION**

### **4.1 Summary**

Upgrading the Kahanahou WWPS and constructing the new 10-inch force main from the WWPS are likely to be constructed at the same time but could also be done in two separate projects. It is unknown at this time how these projects will be phased during construction. In order to ensure that the existing sewer system service continues uninterrupted, a conceptual construction sequence plan has been included in the next section. This construction sequence plan assumes that the new force main will be constructed before upgrading the WWPS, and takes some measures to prepare the site for the WWPS upgrades. Additional assumptions are as follows:

- FM connections done at night
- Dry weather conditions
- One hour to make both connections
- Flow of .45 MGD (derived from average of monthly minimum flows x 2)
  - ~313 gpm
  - 18,800 gallons of storage required for one hour shut down time
- Allowed to use distribution system to temporarily store sewage (capacity unknown)
- Sufficient pumps and tankers are available to be used as backup
- Other utilities may have to be rerouted.

See Attachment 9 for a construction sequence site plan. A test shutdown may also be implemented to determine how much time the contractor might have to complete the connections.

### **4.2 Construction Sequence**

#### **Force Main in WWPS Site:**

1. Install new piping, valves, and vaults up to the connection points – flow tube and ball valve within the site but away from proposed generator building footprint.
2. Prepare connection points:
  - a. Flow tube
    - i. Open trench, outlet side of existing vault
    - ii. Existing pipe is HDPE
    - iii. New pipe installed up to connection point
    - iv. Complete any pre-assemblies
  - b. Ball valve
    - i. Opening in vault wall for pipe penetration



- ii. Existing pipe is HDPE
  - iii. New pipe installed up to connection point
  - iv. Complete any pre-assemblies.
3. Install temporary above ground piping system as a backup.
4. Install temporary pumps with intakes in wet wells and discharge in tankers:
  - a. Only as backup.
  - b. Use distribution system as storage.
  - c. Monitor lowest manhole.
  - d. Pump as needed.
5. Make connections:
  - a. Night construction and weather conditions as close to ideal as possible.
  - b. Stop flow into WWPS.
  - c. Shut off booster pumps.
  - d. Make connections simultaneously.
6. Start up boosters.
7. Shut off temporary pumps, demob pumps/tankers.
8. Backfill trenches.

Gravity Main in WWPS Site:

1. Install new sewer line outside of proposed generator building footprint.
2. Install and run bypass system from MH fronting WWPS site to MH near wet well.
3. Install two new MH between the two MH described above and connect to new pipe.
4. Remove temporary bypass.

Construction Method Notes:



- Other options to minimize down time during the connection will be explored.
- Other methods of handling the sewage flow during the connections will be explored as well; the method used will be the City-approved method.

- Trenchless installation methods may be utilized in certain areas to minimize disturbance to existing improvements; methods to be determined during the design phase.
- Force main construction will not cause odors to be released since it does not require opening of the existing sewer system.
- Traffic control plans will either be included in the construction documents or will be provided by the contractor.

# APPENDIX

# **Attachment 1**

**Preliminary Plan & Profile Sheets**



REVISION	DATE	BRIEF	BY	APPROVED

WASTEWATER DIVISION  
 DEPARTMENT OF DESIGN & CONSTRUCTION  
 CITY AND COUNTY OF HONOLULU

PROJECT: **KANEOHE, OAHU, HAWAII  
 KAHANAHOU WASTEWATER**



ITEM:

DESIGNED BY: CH  
 DRAWN BY: BKHM  
 APPROVED:

CHECKED BY: BKM  
 SECTION HEAD  
 BRANCH HEAD



CHIEF \_\_\_\_\_ DATE \_\_\_\_\_

EXPIRATION DATE OF THE LICENSE




REVISION	DATE	BRIEF	BY	APPROVED

PROJECT: **KANEOHE, OAHU, HAWAII  
KAHANAHOU WASTEWATER**  
 ITEM: \_\_\_\_\_  
 DESIGNED BY: CH  
 DRAWN BY: BKHM  
 APPROVED: \_\_\_\_\_  
 CHECKED BY: BKM  
 SECTION HEAD: \_\_\_\_\_  
 BRANCH HEAD: \_\_\_\_\_  
 CHIEF: \_\_\_\_\_ DATE: \_\_\_\_\_




REVISION	DATE	BRIEF	BY	APPROVED

PROJECT: **KANEOHE, OAHU, HAWAII  
KAHANAHOU WASTEWATER**  
 ITEM: \_\_\_\_\_  
 DESIGNED BY: CH      CHECKED BY: BKM  
 DRAWN BY: BKHM      SECTION HEAD: \_\_\_\_\_  
 APPROVED: \_\_\_\_\_ BRANCH HEAD: \_\_\_\_\_  
 \_\_\_\_\_ DATE: \_\_\_\_\_



PLAN  
SCALE: 1"=20'




PROFILE  
SCALE: HORIZ. 1"=20'  
VERT. 1"=4'

REVISION	DATE	BRIEF	BY	APPROVED
<b>WASTEWATER DIVISION</b> DEPARTMENT OF DESIGN & CONSTRUCTION CITY AND COUNTY OF HONOLULU				
PROJECT: <b>KANEOHE, OAHU, HAWAII</b> <b>KAHANAHOU WASTEWATER</b>				
DESIGNED BY: CH DRAWN BY: BKHM APPROVED: _____				
CHECKED BY: BKM SECTION HEAD: _____ BRANCH HEAD: _____				
EXPIRATION DATE OF THE LICENSE: _____				


W8-06

FILE	POCKET	FOLDER	NO.
------	--------	--------	-----





PLAN  
SCALE: 1"=20'





PROFILE  
SCALE: HORIZ. 1"=20'  
VERT. 1"=4'

REVISION	DATE	BRIEF	BY	APPROVED

PROJECT: **KANEOHE, OAHU, HAWAII  
KAHANAHOU WASTEWATER**  
 ITEM: \_\_\_\_\_  
 DESIGNED BY: CH  
 DRAWN BY: BKHM  
 APPROVED: \_\_\_\_\_  
 CHECKED BY: BKM  
 SECTION HEAD: \_\_\_\_\_  
 BRANCH HEAD: \_\_\_\_\_  
 DATE: \_\_\_\_\_

EXPIRATION DATE OF THE LICENSE: \_\_\_\_\_

W8-06



REVISION	DATE	BRIEF	BY	APPROVED



WASTEWATER DIVISION  
 DEPARTMENT OF DESIGN & CONSTRUCTION  
 CITY AND COUNTY OF HONOLULU

PROJECT: **KANEOHE, OAHU, HAWAII  
 KAHANAHOU WASTEWATER**

DESIGNED BY: CH  
 DRAWN BY: BKHM  
 APPROVED: \_\_\_\_\_

CHECKED BY: BKM  
 SECTION HEAD: \_\_\_\_\_  
 BRANCH HEAD: \_\_\_\_\_

EXPIRATION DATE OF THE LICENSE: \_\_\_\_\_




REVISION	DATE	BRIEF	BY	APPROVED

PROJECT: **KANEOHE, OAHU, HAWAII  
KAHANAHOU WASTEWATER**  
 ITEM: \_\_\_\_\_  
 DESIGNED BY: CH      CHECKED BY: BKM  
 DRAWN BY: BKHM      SECTION HEAD: \_\_\_\_\_  
 APPROVED: \_\_\_\_\_ BRANCH HEAD: \_\_\_\_\_  
 \_\_\_\_\_ CHIEF      \_\_\_\_\_ DATE


THIS WORK WAS PREPARED BY ME OR UNDER MY SUPERVISION AND CONSTRUCTION OF THIS PROJECT WILL BE UNDER MY OBSERVATION

W8-06

FILE	POCKET	FOLDER	NO.
------	--------	--------	-----



PLAN  
SCALE: 1"=20'



PROFILE  
SCALE: HORIZ. 1"=20'  
VERT. 1"=4'

REVISION	DATE	BRIEF	BY	APPROVED

PROJECT: **KANEOHE, OAHU, HAWAII  
KAHANAHOU WASTEWATER**

DESIGNED BY: CH      CHECKED BY: BKM  
 DRAWN BY: BKHM      SECTION HEAD: \_\_\_\_\_  
 APPROVED: \_\_\_\_\_      BRANCH HEAD: \_\_\_\_\_

EXPIRATION DATE OF THE LICENSE: \_\_\_\_\_

W8-06

FILE	POCKET	FOLDER	NO.

# **Attachment 2**

**INFIX Data Printout**

AREA : KANEOHE BASIN

PREPARED BY : CITY & COUNTY OF HONOLULU

Date : 01/06/11

PLANT/ STATION	TRIBUTARY AREA  (ACRES)	TRIBUTARY EQUIVALENT POPULATION			WASTEWATER FLOW COMPUTATION							
		RES.	OTHER	TOTAL	AVE.	MAX	MAX	DRY	DESIGN	DESIGN	WET	DESIGN
					Q	FF	Q	I/I	AVE	Q MAX	I/I	Q PEAK
(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	(MGD)	
KK 20	619.7	8267	3006	11273	0.9018	3.08	2.7777	0.0695	0.9713	2.8472	0.8198	3.6670
KK 21	16.2	373	12	385	0.0308	5.00	0.1541	0.0019	0.0327	0.1560	0.0202	0.1762
KK 22	195.2	2040	135	2176	0.1740	4.28	0.7449	0.0240	0.1981	0.7690	0.2891	1.0581
KK 23	171.6	1900	62	1963	0.1570	4.37	0.6860	0.0221	0.1791	0.7080	0.2554	0.9634
KK 24	103.6	1154	17	1171	0.0936	4.84	0.4537	0.0128	0.1064	0.4665	0.1493	0.6158
KK 30	4151.8	51276	40850	92126	7.3700	2.02	14.9129	0.6261	7.9960	15.5389	6.1627	21.7016
KK 31	9.0	88	24	112	0.0090	5.00	0.0449	0.0006	0.0095	0.0454	0.0113	0.0567
KK 32	68.6	832	22	854	0.0684	5.00	0.3418	0.0149	0.0832	0.3567	0.1218	0.4784
KK 33	42.4	674	226	900	0.0720	5.00	0.3598	0.0095	0.0815	0.3694	0.0731	0.4424
KK 34	142.5	2364	0	2364	0.1891	4.21	0.7961	0.0118	0.2009	0.8079	0.1781	0.9861
KK 35	425.5	743	931	1674	0.1339	4.51	0.6041	0.0084	0.1423	0.6124	1.1111	1.7235
KK 36	165.5	2354	2105	4459	0.3567	3.71	1.3226	0.0329	0.3896	1.3555	0.2251	1.5806
KK 37	181.1	2695	277	2972	0.2377	4.02	0.9560	0.0459	0.2837	1.0019	0.3231	1.3251
KK 45	27.7	442	61	503	0.0402	5.00	0.2012	0.0025	0.0428	0.2037	0.0346	0.2383
KK 48	4.2	68	0	68	0.0054	5.00	0.0272	0.0003	0.0058	0.0275	0.0053	0.0328
KK 50	464.4	4724	1078	5802	0.4642	3.52	1.6328	0.0869	0.5511	1.7197	0.7669	2.4866
KK 51	280.9	2658	797	3455	0.2764	3.90	1.0784	0.0610	0.3374	1.1394	0.4651	1.6045
KK 52	175.7	1763	776	2538	0.2031	4.15	0.8428	0.0536	0.2567	0.8964	0.3193	1.2157
KK 53	42.0	392	19	411	0.0329	5.00	0.1645	0.0061	0.0390	0.1706	0.0815	0.2521

AREA : KANEOHE BASIN

PREPARED BY : CITY & COUNTY OF HONOLULU

Date : 01/06/11

PLANT/ STATION	TRIBUTARY AREA  (ACRES)	TRIBUTARY EQUIVALENT POPULATION			WASTEWATER FLOW COMPUTATION							
		RES.	OTHER	TOTAL	AVE. Q  (MGD)	MAX FF	MAX Q  (MGD)	DRY I/I  (MGD)	DESIGN AVE  (MGD)	DESIGN Q MAX  (MGD)	WET I/I  (MGD)	DESIGN Q PEAK  (MGD)
KK 20	892.7	18101	4398	22500	1.8001	2.68	4.8286	0.2966	2.0967	5.1252	1.5703	6.6955
KK 21	162.4	2780	12	2792	0.2234	4.07	0.9095	0.0858	0.3091	0.9953	0.4223	1.4176
KK 22	313.0	4721	1314	6035	0.4829	3.49	1.6853	0.1343	0.6172	1.8196	0.6130	2.4326
KK 23	178.2	2943	56	2999	0.2400	4.01	0.9631	0.0363	0.2762	0.9994	0.2736	1.2730
KK 24	110.3	1747	17	1763	0.1411	4.46	0.6298	0.0202	0.1613	0.6500	0.1675	0.8176
KK 30	4470.7	83082	46631	129713	10.3771	1.89	19.6087	1.0568	11.4339	20.6655	7.0392	27.7047
KK 31	9.0	88	97	185	0.0148	5.00	0.0739	0.0009	0.0157	0.0748	0.0113	0.0861
KK 32	76.0	1123	18	1141	0.0913	4.87	0.4447	0.0206	0.1120	0.4653	0.1422	0.6075
KK 33	42.4	757	261	1018	0.0814	4.98	0.4055	0.0113	0.0927	0.4168	0.0731	0.4899
KK 34	142.5	2643	0	2643	0.2115	4.12	0.8705	0.0132	0.2247	0.8837	0.1781	1.0618
KK 35	425.5	811	931	1742	0.1394	4.47	0.6236	0.0087	0.1481	0.6323	1.1111	1.7434
KK 36	170.9	3850	2177	6027	0.4822	3.49	1.6833	0.0440	0.5262	1.7274	0.2398	1.9671
KK 37	188.5	3260	405	3665	0.2932	3.86	1.1306	0.0567	0.3499	1.1874	0.3436	1.5310
KK 45	27.7	530	61	591	0.0473	5.00	0.2365	0.0030	0.0503	0.2395	0.0346	0.2740
KK 48	4.2	92	0	92	0.0074	5.00	0.0369	0.0005	0.0078	0.0373	0.0053	0.0426
KK 50	464.4	7198	1145	8343	0.6675	3.27	2.1834	0.1114	0.7788	2.2947	0.7669	3.0616
KK 51	280.9	4637	831	5468	0.4375	3.56	1.5572	0.0824	0.5198	1.6395	0.4651	2.1046
KK 52	175.7	2983	776	3759	0.3007	3.84	1.1536	0.0692	0.3699	1.2228	0.3193	1.5421
KK 53	42.0	643	19	662	0.0529	5.00	0.2647	0.0122	0.0651	0.2769	0.0815	0.3584

# **Attachment 3**

**Boring Log Plan Sheet**







# **Attachment 4**

**FEMA Flood Zone Map**



MAP SCALE 1" = 1000'



NATIONAL FLOOD INSURANCE PROGRAM

PANEL 0270H

**FIRM**  
FLOOD INSURANCE RATE MAP

CITY AND COUNTY OF  
HONOLULU,  
HAWAII

PANEL 270 OF 395

(SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:

COMMUNITY	NUMBER	PANEL	SUFFIX
HONOLULU, CITY AND COUNTY OF	150001	0270	H

Notice to User: The Map Number shown below should be used when placing map orders; the Community Number shown above should be used on insurance applications for the subject community.



MAP NUMBER  
15003C0270H

MAP REVISED  
JANUARY 19, 2011

Federal Emergency Management Agency

This is an official copy of a portion of the above referenced flood map. It was extracted using F-MIT On-Line. This map does not reflect changes or amendments which may have been made subsequent to the date on the title block. For the latest product information about National Flood Insurance Program flood maps check the FEMA Flood Map Store at [www.msc.fema.gov](http://www.msc.fema.gov)

# **Attachment 5**

**Design Flow Guidance Email**

**From:** [Nikaido, Jason Y](#)  
**To:** "[bmeyers@okahara.com](mailto:bmeyers@okahara.com)"; [Tamashiro, Roy J](#)  
**Cc:** "[Tyson Toyama](#)"; [hilo@okahara.com](mailto:hilo@okahara.com); [Oahu Office](#)  
**Subject:** RE: Design Flow for Kahanahou  
**Date:** Wednesday, June 19, 2013 12:33:08 PM

---

Bruce –

The 2-year flow is 1.18 mgd. The 5-year flow is 1.27 mgd. Both flows are for the 24-hour design storm as they are higher than the 6-hour storm. Based on the small difference, I would recommend designing to the 5-year flow. The results are from the 2030b – 2yr model which means 2030 flows with all 2-year bottlenecks removed. Please let me know if you have any questions.

Jason Nikaido, P.E.  
City and County of Honolulu  
Department of Design and Construction  
Wastewater Division, Collection System Engr. Branch  
650 S. King Street, 14th Floor  
Honolulu, HI 96813  
[jnikaido@honolulu.gov](mailto:jnikaido@honolulu.gov)  
Phone: (808) 768 - 8775  
Fax: (808) 768 - 4642

---

**From:** Bruce K. Meyers [<mailto:bmeyers@okahara.com>]  
**Sent:** Wednesday, June 19, 2013 9:29 AM  
**To:** Tamashiro, Roy J  
**Cc:** Nikaido, Jason Y; 'Tyson Toyama'; [hilo@okahara.com](mailto:hilo@okahara.com); Oahu Office  
**Subject:** Design Flow for Kahanahou

Hi Roy,

It was good talking to you yesterday. I'll be sending the revised schedule today or tomorrow. Also, we discussed what design flow to use and that you were going to follow-up on what that will be for our DAR/PER purposes. If that has been determined, please send it at your earliest convenience.

Thank you,  
Bruce  
210-002

# **Attachment 6**

## **Force Main Calculations**

## TOTAL DYNAMIC HEAD CALCULATIONS FOR ROUTE 2

### STATIC HEAD LOSSES

Pump Off Elev at intake in pump house =	-14.5 ft
Discharge Elev (Sta. 0+00) =	60 ft
<b>Static Head Loss =</b>	<b>-74.5 ft</b>

### PIPE FRICTION LOSSES

See FlowMaster Worksheets:

Existing 8" FM (25 linear feet) =	-0.28 ft
New 10" FM (3,195 linear feet) =	-11.97 ft

**Total Pipe Friction Loss = -12.25 ft**

### FIXTURE LOSSES

Along Exist 8" FM:

8"x6" D.I. Wye, M.J.	14 ft
8" Venturi Meter	6 ft
8" Valve	6 ft
8" HDPE Flanged Adapter	-- ft
Equivalent Straight Pipe Length =	26 ft
Fixture Loss =	-0.29 ft

Along New 10" FM:

10"x8" 90 Degree Reducing Elbow	26 ft
10" 90 Degree Bend	26 ft
10" 90 Degree Bend	26 ft
10" Switch Valve	7 ft
10" 90 Degree Bend	26 ft
10" 45 Degree Bend	14 ft
Air Relief Valve (ARV)	7 ft
Air Relief Valve (ARV)	7 ft
Air Relief Valve (ARV)	7 ft
Equivalent Straight Pipe Length =	146 ft
Fixture Loss =	-0.55 ft

**Total Fixture Losses = -0.84 ft**

**TOTAL DYNAMIC HEAD LOSS = -88 ft**

Assumed friction loss in pump house is less than 12 feet.

# FlowMaster Worksheet - Exist 8" Force Main (Kahanahou WWPS to New FM)

## Worksheet for Pressure Pipe

---

### Project Description

---

Worksheet	Exist 8" Force Main (Kahanahou WWF
Flow Element	Pressure Pipe
Method	Hazen-Williams Formula
Solve For	Pressure at 1

---

---

### Input Data

---

Pressure at	20.78	psi
Elevation at	1.50	ft
Elevation at	1.50	ft
Length	25.00	ft
C Coefficient	150.0	
Diameter	8	in
Discharge	1.270	mgd

---

---

### Results

---

Pressure at 1	20.66	psi
<b>Headloss</b>	<b>-0.28</b>	<b>ft</b>
Energy Grade at	49.65	ft
Energy Grade at	49.92	ft
Hydraulic Grade :	49.15	ft
Hydraulic Grade :	49.43	ft
Flow Area	0.3	ft <sup>2</sup>
Wetted Perimeter	2.09	ft
Velocity	5.63	ft/s
Velocity Head	0.49	ft
Friction Slope	.011110	ft/ft

---



# FlowMaster Worksheet - Proposed 10" Force Main (Exist 8" FM to Makahio SMH)

## Worksheet for Pressure Pipe

---

### Project Description

---

Worksheet	Proposed 10" Force Main (Exist 8" FM to Makahio SMH)
Flow Element	Pressure Pipe
Method	Hazen-Williams Formula
Solve For	Pressure at 1

---

---

### Input Data

---

Pressure at :	0.00 psi
Elevation at	1.50 ft
Elevation at	61.40 ft
Length	1,195.00 ft
C Coefficient	150.0
<b>Diameter</b>	<b>10 in</b>
Discharge	1.270 mgd

---

---

### Results

---

Pressure at 1	20.78 psi
<b>Headloss</b>	<b>-11.97 ft</b>
Energy Grade at	49.63 ft
Energy Grade at	61.60 ft
Hydraulic Grade :	49.43 ft
Hydraulic Grade :	61.40 ft
Flow Area	0.5 ft <sup>2</sup>
Wetted Perimeter	2.62 ft
<b>Velocity</b>	<b>3.60 ft/s</b>
Velocity Head	0.20 ft
Friction Slope	0.003747 ft/ft

---

# FlowMaster Worksheet - Exist 8" Force Main Fixture Losses

## Worksheet for Pressure Pipe

---

### Project Description

---

Worksheet	Exist 8" Force Main - Fixture L
Flow Element	Pressure Pipe
Method	Hazen-Williams Formula
Solve For	Pressure at 1

---

---

### Input Data

---

Pressure at	20.78	psi
Elevation at	1.50	ft
Elevation at	1.50	ft
Length	26.00	ft
C Coefficient	150.0	
Diameter	8	in
Discharge	1.270	mgd

---

---

### Results

---

Pressure at 1	20.65	psi
<b>Headloss</b>	<b>-0.29</b>	<b>ft</b>
Energy Grade at	49.63	ft
Energy Grade at	49.92	ft
Hydraulic Grade :	49.14	ft
Hydraulic Grade :	49.43	ft
Flow Area	0.3	ft <sup>2</sup>
Wetted Perimeter	2.09	ft
Velocity	5.63	ft/s
Velocity Head	0.49	ft
Friction Slope	.011110	ft/ft

---

# FlowMaster Worksheet - Proposed 10" Force Main Fixture Losses

## Worksheet for Pressure Pipe

---

### Project Description

---

Worksheet	Proposed 10" Force Main - Fixtur
Flow Element	Pressure Pipe
Method	Hazen-Williams Formula
Solve For	Pressure at 1

---

---

### Input Data

---

Pressure at :	0.00 psi
Elevation at	1.50 ft
Elevation at	61.40 ft
Length	46.00 ft
C Coefficient	150.0
Diameter	10 in
Discharge	1.270 mgd

---

---

### Results

---

Pressure at 1	25.73 psi
<b>Headloss</b>	<b>-0.55 ft</b>
Energy Grade at	61.05 ft
Energy Grade at	61.60 ft
Hydraulic Grade :	60.85 ft
Hydraulic Grade :	61.40 ft
Flow Area	0.5 ft <sup>2</sup>
Wetted Perimeter	2.62 ft
Velocity	3.60 ft/s
Velocity Head	0.20 ft
Friction Slope	0.003747 ft/ft

---

# **Attachment 7**


**TMK Maps showing Route 2 Private Properties**



True North  
Scale: 1 in. = 50 Ft.

28 Arthur G. Hook - 1/2  
Willis S. Hook & w/f  
Clara L.H. - 1/2 - 1/2  
(William R. Anderson &  
w/f Ellen K. - 1/2) A/S

Begin Force Main  
(Route 2) through  
private properties



DWG. NO. 4090  
SOURCE: Map by K. Hanatani Direct Tracing  
BY: H.N./S.I. July 1952

POR KALOKOHANAHOU, KANEOHE, OAHU (Formerly Por 4-5-01 & 4-5-02)

SUBJECT TO CHANGE

DEPARTMENT OF THE TAX COMMISSIONER			
TAXATION MAPS BUREAU			
TERRITORY OF HAWAII			
TAX MAP			
FIRST	DIVISION		
ZONE	SEC.	PLAT	
4	5	57	
CONTAINING			PARCELS
SCALE: 1 IN. = 50 FT.			

# **Attachment 8**

**Budgetary Opinion of Probable Construction Cost**

**BUDGETARY OPINION OF PROBABLE COST**  
**Kahanahou WWPS Force Main Sewer Line Study**  
**New 10" Force Main - Route 2**

Date: December 2013

ITEM NO.	DESCRIPTION	QTY	UNIT	UNIT COST	TOTAL COST
	<b>NEW 10" FORCE MAIN</b>				
	10" HDPE Force Main Sewer (includes A.C. re-pave, trench, backfill)	3,240	LF	\$200	\$648,000
	6'x6' Valve Box and Switch Valve	1	EA	\$20,000	\$20,000
	Manual Pressure Release Valve & Box	3	EA	\$5,000	\$15,000
	Vault w/Access Tee	3	EA	\$10,000	\$30,000
	Concrete Jacket (through private properties)	750	LF	\$100	\$75,000
	Sewer Manhole	1	EA	\$7,000	\$7,000
	Connection to Existing Sewer Manhole	1	EA	\$3,000	\$3,000
	Connection to Existing Force Main	2	EA	\$3,000	\$6,000
	Temporary Traffic Control	1	LPSM	\$20,000	\$20,000
	Temporary Bypass Measures (at Kahanahou WWPS connection)	1	LPSM	\$50,000	\$50,000
	<b>NEW 8" GRAVITY MAIN (at Kahanahou WWPS)</b>				
	8" HDPE Gravity Sewer Line (includes concrete re-pave, trench, backfill)	108	LF	\$125	\$13,500
	Sewer Manhole	2	EA	\$5,000	\$10,000
	Connection to Existing Gravity Sewer	2	EA	\$2,000	\$4,000
	Temporary Bypass Measures (at Kahanahou WWPS connection)	1	LPSM	\$10,000	\$10,000
	Miscellaneous Site Work	1	LPSM	\$50,000	\$50,000
	Subtotal				\$961,500
	Mobilization (10% of subtotal)				\$96,150
	Contingency (25% of subtotal+mobilization)				\$264,413
	<b>GRAND TOTAL</b>				<b>\$1,322,063</b>


Notes:

1. This estimate is for budgetary and the final engineering report purposes only, and is subject to change as design progresses.
2. Overhead and profit are included in the above unit costs.
3. No piles for pipe support.




# **Attachment 9**


## **Construction Sequence Site Plan**



**CONNECTION AT FLOW TUBE**  
 (FROM 2005 FORCE MAIN CONSTRUCTION PLANS)  
 NOT TO SCALE



**CONNECTION AT EXIST. BALL VALVE**  
 (FROM 2005 FORCE MAIN CONSTRUCTION PLANS)  
 NOT TO SCALE



**SITE PLAN - KAHANAHOU WWPS**  
 NOT TO SCALE

DESCRIPTION	<b>FORCE MAIN AND GRAVITY MAIN CONCEPTUAL CONNECTION PLAN</b>		DEPARTMENT OF DESIGN AND CONSTRUCTION WASTEWATER DIVISION CITY AND COUNTY OF HONOLULU	
			<b>KAHANAHOU WASTEWATER</b> KANE OHE, OAHU	
OKAHARA AND ASSOCIATES	JOB NUMBER -	DATE OCTOBER 2013		


# **Attachment 10**

**SMA Exemption Letter**

File

DEPARTMENT OF PLANNING AND PERMITTING  
**CITY AND COUNTY OF HONOLULU**

650 SOUTH KING STREET, 7TH FLOOR • HONOLULU, HAWAII 96813  
TELEPHONE: (808) 768-8000 • FAX: (808) 768-6041  
DEPT. WEB SITE: www.honolulu.gov • CITY WEB SITE: www.honolulu.gov



MUFI HANNEMANN  
MAYOR

DAVID K. TANOUE  
DIRECTOR  
ROBERT M. SUMITOMO  
DEPUTY DIRECTOR


2010/ELOG-449(AA)

March 10, 2010

**MEMORANDUM**

TO: CRAIG I. NISHIMURA, P.E., DIRECTOR  
DEPARTMENT OF DESIGN AND CONSTRUCTION

ATTENTION: WASTEWATER DIVISION

FROM:  DAVID K. TANOUE, DIRECTOR  
DEPARTMENT OF PLANNING AND PERMITTING

SUBJECT: SPECIAL MANAGEMENT AREA DETERMINATION  
KAHANAHOU WASTEWATER PUMP STATION UPGRADE PROJECT  
45-13 KA HANAHOU PLACE - KANEOHE  
TAX MAP KEY: 4-5-47: 95

This responds to your request, received on March 3, 2010, for information on the Special Management Area (SMA) use permit requirements to upgrade an existing wastewater pump station facility in the SMA.

The project will entail miscellaneous site improvements, and the repair and/or replacement of pumps, piping, mechanical and electrical equipment, emergency power system, structures, and ventilation system within an existing building. The project site is in the SMA; however, we confirm that the project will not require an SMA use permit pursuant to Sections 25-1.3(2)(D) and (M), Revised Ordinances of Honolulu. The proposed work is not expected to have any significant environmental or ecological effect on the SMA.

The project is subject to the environmental compliance law of Chapter 343 HRS. The applicant indicates that the project is exempt pursuant to Exemption Class #2 (Item 7) of the Department of Environmental Services Comprehensive Exemption List.

If you have any questions, please contact Ann Asaumi of our staff at 768-8020.


DKT:nw

2010/ELOG-449

DEPARTMENT OF DESIGN AND CONSTRUCTION  
CITY AND COUNTY OF HONOLULU

650 SOUTH KING STREET, 11<sup>TH</sup> FLOOR  
HONOLULU, HAWAII 96813  
Phone: (808) 768-8480 • Fax: (808) 768-4567  
Web site: [www.honolulu.gov](http://www.honolulu.gov)

MUFI HANNEMANN  
MAYOR



CRAIG I. NISHIMURA, P.E.  
DIRECTOR

COLLINS D. AM P.E.  
DEPUTY DIRECTOR

WW.P10-046

March 3, 2010

MEMORANDUM

TO: DAVID K. TANOUE, DIRECTOR  
DEPARTMENT OF PLANNING AND PERMITTING

FROM: *For* *Craig I. Nishimura*  
CRAIG I. NISHIMURA, P.E., DIRECTOR  
DEPARTMENT OF DESIGN AND CONSTRUCTION

SUBJECT: KAHANAHOU WASTEWATER PUMP STATION UPGRADE PROJECT  
SPECIAL MANAGEMENT AREA (SMA) USE PERMITS

We are requesting your concurrence that the above mentioned project is exempt from the SMA Use permit.

The Kahanahou Wastewater Pump Station Upgrade Project has been initiated by the Department of Environmental Services to upgrade/replace pumps, piping, mechanical and electrical equipment, emergency power system, structures, ventilation system, and miscellaneous site improvements. The wastewater pump station site is identified by TMK: 4-5-047:95 (See enclosed plan).

It is our understanding that repair and maintenance of appurtenant structures such as sewer pump stations are exempt from SMA Use permits. The scope of this project will be limited to upgrading the sewer pump station. Upon completion of project, all adjacent ground features disturbed during construction will be restored to its original or better condition.

If you have any questions or require additional information to make your determination, please feel free to call Roy Tamashiro of the Wastewater Division at 768-8760

I hereby concur with the SMA exemption for Kahanahou Wastewater Pump Station Upgrade Project.

David K. Tanoue, Director  
Department of Planning & Permitting

Date

Enclosure

# **Attachment 11**

**October 15, 2013 Meeting Minutes**

**From:** [Bruce K. Meyers](#)  
**To:** ["Tamashiro, Roy J"](#)  
**Cc:** ["hilo@okahara.com"](#); ["oahu@okahara.com"](#); ["Nikaido, Jason Y"](#); ["Tyson Toyama"](#)  
**Subject:** Kahanahou Mtg Minutes and Schedule  
**Date:** Thursday, November 7, 2013 11:47:00 AM  
**Attachments:** [Route 2 - Public Roads and Upper Marina for report.pdf](#)

---

Hi Roy,

Here are the meeting minutes for your review and comment.

Kahanahou WWPS Meeting Minutes

October 15, 2013

CSM Conference Room, Halawa

1. Purpose of meeting is to present the Preliminary Engineering Report (PER) and approve the recommended route.
2. The Kahanahou WWPS will be upgraded to pump the future design flow of 1.27 MGD.
3. Existing 8" diameter force main does not have the capacity for this flow.
4. Existing receiving gravity line that the existing FM discharges into goes along the shoreline, under buildings, through very narrow corridors, and has had a history of leaks at the shoreline. It was decided not to continue to discharge the Kahanahou WWPS effluent into this system.
5. A new force main is to be constructed to bypass this gravity, main which flows into the Waikapoki WWPS and discharge directly into the Waikalua tributary via the gravity main on Makahio Street.
6. Waikapoki WWPS upgrade issues (not in scope).
  - a. In tight space and close to housing complex. Difficult to do significant upgrade.
  - b. Noise complaints.
  - c. The upgrade requirements are unknown at this time.
  - d. Removing Kahanahou WWPS tributary will reduce Waikapoki WWPS upgrade requirements.
7. The PER describes four alternatives routes and makes a recommendation (see attached map for recommended route). The discussion concentrated on the recommended route.
  - a. Route 1: The TDH exceeds 100 feet.
  - b. Route 2: Recommended route.
  - c. Route 3: Similar to Route 2 but goes through more private parcels and narrow corridors.
  - d. Route 4: Similar to Route 2 but goes through the lower elevations of the Makani Kai Marina. Discouraged by Marina manager.
8. Route 2:
  - a. Two private properties involved:
    1. Mr. Miyazaki has existing 5' wide easement. Try to increase easement width. Can fit FM in 5' easement if needed. Will concrete jacket.
    2. Makani Kai Marina has no existing easement. Will go through landscaped walkway. Concrete jacket also.
    3. Need to get City's Land Division involved.

4. Okahara to work on easement geometry.
  - b. Remaining route in City streets.
9. Pipe will be fusible HDPE pipe.
10. Install manual relief valves in lieu of the automatic air relief valves.
11. Install vaults with tee and cap for maintenance access in lieu of pressurized manholes.
12. Recommended route, Route 2 was approved.
13. Next steps by Okahara:
  - a. Finish Design Alternatives Report (DAR) for Kahanahou WWPS.
  - b. Proceed with environmental work.
  - c. Provide easement information to City.
  - d. Update schedule.
14. Meeting adjourned.

All, please provide comments by November 12, 2013.

Thanks,  
Bruce

**Bruce K. Meyers, P.E.**  
**Okahara and Associates, Inc.**

ENGINEERING CONSULTANTS

**Hilo Office:**

**200 Kohola Street, Hilo, HI 96720**

**Website:** [www.okahara.com](http://www.okahara.com)

**Phone: (808) 961-5527**

**Watts from Oahu: 538-7716**

**Cell: (808) 640-8544**

**Fax: (808) 961-5529**

**Email:** [bmeyers@okahara.com](mailto:bmeyers@okahara.com)

**Oahu Office:**

**677 Ala Moana Blvd. Suite 703**

**Honolulu, HI 96713-5415**


**Phone: (808) 524-1224**

**Fax: (808) 521-3151**

**CONFIDENTIALITY NOTICE:** *This e-mail message, including any attachments, is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure or distribution is prohibited. If you are not the intended recipient, please contact the sender by reply e-mail and destroy all copies of the original message. Any personal opinions expressed in this message do not necessarily represent the views of Okahara and Associates, Inc.*

**DISCLAIMER FOR ELECTRONIC ATTACHMENTS:** *Any use or reuse of original or altered files by the Owner or others without written verification by Okahara and Associates, Inc. or CADD adaptation from the specific purpose intended will be at the Owner's risk and full legal responsibility. A hard copy from Okahara and Associates, Inc. retains control over any variances or changes that might be introduced. Furthermore, the Owner will, to the fullest extent permitted by law, indemnify and hold Okahara and Associates, Inc. harmless from any and all claims, suits, liability, demands, or costs arising out of or resulting therefrom. Any verification of such adaptation by the Owner will entitle Okahara and Associates, Inc. to additional compensation at the then current rate.*





Google earth

feet  
meters







## **Appendix C**

Digital Flood Insurance Map (Federal Emergency Management Agency, 2013)  
City and County of Honolulu Department of Planning and Permitting, March 2010





MAP SCALE 1" = 1000'



NATIONAL FLOOD INSURANCE PROGRAM

PANEL 0270H

**FIRM**  
FLOOD INSURANCE RATE MAP

CITY AND COUNTY OF  
HONOLULU,  
HAWAII

PANEL 270 OF 395

(SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:

COMMUNITY	NUMBER	PANEL	SUFFIX
HONOLULU, CITY AND COUNTY OF	150001	0270	H

Notice to User: The Map Number shown below should be used when placing map orders; the Community Number shown above should be used on insurance applications for the subject community.



MAP NUMBER  
15003C0270H

MAP REVISED  
JANUARY 19, 2011

Federal Emergency Management Agency

This is an official copy of a portion of the above referenced flood map. It was extracted using F-MIT On-Line. This map does not reflect changes or amendments which may have been made subsequent to the date on the title block. For the latest product information about National Flood Insurance Program flood maps check the FEMA Flood Map Store at [www.msc.fema.gov](http://www.msc.fema.gov)



## **Appendix D**

Pre-Environmental Assessment Consultation





**Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades  
Preliminary Draft Environmental Assessment**

**APPENDIX D**

**Pre-Environmental Assessment Consultation**

The following parties were contacted during the preparation of the Draft Environmental Assessment. Those identified with a check mark provided comments

**CITY AND COUNTY OF HONOLULU**

Department of Environmental Services  
Department of Facility Maintenance  
Department of Planning and Permitting  
Department of Transportation Services  
Honolulu Board of Water Supply  
Honolulu Fire Department  
Honolulu Police Department  
Neighborhood Board #30: Kaneohe  
Honolulu City Council, District 3

**STATE OF HAWAII**

Department of Business, Economic Development & Tourism, Office of Planning  
✓ Department of Health, Environmental Management Division  
Department of Land and Natural Resources  
    Commission on Water Resource Management  
    ✓ Engineering Division  
    Office of Conservation and Coastal Lands  
State Historic Preservation Division  
Department of Transportation, Highways Division  
Office of Hawaiian Affairs  
University of Hawaii at Manoa  
    Environmental Center  
    Water Resources Research Center  
Hawaii State House of Representatives, District 48  
Hawaii State Senate, District 24

**UTILITY COMPANIES**

Hawaii Gas  
Hawaiian Electric Company  
Hawaiian Telcom

**Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades  
Preliminary Draft Environmental Assessment**

**APPENDIX D (continued)**

**Pre-Environmental Assessment Consultation**

The following parties were contacted during the preparation of the Draft Environmental Assessment. Those identified with a check mark provided comments:

**PRIVATE LANDOWNERS**

Makani Kai Marina townhouse complex

Affected landowners

NEIL ABERCROMBIE  
GOVERNOR OF HAWAII



LINDA ROSEN, M.D., M.P.H.  
DIRECTOR OF HEALTH

STATE OF HAWAII  
DEPARTMENT OF HEALTH  
P. O. BOX 3378  
HONOLULU, HI 96801-3378

In reply, please refer to:  
File:

LUD-1 4 5 047 095-ID1736  
Kahanahou WWPS initial Cons

May 23, 2014

Ms. Sherri Hiraoka, Senior Planner  
Townscape, Inc.  
Environmental and Community Planning  
900 Fort Street Mall Suite 1160  
Honolulu, Hawaii 96813

Dear Ms: Hiraoka:

Subject: Initial Consultation for the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades – start at TMK (1) 4-5-047: 095 / end at TMK (1) 4-5-002: 001  
Kahanahou WWPS – Makani Kai Marina, Kaneohe, Hawaii 96744

We appreciate the opportunity to review the subject initial consultation information for the proposed project and have determined that we have no comments to offer at this time.

Should you have any questions, please contact Mr. Mark Tomomitsu of our branch at 586-4294.

Sincerely,

SINA PRUDER, P.E., CHIEF  
Wastewater Branch

LM/MST:lmj

c: Ms. Laura McIntyre, DOH-Environmental Planning Office (14-037)  
Mr. George I. Atta, C&C of Honolulu, Dept. of Planning & Permitting 7<sup>th</sup> Floor

**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014


Ms. Sina Pruder, P.E., Chief  
Wastewater Branch  
Department of Health  
State of Hawai'i  
P.O. Box 3378  
Honolulu, HI 96801-3378

Subject: Response to comments on the preparation of an Environmental Assessment for the  
proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Ms. Pruder:

Thank you for informing us that the Wastewater Branch has no comments on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades at this time. Should you have any questions in the future, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherrj@townscapeinc.com.

Sincerely,



Sherri Hiraoka  
Senior Planner



STATE OF HAWAII  
DEPARTMENT OF HEALTH  
P. O. BOX 3378  
HONOLULU, HI 96801-3378

In reply, please refer to:  
File:  
EPO 14-087

May 16, 2014

Ms. Sherri Hiraoka, Senior Planner  
Townscape, Inc.  
900 Fort Street Mall, Suite 1160  
Honolulu, Hawaii 96813

Dear Ms. Hiraoka:

**SUBJECT: Initial Consultation for the Preparation of an Environmental Assessment for the Proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades**

The Department of Health (DOH), Environmental Planning Office (EPO), acknowledges receipt of your letter dated May 8, 2014. Thank you for allowing us to review and comment on the subject document. The document was routed to the relevant Environmental Health divisions and offices. They will provide specific comments to you if necessary. EPO recommends that you review the standard comments at:

<http://health.hawaii.gov/epo/home/landuse-planning-review-program/>.

You are required to adhere to all applicable standard comments.

You may also wish to review the recently revised Water Quality Standards Maps that have been updated for all islands. The new Water Quality Standards Maps (2013) can be found at:

<http://health.hawaii.gov/cwb/site-map/clean-water-branch-home-page/water-quality-standards/>

The EPO suggests that you examine the many sources available on strategies to support the sustainable and healthy design of communities and buildings, including the following sites:

State of Hawaii, Office of Planning: [www.planning.hawaii.gov](http://www.planning.hawaii.gov) and the 2013 ORMP;

U.H., School of Ocean and Earth Science and Technology: [www.soest.hawaii.edu](http://www.soest.hawaii.edu);

U.S. Health and Human Services: [www.hhs.gov/about/sustainability](http://www.hhs.gov/about/sustainability);

U.S. Environmental Protection Agency's sustainability programs: [www.epa.gov/sustainability](http://www.epa.gov/sustainability); and Intergovernmental Panel on Climate Change (IPCC):

[http://ipcc-wg2.gov/AR5/images/uploads/WGIIAR5-Chap29\\_FGDall.pdf](http://ipcc-wg2.gov/AR5/images/uploads/WGIIAR5-Chap29_FGDall.pdf)

The DOH encourages everyone to apply these sustainability strategies and principles early in the planning and review of projects. We also request that for future projects you consider conducting a Health Impact Assessment (HIA). More information is available at:

[www.cdc.gov/healthyplaces/hia.htm](http://www.cdc.gov/healthyplaces/hia.htm); and

[www.epa.gov/research/healthscience/health-impact-assessment.htm](http://www.epa.gov/research/healthscience/health-impact-assessment.htm).

We request you share all of this information with others to increase community awareness on sustainable, innovative, inspirational, and healthy community design.

Mahalo,

A handwritten signature in blue ink, appearing to read "Laura Leialoha Phillips McIntyre".

Laura Leialoha Phillips McIntyre, AICP  
Program Manager, Environmental Planning Office

**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014

Ms. Laura McIntyre, AICP  
Program Manager, Environmental Planning Office  
Department of Health  
State of Hawai'i  
P.O. Box 3378  
Honolulu, HI 96801-3378


Subject: Response to comments on the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Ms. McIntyre:


Thank you for commenting on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades. The project team has reviewed the DOH's Standard Comments and will address applicable comments during the design and permitting phases of the project.

Should you have any questions, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,



Sherri Hiraoka  
Senior Planner



## OFFICE OF PLANNING STATE OF HAWAII

NEIL ABERCROMBIE  
GOVERNOR

LEO R. ASUNCION  
ACTING DIRECTOR  
OFFICE OF PLANNING

235 South Beretania Street, 6th Floor, Honolulu, Hawaii 96813  
Mailing Address: P.O. Box 2359, Honolulu, Hawaii 96804

Telephone: (808) 587-2846  
Fax: (808) 587-2824  
Web: <http://planning.hawaii.gov/>

Ref. No. P-14440

May 29, 2014

Ms. Sherri Hiraoka  
Townscape, Inc.  
900 Fort Street Mall, Suite 1160  
Honolulu, Hawaii 96813

Dear Ms. Hiraoka:

**Subject:** Pre-Assessment Consultation Request for an Environmental Assessment for the Proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrade, Honolulu, Oahu, Hawaii; TMK: (1) 4-5-047:095; 4-5-057:15; 4-5-002:01

Thank you for the opportunity to provide comments on the Kahanahou Wastewater Pump Station Force Sewer Line Upgrades project. We have reviewed the documents you submitted to us by letter dated May 8, 2014, and have the following comments to offer:

1. The Office of Planning (OP) provides technical assistance to state and county agencies in administering the statewide planning system in Hawaii Revised Statutes (HRS) Chapter 226, the Hawaii State Plan. The Hawaii State Plan provides goals, objectives, priorities, and priority guidelines for growth, development, and the allocation of state resources. In particular, the Draft Environmental Assessment (Draft EA) should address how this project meets the principles to promote sustainability, see HRS § 226-108. The Sustainability Guidelines can be viewed or downloaded from the OP website at [http://files.hawaii.gov/dbedt/op/docs/OP\\_TAM\\_2013-12-03.pdf](http://files.hawaii.gov/dbedt/op/docs/OP_TAM_2013-12-03.pdf)
2. OP is the lead agency for the Hawaii Coastal Zone Management (CZM) Program. The coastal zone management area is defined as "all lands of the State and the area extending seaward from the shoreline to the limit of the State's police power and management authority, including the U.S. territorial sea" see HRS § 205A-1 (definition of "coastal zone management area"). The Draft EA should include a discussion of the proposed project's ability to meet the objectives and policies set forth in HRS § 205A-2. These objectives and policies include: recreational resources, historic resources, scenic and open space resources, coastal ecosystems, economic uses, coastal hazards, managing development, public participation, and marine resources.
3. The Draft EA should include the Coastal Zone Management Act, HRS Chapter 205A, in a list of "relationships to land use plans, policies, and controls."
4. In the Draft EA, please provide a list of any Federal, State, or county permits required for this project. A listing of required permits will allow the Office of Planning to determine whether a Coastal Zone Management Federal Consistency evaluation is necessary for this project.

5. A portion of the proposed project may lie within the Special Management Area (SMA) delineated by City and County of Honolulu. Please confirm with the City and County of Honolulu's Department of Planning and Permitting to make a determination on where your project lies in relation to the SMA boundaries and if a SMA permit or Shoreline Setback variance is required.
6. Because of the frequent rainy weather patterns for Windward, Oahu, and the close proximity of the project to Kaneohe Bay, this project may have nonpoint pollution implications on coastal waters. Trenching work for the sewer line upgrades and/or grading and clearing work for the pump station may result in erosion and sediment loss and have a negative environmental impact. Please review the Hawaii Watershed Guidance, which provides a summary and links to management measures that may be implemented to minimize coastal nonpoint pollution impact. Specifically, please examine page 122 (Site Development Management Measure for urban runoff). The Watershed Guidance can be viewed or downloaded from the OP website at [http://files.hawaii.gov/dbedt/op/czm/initiative/nonpoint/HI Watershed Guidance Final.pdf](http://files.hawaii.gov/dbedt/op/czm/initiative/nonpoint/HI_Watershed_Guidance_Final.pdf)
7. Please consider utilizing the OP's *Stormwater Impact Assessment* to identify and evaluate information on hydrology (i.e. proximity to drainage ways, stream channels, sensitive ecosystems in receiving waters), stressors (i.e. water quality and pollutants), sensitivity of resources (i.e. aquatic resources and riparian resources), and management considerations. This guidance document will assist in integrating stormwater impact assessment within your review process.

The purpose of this document is to provide guidance on assessing stormwater impacts in the planning phase of project development. The goal is to provide a suggested framework and various tools for integrating stormwater impacts assessment. The Appendices include a list of Data Resources, Best Management Practice Techniques and a Reviewers Checklist. The *Stormwater Impact Assessment* guidance document can be found at [http://files.hawaii.gov/dbedt/op/czm/initiative/stomwater\\_impact/final\\_stormwater\\_impact\\_assessments\\_guidance.pdf](http://files.hawaii.gov/dbedt/op/czm/initiative/stomwater_impact/final_stormwater_impact_assessments_guidance.pdf).

If you have any questions regarding this comment letter, please contact Josh Hekeia of our Hawaii CZM Program at 587-2845.

Sincerely,



Leo R. Asuncion  
Acting Director



**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014

Mr. Josh Hekeia  
Hawaii CZM Program, Office of Planning  
Dept. of Business, Economic Development & Tourism  
State of Hawai'i  
235 South Beretania Street, 6<sup>th</sup> Floor  
Honolulu, HI 96804

Subject: Response to comments on the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Mr. Hekeia:

Thank you for commenting on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades. Your comments will be addressed either in the Draft Environmental Assessment or during the design and permitting phases of the project.

Should you have any questions, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,



Sherri Hiraoka  
Senior Planner

NEIL ABERCROMBIE  
GOVERNOR OF HAWAII



**STATE OF HAWAII**  
**DEPARTMENT OF LAND AND NATURAL RESOURCES**

ENGINEERING DIVISION  
POST OFFICE BOX 373  
HONOLULU, HAWAII 96809

**MAY 22 2014**

**WILLIAM J. AILA, JR.**  
CHAIRPERSON  
BOARD OF LAND AND NATURAL RESOURCES  
COMMISSION ON WATER RESOURCE MANAGEMENT

**JESSE SOUKI**  
FIRST DEPUTY DIRECTOR

**WILLIAM M. TAM**  
DEPUTY DIRECTOR - WATER

AQUATIC RESOURCES  
BOATING AND OCEAN RECREATION  
BUREAU OF CONVEYANCES  
COMMISSION ON WATER RESOURCE MANAGEMENT  
CONSERVATION AND COASTAL LANDS  
CONSERVATION AND RESOURCES ENFORCEMENT  
ENGINEERING  
FORESTRY AND WILDLIFE  
HISTORIC PRESERVATION  
KAHOOLAWE ISLAND RESERVE COMMISSION  
LAND  
STATE PARKS

Ms. Sherri Hiraoka, Senior Planner  
Townscape, Inc.  
900 Fort Street Mall, Suite 1160  
Honolulu, Hawaii 96813

Dear Ms. Hiraoka:

**Initial Consultation for the Preparation of an Environmental Assessment for the  
Proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades**

Thank you for the opportunity to provide comments on any issues that may be identified as important and addressed in the subject environmental assessment.

According to the Flood Insurance Rate Map (FIRM), the project site is located in Zone X. The National Flood Insurance Program (NFIP) does not regulate developments within Zone X. A copy of the Flood Hazard Assessment Report, which contains the FIRM, is enclosed for your information and use.

Should you have any questions, please call Mr. Dennis Imada of my staff at 587-0257, or email him at [dennis.t.imada@hawaii.gov](mailto:dennis.t.imada@hawaii.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "Carty S. Chang".

**CARTY S. CHANG**  
Chief Engineer

DI:et  
Enclosure



**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014

Mr. Dennis Imada  
Engineering Division  
Department of Land and Natural Resources  
State of Hawai'i  
P.O. Box 373  
Honolulu, HI 96809

Subject: Response to comments on the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Mr. Imada:


Thank you for commenting on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades. We understand that the proposed project is in Zone X on the Flood Insurance Rate Map, which the National Flood Insurance Program does not regulate. This will be noted in the Draft Environmental Assessment.

Should you have any questions, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,



Sherri Hiraoka  
Senior Planner



**STATE OF HAWAII**  
**DEPARTMENT OF TRANSPORTATION**  
869 PUNCHBOWL STREET  
HONOLULU, HAWAII 96813-5097

FORD N. FUCHIGAMI  
INTERIM DIRECTOR

Deputy Directors  
RANDY GRUNE  
AUDREY HIDANO  
ROSS HIGASHI  
JADINE URASAKI  
IN REPLY REFER TO:

**HWY-1920**  
**HWY-PS 2.7310**

June 3, 2014

Ms. Sherri Hiraoka  
Townscape, Inc.  
900 Fort Street Mall, Suite 1160  
Honolulu, Hawaii 96813

Dear Ms. Hiraoka:

Subject: Consultation for Preparation of an Environmental Assessment  
Kahanahou Wastewater Pumping Station and Force Main, Kaneohe, Oahu  
TMK: (1) 4-5-047:095 (var. parcels)

Thank you for requesting our comments on the proposed improvement to the Kahanahou wastewater pumping station and installation of a new force main. The proposed project will take place in residential areas of Kaneohe in the general vicinity of the Makani Kai Marina.

The roads in this area are under the jurisdiction of the City and County of Honolulu. We have no comment on the proposed project.

If there are any questions, please contact Gary Ashikawa, Systems Planning Engineer, Highways Division, Planning Branch, at 587-6336. Please reference file review number 2014-098 in all contacts and correspondence regarding these comments.

Very truly yours,

A handwritten signature in blue ink that reads "Alvin A. Takeshita".

Alvin A. Takeshita  
Highways Administrator

**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014


Mr. Gary Ashikawa  
Systems Planning Engineer  
Department of Transportation Highways Division  
State of Hawai'i  
869 Punchbowl Street  
Honolulu, HI 96813-5097

Subject: Response to comments on the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Mr. Ashikawa:

Thank you for informing us that the Department of Transportation has no comments on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades at this time. Should you have any questions in the future, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,



Sherri Hiraoka  
Senior Planner

# Clean Water Branch Standard Comments

October 22, 2013

## Clean Water Branch

The Clean Water Branch (CWB) protects the public health of residents and tourists who enjoy playing in and around Hawaii's coastal and inland water resources. The CWB also protects and restores inland and coastal waters for marine life and wildlife. This is accomplished through statewide coastal water surveillance and watershed-based environmental management through a combination of permit issuance, monitoring, enforcement, sponsorship of polluted runoff control projects, and public education.

## Permit Issuance

- Any project and its potential impacts to State waters must meet the State's:
  - 1) Antidegradation policy, which requires that the existing uses and the level of water quality necessary to protect the existing uses of the receiving State water be maintained and protected;
  - 2) Designated uses, as determined by the classification of the receiving State waters; and
  - 3) Water quality criteria [Hawaii Administrative Rules (HAR), Chapter 11-54].
- A Section 401 Water Quality Certification (WQC) is required:
  - If your project/activity requires a federal license or permit; and
  - May result in a discharge into State waters. The term "discharge" is defined in Clean Water Act, Subsections 502(16), 502(12), and 502(6); Title 40 of the Code of Federal Regulations (CFR), Section 122.2; and HAR, Chapter 11-54.

Typical federal license or permits that may trigger a Section 401 WQC include the Department of the Army permits (Tel: 808-438-9258), Federal Energy Regulatory Commission permits (Tel: 202-502-6088), and Environmental Protection Agency permits (Tel: 415-947-8000).

To request a Section 401 WQC, you must complete and submit the Section 401 WQC application. This application is available on the e-Permitting Portal website located at: <https://eha-cloud.doh.hawaii.gov/epermit/View/home.aspx>.

- National Pollutant Discharge Elimination System (NPDES) permit coverage is required for:
  - Storm water associated with construction activities for land disturbances of one (1) acre or more. Land disturbance includes, but is not limited to, clearing, grading, grubbing, excavation, demolition, uprooting of vegetation, equipment staging, and storage areas.
  - Storm water associated with industrial activities for facilities with Standard Industrial Classification Codes regulated in 40 CFR 122.26(b)(14)(i) through (ix) and (xi).

- Storm water and certain non-storm water from a small Municipal Separate Storm Sewer System.
- Discharges of water pollutants into State surface waters. Examples of these discharges include, but are not limited to, cooling water, hydrotesting waters, dewatering effluent, and process wastewater.
- Discharges from the application of pesticides (including insecticides, herbicides, fungicides, rodenticides, and various other substances to control pest) to State waters.

An application for an NPDES individual permit must be submitted at least 180 calendar days before the commencement of the discharge or start of construction activities. To request an NPDES individual permit, you must complete and submit the NPDES individual permit application. This application is available on the e-Permitting Portal website located at:

<https://eha-cloud.doh.hawaii.gov/epermit/View/home.aspx>.

A Notice of Intent (NOI) for coverage under a specific NPDES general permit must be submitted at least 30 calendar days before the commencement of the discharge or start of construction activities. To request NPDES general permit coverage, you must complete and submit the NOI. The NOI is available on the e-Permitting Portal website located at: <https://eha-cloud.doh.hawaii.gov/epermit/View/home.aspx>.

- According to State law, all discharges related to the project construction or operation activities, whether or not NPDES permit coverage and/or Section 401 WQC are required, must comply with the State's Water Quality Standards.

### **Monitoring**

- Effluent discharge and/or receiving water monitoring may be required as conditions of Section 401 Water Quality Certifications and NPDES General and Individual permits.

### **Enforcement**

- Noncompliance with water quality requirements contained in HAR, Chapter 11-54 and/or permitting requirements specified in HAR, Chapter 11-55 may be subject to penalties of \$25,000 per day per violation.

### **Polluted Runoff Control Projects**

- Projects to address polluted runoff, identified in Watershed Based Plans, which meet EPA and State criteria, may qualify for federal grants administered by our office.



- At a minimum, grant funds must be matched 25% with match funding or in-kind contributions from non-federal sources and are subject to the requirements of EPA 40 CFR Chapter 1 (7-1-98 Edition), Section 31.24 Matching or Cost Sharing.
- Request for Proposals to solicit qualified projects for grant funding are issued on an annual basis and interested parties can request to be placed on a mailing list to receive a copy of the RFP when it is issued. The deadline for submittal of a proposal is usually one (1) month from the date of the RFP. For more information, please read our website at: <http://health.hawaii.gov/cwb/>.

**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014

Mr. Alec Wong, P.E., Chief  
Clean Water Branch  
Department of Health  
State of Hawai'i  
P.O. Box 3378  
Honolulu, HI 96801-3378


Subject: Response to comments on the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Mr. Wong:

Thank you for commenting on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades. The project team has reviewed the Clean Water Branch's Standard Comments (October 22, 2013) and will address them during the design and permitting phases of the project.

Should you have any questions, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,



Sherri Hiraoka  
Senior Planner

POLICE DEPARTMENT  
CITY AND COUNTY OF HONOLULU

801 SOUTH BERETANIA STREET · HONOLULU, HAWAII 96813  
TELEPHONE: (808) 529-3111 · INTERNET: [www.honolulu.org](http://www.honolulu.org)



KIRK CALDWELL  
MAYOR

LOUIS M. KEALOHA  
CHIEF

DAVE M. KAJIHIRO  
MARIE A. MCCAULEY  
DEPUTY CHIEFS

OUR REFERENCE EO-WS

May 29, 2014

Dear Ms. Hiraoka:

This is in response to your letter dated May 8, 2014, requesting comments on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades project.


The Honolulu Police Department anticipates possible short-term impacts to neighborhood vehicular and pedestrian traffic during the construction phase of the project. The roadways that may be impacted are Springer Place, Ka Hanahou Place, Lilipuna Road, and Makahio Street.

We recommend that adequate personnel be hired to conduct traffic control. Additionally, we recommend that all necessary signs, lights, barricades, cones, and other safety equipment be installed and maintained by the contractor to facilitate the flow of vehicular and pedestrian traffic during certain phases of the construction. The contractor should give adequate notice to inform the public of any construction related road closures in the project area.

If there are any questions, please contact Major Ryan Borges of District 4 (Kaneohe/Kailua/Kahuku) at 723-8639 or via e-mail at [rborges@honolulu.gov](mailto:rborges@honolulu.gov).

Sincerely,

LOUIS M. KEALOHA  
Chief of Police

By   
RANDAL K. MACADANGDANG  
Assistant Chief  
Support Services Bureau

**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014

Major Ryan Borges  
Honolulu Police Department, District 4  
City and County of Honolulu  
801 South Beretania Street  
Honolulu, HI 96813


Subject: Response to comments on the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Major Borges:

Thank you for commenting on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades. Your comments regarding short-term traffic impacts will be addressed in the Draft Environmental Assessment or during the design and permitting phases of the project.

Should you have any questions, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,



Sherri Hiraoka  
Senior Planner

HONOLULU FIRE DEPARTMENT  
**CITY AND COUNTY OF HONOLULU**

636 South Street  
Honolulu, Hawaii 96813-5007  
Phone: 808-723-7139 Fax: 808-723-7111 Internet: [www.honolulu.gov/hfd](http://www.honolulu.gov/hfd)

KIRK CALDWELL  
MAYOR



MANUEL P. NEVES  
FIRE CHIEF

LIONEL CAMARA JR.  
DEPUTY FIRE CHIEF

May 29, 2014

Ms. Sherri Hiraoka, Senior Planner  
Townscape, Inc.  
900 Fort Street Mall, Suite 1160  
Honolulu, Hawaii 96813

Dear Ms. Hiraoka:

Subject: Initial Consultation for the Preparation of an Environmental Assessment  
Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

In response to your letter of May 8, 2014, regarding the above-mentioned subject, the Honolulu Fire Department determined that there will be no significant impact to fire department services.

Please notify Battalion Chief (BC) Alan Carvalho of our Fire Operations at 723-7182 or [acarvalho@honolulu.gov](mailto:acarvalho@honolulu.gov) to discuss possible road closures and alternate routes before the project commences.

Should you have questions, please contact Acting BC Terry Seelig of our Fire Prevention Bureau at 723-7151 or [tseelig@honolulu.gov](mailto:tseelig@honolulu.gov).

Sincerely,

A handwritten signature in blue ink that reads "Socrates D. Bratakos".

SOCRATES D. BRATAKOS  
Assistant Chief

SDB/SY:bh

cc: Fire Operations

**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014

Terry Seeling  
Acting Battalion Chief  
Honolulu Fire Department, Fire Prevention Bureau  
City and County of Honolulu  
636 South Street  
Honolulu, HI 96813-5007

Subject: Response to comments on the preparation of an Environmental Assessment for the  
proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Acting Battalion Chief Seelig:

Thank you for commenting on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades. Coordination with the Honolulu Fire Department regarding possible road closures and alternate routes will occur during the design and permitting phases of the project.

Should you have any questions, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,




Sherri Hiraoka  
Senior Planner

DEPARTMENT OF TRANSPORTATION SERVICES  
CITY AND COUNTY OF HONOLULU

650 SOUTH KING STREET, 3RD FLOOR  
HONOLULU, HAWAII 96813  
Phone: (808) 768-8305 • Fax: (808) 768-4730 • Internet: www.honolulu.gov

KIRK CALDWELL  
MAYOR



MICHAEL D. FORMBY  
DIRECTOR

MARK N. GARRITY, AICP  
DEPUTY DIRECTOR

TP5/14-562448R

June 5, 2014

Ms. Sherri Hiraoka  
Senior Planner  
Townscape, Inc.  
900 Fort Street Mall, Suite 1160  
Honolulu, Hawaii 96813

Dear Ms. Hiraoka:

SUBJECT: Initial Consultation for Environmental Assessment  
Kahanahou Wastewater Pump Station Force Main  
Sewer Line Upgrades; Kaneohe, Oahu, Hawaii

In response to your letter dated May 8, 2014, we have the following comments:

1. The Draft Environmental Assessment should discuss any short-term traffic impacts that the project may have on any surrounding City roadways during construction and measures to mitigate these impacts.
2. The local Neighborhood Board, as well as the area residents, businesses, emergency personnel, Oahu Transit Services, Inc. (TheBus), etc., should be kept apprised of the details of the proposed project and the impacts, particularly during construction, the project may have on the adjoining local street area network.
3. Any construction materials and equipment should be transferred to and from the project site during off-peak traffic hours (8:30 a.m. to 3:30 p.m.) to minimize any possible disruption to traffic on the local streets.
4. Should the project require any temporary lane closure on a City street, a street usage permit will be required from our department. A traffic plan should be submitted to our Street Usage Section for approval.

Ms. Sherri Hiraoka  
June 5, 2014  
Page 2

Thank you for the opportunity to review this matter. Should you have any questions, please contact Renee Yamasaki of my staff at 768-8383.

Very truly yours,

A handwritten signature in black ink, appearing to read "Michael D. Formby". The signature is fluid and cursive, with a long horizontal stroke at the end.

Michael D. Formby  
Director



**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014

Ms. Renee Yamasaki  
Department of Transportation Services  
City and County of Honolulu  
650 South King Street, 3<sup>rd</sup> Floor  
Honolulu, HI 96813

Subject: Response to comments on the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Ms. Yamasaki:

Thank you for commenting on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades. Your comments regarding short-term traffic impacts will be addressed in the Draft Environmental Assessment or during the design and permitting phases of the project.

Should you have any questions, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,



Sherri Hiraoka  
Senior Planner

**BOARD OF WATER SUPPLY**

CITY AND COUNTY OF HONOLULU  
630 SOUTH BERETANIA STREET  
HONOLULU, HI 96843



May 29, 2014

KIRK CALDWELL, MAYOR

DUANE R. MIYASHIRO, Chair  
MAHEALANI CYPHER, Vice Chair  
THERESIA C. McMURDO  
ADAM C. WONG  
DAVID C. HULIHEE

ROSS S. SASAMURA, Ex-Officio  
FORD N. FUCHIGAMI, Ex-Officio

ERNEST Y. W. LAU, P.E.  
Manager and Chief Engineer

ELLEN E. KITAMURA, P.E.  
Deputy Manager and Chief Engineer *ELK*

Ms. Sherri Hiraoka, Senior Planner  
Townscape, Inc.  
900 Fort Street Mall, Suite 1160  
Honolulu, Hawaii 96813

Dear Ms. Hiraoka:

Subject: Your Letter Dated May 8, 2014 on the Environmental  
Assessment Initial Consultation for the Kahanahou  
Wastewater Pump Station Force Main Sewer Line Upgrades

Thank you for the opportunity to comment on the proposed sewer line upgrades.

The construction drawings should be submitted for our review.

The construction schedule should be coordinated to minimize impact to the water system.

If you have any questions, please contact Robert Chun, Project Review Branch of our Water Resources Division at 748-5443.

Very truly yours,

ERNEST Y. W. LAU, P.E.  
Manager and Chief Engineer

**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

June 6, 2014

Mr. Robert Chun  
Project Review Branch  
Water Resources Division  
Honolulu Board of Water Supply  
City and County of Honolulu  
630 South Beretania Street  
Honolulu, HI 96843


Subject: Response to comments on the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Mr. Chun:

Thank you for commenting on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades. Your comments regarding submission of construction drawings and schedule to the Board of Water Supply will be addressed in the Draft Environmental Assessment or during the design and permitting phases of the project.

Should you have any questions, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,



Sherri Hiraoka  
Senior Planner



June 5, 2014

Townscape, Inc.  
Environmental and Community Planning  
900 Fort Street Mall, Suite 1160  
Honolulu, Hawaii 96813  
Attention: Ms. Sherri Hiraoka

Dear Ms. Hiraoka:

Subject: **Initial consultation for the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades**

Thank you for the opportunity to review and comment on the initial consultation phase for the subject project.

In response to your letter dated May 8, 2014, Hawaiian Telcom does not have any comments to offer at this time.

If you have any questions or require assistance in the future on this project, please call me at 546-7761.

Sincerely,



Les Loo  
Network Engineer – OSP Engineering  
Network Engineering & Planning

cc: File [Kaneohe]



**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014


Mr. Les Loo  
Network Engineer – OSP Engineering  
Hawaiian Telcom  
P.O. Box 2200  
Honolulu, HI 96841

Subject: Response to comments on the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Mr. Loo:

Thank you for informing us that Hawaiian Telcom has no comments on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades at this time. Should you have any questions in the future, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,



Sherri Hiraoka  
Senior Planner

## **Sherri Hiraoka**

---

**From:** Liu, Rouen <rouen.liu@hawaiianelectric.com>  
**Sent:** Thursday, June 12, 2014 1:34 PM  
**To:** Sherri Hiraoka  
**Cc:** 1.11.136609@ecollab.heco.com  
**Subject:** Initial consultation - request for comments on the Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Ms. Hiraoka,

Thank you for the opportunity to comment on the subject project. Hawaiian Electric Company has no objections to the project. Should HECO have existing easements and facilities on the subject property, we will need continued access for maintenance of our facilities.

We appreciate your efforts to keep us apprised of the subject project in the planning process. As the Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades comes to fruition, please continue to keep us informed. Further along in the design, we will be better able to evaluate the effects on our system facilities.

If you have any questions, please call me at 543-7245.

Sincerely,  
Rouen Q. W. Liu  
Permits Engineer

---

CONFIDENTIALITY NOTICE: This e-mail message, including any attachments, is for the sole use of the intended recipient(s) and may contain confidential and/or privileged information. Any unauthorized review, use, copying, disclosure or distribution is prohibited. If you are not the intended recipient, please contact the sender immediately by reply e-mail and destroy the original message and all copies.

**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014

Mr. Rouen Q. W. Liu  
Permits Engineer  
Hawaiian Electric Co.  
P.O. Box 2750  
Honolulu, HI 96840


Subject: Response to comments on the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Mr. Liu:

Thank you for informing us that HECO has no comments on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades at this time. We will continue to inform you of the project as it progresses to ensure coordination among the utilities.

Should you have any questions in the future, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,




Sherri Hiraoka  
Senior Planner

DEPARTMENT OF FACILITY MAINTENANCE  
**CITY AND COUNTY OF HONOLULU**

1000 Ulu`ohia Street, Suite 215, Kapolei, Hawaii 96707  
Phone: (808) 768-3343 • Fax: (808) 768-3381  
Website: www.honolulu.gov

KIRK CALDWELL  
MAYOR



ROSS S. SASAMURA, P.E.  
DIRECTOR AND CHIEF ENGINEER

EDUARDO P. MANGLALLAN  
DEPUTY DIRECTOR

IN REPLY REFER TO:  
DRM 14-500

June 25, 2014

Ms. Sherri Hiraoka, Senior Planner  
Townscape, Inc.  
900 Fort Street Mall, Suite 1160  
Honolulu, Hawaii 96813

Dear Ms. Hiraoka:

**SUBJECT:** Initial Consultation for the Preparation of an  
Environmental Assessment for the proposed  
Kahanahou Wastewater Pump Station Force  
Main Sewer Line Upgrade

Thank you for opportunity to review and comment on the subject project. We apologize for the late response. Our comments are as follows:

- Once construction phase commences, install approved Best Management Practice fronting all drainage facilities (catch basin/drainage inlets along the subject sewer line route).
- During construction and upon completion of project; any damages/deficiencies to any City maintained roadway's right-of-ways shall be corrected to City standards and accepted by the City.

If you have any questions, please call Mr. Kyle Oyasato of the Division of Road Maintenance, at 768-3600.

Sincerely,

A handwritten signature in black ink, appearing to read "Ross S. Sasamura".

Ross S. Sasamura, P.E.  
Director and Chief Engineer



**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014

Mr. Kyle Oyasato  
Division of Road Maintenance  
Department of Facility Maintenance  
City and County of Honolulu  
1000 Ulu'ohia Street, Suite 215  
Kapolei, HI 96707


Subject: Response to comments on the preparation of an Environmental Assessment for the  
proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Mr. Oyasato:

Thank you for commenting on the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades. Your comments regarding Best Management Practices and damages to City roadway rights of way will be addressed either in the Draft Environmental Assessment or during the design and permitting phases of the project.

Should you have any questions in the future, please contact the undersigned at (808) 536-6999, extension 6 or via email at sherri@townscapeinc.com.

Sincerely,



Sherri Hiraoka  
Senior Planner



June 30, 2014

Ms. Sherri Hiraoka  
Townscape, Inc.  
900 Fort Street Mall, Suite 1160  
Honolulu, Hawaii 96813

Dear Ms. Hiraoka:

Subject: Initial Consultation for the preparation of an Environmental Assessment (EA) for the proposed Kahanahou Wastewater Pump Force Main Sewer Line Upgrades

In response to your letter dated June 30, 2014, it has been determined that the area is currently clear of utility gas facilities.

Thank you for the opportunity to review the map. Should there be any questions, or if additional information is desired, please feel free to call Kris Tanner at 596-1425.

Sincerely,

Hawaii Gas

Keith K. Yamamoto  
Manager, Engineering

KKY:krs  
14-180

**TOWNSCAPE, INC.**  
ENVIRONMENTAL AND COMMUNITY PLANNING

---

900 Fort Street Mall, Suite 1160, Honolulu, HI 96813  
Telephone (808) 536-6999 Facsimile (808) 524-4998  
email address: mail@townscapeinc.com

July 9, 2014


Mr. Kris Tanner  
Hawai'i Gas  
P.O. Box 3000  
Honolulu, HI 96802-3000

Subject: Response to comments on the preparation of an Environmental Assessment for the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades

Dear Mr. Tanner:

Thank you for informing us that the proposed Kahanahou Wastewater Pump Station Force Main Sewer Line Upgrades project area is currently clear of utility gas facilities. Should you have any questions in the future, please contact the undersigned at (808) 536-6999, extension 6 or via email at [sherri@townscapeinc.com](mailto:sherri@townscapeinc.com).

Sincerely,



Sherri Hiraoka  
Senior Planner



## **Appendix E**

Archaeological Literature Review and Field Inspection,  
Kahanahou Wastewater Pump Station Force Main Sewer Line Study,  
Kaneohe Ahupuaa, Koolaupoko, Oahu, TMK: [1] 4-5-047:095  
Cultural Surveys Hawaii, January 2013



---

**Draft**

**Archaeological Literature Review and Field Inspection,  
Kahanahou Wastewater Pump Station Force Main Sewer  
Line Study, Kāne‘ohe Ahupua‘a, Ko‘olaupoko, O‘ahu,  
TMK: [1] 4-5-047:095**

**Prepared for  
Townscape, Inc.**

**Prepared by  
Constance R. O’Hare, B.A.,  
David W. Shideler, M.A.,  
and  
Hallett H. Hammatt, Ph.D.**

**Cultural Surveys Hawai‘i, Inc.  
Kailua, Hawai‘i  
(Job Code: KANEOHE 34)**

**January 2014**

---

**O‘ahu Office  
P.O. Box 1114  
Kailua, Hawai‘i 96734  
Ph.: (808) 262-9972  
Fax: (808) 262-4950**

[www.culturalsurveys.com](http://www.culturalsurveys.com)

**Maui Office  
1860 Main St.  
Wailuku, Hawai‘i 96793  
Ph: (808) 242-9882  
Fax: (808) 244-1994**

---

## Management Summary

<b>Reference</b>	Archaeological Literature Review and Field Inspection, Kahanahou Wastewater Pump Station Force Main Sewer Line Study, Kāneʻohe Ahupuaʻa, Koʻolaupoko, Oʻahu, TMK: [1] 4-5-047:095 (OʻHare et al. 2013)
<b>Date</b>	January 2014
<b>Project Number (s)</b>	Cultural Surveys Hawaiʻi, Inc. (CSH) Job Code: KANEOHE 34
<b>Investigation Permit Number</b>	CSH conducted the archaeological field inspection for this investigation under state archaeological permit number 13-06, issued by Hawaiʻi State Historic Preservation Division/Department of Land and Natural Resources (SHPD).
<b>Project Location</b>	The project area is located in the Kahanahou Subdivision, on portions of Ka Hanahou Place, Ka Hanahou Circle, Lilipuna Road, and Lilipuna Place; it then crosses Wailele Road and extends to a small portion of Makahīʻō Street.
<b>Land Jurisdiction</b>	State of Hawaiʻi
<b>Agencies</b>	State Historic Preservation Division/State of Hawaiʻi Department of Land and Natural Resources (SHPD), State of Hawaiʻi
<b>Project Description</b>	The City and County of Honolulu, Wastewater Division, is planning to replace a portion of the existing sewer line that extends from the Kahanahou Wastewater Pump Station and discharges at a sewer manhole on Makahia Street. The current force main consists of an 8-inch high density polyethylene (HDPE), which will be replaced by a 10-inch HDPE fusible pipe.
<b>Project Acreage</b>	The proposed sewer line is approximately 1,000 m long, covering 2.9 acres.
<b>Document Purpose</b>	This investigation is not an archaeological inventory survey, per the requirements of Hawaiʻi Administrative Rules (HAR) §13-276; however, through historical, cultural, and archaeological background research, and a field inspection of the project area, this investigation was intended to identify any cultural resources that may be affected by the project. This document is intended to facilitate the project's planning and support the project's historic preservation compliance. Based on results, cultural resource management recommendations are presented. <sup>1</sup>
<b>Fieldwork Effort</b>	The fieldwork component for this historical resources study was conducted on 9 December 2013 by CSH archaeologists Constance R. OʻHare, B.A. and David W. Shideler, M.A. This fieldwork consisted of a limited field inspection of the water line area to identify any surface archaeological features, and to investigate and assess the potential for impact to historic properties.



<b>Historic Properties Potentially Affected</b>	This field inspection did not observe any property of cultural significance. However, there is a potential for encountering pre-Contact and post-Contact subsurface cultural deposits related to traditional Native Hawaiian land use and habitation.
<b>Discussion of Project Effect and Recommendations</b>	<p>Based on this study's results, an archaeological inventory survey of the project area (per the requirements of HAR §13-276) does not appear warranted for development within the project area. Depending on the extent and location of ground disturbance during future proposed renovations in the project area, an archaeological monitoring program might be appropriate for portions of the project area as an historic preservation mitigation measure. Should the project proceed with open trench excavation then an archaeological monitoring program with on-site archaeological monitoring is recommended.</p> <p>Early consultation with the SHPD is recommended (to be informed by this study) to determine appropriate cultural resource management.</p>

<sup>1</sup> In historic preservation parlance, cultural resources are the physical remains and/or geographic locations that reflect the activity, heritage, and/or beliefs of ethnic groups, local communities, states and/or nations. Generally, they are at least 50 years old, although there are exceptions, and include buildings and structures; groupings of buildings or structures (historic districts); certain objects; archaeological artifacts, features, sites, and/or deposits; groupings of archaeological sites (archaeological districts); and, in some instances, natural landscape features and/or geographic locations of cultural significance.

# Table of Contents

<b>Management Summary .....</b>	<b>i</b>
<b>Section 1 Introduction .....</b>	<b>1</b>
1.1 Project Background .....	1
1.2 Scope of Work .....	1
1.3 Environmental Setting .....	7
1.3.1 Natural Environment.....	7
1.3.2 Built Environment .....	7
1.4 Methods .....	9
1.4.1 Field Methods .....	9
1.4.2 Document Review .....	9
<b>Section 2 Traditional and Historic Background .....</b>	<b>10</b>
2.1 Traditional Accounts .....	10
2.2 Historic Background.....	12
2.2.1 Pre-Contact Period.....	12
2.2.2 Early Historic Period to Mid-1800s.....	14
2.2.3 The Māhele (Land Divisions).....	16
2.2.4 Mid-1800s to early 1900s .....	17
2.2.5 1900s to the Present .....	25
<b>Section 3 Previous Archaeological Research .....</b>	<b>33</b>
3.1 Early Archaeological Surveys .....	33
3.2 Modern Archaeological Surveys .....	38
3.2.1 Proposed Nani Pua Gardens II Subdivision Project .....	38
3.2.2 Keaahala Military Reservation .....	38
3.2.3 Castle Hills Access Road Monitoring.....	39
3.2.4 Waikalua Road, Kāneʻohe Bay Project .....	39
3.2.5 Bay View Golf Course Archaeological Survey and Assessment .....	39
3.2.6 Waikalua Loko Fishpond Preservation Plan.....	40
3.2.7 Kāneʻohe Civic Center Playground Parking Lot .....	40
3.2.8 Kāneʻohe-Kailua Wastewater Conveyance Alternative Project .....	40
3.2.9 Bay View Golf Course/YMCA Sewer Line Rehabilitation Project .....	41
<b>Section 4 Results of Field Inspection and Recommendations .....</b>	<b>42</b>
4.1 Field Inspection .....	42
4.2 Summary and Recommendations .....	42
<b>Section 5 References Cited .....</b>	<b>52</b>
<b>Appendix A Land Commission Award Testimony in Vicinity of Project Area .....</b>	<b>57</b>

## List of Figures

Figure 1. Portion of 1998 Kaneohe USGS 7.5-Minute Series Topographic Quadrangle, showing the location of the project area.....	2
Figure 2. Aerial photograph (source: Google Earth 2013), showing the location of the project area .....	3
Figure 3. Tax Map Key (TMK) [1] 4-4-047, showing northern end of the project area .....	4
Figure 4. TMKs: [1] 4-4-045 (top) and [1] 4-4-057 (bottom) showing central section of the project area .....	5
Figure 5. TMKs: [1] 4-4-002 (top) and [1] 4-4-074 (bottom), showing southern end of the project area .....	6
Figure 6. Aerial photograph (Google Earth 2013) with overlay of USDA soil boundaries (soil information from Foote et al. 1972) .....	8
Figure 7. 1876 map of Kane‘ohe and West Kailua (portion), showing names and locations of ‘ili surrounding the project area (Lyons 1876); note the project area is within the ‘ili of Kalokohanahou and Kanohuli‘iwi, and on the boundary of the ‘ili of Lilipuna .	11
Figure 8. 1897 map of Kāne‘ohe and He‘eia (portion), showing Land Commission Awards near and within the project area (Monsarrat 1897) .....	18
Figure 9. 1931 map of land acquisition by the Kaneohe Land Company, Ltd. for lands in the ‘ili of Lilipuna, Kalaepaa, Kanohulu‘iwi, Waialele, Kalokohanahou, and Kaopulioloa (King 1931).....	20
Figure 10. 1906 map of O‘ahu (portion), showing land use in the project area (Donn 1906); note the project area is in the wetlands area (diagonal blue lines) used for taro and then rice cultivation, but also partially within the boundary of “pasture land” used for ranching (between two solid yellow lines) .....	21
Figure 11. 1887 photograph of Kāne‘ohe fishponds; Kalokohanahou (right background) and Kanohulu‘iwi (left center); ponds are unfilled (Hawai‘i State Archives 1887).....	26
Figure 12. 1930s photograph of west shore of Kāne‘ohe Bay, showing (from right to left) Kalokohanahou, Kanohulu‘iwi, Waikapoki, and Punalu‘u Fishponds (Hawai‘i State Archives 1930s); ponds are silted in .....	27
Figure 13. 1940s photograph of western shore of Kāne‘ohe Bay; Kalokohanahou Fishpond (center) has been filled to create the Kahanahou residential neighborhood (Hawai‘i State Archives 1940s).....	27
Figure 14. 1919 U.S. Army War Department fire control map, Waimanalo quadrangle, showing the project area with unfilled Kalokohanahou Pond; note the old ‘auwai is pictured as a ditch (dotted line) .....	28
Figure 15. 1936 U.S. Army War Department terrain map, Kaneohe quadrangle, showing the project area with unfilled Kalokohanahou Pond; there is no longer an ‘auwai or ditch labeled .....	29
Figure 16. 1943 U.S. Army War Department terrain map, Kaneohe quadrangle, showing the project area with Kalokohanahou and adjacent fishponds partially filled .....	30
Figure 17. 1954 Kaneohe USGS topographic quadrangle; Kalokohanahou has been filled to create the Kahanahou residential neighborhood, while other fishponds to the east remain unfilled but are modified .....	31

Figure 18. 1978 aerial USGS orthophotoquad, Kaneohe quadrangle; Punalu‘u Pond at the right of the photo remains untilled .....32

Figure 19. Previous archaeological studies in west coastal Kāne‘ohe near the project area .....34

Figure 20. Previously identified archaeological sites in west coastal Kāne‘ohe near the project .35

Figure 21. Kahanahou Wastewater Pump Station, eastern end of project area, view to northwest (CSH photograph).....43

Figure 22. Kahanahou Place, view southwest from Pump Station entrance; Kalokohanahou Fishpond wall remnant beneath *naupaka* hedge at left side of road (CSH photograph) .....43

Figure 23. Kalokohanahou Fishpond wall remnant covered by *naupauka* (CSH photograph).....44

Figure 24. Kalokohanahou Fishpond stacked stonewall remnant beneath *naupauka* (CSH photograph) .....44

Figure 25. Kahanahou Circle, view southeast back to Kahanahou Place (CSH photograph) .....45

Figure 26. Kahanahou Circle (front section) and Lilipuna Road (back section), view southwest toward junction with Lilipuna Place; note manhole in center of roadway (CSH photograph) .....45

Figure 27. Lilipuna Place, view west-southwest towards private property between Lilipuna Place and Wailele Road (CSH photograph) .....46

Figure 28. Lilipuna Place, view northwest toward the elevation of Pu‘u Pahu (left background), former location of Pu‘upahu Heiau; note manhole in left lane (CSH photograph) .....46

Figure 29. Private property between Wailele Road and Lilipuna Place, western section, view to east-northeast (CSH photograph).....47

Figure 30. Private property between Wailele Road and Lilipuna Place, central section, view to east-northeast (CSH photograph).....47

Figure 31. Private property between Wailele Road and Lilipuna Place, eastern section, view to east-northeast (CSH photograph).....48

Figure 32. Junction of Wailele Road and Makahī‘ō Street, western end of project area, view to west; note manhole in center of roadway (CSH photograph) .....48

Figure 33. Aerial photograph showing the location of the project area and two possible testing areas near Wailele Street (Google Earth 2013), .....50

Figure 34. 1931 map of land acquisition by the Kaneohe Land Company, Ltd., showing possible text excavation locations for the project area near the ‘*auwai* within LCA 10447 and LCA 8456 (King 1931).....51

## List of Tables

Table 1. Land Commission Awards in the Project Area .....19

Table 2. Previous Archaeological Studies in Kāne‘ohe near the Project Area.....36

---

## Section 1 Introduction

---

### 1.1 Project Background

At the request of Townscape, Inc. (900 Fort Street Mall, Suite 1160, Honolulu, Hawai'i 96813), Cultural Surveys Hawai'i, Inc., (CSH) has prepared this archaeological literature review and field inspection (LRFI) to the Kahanahou Wastewater Pump Station Force Main Sewer Line Study, Kāne'ohē Ahupua'a, Ko'olaupoko, O'ahu, TMK: [1] 4-5-047:095, as shown on a U.S. Geological Survey (USGS) topographic map (Figure 1), an aerial photograph (Figure 2), and three tax map plats (Figure 3 through Figure 5). The proposed sewer line is approximately 1,000 m long, covering 2.9 acres.

The project area is located in the Kahanahou Subdivision of Kāne'ohē, on portions of Ka Hanahou Place, Ka Hanahou Circle, Lilipuna Road, and Lilipuna Place; it then crosses Wailele Road and extends to a small portion of Makahī'ō Street, adjacent to portions of TMKs: [1] 4-4-002:045, 047, 057, and 074. The City and County of Honolulu, Wastewater Division, is planning to replace a portion of the existing sewer line that extends from the Kahanahou wastewater pump station and discharges at a sewer manhole on Makahia Street. The force main is located adjacent to roads in most sections, but also passes through some private properties between Lilipuna Place and Wailele Road. The current force main consists of an 8-inch high density polyethylene (HDPE), which will be replaced by a 10-inch HDPE fusible pipe.

This investigation is not an archaeological inventory survey, per the requirements of Hawai'i Administrative Rules (HAR) §13-276; however, through historical, cultural, and archaeological background research, and a field inspection of the project area, this investigation was intended to identify cultural resources that may be affected by the project. This document is intended to facilitate the project's planning and support the project's historic preservation compliance. Based on results, cultural resource management recommendations are presented.

### 1.2 Scope of Work

The scope of work for this project includes the following:

1. Historical research to include study of archival sources, historic maps, Land Commission Awards, and previous reports to construct a history of the project area and vicinity and to determine if there are any historic properties.
2. Limited field inspection of the project area. This assessment will identify any sensitive areas that may require further investigation for this report.
3. Preparation of a report to include the results of the historical research and the limited fieldwork assessment with recommendations for further work, if appropriate. It will also provide mitigation recommendation, if appropriate.




Figure 1. Portion of 1998 Kaneohe USGS 7.5-Minute Series Topographic Quadrangle, showing the location of the project area




Figure 2. Aerial photograph, showing the location of the project area (Google Earth 2013)




Figure 3. Tax Map Key (TMK) [1] 4-4-047, showing northern end of the project area






Figure 4. TMKs: [1] 4-4-045 (top) and [1] 4-4-057 (bottom) showing central section of the project area




Figure 5. TMKs: [1] 4-4-002 (top) and [1] 4-4-074 (bottom), showing southern end of the project area

## 1.3 Environmental Setting

### 1.3.1 Natural Environment

The lands within the project treatment areas are generally level with elevations ranging from 0 to 12 m (0 to 40 ft) above mean sea level. Rainfall in this portion of Kāneʻohe averages 1,000 mm (40 inches) per year (Giambelluca et al. 1986). The northern portion of the project area is within the former offshore fishpond, Kalokohanahou, which was filled to make the Ka Hanahou residential development around 1944. Thus all of the sediments in this area are Fill Land, which is a land type of areas filled with slurry from sugar mills, dredged material, and soil from excavations (Foote et al. 1972:31).

The central portion of the project area extends through an area of Kaneohe silty clay, 8 to 15% slopes (KcG) (Figure 6). Soils of the Keaau Series are described as:

. . . well-drained soils on terraces and alluvial fans on the windward side of Oahu. These soils developed in alluvium and colluviums derived from basic igneous rock. . . . These soils are used for pasture, homesites, and urban development. [Foote et al. 1972:59]

Common modern vegetation includes guava (*Psidium guajava*), Boston fern (*Nephrolepis exaltata*), sensitive plant (*Mimosa pudica*), Hamakua pamakani (*Ageratina riparia*), glenwoodgrass (*Sacciolepis indica*), and hilograss (*Paspalum conjugatum*).

The southern end of the project area is in an area covered with Lolekaa silty clay, 3 to 8% slopes (LoB) (Figure 6). Soils of the Lolekaa series are described as:

. . . well-drained soils on fans and terraces on the windward side of the island of Oahu. These soils developed in old, gravelly colluviums, and alluvium. . . . These soils are used for pasture, homesites, or chards, and truck crops. [Foote et al. 1972:83]

Common modern vegetation includes guava, christmasberry (*Schinus terebinthifolius*), koa haole (*Leucaena glauca*), californiagrass (*Brachiaria mutica*), ricegrass (*Paspalum orbiculare*), and hilograss.

### 1.3.2 Built Environment

The project area is in a residential section with houses set on both sides of the roads. The roads are generally two-lane streets with no sidewalks.




Figure 6. Aerial photograph (Google Earth 2013) with overlay of USDA soil boundaries (soil information from Foote et al. 1972)

## **1.4 Methods**

### **1.4.1 Field Methods**

The field inspection fieldwork was carried out 5 September 2013 by CSH archaeologists David W. Shideler and Constance R. O'Hare. One hour was required. All fieldwork was done under the general supervision of Hallett H. Hammatt, Ph.D. (principle investigator). CSH conducted the fieldwork component of this study under state archaeological fieldwork permit No. 13-06 issued by the State Historic Preservation Division (SHPD), per HAR §13-282. Representative photographs were taken of the project area.

### **1.4.2 Document Review**

Background research included a review of previous archaeological studies on file at the State Historic Preservation Division (SHPD) of the Department of Land and Natural Resources (DNLR). Archaeological reports, historic maps, and photographs contained within the CSH library were also consulted.

## Section 2 Traditional and Historic Background

---

### 2.1 Traditional Accounts

The project area is located within the Windward O'ahu district of Ko'olaupoko, in the *ahupua'a* (land division) of Kāne'ohē. This report section focuses on the traditional background of the near-coastal locations of the western shore of Kāne'ohē Bay.

Kāne'ohē is a large *ahupua'a* of approximately 8,000 acres, extending from the crest of the Ko'olau Range to the coast at Kāne'ohē Bay, and including most of the Mōkapu Peninsula. It is watered by three streams, the Kawā Stream, Kane'ohē Stream and its tributaries, and Kea'ahala ("the pandanus root") Stream. He'eia Ahupua'a is to the west and the boundary between these two *ahupua'a* at the coast extends from the boundary point called Pōhākea ("white stone") near the shore, inland to the peak called Pu'u Pahu. The project area is mainly located in the *'ili* (small land divisions) of Kalokohanahou and Kanahulu'iwi (Figure 7).

The meaning of the place name Kāne'ohē may come from *kāne* (man), which may be a reference to Kāne, the god of creation, and *ohē*, which means "bamboo." The word *kāne* has also been interpreted as "husband." The place name Kāne'ohē has been attributed to a story about a woman who compared her husband's cruelty to the cutting edge of a bamboo knife (Clark 2002:160-161). Kāne'ohē may also be derived from *'ohē*, which is said to be one of the *kinolau* (body forms) of the god Kāne (Abbott 1992:15).

Pu'u Pahu and Pōhākea are the hills along the boundary and ridgeline that separate Kāne'ohē Ahupua'a to the east and He'eia Ahupua'a to the west. There was a *kahuna* (priest) named Manuwahi who lived with his sons in La'ie. They controlled the *akua* (gods) of the area. In the early post-Contact period, Kamehameha I sent one of his bodyguards, Kahalau, to conquer the family and the land of Mālaekahana. Kahalau and his forces surrounded the home of Manuwahi, but the *kahuna* called up all of the *akua* to fight the soldiers, who were all slain except Kahalau. After the battle, Manuka, son of Manuwahi, moved to Kāne'ohē. When he died, the people dug a large grave and placed him in it. Before they could bury him, the *akua* brought red dirt from 'Ewa in a cloud and filled the grave, making a red hill, the only area with red dirt in the district (Rice 1977:125-126). A *heiau* (ceremonial structure) by the same name as the peak (Pu'u Pahu) was once located atop the hill, but was destroyed before 1933 (McAllister 1933:177). Nearby is an adjacent peak called Pōhākea. This name is also given to an underwater site off Kualoa Point; it can be translated as "first light of dawn," according to a local informant. A more prosaic translation of Pōhākea would be "white rock" as might have related to discoloration from the droppings of birds resting on a promontory.

The place name Pu'u Pahu may also relate to a legendary woman named Lo'e who was expelled from 'Ewa along with her three brothers for constantly fighting with their parents. In the story of the Kāne'ohē peak, Keahiakahoe, Pahu is a fisherman while Kahoe and Kahuauli are farmers living inland (these two names are also adjacent peaks behind Lulukū) with their sister Lo'e. Pahu is the fisherman who withholds his catch from his brother Kahoe even though his brother supplies him with plenty of taro. He betrays the Hawaiian socio-economic tradition of sharing with family in the *ahupua'a*, but Kahoe finds out when the sister asked him if the *'ulua* was finished cooking in the *imu* (earth oven). Then, during a time of famine, Pahu could only stare




Figure 7. 1876 map of Kaneohe and West Kailua (portion), showing names and locations of 'ili surrounding the project area (Lyons 1876); note the project area is within the 'ili of Kalokohanahou and Kanohuli'iwi, and on the boundary of the 'ili of Lilipuna

silently at the smoke from his brother's oven full of *kalo* because of the guilt he felt from the wrongdoing. Pahu became the hill near his residence, Pu'u Pahu, and the islet Moku Lo'e (Coconut Island) was named for Lo'e. It was said that where Lo'e's tears fell, they formed a spring in front of the cliff of Keahiakahoe facing Pahu and there it is to this day. Its name is Lo'e-wai, and it is located near the site of Kukui o Kāne Heiau (Bishop Museum HEN:1:2181 in Sterling and Summers 1978:206).

## 2.2 Historic Background

### 2.2.1 Pre-Contact Period

The *ahupua'a* of Kāne'ohe was prosperous and densely populated in pre-Contact times. With fresh water from *mauka* (inland) springs and perennial streams, as well as a well-developed fishpond system, Kāne'ohe was rich in agricultural and aquacultural productivity. It was one of the primary population centers on O'ahu:

. . . along the windward coast, beginning with Waikane and continuing through Waiahole, Ka'alaea, Kahalu'u, He'eia, and Kane'ohe, were broad valley bottoms and flatlands between the mountains and the sea which, taken all together, represent the most extensive wet-taro area on Oahu. These taro lands were irrigated from both streams and springs. Along the shores thereabouts were also some very large salt-water fishponds. This whole region must have supported a dense population . . .

The area that included what is now Kane'ohe and Kailua, which was rich in fishponds and tillable lands, was the seat of the ruling chiefs of Ko'olaupoko (Short Ko'olau) which was the southern portion of the windward coast. [Handy and Handy 1972:271-272]

Nathaniel Portlock, captain of the British vessel *King George*, provided the following description of Kāne'ohe ca. the late 1780s, shortly after Western Contact:

The [Kāne'ohe] bay all round has a very beautiful appearance, the low land and valleys being in a high state of cultivation, and crowded with plantations of taro, sweet potatoes, sugar cane, etc., interspersed with a great number of coconut trees, which renders the prospect truly delightful. [Handy and Handy 1972:455]

Pre-Contact land use in Kāne'ohe consisted primarily of plantations of *kalo* (taro), bananas, sweet potatoes, and coconut trees, as well as groves of *hala* (pandanus; used for making household furnishings such as mats) and *wauke* (paper mulberry; used for making cloth) (Handy and Handy 1972:456). Handy and Handy (1972) describe how the natural environment of Kāne'ohe was conducive to development of a complex agricultural system:

The broken topography of Kaneohe arranges the areas of flatland like chains of pockets connecting along its stream channels between hills. On the north side of the *ahupua'a* near the boundary of He'eia, Kea'ahala Stream flows into Kalimukele, coming out of He'eia. Some of the best *lo'i* [taro patches] still in use in 1953, *mauka* of the highway, were irrigated by Kea'ahala, and a large old *lo'i* system once extended downstream below the highway. An elaborate system of



water rights prevailed in ancient times throughout these sections irrigated from Kea'ahala.

The other streams—Waialele (formerly Pani'ohēlele), Hi'ilaniwai, Kahuaiki, Mamalahoa—likewise watered many taro *lo'i* . . . Hi'ilaniwai is a very long stream, with its origin in the slopes that drain Pu'u Lanihuli, the peak that flanks the northern side of the Nu'uuanu Pali road and the southern boundary of Kaneohe. In fact all of the *ahupua'a* is like a vast green amphitheater below the serrated sheer cliffs that extend from Pu'u Lanihuli northward to Ha'iku Valley and known as the Ke-ahi-a-Kahoe (Fires-of-Kahoe) Cliffs. As the ground rises steeply from the stream beds along their upper courses, there is little evidence of systematic terracing observable in these areas, as might have been expected. The lowland areas were so extensive that evidently the more laborious terracing of the interior slopes was not regarded by the early Hawaiians as necessary.

The kula [pasture, wasteland] lands between the streams were planted in pandanus, *wauke*, bananas, and sweet potatoes. *Kalo malo'o* (dry-taro) was not planted here. The number of names of *'ili* and *kuleana* on *kula* lands along the Hi'ilaniwai and its tributaries, however, indicates intensive cultivation of products other than taro, and the abundant rains sweeping down from the cliffs made such cultivation profitable. [Handy and Handy 1972:455-456]

In general, lands suitable for development of *lo'i* (irrigated terraces) were located along main streams and coastal lowlands (Devaney et al. 1982:36). *Lo'i* development required diversion of stream water for irrigation, and construction of terraces to pond the water. Steen Bille, writing in Dutch, describes the system:

. . . this [taro] root, the principal food of the inhabitants of these Islands, grows only in low, well watered places, and where no such places are provided by nature the natives frequently with great difficulty make excavations so that water may collect in these basins which frequently are several ells deep. [Devaney et al. 1982:35-36]

In addition to the extensive agricultural cultivation, the people of Kāne'ōhe Bay sought the bountiful marine resources:

The sea adjoining an *ahupua'a* [Kāne'ōhe] was considered to be an extension of that *ahupua'a*; its resources were shared by the chief and all of the tenants (*hoa'āina*) living in the *ahupua'a*. Access to the sea was part of the *mauka-makai* concept, which made the products of land and sea available to the people living in the *ahupua'a*. [Devaney et al. 1982:135]

Just as the land-based resources of the *ahupua'a* were managed through subdivision into *'ili*, the marine resources of the *ahupua'a* were also partitioned, with discreet fisheries associated with the *'ili* along the Kāne'ōhe Bay coast. In addition to shoreline and offshore fishing, fishponds were constructed along the Kāne'ōhe Bay shoreline to provide regular supplies of fish to the inhabitants of the *ahupua'a*:

Shoreline fishing is highly susceptible to the vagaries of weather and surf conditions. With walled fishponds, Hawaiians provided for themselves a regular

supply of fish when other types of fishing were not possible or yielded an insufficient supply. The fringing reefs along the shoreline of Kaneohe Bay were ideal for the type of walled fishponds that extended out from the land.

Mullet, one of the world's most important food fishes, was the most common species raised by Hawaiians in their fishponds; *awa* (milkfish) followed a close second. [Devaney et al. 1982:140]

Several *loko* (fishponds) were located in the vicinity of the current project area, including (from west to east) Kalokokahāhou, Kanohuluiwi, Punalu'u, Waikalua, and Keana. Kamakau relates the number of fishponds in an area to the population that would have been necessary for their construction:

The making of walls (*kuapa*) of the shore ponds was heavy work, and required the labor of more than ten thousand men. Some of these fishponds covered an area of sixty of seventy acres, more or less. Walls had to be made on the seaward side sometime in deep water and sometime in shallow, and many stones were needed.

Many *loko kuapa* [fishpond walls] were made on Oahu, Molokai and Kauai, and a few on Hawaii and Maui. This shows how numerous the population must have been in the old days, and how they must have kept the peace, for how could they have worked together in unity and make these walls if they had been frequently at war and in opposition one against another? [Kamakau 1976:47]

### 2.2.2 Early Historic Period to Mid-1800s

In 1795 Kamehameha, at that time the Hawai'i Island chief, invaded O'ahu to secure control of the islands of O'ahu, Moloka'i, and Lāna'i after his successful conquest of Maui. The O'ahu Island chief Kalanikūpule, Moloka'i Island chief Ka'iana, and their forces met Kamehameha's army in the valley of Nu'uānu. The following account describes the final stages of the battle at the Nu'uānu Pali, the knife-edge ridge of the Ko'olau Range separating Nu'uānu from Kāne'ohe Ahupua'a:

The forces of Kamehameha charged; in the onslaught many of the Oahuans were slain, and the rest pursued with great slaughter until they were driven to the end of the valley, which terminates in a precipice of six hundred feet, nearly perpendicular height, forming a bold and narrow gorge between two forest-clad mountains. A few made their escape; some were driven headlong over its brink, and tumbled, mangled and lifeless corpses, on the rocks and trees beneath; others fought with desperation and met a warrior's death, among whom was Kalanikūpule, who gallantly contested his inheritance to the last. [Jarves 1872:85]

Kamakau (1992:172) offers an alternate fate for Kalanikūpule, stating he escaped to the mountains with some of his men for several months, but was later discovered and sacrificed to Kamehameha's war god Kūkā'ilimoku.

Following the conquest of O'ahu by Kamehameha, the lands of the island were divided between Kamehameha and his followers. Likely due to its agricultural and fishery productivity, Kāne'ohe Ahupua'a was seen as the "most valuable part" of the Ko'olaupoko District (Kamakau 1992:303). Kāne'ohe Ahupua'a was retained by Kamehameha as his personal property, and was

later inherited by his sons Liholiho and Kauikeaouli, Kamehameha II and III (Kame'eleihiwa 1992:233).

In the early 1800s, there were three primary routes to Windward O'ahu from the growing town of Honolulu. These were

around the island by canoe; through Kalihi Valley and over the pali [cliff] by ropes and ladders (Graham 1826:142); and over the Nuuanu Pali, the easiest, quickest, and most direct route. [Devaney et al. 1982:163]

The trail over the Nu'uanu Pali was a heavily utilized transportation corridor since it allowed the people of Windward O'ahu to bring their agricultural products to Honolulu for sale. The Reverend Reuben Tinker described his trip over the Nu'uanu Pali in 1831:

It seemed to me a sublime pass, yet almost too fearful to be enjoyed, for though not unaccustomed to hills, and the ups and downs of life, I suffered from apprehension lest I should fall from the rocky steep. I took off my shoes and by setting my feet in the crevices of the rocks, I worked myself along, assisted by a native, who saw nothing to wonder at but my awkwardness and fear on passing this grand highway, though to them common. The natives do not think it is either wonderful or difficult. It is the main road connecting the opposite sides of the island, and men and women are going up and down with their ordinary burdens on their shoulders, and in their arms, such as bundles of potatoes and taro, calabashes of poi, fowls, goats and swine.

Mothers were passing along the most precipitous places with their children on their shoulders, as careless of danger as if they were on a level plain . . . [Tinker 1900:88]

Traditional agricultural practices, including wetland taro cultivation, continued to dominate land use in Kāne'ohe in the early years following Western Contact, although to a lesser degree. Introduced diseases dramatically reduced the Native Hawaiian population to a fraction of its pre-Contact level. Native Hawaiian historian David Malo notes that:

In the reign of Kamehameha, from the time I was born until I was nine years old, the pestilence (*mai ahulau*) visited the Hawaiian Islands, and the majority (*ka pau nui ana*) of the people from Hawaii to Niihau died. [Devaney et al. 1982:8]

Agricultural lands were subsequently abandoned due to the population decrease. In 1828, the missionary Levi Chamberlain embarked on a tour around the island of O'ahu to determine the progress occurring at schools established to educate Native Hawaiians. During his tour, Chamberlain (1828:26) made observations of the landscape and people around the island commenting on the "present neglected state" of formerly cultivated agricultural lands:

[The natives] ascribed it to the decrease in population. There have been two seasons of destructive sickness, both within the period of thirty years, by which, according to the account of the natives, more than one half of the population of the island was swept away. The united testimony of all, of whom I have ever made any inquiry respecting the sickness, has been, that 'Greater was the number of the dead than of the living.'

. . . it may, I think, be safely asserted, that since the discovery of these islands by Cap. Cook there has been a decrease of population, by desolating wars, the ravages of disease and other causes, of at least one half of the number of inhabitants that might have been fairly estimated, at the time that celebrated voyager last visited these islands. [Chamberlain 1828:26]

### 2.2.3 The Māhele (Land Divisions)

In 1845, the Board of Commissioners to Quiet Land Titles, also called the Land Commission, was established “for the investigation and final ascertainment or rejection of all claims of private individuals, whether natives or foreigners, to any landed property” (Chinen 1958:8). This led to the Māhele, the division of lands between the king of Hawaii, the *ali'i* (chiefs), and the common people, which introduced the concept of private property into Hawaiian society. In 1848, Kamehameha III divided the land into four categories: certain lands to be reserved for himself and the royal house were known as Crown Lands; lands set aside to generate revenue for the government were known as Government Lands; lands claimed by *ali'i* and their *konohiki* (supervisors) were called Konohiki Lands; and habitation and agricultural plots claimed by the common people were called *kuleana* (Chinen 1958:8-15).

Kamehameha III inherited Kāneʻohe and retained the bulk of the *ahupuaʻa* during the Māhele. Following the death of Kamehameha III in 1854, his wife, Queen Kalama (Hakaleleponi), retained their Kāneʻohe lands (Land Commission Award [LCA] 4452). Along with the *ahupuaʻa* of Kailua and Hakipuʻu, Kāneʻohe was seen as “her most valuable *ʻĀina* [land] . . . all in the fertile, well-watered district of Koʻolaupoko” (Kameʻeleihiwa 1992:264). Several *ʻili* in Kāneʻohe were subsequently awarded as Konohiki Lands to the *ali'i* and others with close ties to the royal family. The title to the *ʻili* typically included ownership of the *ʻili* fishpond and offshore fishing rights (Devaney et al. 1982:143). High-ranking *ali'i* were awarded entire *ʻili*, while lesser *konohiki* were awarded half of an *ʻili* each (Kameʻeleihiwa 1992:269, 279). In addition to Queen Kalama, 14 *konohiki* LCA parcels were awarded for Kāneʻohe lands (Kelly 1976:7).

An 1897 map of Kāneʻohe (Figure 8) shows the Crown Lands, Government Lands, and large LCA lots distributed to the *ali'i* and *konohiki* in the vicinity of the current project area.

The lands awarded as Crown Lands and Konohiki Lands, as well as lands designated as Government Lands, were “subject to the rights of native tenants” (Chinen 1958). The Kuleana Act of 1850 “authorized the Land Commission to award fee simple titles to all native tenants who occupied and improved any portion of Crown, Government, or Konohiki Lands” (Chinen 1958:29). Surveyor C.J. Lyons stated:

Small tenants were permitted to acquire a full title to the lands which they had been improving for their own use. In the true view of the case, this was perfectly a measure of justice, for it was the labor of these people and their ancestors that had made the land what it was. [Lyons 1894:1699]

One hundred seventeen *kuleana* land claims were awarded in Kāneʻohe Ahupuaʻa, with the average award being approximately 2.4 acres (Kelly 1976:8). Testimonies associated with the LCA parcels indicated the primary land use for the claimed lands was *loʻi*, irrigated fields used for cultivating taro (Kelly 1976:8). Testimonies include other land uses such as growing

breadfruit, coconut, *hala* (*Pandanus tectorius*), gourds, melons, *'ape* (*Alocasia macrorrhiza*), *pia* (*Tacca leontopetaloides*), pineapple, and banana; salt ponds; and *kula* (pasture) for raising animals (Devaney et al. 1982:23).

There are 11 LCA claims within of the current project area, as listed in Table 1 and shown on the 1897 map (see Figure 8) and on a 1931 map (Figure 9). The full texts of the 11 claims are presented in Appendix A.]

Most of the awardees claimed several *'āpana* (lots), at least one for irrigated taro cultivation, a house lot, and upland land ("*kula*"). The testimony of several mention a river or creek called Wailele or Kāne'ōhe, an *'auwai* called Kanohuli'iwi, the fishponds Kalokohanahou, Kanohuli'iwi, and Waikapoki, a *pali* (cliff) called Wai'ape, and a high hill, probably Pu'u Pahu. The 1897 map indicates the water source for the irrigated taro was a stream, Kane'ōhe Stream, which flows toward the sea, then bends at a 90 degree angle to extend parallel to the coast. On the 1931 map this stream is labeled as an *'auwai* (irrigation ditch). When the claims have a separate house lot, it is usually located near the shore or in the uplands. The lots near the stream/*'auwai* are those used for *lo'i* (irrigated taro patches). Some of the claims also mention that neighbors have sweet potato patches near the shore. The current sewer line follows the alignment of this ancient stream/ditch, which was filled in later during residential development in the area.

Kalokohanahou was a 7-acre pond (Cobb 1905:748) awarded to the *ali'i* Kamakahonu as part of his Konohiki Award (M.A. [Māhele Award] 30). It is interesting that the small island (LCA 1954) on the northeast shore of the fishpond was awarded to someone else. LCA 1954 was awarded to Kalaikau, who had a larger lot extending inland from the shore of the pond on which he raised taro and had a house lot. The Māhele information indicates the project area was used for irrigated taro cultivation and for house lots, which were utilized throughout the nineteenth century and into the early twentieth century.

#### 2.2.4 Mid-1800s to early 1900s

The mid-nineteenth century brought great changes to Kāne'ōhe Ahupua'a, including private and public land ownership laws during the Māhele, commercial rice, sugar cultivation, and ranching. Agricultural cultivation and ranching established the region as a source of market resources for Honolulu and beyond. Fishponds also became commercial entities during this period. A 1906 map (Figure 10) illustrates the ecological zones for the different types of resources in this section of Kāne'ōhe, with the project area within extensive wetland areas used to grow taro and later rice, but also within the zone used as cattle pasture.

##### 2.2.4.1 Sugar

One of the earliest sugar plantations on O'ahu was owned by Charles Coffin Harris, who came to Hawai'i in 1850, planning to practice law. He established the Kaneohe Sugar Plantation Company (ca. 1865) on 7,000 acres of Queen Kalama's land (Dorrance and Morgan 2000:41). In 1871, Harris bought Queen Kalama's Ko'olaupoko properties from her heir, Charles Kana'ina, as well as some land in Honolulu for \$22,448. The sale included ". . . livestock, tools, fishponds, and fishing rights" (Devaney et al 1982:29). The plantation land was used for a variety of purposes, as can be seen in the following 1884 description from McKenney's Hawaiian Directory:



Table 1. Land Commission Awards in the Project Area

LCA #	Claimant	'Ili	Acres	Description
1954	Kalaikau	Kalokohanahou	1.67	Sixteen taro <i>lo'i</i> , a <i>kula</i> , a house, and a small island on Kalokohanahou Pond
M.A. 35	Kamakahonu	Kalokohanahou	52.54	No information on use of land
2491B	Kamanene	Kalokohanahou [Lokohou]	1.00	No information on use of land; bounded by the stone wall of Kalokohanahou Fishpond
2345	Keau	Kalokohanahou [Kalokohou]	0.48	Four taro <i>lo'i</i> , one <i>kula</i> , and one house; the house is in a second lot near the project area, but not within it
3431B	Kauwa	Kalokohanahou [Kalokohou]	1.99	Eleven <i>lo'i</i> in a lot near the project area; house lot within the project area
2343	Keliiwai-waiole	Kalokohanahou [Kalokohou]	6.09	Eighteen taro <i>lo'i</i> , one <i>mo'o</i> (garden), <i>kula</i> , and a house; mentions a neighbor's potato (sweet potatoes) patch, a fishpond, a river, and a high hill (probably Pu'u Pahu) as boundary marks
2555	Wahaulaula	Waikapoki	0.89	Taro land; bound by the fishpond of Kanohuouliwai to the north and east; house is on a separate lot in the uplands
2460	Kekuaikolia	Waiape	0.88	Five taro <i>lo'i</i> ; house is in separate parcel; bound on the west side by the <i>pali</i> of Wai'ape and on the east by Kaneohe Creek
2496	Keliiholo-moku	Lilipuna	2.27	Four <i>lo'i</i> , one <i>kula</i> , and one house
1966:1	Opu	Waikapoki	0.29	Four taro <i>lo'i</i> , bounded on the west side by Wailele Creek; house lot on different parcel
1967:1	Kahinu	Kailipaa, Waikapoki	2.22	Seven taro <i>lo'i</i> ; two houses on a fenced lot; bounded on the west by Wailele Creek




Figure 9. 1931 map of land acquisition by the Kaneohe Land Company, Ltd. for lands in the 'ili of Lilipuna, Kalaepaa, Kanohulu'iwi, Wailele, Kalokohanahou, and Kaopulioloa (King 1931)





Kaneohe Sugar Plantation, Mrs. N.R. Brewer proprietress, M. Rose manager . . . 10,000 acres, 500 acres under cultivation, 200 with sugar and 300 with rice, the remainder grazing land on which are 3,000 head of cattle, capacity of mill three tons per diem, estimated yield for 1884 500 tons, men employed seventy-five. [McCoy et al. 1972:9]

C.C. Harris's plantation closed in 1891 since the sugar yield was not enough to support the operation (Dorrance and Morgan 2000:41). Harris's daughter and heir, Mrs. David Rice, incorporated the lands as Kaneohe Ranch and converted them to stock farming. There were also a number of small dairy ranches in the area around the turn of the century (McCoy et al. 1972:9). James B. Castle purchased a large block of their land holdings in 1907 (Dorrance and Morgan 2000:42).

#### 2.2.4.2 Rice

Rice cultivation was to eventually supersede taro and dominate the lowlands of Kāneʻohe. The ancient taro *loʻi* and *ʻauwai* irrigation systems were used and additional new ditches were built to support rice cultivation. During the height of rice cultivation (ca. 1880-1920), Chinese dominated the business. “To a great extent the rice business, growing and milling was controlled by Chinese *hui* (firms), which recruited laborers from China, handled investment capital from rich absentee landlords, and tallied profits” (Devaney et al. 1982:49). By the late 1880s, virtually the entire floodplain area of Kāneʻohe was under rice cultivation. In 1892-1893, the Kaneohe Rice Mill was erected and began production on property adjoining Waikalua Stream. A flume brought water from the river to the rice mill. Mrs. Polly Ching related in a 1976 personal interview that about twice a week a steamer came into Kāneʻohe Bay to pick up and transport rice to market in Honolulu (Devaney et al. 1982:52).

By the 1920s, rice had gradually declined in importance due to a number of factors. Two of the primary reasons for this decline were the beginning of rice production in California and the “annexation of Hawaii by the United States in 1898 [which] resulted in restrictions on the number of Chinese laborers arriving from the Far East” (Devaney et al. 1982:53). However, rice cultivation, as well as some taro cultivation, continued up to ca. 1960.

#### 2.2.4.3 Pineapple

Commercial cultivation of pineapple in Kāneʻohe began in the 1890s and the first decade of the twentieth century. From approximately 1910 to 1925, pineapple cultivation was a major industry in this area. In 1911, the company of Libby, McNeill and Libby built a pineapple cannery in Heʻeia. At its peak, 2,500 acres were under pineapple cultivation on Windward Oʻahu (Harper 1972), stretching from Kāneʻohe to Kahaluʻu. Most of the pineapple lands in Kāneʻohe were “located below the Pali where the golf course, Hawaii Loa College, and the Hawaiian Memorial Park are today” (Kelly 1987:295-296). A *heiau*, Kaulauki Heiau in Heʻeia, was mostly destroyed by pineapple field clearance during this time—a likely fate of many archaeological sites (Kelly 1987:295-296). In 1919, the Kaneohe Ranch Company and Heeia Agricultural Company, Ltd. leased 1,000 acres of land in Heʻeia, Kāneʻohe, and Kailua, formerly planted in sugar, to the Libby Company for a term of 17 years. The extent of pineapple fields near the project area in the early twentieth century is shown on the 1906 land use map (see Figure 10). In 1917, Libby leased an additional 600 acres in Heʻeia (Devaney et al. 19982:61).

While the rice fields that covered old taro lands were mainly located near streams and near the coast, pineapple was also grown on the slopes of higher lands, usually on land subleased to individual Japanese farmers:

Pineapples were planted by individual Chinese and Japanese farmers on moderately sloped hill land where rice and taro could not be grown . . . these areas included the dissected alluvial terraces and the lower slopes and spurs of the Ko'olau range. [Miyagi 1963:115]

The change to the Windward landscape due to pineapple cultivation is illustrated by the following passage from H.F. Alexander's 1914 *Mid Pacific Magazine* article on cycling around O'ahu:

At last we reached the foot of the Pali . . . Joe and I looked over the surrounding hills, but looked in vain for the great areas of guava through which but a few months ago we had fought and cut our way. As far as the eye could reach pineapple had taken the place of the forest of wild guava. The newest industry in Hawaii was beginning even to press upon the cane fields of this side of the island. [Devaney et al. 1982:62]

The pineapple fields were abandoned when Molokai and Lāna'i pineapple cultivation began to boom, and Libby dissolved the Ko'olaupoko enterprise (Kelly 1976:47). The cannery closed in 1923 (Dorrance 1998:95), and most of the former pineapple land went to grass, some of which was used to graze cattle. Several of the small farmers returned to rice cultivation at that time (Kelly 1975:47).

#### 2.2.4.4 Ranching

English Captain George Vancouver introduced cattle and sheep to O'ahu in 1793 (Henke 1929:8) and by the 1840s, the cattle had multiplied into a large herd (Devaney et al. 1982:70). At its peak, Kaneohe Ranch extended from the ocean in Kailua to the Pali and included 12,000 acres and 2,000 head of cattle (Henke 1929:62). By the mid-1860s, the cattle were so numerous they caused environmental degradation. Alien grasses and other species such as pigeon peas were introduced to the area as cattle fodder (Henke 1929:62). Much of the land modification in the upland and hilly portions of Kāne'ohe may be the result of heavy cattle grazing over a long period of time. An 1854 visitor to the Islands, standing atop the Pali and looking down at Kāne'ohe, noted that "hundreds of cattle may be seen feeding on the rich pasture with which these plains are covered, adding to the landscape an exquisite finish (Bates 1854:104).

By the mid-1860s, we have an indication that livestock were altering the landscape. The undulating plains at the foot of Nu'uaniu Pali were described as "a rich land a while ago but now there are not many plants because animal are permitted there" (Devaney et al. 1982:70). In the post-World War II years, the dairy industry rose to prominence over beef cattle ranching. The shortage of available land due to urban expansion, the shortage of fee simple land, and the high price of land leases forced farmers in the dairy districts near Honolulu (e.g., Koko Head) to relocate to more remote areas of O'ahu (Durand 1959:241). In the 1950s, Kailua-Kāne'ohe was an important dairy district of Windward O'ahu. Dairy farming was dominated by Caucasians particularly of Portuguese and Spanish ancestry, and secondarily by Japanese farmers (Durand 1959:235). "Among the names of island dairymen, illustrating the Portuguese-Spanish-Mainland

importance . . . are . . . Brazil, Carlos, Campos, Costa, Ferreria, Foster, Freitas, Knowles, Medeiros, Moniz, Ornellas, Rapoza, Santos, Toledo, Vause and White” (Durand 1959:235). This period, however, was relatively short-lived as the opening of the Pali route, exorbitant land prices in Honolulu, and more automobiles on O‘ahu contributed to rapid urbanization in Kailua-Kāne‘ohe (Durand 1959:244-245). Many landowners decided to develop their land for suburban housing and terminated leases with farm leaseholders.

By the end of World War II, ranching was no longer economically viable for Kaneohe Ranch, so the ranch became primarily a landlord to farmers. Following the war, residential developments began to change the face of Kāne‘ohe Ahupua‘a. The opening of the Wilson Tunnel and the expansion of the Pali Highway in the 1950s and 1960s, creating an easier passage from Honolulu to windward communities, led the way to a development boom on O‘ahu’s windward side. High tax rates on real estate sales forced many old-time landowners to lease their land to residential developers rather than sell on a fee-simple basis. Kaneohe Ranch at one time leased out their land for over 5,000 single-family residential lots in Kailua and Kāne‘ohe. The vast majority of the leaseholds were later sold to the lessees.

#### 2.2.4.5 Fishponds

As previously mentioned, during the Māhele, fishponds were considered to be part of the land to which they were attached. As such, fishponds were typically designated as Crown or Government Lands, or awarded to the *ali‘i* as Konohiki Lands. Some of the lands owned by the government and *ali‘i*, along with the fishponds, were subsequently sold to entities pursuing commercial agriculture, such as sugar cane and pineapple cultivation, or ranching.

Once fishponds were declared private property, they were taxed by the government along with the rest of the real property. When commercial agriculture brought promises of high profits, few large landowners paid much attention to the fishponds attached to their land holdings. They were satisfied to lease them to Hawaiians or Chinese who had the technical knowledge necessary to properly manage fishponds. Yet when disaster struck, such as a break in the fishpond wall, few lessees could afford the capital required to undertake repairs. As a result, many fishponds deteriorated with the passage of time, and the practice of aquaculture, for all practical purposes, ceased (Devaney et al. 1982:143). By 1901 only 16 fishponds were present within Kāne‘ohe Bay, perhaps less than half the fishponds present in the mid-1800s.

The extensive grazing and agricultural uses of the inland areas of Kāne‘ohe increased erosion and infilling of nearshore marine environments, including fishponds. In addition to being a bountiful source of fish, in 1976 oysters were cultivated in fishponds (Devaney et al. 1976:145). Local Japanese (Little-neck) clams (*V. philipinarum*) were introduced into various ponds along Kāne‘ohe Bay between 1920 and 1939, and some Kāne‘ohe fishponds were well-known as a desirable clamming destination during the September to October season. However, in 1969 an article in the *Honolulu Star-Bulletin* reported soil erosion caused a “massive wipe-out of the transplanted Japanese little-neck clams” (Devaney et al. 1982:101).

The western shore of Kāne‘ohe Bay was dotted with numerous fishponds—Kalokohanahou near the border with He‘eia Ahupua‘a at Pōhākea Peninsula, Kanohulu‘iwi Fishpond, Waikapoki Fishpond, an unnamed fishpond, and Punalu‘u Fishpond. An older name for Kalokohanahou (“the repaired pond”) was Kahanahou, “the remaking” (Pukui et al 1974:63, 78). The pond was

approximately 7 acres in size, with a small island at the northeast end but no oceanside *makaha* (gates). It was filled in the 1940s for the development of the Kahanahou residential neighborhood.

Three photographs (Figure 11 through Figure 13) illustrate fishpond evolution. An 1887 photograph shows Kalokohanahou Pond near the tip of a peninsula, with Kanohulu'iwi Pond adjacent. The small island on the northeast side is also clearly visible. A 1930s photograph shows the fishponds from Kalokohanahou to Punalu'u. The ponds are not filled, but appear to be unused and silted-in. The island on Kalokohanahou is still visible. The last photograph is from the 1940s. Although the island on Kalokohanahou is still present, the interior of the pond is in the process of filling. There are already a few structures visible in the interior over a layer of topsoil. The other ponds of Kāne'ohe on the western shore are filled with sediments and sand.

### 2.2.5 1900s to the Present

A series of USGS and U.S. Army War Department maps and photographs (Figure 14 through Figure 18) show the residential development of the western shore of Kāne'ohe Bay in the twentieth century. On a 1914 map (Figure 14), three ponds on the western shore of Kāne'ohe Bay are clearly delineated. Most of the inland roads are "unimproved" (not paved, denoted by dotted lines) and have scattered houses on both sides. The shore lands are shown as wetlands. There are cattle paddocks inland and near the shore. The map indicates the land at this time was used for agriculture, ranching, habitation, and fishpond use. The *'auwai* within the project area is still present. By 1936 (Figure 15), there are many improved, paved roads in the area branching off from the newly designated coastal highway, and houses are more formally placed and aligned with these main roads. The former cattle paddock area near the shore has been developed into the Coral Gardens residential area. On both the 1914 and 1936 maps (see Figure 14 and Figure 15), Kalokohanahou, Kanohulu'iwi, and Punalu'u fishponds are shown as open and unfilled. This is in contrast to the 1943 map (Figure 16), in which the ponds are shown as partially filled, either by natural sedimentation or by filling with dredged material. By 1954 (Figure 17), Kalokohanahou has been completely filled to develop the Kahanahou residential neighborhood, although the ponds to the east still remain unfilled. The area is densely developed for residences with numerous streets and houses aligned with the streets. In a 1978 aerial photograph (Figure 18), residential development is also shown. The outline of former pond boundaries offshore can also be seen in this photograph.




Figure 11. 1887 photograph of Kāneʻohe fishponds; Kalokohanahou (right background) and Kanohuluʻiwi (left center); ponds are unfilled (Hawaiʻi State Archives 1887)



Figure 12. 1930s photograph of west shore of Kāneʻohe Bay, showing (from right to left) Kalokohanahou, Kanohuluʻiwi, Waikapoki, and Punaluʻu Fishponds (Hawaiʻi State Archives 1930s); ponds are silted in



Figure 13. 1940s photograph of western shore of Kāneʻohe Bay; Kalokohanahou Fishpond (center) has been filled to create the Kahanahou residential neighborhood (Hawaiʻi State Archives 1940s)




Figure 14. 1919 U.S. Army War Department fire control map, Waimanalo quadrangle, showing the project area with unfilled Kalokohanahou Pond; note the old 'auwai is pictured as a ditch (dotted line)





Figure 15. 1936 U.S. Army War Department terrain map, Kaneohe quadrangle, showing the project area with unfilled Kalokohanahou Pond; there is no longer an 'auwai or ditch labeled




Figure 16. 1943 U.S. Army War Department terrain map, Kaneohe quadrangle, showing the project area with Kalokohanahou and adjacent fishponds partially filled




Figure 17. 1954 Kaneohe USGS topographic quadrangle; Kalokohanahou has been filled to create the Kahanahou residential neighborhood, while other fishponds to the east remain unfilled but are modified



Figure 18. 1978 aerial USGS orthophotoquadrangle, Kaneohe quadrangle; Punalu'u Pond at the right of the photo remains untilled

## Section 3 Previous Archaeological Research

---

Archaeological studies conducted in the vicinity of the current project area in Kāneʻohe Ahupuaʻa are summarized in Table 2. The location of previous studies and previously identified sites are shown on Figure 19 and Figure 20. A discussion of archaeological findings relevant to each portion of the project area follows.

### 3.1 Early Archaeological Surveys

The first systematic archaeological study of the Kāneʻohe area was conducted by J. Gilbert McAllister of the Bernice Pauahi Bishop Museum in the 1930s. McAllister (1933) consulted with knowledgeable informants about both physical and legendary sites of each district during his island-wide survey of Oʻahu. McAllister recorded a number of *heiau* and other sites in the vicinity of the current project area. The eight sites he recorded near the project area are sites 331–335 and 338–341. These can be located on Figure 12.

McAllister's sites:

**Site 342.** Puʻupahu Heiau, said to have been located on the elevation called Puʻupahu Kāneʻohe. There are no remains now [ca. 1931]

**Site 343.** Kalokohanahou fishpond, adjacent to Kalokohanahou and just beneath Puʻu Pahu.

According to Bell, this is not the old name, but the one used by Parker when he rebuilt the pond. The walls are but a few feet wide, loosely built of lava stones through which the water seeps. A small island occupies a portion of the wall. There were two watch-houses and no outlet gates (*mākāhā*). According to Cobb, it covered 7 acres.

[Cobb notes that the old name for this fishpond was Kohanahou (Cobb 1903)]

**Site 344.** Kanohuluiwi pond, adjacent to Kanohuluiwi.

The name was given me by John Bell. The pond is small, with narrow lava-rock walls, and covers an area of 2.5 acres. It is apparently still in use. On one of the old maps in the land office there are two adjacent ponds of about the same size. The broken wall of one is still to be seen, the name of which is probably Waiapoki, with an area of 4 acres. The other pond has been obliterated [by ca. 1931].

**Site 345.** Punaluʻu Pond, adjacent to Punaluʻu Kāneʻohe. Covers 12.5 acres and has a wall length of approximately 1600 feet. The walls are of basalt, a few feet in width.

**Site 346.** Deep ditch dividing the lands of Punaluʻu and Waikalua, Kāneʻohe. Built by the chief of the district in order to keep his pigs from wandering from Waikalua, which seems to have been a land set aside for the royal swine. Occasionally there was built an incline leading from the bottom of the ditch to Waikalua, in order that the pigs that fell into the trench might again gain access to the pen in which they were kept.




Figure 19. Previous archaeological studies in west coastal Kaneohe near the project area




Figure 20. Previously identified archaeological sites in west coastal Kaneohe near the project

Table 2. Previous Archaeological Studies in Kāneʻohe near the Project Area

Source	Study	Location	Results
McAllister 1933	Sites 342–352	Island-wide	Identified ten sites near project area within Kaneʻohe Ahupuaʻa, five fishponds, three <i>heiau</i> , ditch, and chief's house cluster (SIHP # 50-80-10-342-352)
Kurashina et al. 1986	Reconnaissance survey	Nani Pua Gardens II Subdivision	Identified several sites, including two lithic scatters, former rice field and taro field with stone retaining wall, historic house foundation, two stone platforms, and Italian prisoner-of-war camp, Kaneʻohe rice mill, and SIHP # 50-80-10-2937 (Hawaiian habitation site). Preliminary test excavations conducted at SIHP # -2937. Pre-Contact artifacts, post-Contact artifacts, and charcoal recovered
Clark and Riford 1986	Archaeological salvage excavations	Nani Pua Gardens II Subdivision	Salvage excavations at Bishop Museum site 50-Oa-G5-101 (SIHP # 50-80-10-2937), pre-Contact Hawaiian habitation site; two human burials and additional fragmentary remains found; reports <sup>14</sup> C date of AD 1070-1405; substantial discussion of lithic finds
Hammatt and Borthwick 1989	Inventory survey and subsurface testing	Bay View Golf Course	No significant findings within eight trenches, excavated at 50-100 ft intervals; each trench averaged 7.5 m long and 230-240 cm deep (to water table)
Department of the Army 1991	Field inspection	Keaahala Military Reservation	No surface features noted; background research indicates area may never have been used by military
Hammatt et al. 1992	Inventory survey	Castle Hills access road	No surface features noted; historic bottles recovered from one test excavation
Duncan and Hammatt 1992	Archaeological monitoring	Castle Hills access road	During monitoring, one archaeological site recorded, SIHP # 50-80-10-4523; included historic trash pit with bottles and probable water trough
Stride et al. 1994	Inventory survey	Coral Gardens	No cultural remains noted during excavation of eight backhoe trenches
Dashiell 1995	Preservation plan	Waikalua Loko Fishpond	Recommended preserving, restoring, and maintaining fishpond; establishment of interpretive program also recommended



Source	Study	Location	Results
Perzinski and Hammatt 2000	Inventory survey	Kāneʻohe Civic Center playground parking lot	No surface features noted; only fill material noted in excavations
Sinoto and Titchenal 2010	Archaeological assessment	Kāneʻohe-Kailua Force Main	Pre-construction testing and/or monitoring recommended
Sinoto and Dashiell 2011	Archaeological monitoring	Bay View Golf Course	During monitoring of 125 linear-ft sewer line replacement, fill observed to 5.54 m below surface

Though John Bell pointed out the exact site of this division line, no evidence of the ditch remains; but the idea of such a barrier is worthy of note.

**Site 347** Kalaoa Heiau, Waikalua, Kāneʻohe.

This heiau was located on an elevation to the left of the road leading to the Kāneʻohe municipal camping grounds just beyond lane which leads to the coral gardens. Nothing remains of the heiau, the stones having been used in the construction of the mill. The *heiau* was built by Laʻamaikahiki, according to John Bell, who took me to the site.

**Site 348.** Site of the houses of Laamaikahiki [a chief], Waikalua, Kāneʻohe.

. . . On the southeast side of the Trask home is an oval pile of rocks, 20 feet long, 15 feet wide, and 3 feet high, with a great amount of coral scattered throughout. . . A similar pile of coral and stone, though much smaller, is found on the other side of the house. The sands in front of the place are known as Naonealaa and were tapu [tabu] to the commoner when the alii lived there.

On this same elevation Laamaikahiki wanted to build his heiau, Kalaoa (Site 347), but he was advised by his kahuna to place it considerably farther from the chief's houses, for the women of the household would be too close to the sacred inclosure tapu to them. . . . Naonealaa is listed by Thrum . . . as a heiau.

**Site 349.** Waikalua fishpond, adjacent to Waikalua, Kāneʻohe.

The rebuilding of the pond has been completed. The wall was 1420 feet long, of waterworn basalt 3 to 4 feet high but somewhat wider. The pond covers 11 acres.

**Site 350.** Two ponds, Kailua side of Waikalua.

The pond in use is said to be Keana with an area of 3.5 acres. According to Bell, the name of the other is Kalokohanahou. (See Site 343). Its wall is broken. Both were built of waterworn basalt. The dirt-filled wall of Keana is wide enough for trees to grow on it.

**Site 352.** Ahukini heiau, Keana (now known as Kokokahi), Kāneʻohe

A small structure, 70 by 127 feet, built on the top of an elevation 1200 feet from the sea. The ground slopes away from the heiau in all directions. The only features remaining are the low walls, unusual because they are built of stones a few inches in size. Here and there at the bottom larger stones have been used, and at a few places the wall stands 1 foot in height, but most of the remains are scattered for it is very easy to the cattle to disturb the small stones . . . There appears to have been only this one platform, which was dirt-paved, though on the end toward the mountains there are many scattered stones, also small, which may, at one time, have been used for paving a small area. When the drums at this heiau were beaten they could be heard over Kaneohe, but not just on the other side of the low ridge in Kailua. [McAllister 1933:177–179]

## 3.2 Modern Archaeological Surveys

### 3.2.1 Proposed Nani Pua Gardens II Subdivision Project

In 1986, the Bishop Museum conducted archaeological salvage excavations of site G5-101 (SIHP # -2937) within TMK: [1] 4-5-030:043 (Clark and Riford 1986). This pre-Contact Hawaiian habitation site is within the Nani Pua Gardens II Subdivision and was identified during archaeological investigations by the Bishop Museum in 1986 (Kurashina et al. 1986). The 1.7-acre parcel is bordered on the north and east by Kāneʻohe Stream.

Preliminary investigations revealed a surface layer with lithic artifacts and a buried cultural layer. Additional sites recorded in the area included two lithic scatters (Site 50-Oa-G5-100), a former rice field and taro terrace (Site 50-Oa-G5-104), an Italian prisoner-of-war camp, and the Kaneohe Rice Mill. Subsurface testing recovered a relatively early radiocarbon date of AD 1070-1405. A large assemblage of lithic artifacts suggested the historic property was primarily used by “craftsman specializing in the manufacture of stone tools, primarily adzes” (Clark and Riford 1986:110). Two human burials, discovered in a fully extended position, lacked cultural material. Additional fragmentary remains were encountered in the context of pre-Contact basalt artifacts (Clark and Riford 1986:45, 104). Clark and Riford (1986:110) concluded the historic property housed craftsmen specializing in the production of stone tools, primarily adzes.

### 3.2.2 Kealahala Military Reservation

In 1990, the Department of the Army (1991) conducted a field inspection of a 21.64-acre inland parcel. This parcel was formerly part of the Kealahala Military Reservation, which was established in 1914 as an artillery range. The Governor requested the return of this property in 1928 as it was not being used. Most of the land was returned to the Hawaiian government, and the land was used for a Territorial Mental Hospital, which became the present Hawai'i State Hospital (Department of the Army 1991:Supporting Documents). During the field visit, no evidence of the existence of any buildings, structures, or debris related to the Kealahala Military Reservation were observed, and a review of documents indicated the area may never have been used by the military (Department of the Army 1991:2).

### 3.2.3 Castle Hills Access Road Monitoring

In 1991, CSH conducted an inventory survey for the 500 m Castle Hills access road, located approximately 2 km inland of the present project area (Hammatt et al. 1992). One test excavation was dug on the north side of Kapunahala Stream. Modern bottles were found in the top stratum, possibly incorporated into the soil from recent disturbance, such as plowing. In 1992, CSH (Duncan and Hammatt 1992) monitored all grubbing and grading for the road. One archaeological site was recorded, SIHP # -4523. The site had two features, an historic trash pit with bottles dating to the late 1800s and a cement box, possibly a water trough for livestock (Duncan and Hammatt 1992:29).

### 3.2.4 Waikalua Road, Kāneʻohe Bay Project

In 1993, CSH conducted an archaeological inventory survey within 3.2 acres along the shoreline of Kāneʻohe Bay at Waikalua Road, near Punaluʻu Fishpond (Stride et al. 1994). Research indicated a high probability that the project area had been a traditional Hawaiian settlement. The property was also the location of Coral Gardens resort hotel from 1915 to 1940. Eight backhoe trenches were excavated to determine the presence or absence of cultural deposits. No cultural material or human remains were observed during the survey or backhoe testing other than modern trash. No further archaeological work was recommended for the project.

### 3.2.5 Bay View Golf Course Archaeological Survey and Assessment

Hammatt and Borthwick (1989) conducted an archaeological survey and assessment of the 90-acre Bay View Golf Course. Background research indicated over 40 Land Commission Awards (LCA) granted for this area traditionally used for taro planting and aquaculture within three fishponds along Kāneʻohe Bay. Modern development of the area including the golf course, sewage treatment plant (Kaneohe WWPTF), surrounding residential subdivisions, and flood control projects, had caused extensive modifications of the land.

Waikalua Loko Fishpond and Waikalua Fishpond were the only two archaeological features found within the project area. Waikalua Loko Fishpond has been a continuously functioning fishpond since pre-Contact times. Waikalua Fishpond was in poor condition due to mangrove intrusion, but still showed an intact seawall. Both fishponds were recommended for preservation. Archaeological monitoring during initial clearing and grading was also recommended.

Subsurface testing was conducted between Kāneʻohe and Kāwā Streams in a strip of undeveloped pasture between Kāneʻohe WWPTF and the Bay View Golf Course on City and County land. The area was thought to be the only possibly undisturbed portion of the floodplain within the project area. The trench was located just west of the western boundary of the Kaneohe WWPTF.

Eight trenches were excavated at 50-100 ft (15.2-30.5 m) intervals with each trench averaging 7.5 m long and 230-240 cm deep (to the water table). Both sides of the trenches were examined for cultural materials and features as well as changes in stratification. A soil profile description was made for each trench and samples of all subsurface deposits were collected. Elevation rise from Trench 1 to Trench 8 was approximately 1 m.

Neither cultural materials nor features were observed within the backhoe trenches. The former *ʻauwai* shown on early maps was not discerned in the profiles of any of the trenches, nor was

there any indication of earthen field boundaries. Only “the original ponded, gleyed sediments associated with former taro/rice planting” was found beneath approximately 60-120 cm of fill (Hammatt and Borthwick 1989:40). No terracing or buried cultural material was observed. Archaeological monitoring was recommended during initial grubbing and grading of the property due to the possibility of subsurface cultural material associated with *lo‘i* cultivation.

### **3.2.6 Waikalua Loko Fishpond Preservation Plan**

Dashiell (1995) prepared a preservation plan for the Waikalua Loko Fishpond prior to the mid-1990s expansion of Bay View Golf Course. Two major components of the plan were proposed:

1. Preservation, restoration, and maintenance of the pond based on its present [1995] construction features, environment, and configuration. Actual operation of the pond could take place at any time, dependent on the desires of the owner and the WLFPS [Waikalua Loko Fishpond Preservation Society].
2. Interpretation program, which at a minimum may consist of a booklet and a self-guided tour along the public access route. Under the purview of the WLFPS, additional components of the interpretation program could be added, such as an interpretive center. The interpretive program was proposed to educate students or visitors to Hawai'i. The possibility that Windward Community College may be interested in establishing some sort of effort was also proposed. [Dashiell 1995:10]

### **3.2.7 Kāneʻohe Civic Center Playground Parking Lot**

The archaeological inventory survey of the proposed Kaneʻohe Civic Center Playground Parking Lot (Perzinski and Hammatt 2000) involved a surface field survey and limited subsurface testing. There were no pre-Contact or early historic structures visible in the project area. Some walls and rock mounds associated with the drainage canal from Kāneʻohe Stream were noted at the boundaries of the project area. One test excavation was placed near the canal. All of the soil was a fill material, and it was concluded that intensive land-altering activities had significantly changed the original soil structure of the area.

### **3.2.8 Kāneʻohe-Kailua Wastewater Conveyance Alternative Project**

Sinoto and Titchenal (2010) prepared an archaeological assessment for an alternative conveyance route of the Kāneʻohe-Kailua Wastewater Conveyance and Treatment Facilities (WWTP). That project involved the construction of a force main and installation of “nearly 10,000 linear feet of jacketed pipeline” that extended beneath Kāneʻohe Bay (Sinoto and Titchenal 2010:i). Either micro-tunneling or open trenching was planned for a two segments, a 1,000 linear ft (304.8 m) segment leading to the Kāneʻohe WWPTF and a 2,500 linear ft (762 m) segment leading to the Kailua WWTP. No subsurface testing was undertaken as two alternatives were proposed for the project.

Sinoto and Titchenal (2010) recommended “pre-construction spot testing” in the Kailua WWPTF segment if open trenching was planned. If micro-tunneling was planned, pre-construction of the “jacking pit or other access point localities” was recommended. Monitoring was recommended during open trenching of the Kāneʻohe WWPTF segment due to the presence of the Waikalua Loko Fishpond wall, and the presence of a “manmade embankment.”

Additionally, “a buffer zone of roughly 30 feet shall be established along the land-based perimeter of Waikalua-loko Fishpond to prevent inadvertent intrusions and damage to the structural components of the fishpond” (Sinoto and Titchenal 2010:54).

### **3.2.9 Bay View Golf Course/YMCA Sewer Line Rehabilitation Project**

Sinoto and Dashiell (2011) conducted archaeological monitoring for the Bay View Golf Course/YMCA Sewer Line Rehabilitation Project. The location of the sewer line is described as “on the grounds of the existing Bay View Golf Course immediately south of Kāwā Stream and Waikalua-loko Fishpond” (Sinoto and Dashiell 2011:1).

The project entailed open trenching for 125 ft (38.1 m) to replace approximately 1,600 ft (487.7 m) of existing sewer line. The trench measured 10 ft (3.05 m) wide and 15-16 ft (4.6-4.9 m) deep. Trenches contained “vast amounts of fill materials including imported soils and some organic detritus such as *hau* and mangroves to fill marshy areas during original pipeline installation followed by golf course construction” (Sinoto and Dashiell 2011:6).

## Section 4 Results of Field Inspection and Recommendations

---

### 4.1 Field Inspection

The fieldwork component for this historical resources study was conducted on 9 December 2013 by CSH archaeologists Constance R. O'Hare, B.A. and David W. Shideler, M.A. This fieldwork consisted of a limited field inspection of the water line area to identify any surface archaeological features, and to investigate and assess potential impact to historic properties. The only surface historic structure noted during the field inspection was the Kalokohanahou Fishpond wall, which has already been designated SIHP # 50-10-10-343.

The field inspection began at the Kahanahou Pump Station (Figure 21) at the coast at the end of Kahanahou Place. A remnant of the old Kalokohanahou Fishpond stacked-rock wall is still evident beneath a dense cluster of *naupaka* (*Scaevola taccada*) to the east of the pump station at the western shore of a private boat harbor (Figure 22 through Figure 24).

The field inspection continued by driving down Kahanahou Place to the intersection with Kahanahou Circle to the west and then down Kahanahou Circle to its junction with Lilipuna Place (Figure 25 through Figure 28). Sewer manholes along this route were noted not only on the edges of the residential roads, but also in the center of the roads. At the east end of Lilipuna Place is the northeast end of the private residential section that does not have a road, as shown in Figure 29 through Figure 31. To access the southwest end of this private property it was necessary to take an alternate route to the junction of Makahī'ō Street and Wailele Road. The end of the private property section, shown in Figure 31, is an open southwestern sloping area. The project area continues along Makahī'ō Street a short distance past the junction with Wailele Street (Figure 32).

### 4.2 Summary and Recommendations

Only one historic property, the remnants of a stacked stone wall for Kalokohanahou Fishpond was noted during the field inspection. The plans for the wastewater improvements include excavation near the wall (in Kahanahou Place in the interior of the former fishpond, see Figure 22 for relationship) but do not include any modifications to this wall.

Historical research indicates that this area was used intensively in the mid-nineteenth century for taro cultivation (see Figure 8), as ponded fields and perhaps dryland gardens were placed adjacent to both sides of an old *'auwai* (irrigation ditch) that extended to the coast. Thus, there may be subsurface cultural deposits and/or burials associated with the habitation and agricultural use of the land beneath the modern surface.

Based on the long, serpentine nature of the project area and this study's results that emphasize the extensive land modification and the seemingly low likelihood of intact cultural deposits in any specific location, an archaeological inventory survey of the project area (per the requirements of HAR §13-276) does not appear warranted for development within the project area. CSH does however recommend an archaeological monitoring program with an archaeological monitor to be present during all subsurface excavations greater than 12 inches deep that are needed for the project. This will ensure any subsurface cultural deposits and/or burials as maybe present can be identified. A monitoring program of on-site archaeological



Figure 21. Kahanahou Wastewater Pump Station, eastern end of project area, view to northwest (CSH photograph)



Figure 22. Kahanahou Place, view southwest from Pump Station entrance; Kalokohanahou Fishpond wall remnant beneath *naupaka* hedge at left side of road (CSH photograph)



Figure 23. Kalokohanahou Fishpond wall remnant covered by *naupauka* (CSH photograph)



Figure 24. Kalokohanahou Fishpond stacked stonewall remnant beneath *naupauka* (CSH photograph)





Figure 25. Kahanahou Circle, view southeast back to Kahanahou Place (CSH photograph)



Figure 26. Kahanahou Circle (front section) and Lilipuna Road (back section), view southwest toward junction with Lilipuna Place; note manhole in center of roadway (CSH photograph)



Figure 27. Lilipuna Place, view west-southwest towards private property between Lilipuna Place and Wailele Road (CSH photograph)



Figure 28. Lilipuna Place, view northwest toward the elevation of Pu'u Pahu (left background), former location of Pu'upahu Heiau; note manhole in left lane (CSH photograph)



Figure 29. Private property between Wailele Road and Lilipuna Place, western section, view to east-northeast (CSH photograph)



Figure 30. Private property between Wailele Road and Lilipuna Place, central section, view to east-northeast (CSH photograph)



Figure 31. Private property between Wailele Road and Lilipuna Place, eastern section, view to east-northeast (CSH photograph)



Figure 32. Junction of Wailele Road and Makahī'ō Street, western end of project area, view to west; note manhole in center of roadway (CSH photograph)

monitoring is recommended for all ground disturbance conducted within the project area below the existing ground surface to facilitate the identification and treatment of any historic properties and/or burials that might be discovered during project construction. Any departure from this will require consultation with and written concurrence from SHPD.

If deemed necessary by the SHPD, it is possible that one or more archaeological inventory survey test excavations could be placed in the open area of the private property area near Waialele Street (Figure 33) in an area of former LCAs. These test excavations could reveal the soil stratigraphy, search for any remains of the old *'auwai* (ditch) shown on historic maps, and reveal habitation remains in the vicinity of LCA 10447 and 8456 (Figure 34).



Figure 33. Aerial photograph showing the location of the project area and two possible testing areas near Waialele Street (Google Earth 2013),



## Section 5 References Cited

---

### **Abbott, Isabella A.**

1992 *Lā'au Hawai'i: Traditional Hawaiian Uses of Plants*. Bishop Museum Press, Honolulu.

### **Allen, Jane (editor)**

1987 *Five Upland 'Ili: Archaeological and Historical Investigations in the Kane'ohē Interchange, Interstate Highway H-3, Island of O'ahu*. Departmental Report Series B7-1, Department of Anthropology, Bernice Pauahi Bishop Museum, Honolulu.

### **Bates, George Washington**

1854 *Sandwich Island Notes by a Haole*. Harper & Brothers, New York.

### **Bishop Museum, Bernice Pauahi**

n.d. *Ke-ahi-a-Kahoe*. Hawaiian Ethnological Notes, HEN Vol. 1, p. 2181. Bishop Museum Archives, Bernice Pauahi Bishop Museum, Honolulu.

### **Chamberlain, Levi**

1828 *Tour Around Oahu, 1828*. Manuscript on file at Hawaii Mission Children's Society, Hawaiian Historical Society Library, Honolulu.

### **Chinen, Jon J.**

1958 *The Great Mahele, Hawaii's Land Division of 1848*. University of Hawai'i Press, Honolulu.

### **Clark, John R.K.**

2002 *Hawaii Place Names*. University of Hawai'i Press, Honolulu.

### **Clark, Stephan Dane and Mary Riford**

1986 *Archaeological Salvage Excavations at Site 50-Pa-G5-101, Waikalua-Loko, Kāne'ohē, Ko'olaupoko, O'ahu Island, Hawai'i*. Department of Anthropology, Bernice Pauahi Bishop Museum, Honolulu.

### **Cobb, John N.**

1905 *The Commercial Fisheries of the Hawaiian Islands in 1903*. U.S. Fish Commission Report for 1904. Government printer, Washington, D.C.

### **Coulter, John W.**

1931 *Population and Utilization of Land and Sea in Hawai'i, 1853*. Bernice Pauahi Bishop Museum Bulletin 88. Bernice Pauahi Bishop Museum, Honolulu.

### **Dashiell, Eugene P.**

1995 *Waikalua Loko Fishpond Preservation Plan, Kāne'ohē, Hawai'i*. AICP, Planning Services, Honolulu.

### **Department of the Army**

1991 *Defense Environmental Restoration Program for Formerly-Used Sites, Inventory Project Report, Kaneohe District Park (Keaahala Military Reservation), Kaneohe, Koolaupoko, Island of Oahu, Hawaii. Project No. H09HI017400*. Department of the Army, U.S. Army Engineer District, Pacific Ocean Division, Ft. Shafter, Oahu.



**Devaney, Dennis M., Marion Kelly, Polly Jae Lee, and Lee S. Motteler**

1982 *Kāne'ōhe: A History of Change*. Bess Press, Honolulu.

**Donn, John M.**

1906 Based on 1902 map of "Oahu Hawaiian Islands" by Walter E. Wall with data from private surveys by John M. Donn. Land use as of 1906 added to map. Registered Map 2374. Available at the Hawai'i Land Survey Division, Department of Accounting and General Services, 1151 Punchbowl Street, Room 210, Honolulu.

**Dorrance, William H.**

1998 *Oahu's Hidden History: Tours into the Past*. Mutual Publishing, Honolulu.

**Dorrance, William H. and Francis S. Morgan**

2000 *Sugar Islands: The 165-Year Story of Sugar in Hawai'i*. Mutual Publishing, Honolulu.

**Duncan, Edward D. and Hallett H. Hammatt**

1992 *Archaeological Monitoring Results for Castle Hills Access Road, Kāne'ōhe, Ko'olaupoko, O'ahu (TMK 4-5-23:3)*. Cultural Surveys Hawai'i, Inc., Kailua, Hawai'i.

**Durand, Loyal, Jr.**

1959 The Dairy Industry of the Hawaiian Islands. *Economic Geography* 35(3):228-246.

**Foote, Donald E., E.L. Hill, S. Nakamura, and F. Stephens**

1972 *Soil Survey of the Islands of Kauai, Oahu, Maui, Molokai and Lanai*. State of Hawaii, U.S. Department of Agriculture, U.S. Government Printing Office, Washington, D.C.

**Giambelluca, Thomas W., Michael A. Nullet, and Thomas A. Schroeder**

1986 *Rainfall Atlas of Hawai'i*. Department of Land and Natural Resources, Honolulu.

**Google Earth**

2013 Aerial photographs of Hawai'i. Google Inc., 1600 Amphitheatre Parkway, Mountain View, California. Available online at [www.google.com/earth.html](http://www.google.com/earth.html).

**Graham, Mrs. Maria (compiler)**

1826 *Voyage of the H.M.S. Blonde to the Sandwich Islands, in the Years 1824-25*. John Murray, London.

**Hammatt, Hallett H. and Douglas K. Borthwick**

1989 *Archaeological Survey and Assessment of a 90-Acre Parcel for the Proposed Expansion of the Bay View Golf Course Kāne'ōhe, O'ahu*. Cultural Surveys Hawai'i, Inc., Kailua, Hawai'i.

**Hammatt, Hallett H., Douglas Borthwick, and William Folk**

1992 *Archaeological Inventory Survey of Castle Hills Access Road, Kāne'ōhe, Ko'olaupoko, O'ahu*. Cultural Surveys Hawai'i, Inc., Kailua, Hawai'i.

**Handy, E. Craighill and Elizabeth G. Handy**

1972 *Native Planters of Hawaii: Their Life, Lore, and Environment*. Bishop Museum Bulletin 233. Bishop Museum Press, Honolulu.

**Harper, Joseph**

- 1972 Pineapple, A Major Industry in the Area 50 Years Ago. *Ka Lama* 3(2):3, 8. Kahaluu Printing Company, Kahalu'u, Hawai'i.

**Hawai'i State Archives**

- 1887 Photograph of fishponds on west shore of Kane'ohe Bay. Hawai'i State Archives, Kekāuluohi Building, 364 S. King Street, Honolulu.
- 1930s Photograph of fishponds on west shore of Kane'ohe Bay. Hawai'i State Archives, Kekāuluohi Building, 364 S. King Street, Honolulu.
- 1940s Photograph of fishponds on west shore of Kane'ohe Bay. Hawai'i State Archives, Kekāuluohi Building, 364 S. King Street, Honolulu.

**Hawai'i TMK Service**

- 1984 Tax Map [1] 4-5-002, 4-5-045, 4-5-047, 44-5-074, 4-5-057. Available at Hawai'i TMK Service, 222 Vineyard Street, Suite 401, Honolulu.

**Henke, Louis A.**

- 1929 *A Survey of Livestock in Hawaii*. University of Hawai'i Research Publication No. 5. University of Hawai'i at Mānoa, Honolulu.

**Jarves, James Jackson**

- 1872 *History of the Hawaiian Islands: Embracing their Antiquities, Mythology, Legends, Discovery by Europeans in the Sixteenth Century, Re-Discovery by Cook, with Their Civil, Religious and Political History, from the Earliest Traditionary Period to the Year 1846*. Fourth edition. Henry M. Whitney, Honolulu.

**Kamakau, Samuel M.**

- 1976 *The Works of the People of Old. Na Hana a ka Po'e Kahiko*. Bishop Museum Special Publication 61. Bishop Museum Press, Honolulu.
- 1992 *Ruling Chiefs of Hawaii*. Revised edition. Kamehameha Schools Press, Honolulu.

**Kame'eleihiwa, Lilikalā**

- 1992 *Native Land and Foreign Desires: Pehea Lā E Pono Ai?* Bishop Museum Press, Honolulu.

**King, Robert D.**

- 1931 Map and Description for Land Court Application Map 2001, Map 1 for Kaneohe Land Company, Ltd., Applicant. Being land at Lilipuna, Kalaepaa, Kanohuluiwi, Wailele, Kalokohanahou, Kaopulolia, Kaneohe, Koolaupoko, Oahu, T.H. Available at the Hawai'i Land Survey Division, Department of Accounting and General Services, 1151 Punchbowl Street, Room 210, Honolulu.

**Kelly, Marion**

- 1975 *Lolo I'a O He'eia: Heeia Fishpond*. Department of Anthropology, Bernice Pauahi Bishop Museum, Honolulu.
- 1976 *Report 2 Historical Research: The History of the Land of Kaneohe*. Department of Anthropology, Bernice Pauahi Bishop Museum, Honolulu.

- 1987 Land Use in the 'Ili of Luluku, Kaneohe, Koolaupoko, Oahu. In *Five Upland 'Ili: Archaeological and Historical Investigations in the Kāne'ohē Interchange, Interstate Highway H-2., Island of O'ahu*, edited by Jane Allen, pp. 285-294. Bernice Pauahi Bishop Museum, Honolulu.

**Kurashina, H., H. Leidemann, and M. Kelly**

- 1986 *Archaeological Survey of Lands at Kane'ohē, Ko'olaupoko, Oahu (TMK 4-5-8:1, 4-5-0:1, and 4-5-30:por.1)*. Manuscript at Department Anthropology, Bernice Pauahi Bishop Museum, Honolulu.

**Lyons, C.J.**

- 1894 *Land Matters in Hawaii*. In *United States Senate, Report of the Committee on Foreign Relations Hawaiian Islands*, pp. 1695-1703. Originally published 1875. Government Printing Office, Washington, D.C.
- 1876 "Kaneohe O'ahu With West Kailua" [map]. Surveyed in 1874 by C.J. Lyons. Registered Map 585. Available at the Hawai'i Land Survey Division, Department of Accounting and General Services, 1151 Punchbowl Street, Room 210, Honolulu.

**McAllister, J. Gilbert**

- 1933 *Archaeology of Oahu*. Bishop Museum Bulletin 104. Bernice Pauahi Bishop Museum, Honolulu.

**McCoy, Patrick C., Akihiko Sinoto, and Ranjit Cooray**

- 1972 *Environmental Inventory Study for Kaneohe-Kailua Flood Control Project*. Department of Anthropology, Bernice Pauahi Bishop Museum, Honolulu.

**Miyagi, Michichiro**

- 1963 *Land Use in Waiahole Valley, Oahu*. M.A. thesis, University of Hawai'i at Mānoa, Honolulu.

**Monsarrat, M.D.**

- 1897 "Heeia & Kaneohe Watered from Kalimukele and Kapukauki" [map] by M.D. Monsarrat. Registered Map 1897. Available at the Hawai'i Land Survey Division, Department of Accounting and General Services, 1151 Punchbowl Street, Room 210, Honolulu.

**Perzinski, David and Hallett H. Hammatt**

- 2000 *An Archaeological Inventory Survey of the Kane'ohē Civic Center Playground Parking Lot (TMK 4-5-18:Por.2, 52)*. Cultural Surveys Hawai'i, Inc., Kailua, Hawai'i.

**Pukui, Mary K., Samuel H. Elbert, and Esther Mookini**

- 1974 *Place Names of Hawaii*. University of Hawai'i Press, Honolulu.

**Rice, William Hyde**

- 1977 *Hawaiian Legends*. Bishop Museum Special Publication 63. Bishop Museum Press, Honolulu.

**Sinoto, Aki and Eugene P. Dashiell**

- 2011 *Archaeological Monitoring Report: Bay View Golf Course/YMCA Sewerline Rehabilitation Project Area, Kane'ohē ahupua'a, Ko'olaupoko District, O'ahu Island (TMK: (1) 4-5-030: por. 001)*. Aki Sinoto Consulting, Honolulu.

**Sinoto, Aki and Paul Titchenal**

- 2010 *Archaeological Assessment: Proposed Kane'ohē-Kailua Force Main No.2, Kane'ohē, Ko'olaupoko, O'ahu*. Aki Sinoto Consulting, Honolulu.

**Sterling, Elspeth P. and C.C. Summers**

- 1978 *Sites of Oahu*. Department of Anthropology, Bernice Pauahi Bishop Museum, Honolulu.

**Stride, Mark, Douglas Borthwick, Victoria S. Creed, and Hallett H. Hammatt**

- 1994 *Inventory Survey and Subsurface Testing at Waikalua Road, Kaneohe Bay, O'ahu 3.2 Acres (TMK 4-5-05:1, 2, 12, 13 & 14)*. Cultural Surveys Hawai'i, Inc., Kailua, Hawai'i.

**Tinker, R.**

- 1900 Extracts from the diary of Rev. R. Tinker to the American Board, 23 July 1831. Reprinted as "Nuuanu Pali in Olden Time," in *Hawaiian Almanac and Annual of 1901*, pp. 87-89. Thos. G. Thrum, Honolulu.

**U.S. Army War Department**

- 1919 U.S. Army War Department, 1:20,000 scale, fire control map of O'ahu, Waimanalo quadrangle. Available at USGS Information Services, Box 25286, Denver, Colorado.
- 1936 U.S. War Army Department, 1:20,000 scale, terrain map of O'ahu, Kaneohe quadrangle. Available at USGS Information Services, Box 25286, Denver, Colorado.
- 1943 U.S. Army War Department, 1:20,000 scale, terrain map of O'ahu, Kailua quadrangle. Available at USGS Information Services, Box 25286, Denver, Colorado.
- 1943 U.S. War Department, 1:20,000 Scale terrain map, Kaneohe quadrangle. Available at USGS Information Services, Box 25286, Denver, Colorado.

**U.S. Geological Survey**

- 1954 Kaneohe USGS, 7.5-minute topographic quadrangle. Available at USGS Information Services, Box 25286, Denver, Colorado.
- 1978 USGS Orthophoto, Kaneohe quadrangle. Available at USGS Information Services, Box 25286, Denver, Colorado.
- 1998 Kaneohe USGS, 7.5-minute topographic map of O'ahu, Kaneohe quadrangle. Available at USGS Information Services, Box 25286, Denver, Colorado.

**Waihona 'Aina**

- 2000 *The Māhele Database*. Electronic document, <http://waihona.com>.

# Appendix A Land Commission Award Testimony in Vicinity of Project Area

---

## No. 35 M.A., Kanakahonu

No. 7181, Kamakahonu

N.R. 299-300v5

Hear ye, ye Land Commissioners: Here are my lands, given me by Kamehameha III.

Nunulu, Ahupua'a, Kohala, Hawaii.

Kaiholena, Ahupua'a, Kohala, Hawaii.

Kamooiki, Ili, Waikiki, Kona, Oahu.

Kalokohou, 'Ili, Kaneohe, Koolaupoko, Oahu.

That is my share, from the Royal Palace. All the po'alimas of these lands are for me. That is my claim.

KAMAKAHONU

N.T. 312v10

No. 7181, Kamakahonu, 31 August 1853

Kamakahonu's lands in Mahele Book.

Kalokohanahou ili of Kaneohe, Koolaupoko, Oahu.

Kamooiki ili of Waikiki, Kona, Oahu.

Numelu ahupuaa, Kohala, Hawaii

Kaiholewa ahuaa, Kohala, Hawaii.

TRUE COPY

A.G. Thruston, Clerk

[Award 35 M.A.; R.P. 7158; Kalokohanahou Kaneohe Koolaupoko; 1 ap.; 52.54 Acs; no. 7181 not awarded]

**No. 1954, Kalaikau****N.R. 305v3**

To the Land Commissioners: I, the undersigned, hereby state my claim for land at Kāneʻohe in the ʻIli of Kalokohuluiwi. There are sixteen loʻi, a kula and a house, bounded on the east by the sea, on the north by the lands Laakuaa, on the west, the land of Keliwaiwaiole, on the south, the land of Kamokuwaiole.

KALAIKAU X His mark

December 17, 1847

**F.T. 451v14**

Helu 1954, Kalaikau, See 458 page

Makuakane, hoohikiʻia, Ua ʻike au i kona aina ma Kāneʻohe, Koʻolaupoko.

ʻĀpana 1. 16 loʻi kalo & pāhale ma ka ʻili o Kanohuluiwi.

Panei na palena:

Mauka, ka ʻili o Lipuna

Koʻolauloa, ka ʻili o Kalokohou

Makai, he kahakai

Kailua, ka moʻo ʻāina o Mokuwaiole.

No Puhahaha mai kona aina i ka wa e ola ana o Liliha, mamua i ka M.H. 1839. A ua mau kona noho ma malaila, ʻAʻole mea keakea.

**N.T. 458v14**

No. 1954 Kalaikau, claimant, from page 451

Makuahine, the witness, says the land is in the ʻili of Kanohuluiwi, 16 taro patches.

No. 1. 16 taro patches and house lot. It is bounded:

Mauka, the ʻili Lipuna

Koolauloa, the ʻili Kalokohou

Makai, sea beach

Kailua, taro land of Makuwaiole.

His land is from Puhalahua in the time of Liliha. No one has ever disputed his title.[Award 1954; R.P. 1390; Kawaihae Kāneʻohe Koʻolaupoko; 1 ʻāp.; 1.67 Acs]

**No. 1966, Opu****N.R. 309v3**

Greetings and Peace to the Land Commissioners: I hereby state the boundaries of my land at Kaneohe in the 'ili of Owaikapoki, consisting of four lo'i. On the east is a pond, on the north is the land of Kahuaia, on the west is the land of Hoomaulu, on the south is the land of Malia. One lo'i is at Waiape, one is at Wailele, a house with two planted trees.

OPU

December 18, 1847

**F.T. 99v11**

No. 1966, Opu

Kumuhonua Hoohikiia, Ua ike au i kona aina ma Kaneohe, Koolaupoko

Apana 1. 4 loikalo ma ka ili o Waikapoki

Apana 2. 1 loikalo ma ka ili o Waiape

Apana 3. 1 loikalo ma ka ili o Wailele

Apana 4. Pahale ma ka ili o Wailele

Apana 1.

Mauka, ko Hoonaula aina

Koolauloa, ka aina o Malia

Makai, loi poalima a me ka loi o Kahuaia

Kailua, kahawai o Wailele

Apana 2.

Mauka, ko'u aina

Koolauloa, ko Pahia aina

Makai, ko Kapaula aina

Kailua, ko'u aina

Apana 3.

Mauka, ko Kauikea aina

Koolauloa, pela no

Makai, pela no

Kailua, ko Koe(ill)aakaia, a me ka loi poalima

Apana 4.

Mauka, alanui Aupuni

Koolauloa, kula o Lipuna

Makai, pela no

Kailua, kula o Wailele

No Wahineino mai kona aina i ka wa o Liliha mamua o ka M.H.1839. Apana 2, no Paha mai i ka M.H.1840. Apana3, 4, no Nanikea mai i ka M.H.1845, a ua mua kona noho ana aole mea keakea.

Kaenaakaia Hoohikiia, ua like ko maua ike

**F.T. 58v11**

No. 1966, Opu

Kumuhonua, says under oath, I know claimant's land. It is in Kaneohe.

No. 1 is 4 lois in Waikapoki.

No. 2 is 1 loi in Waiape.

No. 3 is 1 loi in Wailele.

No. 4 is a house & lot in Wailele.

No. 1 is bounded:

Mauka by Hoomaulu's kalo land

Koolauloa by the ili of Wailele

Makai by Kahuia's kalo land & a poalima

Kailua by the creek of Wailele.

No. 2 is bounded:

Mauka by Kumuhonua's kalo land

Koolauloa by Pahia's kalo land

Makai by Kapaula's kalo land

Kailua by Kumuhonua's kalo land.

No. 3 is bounded:

Mauka by Kauikea's kalo land

Koolauloa by Kauikea's kalo land

Makai by Kauikea's kalo land

Kailua by Kunakaia & a poalima.

No. 4 is bounded:

Mauka by the road

Koolauloa by upland of Lipuna

Makai by upland of Lipuna

Kailua by Wailele.

The kalo land in Waikapoke was given to claimant by Wahineino in the time of Liliha. The kalo land in Waiape was given by Peha in the year 1840. The kalo land and house lot in Wailele was given by Kauikea in 1845. Claimant has had them in peace to the present time.



Kuaikolia, testifies to the truth of the above statements.

[Award 1966; R.P. 4902; Waiape Kaneohe Koolaupoko; 1 ap.; .19 Ac.; Waikapoki Kaneohe Koolaupoko; 1 ap.; .29 Ac.; Wailele Kaneohe Koolaupoko; 3 ap.; 1.57 Acs]

**No. 1967, Kahinu**  
**N.R. 309v3**

Greetings and Peace: I hereby state the boundaries of my land in Kaneohe in the 'ili of Kailipaa, consisting of seven lo'i. On the east is a pali, on the north is the land of Kala, on the west is a kula, on the south is the land of Kuaana. There are two houses with a big fence. One lo'i is in the 'ili of Waikapoki.

KAHINU

December 18, 1847

**F.T 66v11**

No. 1967, Kahinu

Kekuahani, Hoohikiia, Ua ike au i kona aina ma Kalaepaa 6 loi kalo, a hookahi loi ma Waikapoki a me ka pahale iloko o Waikapoki a me Wailele, Kaneohe Koolaupoko.

6 loi kalo ma ~~Waikapoki~~ Kalaepaa

Mauka, ko Kuaana aina

Koolauloa, ko Kala aina

Makai, ko Puupuu aina

Kailua, pela no

1 loi kalo

Mauka, ko Keliiholomoku aina

Koolauloa, ko Kala aina

Makai, ko Kauikea aina

Kailua, kahawai o Wailele

Pahale

Mauka, ko Kula aina

Koolauloa, ko Kanehoalani & Keliiholomoku pahale

Makai, ka alanui Aupuni

Kailua, ko Kauikea ainana paa hapa i ka pa, 2 aoao i paa

No'u aku kona aina i ka M.H. 1836, a na noha oia malaila a hiki i keia wa, aole mea keakea

Kumuhonua Hoohikiia, Ua like no ko maua ike me ka Kekuahani i hai ae nei, a ua oiaio kana hoike ana.

**F.T. 3v11**

No. 1967, Kahinu

Kekuahane, sworn says, I am a son of Kaneohe and know the claimant's land. It consists of six lois in the Ili of Kalaepaa, Kaneohe, and one loi adjoining these six lois, but in the Ili of Waikapoki. Also a House lot partly in Waikapoki and partly in Wailele.

The piece of 6 lois is bounded:  
Mauka by Kuaana's lois  
Koolauloa by the Wailele Creek  
Makai by Puupuu's lois  
Kailua by Puupuu's lois.

No. 2 (one loi) is bounded:  
Mauka by Keliiholomoku's lois  
Koolauloa by Kala's land  
Makai by the Ili of Wailele  
Kailua by Wailele Creek.

No. 3 (House Lot ) is bounded:  
Mauka by the kula of Waikapoki  
Koolauloa by Kanehoalani's house lot  
Makai by the government road  
Kailua by the kula of Wailele, Kauikea's land.

The claimant received these lands from me 14 years since, and has possessed them ever since in peace.

Kumuhonua, sworn, says, I am a son of Kaneohe and know the land of claimant. The testimony of Kekuahane is true.

[Award 1967; R.P. 2042; Kalaepaa Kaneohe Koolaupoko; 1 ap.; 2.22 Acs]

## No. 2343, Keli'iwaiwai'ole

### N.R. 460v3

To the Land Commissioners, Greetings: I hereby state my claim for land in the 'ili at Kokokohou in Kāne'ohē, Island of Oahu. 1 mo'ō, 18 taro lo'i, 2 taro lo'i adjoining the mo'ō of Makuakane, 1 lo'i adjoining with the lo'i of Kahawaii, 1 kula adjoining Kikiwelawela. My house claim is in the same 'ili. I got it in the year 1841.

KELIIWAIWAIIOLE X his mark

### F.T. 36v14

Helu 2343, Keli'iwaiwaiole, See 165 page

Kapule, ho'ohikiia, Ua ike au I kona aina ma ka ili o Kalokohou ma Kaneohe.

'Āpana 1. 16 lo'i me kahi kula

'Āpana 2. 2 loi.

'Āpana 3. kula.

'Āpana 4. pāhale.

'Āpana 1:

Mauka, aina o Keliiholomoku

Koolauloa, aina o Kauwa

Makai, moo o konohiki

Kailua, aina o Laahanu.

'Āpana 2:

Mauka, 'āina o Makuakane

Ko'olauloa, kahawai

Makai, loko poalima

Kailua, aina o Kapala.

'Āpana 3:

Mauka, pali o Kekiwelawela

Ko'olauloa, kula o Kauwa

Makai, kai

Kailua, kula o Makuakane.

'Āpana 4:

Mauka, Kahuahale o Keau

Ko'olauloa, kula o Kalokohou

Makai, 'auwai me ka 'āpana mua

Kailua, pāhale o Kauwa & Wahaulaula.

No Kamakahonu mai kona aina I ka M.H. 1843. Ua noho me ka maluhia. Aole mea keakea.

Kahinu, hoohikiia, Ua oiaio no.

**F.T. 165v14**

No. 2343, Keli'iwaiwai'ole, claimant, from 36 page

Kapule, sworn say, claimant land is in the 'ili Kalokohou at Kāne'ohē & is as follows:

No. 1. 16 lo'is taro

No. 2. 2 lo'i taro.

No. 3. Upland.

No. 4. House lot.

No. 1 is bounded:

Mauka by the 'ili of Lipuna

Ko'olauloa by the taro land of Kauwa

Makai by a poalima

Kailua by taro land of Lahanu.

No. 2 is bounded:

Mauka by the taro land of Makuakane

Ko'olauloa by the taro land of Kahawaii

Makai by fish pond

Kailua by the taro land of Kapela.

No. 3 is bounded:

Mauka by high hill

Ko'olauloa by upland of Kauwa

Makai by sea beach

Kailua by potato patch of Makuakane.

No. 4 is bounded:

Mauka by the house lot of Keau

Ko'olauloa by upland of Kalokohou

Makai by a river

Kailua by the house lot of Wahaulaula.

Claimant land is from Kamakahonu in the year 1843 and has had it in peace.

Kahinu, sworn, testifies to the truth of the above statement.

[Award 2343; R.P. 1389; Kaimihana Kaneohe Ko'olaupoko; 1 'āp.; 6.09 Acs]

**No. 2345, Keau,****N.R. 461v3**

To the Land Commissioners, Greetings: I hereby state my claim for land in the 'ili of Kalokohou in Kaneohe, Island of Oahu. There are 4 taro lo'i together in one place, one kula adjoining a kula of Kahawaii. My house claim is in this one 'ili. I acquired my interest before the law was published.

KEAU X, his mark

**F.T. 15v14**

Helu 2345, Keau, continued page 149

Makuakane, hoohikiia, Ua ike au Ikona mau aina ekolu mau Apana ma ka ili of Kalokohou ma Kaneohe.

Apana 1 4 loi ili of Kalokohou.

Apana 2 kula ili of Kalokohou.

Apana 3 Kulanahale ili of Kalokohou.

Apana 1:

Mauka, na loi o Kauwa

Koolauloa, no loi o Kapela

Makai, loko Poalima

Kailua, aina o Manene.

Apana 2. Ua puni I ke kula o he konohiki ma na aoao a pau.

Apana 3:

Mauka, Ili of Lipuna

Koolauloa, kula o Kipuna & Kalokohou

Makai, Kulanahale o Keliwaiwaiole

Kailua, Ili o Kanohuluiwi.

No Kumeheua mai kona aina I ka wa o Kamakahonu oia ka M.H. 1841 aole mea keakea ia ia.

Kahawaii, hoohikiia, Ua oiaio kana.

**F.T. 148-149v14**

No. 2345, Keau, claimant, from 15 page

Makuakane, sworn say, I know claimant's land is in the ili of Kalokohou, Kaneohe.

No. 1 is 4 taro patches.  
No. 2 is a piece of upland, a potatoe field.  
No. 3 is a house lot.

No. 1 is bounded:  
Mauka by the taro land of Kauwa  
Koolauloa by the taro land of Kapela  
Makai by the fish pond  
Kailua by the taro land of Manene.

No. 2 is bounded: On all sides is the upland of Kalokohou. It is a small potatoe field.

No. 3 is bounded:  
Mauka by the upland of Kipuna.  
Koolauloa by the upland of Lipuna & Kalohohou  
Makai by house lot of Keliawaiwaiole  
Kailua by ili of Kanohouluiwi.

Claimant received his land from Kumeheua about the year 1841. No one disturbed claimant in his possessing the above land.

Kahawaii, sworn, testifies to the truth of the above.

[Award 2345, R.P. 1375, Kaopulolia Kaneohe Koolaupoko; 2 ap.; 1.09 Acs]

## No. 2460, Kekuaikolia, December 16, 1848

### N.R. 509v3

To the Land Commissioners, Greetings: I, the one whose name is below, hereby state my land claim, in the 'ili of the konohiki, Nahalelaau. On the north is a po'alima, on the east is a stream, on the south is the land of Maikaipohu, on the west is a pali. There is also a house claim.

KEKUAIKOLIA

Lipuna, Kaneohe Oahu

### F.T. 99v11

No. 2460, Kekuaikolia

Kumuhonua ho'ohikiia, Ua ike au i kona 'āina ma Kāne'ōhe, Ko'olaupoko

'Āpana 1. 5 loikalo ma ka 'ili o Waialele

'Āpana 2. Pahale ma ka 'ili o Lipuna

'Āpana 1.

Mauka, ka aina o Nakahulua

Koolauloa, pali o Waiape

Makai, ka aina o Pahia a me ka loi poalima

Kailua, kahawai o Kane'ōhe

'Āpana 2.

Mauka, kula o Lipuna

Koolauloa, pela no

Makai, ka auwai

Kailua, pela no

No Nahalelaau mai kona 'āina i ka M.H.1844, a ua mau kona noho ana a keia manawa, 'a'ole mea keakea

No Keli'iholomoku mai ka Apana 2; aka, ua noho mua kana poe makua malaila ma ka wa o Kamehameha I, a ua mau ko noho ana malaila, 'a'ole mea keakea

Kukona ho'ohikiia, Ua like pu ko maua ike me ko Kumuhonua

### F.T. 57v11/B>

No. 2460, Kekuaikolia

Kumuhonua, sworn says, claimant's land is in the ili of Waiape and his house in ili Lipuna.

No. 1 is 5 kalo patches in Waiape.



No. 2 is a house lot in Lipuna.

No. 1 is bounded:

Mauka by Nakahuelua's kalo land

Ko'olaupoko by the pali of Waiape

Makai by Pehia's kalo land & a poalima

Kailua by Kaneohe Creek.

No. 2 is bounded:

Mauka by upland of Lipuna

Ko'olaupoko by upland of Lipuna

Makai by a small brook

Kailua by a small brook.

Claimant's title to the kalo land is from Nahalela'au or his agent, Peha, in the year 1844 and has had it undisturbed from that time. His house lot he received from his ancestors, and is confirmed by Keli'iholomoku, the konohiki.

Kukona testifies to the truth of the above statement.

[Award 2460; R.P. 288; Lipuna Kāne'ōhe Ko'olaupoko; 1 'ap.; .88 Ac.]

**No. 2491B, Kamanene****No. 2471, Kamanene****N.R. 514v3**

To the Land

Commissioners: I, the one whose name is below, hereby state my claim in the 'ili of Lokohou, in Kamakahonu. On the north is the stone wall, on the east is a po'alima, on the south is a kula mo'o, on the west is the land of Kumeheua. I also have a kula. I got this land in the time before the publishing of the law.

KAMANENE

Kapulouia, Kaneohe, Oahu, December 18, 1847

**F.T. 17v14**

Helu 2417!, Kamanene, Continued page 150

[should be 2471]

Kuaikolia,

hoohikiia, Ua ike au i kona aina ma ka ili of Kalokohou. E lima loi one ke kula a hiki aku i kahi loi 1. E pili ana me ka Poalima ma Kaneohe nei.

Mauka, aina o Kauwa

Koolauloa, aina o Keau

Makai, lokoia poalima

Kailua, moo poalima.

Nau aku kona aina, no Kamakahonu mai ko'u i ka M.H. 1844. Ua noho me ka maluhia. Aole mea keakea.

Kauwa, hoohikiia, Ua oiaio kona hoike ana.

**F.T. 150v14**

No. 2471, Kamanene, Claimant, from page 17

Kekuaikolia, sworn, say claimant's land is in the ili of Kalokohou.

It is bounded:

Mauka by the taro land Kauwa, Kumupali

Koolauloa by the taro land Kauwa, Keau

Makai by fish pond

Kailua by the poalima land of Kalekohou.

His land was given him by myself in the year 1844. No one has disturbed him.

Kauwa, swear to the truth of the above.

[Award 2491B; R.P. 1398; Kalokohanahou Kaneohe Koolaupoko; 1 ap.; 1 Ac.; no document yet located for 2491B]

**No. 2496, Kelihelemoku****N.R. 525v3**

To the Land Commissioners, Greetings: I hereby state my claim for land in the 'ili at Lilipuna in Kaneohe, Island of Oahu, consisting of 1 mo' o. The boundaries are: On the east, the po'alima, on the south, the land of Puhulu, on the west, my kula, on the north, the land of Kamanu. My house claim and my kula claim are adjacent to Puhalahua's, and also with Kamakahonu's. Here is this claim: I have 4 po'alima lo'i and 1 po'alima kula, which I got before the law was printed.

KELIIHELEMOKU

**F.T. 13v14**

Helu 2496, Keliholomoku, See page 147

Wahaulaula, ho'ohikiia, Ua 'ike au I kona 'aina ma ka 'ili o Lipuna ma Kaneohe nei, mai ka mo'o'aina a he kula a me ke Kahuaahale.

Mauka, ko Puluhi me ke kula o Lipuna  
 Ko'olauloa, kula o Lipuna  
 Makai, 'Ili of Kanohouluiwi  
 Kailua, Owau.

Ua komo na loi poalima e 4 o he konohiki maloko. No Kinau mai kona aina I ka manawa o Kinau he `lii kiaana, aole mea keakea.

Makuakane, ho'ohikiia, Ua oiaio kona.

**F.T. 147v14**

No. 2496, Keliholomoku, claimant, from 13 page.

Wahaulaula, sworn say, claimant's land is in the ili Lipuna. It is a Mooaina.

No. 1 is bounded:

Mauka by the taro land of Puluhi & the upland of Lipuna  
 Ko'olauloa by the upland of Lipuna  
 Makai by the 'ili of Kanohouluiwi  
 Kailua by my land.

Witness says there are two patches included in the above, but claimant has had there is claims [sic] is from Kinau in the time of Kinau before 1839.

Makuakane testifies that the above is true.

[Award 2496; R.P. 289; Lilipuna Kāne'ohē Ko'olaupoko; 1 ap.; 2.27 Acs]

**No. 2555, Wahaulalula****N.R. 553v3**

To the Land Commissioners, Greetings: I hereby state my claim for land in the 'ili of Waikapoki, in Kaneohe, Island of Oahu, consisting of 1 mo'ō. The boundaries are: on the south, the land of Kumuhonua; on the north, the pali; on the east, the land of Waikapoiki; on the west, the land of Kelihelemoku. One kula adjoins the kula of Puhalahua. I got this claim before the law was published.

WAHAULAULA X, his mark

**F.T. 17v14**

Helu 2555, Wahaulaula, Continued page 150

Kelihiholomoku, ho'ohikiia, Ua 'ike au I kona aina ma ka' ili Waikapoki ma Kāne'ōhe.  
Kulanahale ma Kanohuluiwi

'Āpana 1. Mo'ō'āina one ka kula o Waikapoki.

'Āpana 2. Kulanahale ma Kanohuluiwi.

'Āpana 1:

Mauka, ko'u aina

Koolauloa, ko'u aina

Makai loko o Kanohuluiwi

Kailua, loko o Waikapoki.

'Āpana 2:

Mauka, kula o Lipuna

Ko'olauloa, kula o Kalokohou

Makai, kulanahale o Kauwa

Kailua, 'auwai o Lipuna.

No Alapai mai ka 'Āpana mua I ka M.H. 1844. Nona Koa mai ka 'Āpana 2. Ia wa no aole mea keakea ia ia.

Kauwa, ho'ohikiia, Ua oiaio na mea a Kelihiholomoku I hai mai nei.

**F.T. 150v14**

No. 2555, Wahaulaula, Claimant, from page 17

Keli'iholomoku, sworn, says I know claimant's land. It is in the 'ili of Waikapoki.

No. 1 taro land & a little upland.

No. 2 House lot.

No. 1 is bounded:

Mauka by my taro land

Ko'olauloa by my taro land

Makai by the fish pond of Kanohouliwi

Kailua by the fish pond of Kanohouliwi.

No. 2 is bounded:

Mauka by the upland of Lipuna

Ko'olauloa by the upland of Kalokohou

Makai by house lot of Kauwa

Kailua by brook of Lipuna.

Claimant's land is from Alapai in the year 1844, the house lot is from Nakoa, given recently in 1844. He has had it in peace up to this time.

Kauwa, sworn, say the above is true.

[Award 2555; R.P. 1385; Waikapoki Kaneohe Ko'olaupoko; 1 'āp.; .893 Ac.]

## No. 3431B, Kauwa (Kaule)

**Helu 3431B, Kauwa (Kaule) See page 157, No. 4244B**  
**F.T. 27v14**

Ko'ohikiia, ka mea kuleana a 'olelo mai la ua ho'okomo au. I ko'u kuleana a ua kakau ia e Kamali'i o Kaauwai a ua lilo ku'u kapaha ia lākou. 'A'ole nae puka mei nei, ua haule ma Honolulu paha. Ma ka Hale Hoona.

Kuaikalia, hoohikiia, Ua ike au I kona aina ma ka ili o Kaluakau ma Kaneohe he 11 loi me na kumu ulu elua a me kahi kula.

'Āpana 1. 11 lo'i & ulu me kula Kalokohou.  
 'Āpana 2. Pāhale ma Kanohuiwi.

'Āpana 1:  
 Mauka, Mo'o Keliwaiwaiole  
 Ko'olauloa, Mo'o Keliwaiwaiole  
 Makai, Mo'o Manene  
 Kailua, Mo'o poalima.

'Āpana 2:  
 Mauka, pāhale o Wahaulaula  
 Ko'olauloa, 'Ili o Kalokohou  
 Makai, pāhale o Mokuwaiole  
 Kailua, 'Auwai o Kanohuiwi.

No Kamakahonu mai ka 'āpana mua I ka wā o Liliha no Puhalahua mai ka 'Āpana 2 ia wā.  
 'A'ole mea keakea.

Pa, ho'ohikiia, Ua oiaio na 'olelo.

### **F.T. 157v14]**

[No. 3431B], Kauwa, claim not found, This claim is awarded under No. 3431B, page 27  
 [Listed under No. 4244B!]

Kauwa, sworn, say he sent his claim to the Land Commission. It is not found among the claims. He paid for the writing to an individual who came from Honolulu to take the claims.

Kauaiholeia, sworn, says I know the land of claimant in the 'ili of Kalokohou.

No. 1 is bounded:  
 Mauka by the taro land of Keliwaiwaiole

Ko'olauloa by the taro land of Keliiwaiwaiole  
Makai by the taro land of Manene  
Kailua by a poalima taro patches [sic].

No. 2 is bounded:  
Mauka by the house lot of Wahaulaula  
Koolauloa by 'ili of Kalokohou  
Makai by house lot of Mokuwaiole  
Kailua by a brook.

Claimant's land is from Kamakahonu in the time of Liliha. The house lot is from Pualahua. No one has disturbed the claimant to the present time.

Pa testifies to the truth of the above.

[Award 3431B; Kalokohanahou Kaneohe Koolaupoko; 1 'āp.; 1.998 Acs]



## **Appendix F**

Special Management Area Determination Letter

City and County of Honolulu Department of Planning and Permitting, March 2010




2010/ELOG-449

DEPARTMENT OF DESIGN AND CONSTRUCTION  
CITY AND COUNTY OF HONOLULU

650 SOUTH KING STREET, 11<sup>TH</sup> FLOOR  
HONOLULU, HAWAII 96813  
Phone: (808) 768-8480 • Fax: (808) 768-4567  
Web site: [www.honolulu.gov](http://www.honolulu.gov)

MUFI HANNEMANN  
MAYOR



CRAIG I. NISHIMURA, P.E.  
DIRECTOR

COLLINS D. AM P.E.  
DEPUTY DIRECTOR

WW.P10-046

March 3, 2010

MEMORANDUM

TO: DAVID K. TANOUE, DIRECTOR  
DEPARTMENT OF PLANNING AND PERMITTING

FROM: *For* *Craig I. Nishimura*  
CRAIG I. NISHIMURA, P.E., DIRECTOR  
DEPARTMENT OF DESIGN AND CONSTRUCTION

SUBJECT: KAHANAHOU WASTEWATER PUMP STATION UPGRADE PROJECT  
SPECIAL MANAGEMENT AREA (SMA) USE PERMITS

We are requesting your concurrence that the above mentioned project is exempt from the SMA Use permit.

The Kahanahou Wastewater Pump Station Upgrade Project has been initiated by the Department of Environmental Services to upgrade/replace pumps, piping, mechanical and electrical equipment, emergency power system, structures, ventilation system, and miscellaneous site improvements. The wastewater pump station site is identified by TMK: 4-5-047:95 (See enclosed plan).

It is our understanding that repair and maintenance of appurtenant structures such as sewer pump stations are exempt from SMA Use permits. The scope of this project will be limited to upgrading the sewer pump station. Upon completion of project, all adjacent ground features disturbed during construction will be restored to its original or better condition.

If you have any questions or require additional information to make your determination, please feel free to call Roy Tamashiro of the Wastewater Division at 768-8760

I hereby concur with the SMA exemption for Kahanahou Wastewater Pump Station Upgrade Project.

David K. Tanoue, Director  
Department of Planning & Permitting


Date

Enclosure

File

DEPARTMENT OF PLANNING AND PERMITTING  
**CITY AND COUNTY OF HONOLULU**

650 SOUTH KING STREET, 7TH FLOOR • HONOLULU, HAWAII 96813  
TELEPHONE: (808) 768-8000 • FAX: (808) 768-6041  
DEPT. WEB SITE: www.honolulu.gov • CITY WEB SITE: www.honolulu.gov



MUFI HANNEMANN  
MAYOR

DAVID K. TANOUE  
DIRECTOR  
ROBERT M. SUMITOMO  
DEPUTY DIRECTOR


2010/ELOG-449(AA)

March 10, 2010

**MEMORANDUM**

TO: CRAIG I. NISHIMURA, P.E., DIRECTOR  
DEPARTMENT OF DESIGN AND CONSTRUCTION

ATTENTION: WASTEWATER DIVISION

FROM:  DAVID K. TANOUE, DIRECTOR  
DEPARTMENT OF PLANNING AND PERMITTING

SUBJECT: SPECIAL MANAGEMENT AREA DETERMINATION  
KAHANAHOU WASTEWATER PUMP STATION UPGRADE PROJECT  
45-13 KA HANAHOU PLACE - KANEOHE  
TAX MAP KEY: 4-5-47: 95

This responds to your request, received on March 3, 2010, for information on the Special Management Area (SMA) use permit requirements to upgrade an existing wastewater pump station facility in the SMA.

The project will entail miscellaneous site improvements, and the repair and/or replacement of pumps, piping, mechanical and electrical equipment, emergency power system, structures, and ventilation system within an existing building. The project site is in the SMA; however, we confirm that the project will not require an SMA use permit pursuant to Sections 25-1.3(2)(D) and (M), Revised Ordinances of Honolulu. The proposed work is not expected to have any significant environmental or ecological effect on the SMA.

The project is subject to the environmental compliance law of Chapter 343 HRS. The applicant indicates that the project is exempt pursuant to Exemption Class #2 (Item 7) of the Department of Environmental Services Comprehensive Exemption List.

If you have any questions, please contact Ann Asaumi of our staff at 768-8020.

DKT:nw

**Comprehensive Exemption List  
for the  
City and County of Honolulu  
Department of Environmental Services**

HISTORICAL NOTE

This exemption list for the Department of Environmental Services was reviewed and concurred upon by the Environmental Council on May 17, 2012.

GENERAL NOTE

Section 343 of the Hawaii Revised Statutes (HRS) authorizes the Environmental Council to establish procedures to exempt specific types of action from the need to prepare an environmental assessment because the action will have minimal or no significant effect on the environment.

The following types of projects will not be exempt:

1. Projects requiring detailed analysis as provided in an environmental assessment under §343-5. These include, but are not limited to, places listed on the Federal or State registers of historic places.
2. Projects in statutorily defined areas, including but not limited to: critical habitats, special management areas, special design districts, registered view planes or scenic corridors, wet lands, sanctuaries, special habitats, shoreline areas, tsunami inundation areas, or other designations; except where the work is eligible for exemption and there is no negative impact on the conditions that define these areas.
3. Major projects without an Environmental Impact Statement (EIS); an Environmental Assessment with a Finding of No Significant Impact (EA/FONSI); or major projects that were never presented at a public meeting concerning site selection, master plan report, or any phase of incremental construction.
4. Major projects without a program to encourage public input into the design or siting of the project.

Pursuant to HAR Section 11-200-8 (B), all exemptions under the classes in this section are inapplicable when the cumulative impact of planned, successive actions of the same type, in the same place, over time, is significant, or when an action that is normally insignificant in its impact on the environment may be significant in a particularly sensitive environment, as expressed in #2 above.

Pursuant to the administrative rules promulgated under authority of Section 343-6(7) of the Hawaii Revised Statutes (HRS), specifically Section 11-200-8; the Department of Environmental Services has determined that the following types of actions, where they fall within the given classes of action, shall generally be exempt from the preparation of an environmental assessment.

### Exemption Class #1:

Operations, repairs or maintenance of existing structures, facilities, equipment or topographic features involving negligible or no expansion or change of use beyond that previously existing.

1. Clearing and grubbing
2. Construction staging areas, temporary
3. Drainage structures (e.g., culverts, outlets, inlets)
4. Earth berms, drainage swales, and stream banks
5. Equipment installations, including but not limited to pumps; motors; electrical transformers, cabinets, panels, and vaults; power, light, and telephone pole systems; heating, ventilation, and air conditioning (HVAC); supervisory control and data acquisition (SCADA); irrigation controllers; telephone stations; emergency electrical generators; and cathodic protection systems
6. Essential utilities, including but not limited, to wastewater systems, drainage systems, water systems, electrical systems, communication systems, SCADA systems, and fuel systems, except where a State Department of Health permit is required
7. Existing individual wastewater systems (cesspools, septic tanks, aerobic units)
8. Existing public facility structures, facilities, or equipment involving negligible or no expansion or change of use beyond that previously existing
9. Existing topographical features involving negligible or no expansion or change of use beyond that previously existing (e.g., maintenance dredging including dewatering; stream bank restoration; maintenance of vegetated and/or lined swales, wet ponds, and/or other water quality features in parks and golf courses)
10. Exterior stems and stairways
11. Fencing, curbing, walls, and gates
12. Fumigation and treatment of buildings for termites, cockroaches, ants, vermin, and other pests using pesticides registered by the State Department of Agriculture and the United States Environmental Protection Agency (EPA)
13. Landfill erosion control
14. Landfill gas and leachate system
15. Landscaping
16. Maintenance/storage sheds
17. Minor underpinning
18. On-site street cleaning
19. Operations, repairs or maintenance actions for compliance with Occupational Safety and Health Administration (OSHA) requirements
20. Painting of existing buildings
21. Pavements (and striping, as needed), including but not limited to, roadways, driveways, parking lots, walkways, bikeways, jogging paths, or multi-use pathways
22. Planter boxes
23. Refuse collection schedule changes
24. Reroofing or roofing
25. Retaining walls and embankment/slope and erosion repairs
26. Roadways and right-of-way within the confines of a wastewater treatment plant, a wastewater pump station, or a landfill
27. Security lighting for public grounds, structures, and parking lots
28. Signs, posts, flag/banner poles
29. Temporary storage of construction equipment and materials on street remnant properties
30. Trash compactors
31. Trash enclosures and litter containers

32. Wastewater Force Mains (FMs) and associated appurtenances (including but not limited to, air relief valve, flow tube, gate valve, manual air relief valve or air bleeder, check valve, blow off valve, testing station)
33. Wastewater lines (mains and laterals)
34. Wastewater outfalls
35. Wastewater Pump Stations (WWPSs)
36. Wastewater spills
37. Wastewater Treatment Plants (WWTPs)
38. Operation of City vehicles on existing City, State and private roads and roadway easements, including cars, trucks and trailers, but excluding operations that result in significant traffic impacts.
39. Loading, delivery and unloading operations for liquid and solid materials to and from vehicles at existing wastewater treatment plants and pump stations, but excluding operations that add nuisance odors at the property lines.
40. Loading, delivery and unloading operations for municipal solid waste and/or recyclable materials to and from vehicles at landfills, waste-to-energy facilities, transfer stations, convenience centers, and disposal, processing or recycling facilities. "Municipal solid waste" is defined in accordance with Hawaii Revised Statutes section 342G-1. "Recyclable materials" are defined in accordance with Revised Ordinances of Honolulu section 9-1.2.

#### Exemption Class #2

Replacement or reconstruction of existing structure and facilities where the new structure will be located generally on the same site and will have substantially the same purpose, capacity, density, height, and dimensions as the structure replaced.

1. Accessible ramps and handrails
2. Bridge replacement
3. Bollards and vehicular access barriers
4. Clearing, grading, and grubbing
5. Drainage structures (e.g., culverts, outlets, inlets)
6. Earth berms, drainage swales, and stream banks
7. Equipment installations, including but not limited to pumps; motors; electrical transformers, cabinets, panels, and vaults; power, light, and telephone pole systems; heating, ventilation, and air conditioning (HVAC); supervisory control and data acquisition (SCADA); irrigation controllers; telephone stations; emergency electrical generators; and cathodic protection systems
8. Essential utilities, including but not limited, to wastewater systems, drainage systems, water systems, electrical systems, communication systems, SCADA systems, and fuel systems, except where a State Department of Health permit is required
9. Existing individual wastewater systems (cesspools, septic tanks, aerobic units)
10. Existing public facility structures, facilities, or equipment involving negligible or no expansion or change of use beyond that previously existing
11. Existing topographical features involving negligible or no expansion or change of use beyond that previously existing (e.g., reconfiguration of paved parking lots to redirect drainage flow to vegetated areas, demolition and/or regarding areas to provide storm water detention for water quality)
12. Exterior stems and stairways
13. Fencing, curbing, walls, and gates
14. Footbridge

15. Fuel tank modification, repair or replacement in compliance with Federal and State regulations and with concurrence of the State Department of Health
16. Fueling stations
17. Fumigation and treatment of buildings for termites, cockroaches, ants, vermin, and other pests using pesticides registered by the State Department of Agriculture and the United States Environmental Protection Agency (EPA)
18. Guardrails
19. Landfill erosion control
20. Landfill gas and leachate system
21. Landscaping
22. Maintenance/storage sheds
23. Pavements (and striping, as needed), including but not limited to, roadways, driveways, parking lots, walkways, bikeways, jogging paths, or multi-use pathways
24. Planter boxes
25. Replacement or reconstruction actions for compliance with Occupational Safety and Health Administration (OSHA) requirements
26. Retaining walls, embankment/slope, swale, and/or erosion control replacement and reconstruction
27. Roadways and right-of-way within the confines of a wastewater treatment plant, a wastewater pump station, or a landfill
28. Sanitary sewer line modification or replacement in generally the same alignment, or an adjacent parallel alignment, and with the same diameter pipe.
29. Sanitary sewer line rehabilitation, including linings, inserts and coatings applied to existing pipelines and manholes.
30. Sanitary sewer line replacement, with a pipe that is no larger than the next largest nominal diameter size than the existing pipe, in generally the same alignment, or an adjacent parallel alignment, due to the need to increase to a minimum diameter standard for maintenance purposes or to accommodate wet weather peak flows. For the purposes of this item, increasing to the next largest nominal diameter size is considered to be a minor change, and is substantially the same dimensions. Upsizing to larger diameter pipe to service new facilities or structures is precluded.
31. Sanitary sewer relief line, in an adjacent parallel alignment, due to the need to accommodate wet weather peak flows or to restore flow capacity decreased by defect in the existing sewer.
32. Sanitary sewer relief line, in an adjacent parallel alignment, to restore flow capacity for a section of existing sewer that experienced loss of capacity from original design.
33. Sanitary sewer temporary bypass incidental to sewer line rehabilitation, modification, or replacement.
34. Security lighting for public grounds, structures, and parking lots
35. Signs, posts, flag/banner poles
36. Trash compactors
37. Trash enclosures and litter containers
38. Vegetated and/or lined swales, wet ponds, or other water quality features in parks, golf courses, or other recreational areas
39. Wastewater facility/structures (to include, but not be limited to, manholes, junction boxes, tanks, incinerators, etc.)

### Exemption Class #3



Construction and location of single, new, small facilities or structures and the alteration and modification of the same and installation of new, small, equipment and facilities and the alteration and modification of same, including but not limited to:

- a. Single-family residences less than 3,500 square feet not in conjunction with the building of two or more such units;
  - b. Multi-unit structures designed for not more than four dwelling units if not in conjunction with the building of two or more such structures;
  - c. Stores, offices, and restaurants designed for total occupant load of 20 persons or less per structure, if not in conjunction with the building of two or more such structures; and
  - d. Water, sewage, electrical, gas, telephone, and other essential public utility services extension to serve such structure or facilities; accessory or appurtenant structure including garages, carports, patios, swimming pools, and fences; and acquisition of utility easements.
1. Accessible ramps and handrails
  2. Acquisition of utility easements
  3. Auxiliary generators for emergency use
  4. Bollards and vehicular access barriers
  5. Carports
  6. Cathodic protection of pipelines and equipment
  7. Clearing, grading, and grubbing
  8. Comfort facilities at public facility properties
  9. Community recycling bin program expansion, limited to not more than a total bin footprint of 1,000 square feet within the same site.
  10. Construction and location of a single, new, small public facility structure, including but not limited to those intended for recreational, meeting, administration, maintenance, operations, and safety and protection (e.g., police, fire, emergency medical, and wastewater spill response) less than 3,500 square feet in floor area not in conjunction with the building of two or more such units
  11. Construction of ball wash facilities for golf courses
  12. Construction of concrete pads and roofs at existing fueling stations
  13. Construction of concrete pads and roofs for heavy equipment areas at selected maintenance facilities
  14. Construction of small vehicle wash equipment for recycling water at select City facilities
  15. Construction of roofs over existing outdoor showers at select park sites to allow connections to the wastewater system
  16. Construction of vehicle wash facilities for golf carts
  17. Construction or installation of an underground fuel tank with a maximum capacity of 4,000 gallons at fire and police stations
  18. Construction or installations of cesspools that require State Department of Health and Board of Water Supply approvals
  19. Creation of temporary staging areas during periods of City and County construction
  20. Earth berms and drainage swales
  21. Equipment installations, including but not limited to pumps; motors; electrical transformers, cabinets, panels, and vaults; power, light, and telephone pole systems; heating, ventilation, and air conditioning (HVAC); supervisory control and data acquisition (SCADA); irrigation controllers; telephone stations; emergency electrical generators; and cathodic protection systems

22. Essential utilities and new, small equipment, including but not limited to wastewater systems, drainage systems, water systems, electrical systems, communication systems, and irrigation systems
23. Expansion of existing groundwater monitoring wells
24. Expansion of existing landfill gas and leachate systems expansion (e.g., pipelines, flares, vacuumed/condensate/leachate pumps, monitoring wells, etc.)
25. Expansion of existing wastewater pump station and force main facilities (e.g. additional pumping equipment, pipe and appurtenances) within the existing footprint.
26. Extensions, modifications, or additions to existing buildings and new, small equipment less than 3,500 square feet in floor area not in conjunction with the building of two or more such additions
27. Facility improvements to comply with Federal and State requirements with concurrence with the State Department of Health (e.g., National Pollutant Discharge Elimination System (NPDES) requirements such as covered truck parking, surface water diversions swales, permanent structural Best Management Practices (BMPs), etc.)
28. Fencing, curbing, walls, and gates
29. Field office
30. Installation and construction of flare screens, safety barriers, guardrails, energy attenuators, and other appurtenances designed to protect the motoring public
31. Landscaping
32. Loading areas
33. Maintenance/storage sheds
34. Minor street widening and improvements within existing or future City and County street rights-of-way
35. Minor modification of incinerator as directed by EPA or other authorized governmental agencies
36. Modifications of existing facilities to conform to Federal, State and local regulations or codes as directed by authorized governmental agencies
37. Modifications at energy facilities to comply with Federal and State requirements with concurrence with the State Department of Health (e.g., pollution control equipment)
38. Pavements (and striping, as needed), including but not limited to roadways, driveways, parking lots, walkways, bikeways, jogging paths, or multi-use pathways
39. Pedestrian bridges within public facility properties
40. Planter boxes
41. Recycling collection bins
42. Retaining walls, except within the shoreline area
43. Security lighting of public grounds, structures, and parking lots
44. Sewer Improvement District project
45. Sewer lateral extension, involving the extension of an existing lateral to a new property line for road improvement projects or for existing laterals that were inadvertently installed short of the property line
46. Sewer manholes with or without concrete apron to accommodate pumper trucks (septage receiving station)
47. Sewer service installation for existing residential properties, including:
  - a. The construction of a sewer lateral from an existing sewer main located in an easement or street right-of-way to the abutting property line of lots without sewer service
  - b. The construction of additional laterals or the replacement of existing laterals to accommodate other utility lines or to facilitate connections from house sewer connection on the premise to laterals

- c. The extension of an existing sewer main together with a lateral to serve lots without sewer service in areas where no significant environmental or historical resources exist
- 48. Sidewalks and covered walkways
- 49. Signs, posts, and flag/banner poles
- 50. Steps and stairways
- 51. Storm drain line extensions within wastewater treatment plant, wastewater pump station, refuse transfer station, and landfill sites
- 52. Storm drain line modifications
- 53. Trash compactors
- 54. Trash enclosures and litter containers
- 55. Utility connections (electrical, gas, water, wastewater)
- 56. Water tanks, not more than 75,000 gallons in capacity, developed to serve individual public facility needs

#### Exemption Class #4

Minor alterations in the conditions of land, water, or vegetation.

- 1. Berms
- 2. Chemical control of vegetation using herbicides and pesticides registered by the State Department of Agriculture and the EPA
- 3. Clearing, grubbing, or grading of less than 100 cubic feet within existing parks and public facility property boundaries
- 4. Ground improvements (e.g. driveways, parking areas, walls, sidewalks, etc.)
- 5. Landscaping and sprinkler system
- 6. Lining short sections of stream banks for erosion control and slope stability
- 7. Removal of unhealthy trees that endanger life or property and non-significant trees
- 8. Shoulders

#### Exemption Class #5

Basic data collection, research, experimental management, and resource evaluation activities which do not result in a serious or major disturbance to an environmental resource.

- 1. Basic data collection, research, experimental management, and resource evaluation activities that do not result in a serious or major disturbance to an environmental resource, including but not limited to, archaeological surveys, bioassays, biological and ecological studies and surveys, chemical and bacteriological laboratory analysis, fish surveys, fresh and saline water sampling and analysis, industrial waste sampling and analysis, monitoring device installation, oceanographic surveys, receiving water monitoring programs, recycling wastewater and wastewater reuse studies, sediment studies and surveys, storm water runoff sampling and analysis, stream studies and surveys, topographical surveys, virus studies and surveys, exploratory soil boring, reconnaissance, testing, or data recovery

#### Exemption Class #6

Construction or replacement of minor structures accessory to existing facilities.

- 1. Accessible ramps and handrails

2. Air conditioning enclosures
3. Construction field offices, temporary
4. Drinking fountains
5. Guard shacks
6. Hose bibbs
7. Emergency generator structure
8. Exterior lighting
9. Heating ventilation and air conditioning (HVAC) systems for existing wastewater treatment plant, pre-treatment plant, lift station, and pump station buildings
10. Lighting of driveways, streets, and roadways
11. Maintenance/storage sheds
12. Outdoor showers
13. Pedestrian bridges within public facility properties
14. Planter boxes
15. Portable buildings for temporary use of 5 years or less
16. Relocation of buildings within existing facilities
17. Retaining walls, except in shoreline areas
18. Security lighting
19. Signs
20. Solar water heating systems that include exterior solar collectors, nonreflective panels, and storage tanks not greater than 120 gallons each, and associated accessories
21. Steps and stairways
22. Trash compactors
23. Trash enclosures and litter containers
24. Underground fuel tanks and dispensers, except where a State Department of Health permit is required
25. Ventilation and odor control systems for existing wastewater treatment plant, pre-treatment plant, lift station, and pump station buildings
26. Water tanks, not more than 75,000 gallons in capacity, to serve existing facilities

#### Exemption Class #7

Interior alterations involving things such as partitions, plumbing, and electrical conveyances.

1. Interior alterations and renovations to wastewater treatment plant, pre-treatment plant, lift station, and pump station buildings, including but not limited to partitions, doors, counters, cabinets, shelving, plumbing, electrical systems, heating ventilation and air conditioning (HVAC) systems, ventilation and odor control systems, and electrical conveyances

#### Exemption Class #8

Demolition of structures, except those structures located on any historic site as designated in the national register or Hawaii register as provided for in the National Historic Preservation Act of 1966, Public Law 89-665, 16 U.S. C. Sec. 470, as amended, or Chapter 6E, HRS.

1. Demolition of structures at wastewater treatment plant and pump station locations, except those structures located on any historic site

#### Exemption Class #9

Zoning variances except shoreline setback variances.

1. Zoning variances of wastewater facility properties, except shoreline setback variances

Exemption Class #10

Continuing administrative activities including, but not limited to, purchase of supplies and personnel-related actions.

1. Acquisition, but not improvement of property, for public use (including easements) and minor subdivision and consolidation of parcels necessary for acquisition of property for public use (including rounding corners and minor street widening)
2. Subdivision/consolidation of public lands to facilitate their transfer between the City and State for continuing public use without change in existing land use
3. Continuing government administrative activities, including but not limited to purchase of supplies and personnel-related actions
4. Operation of initial or continuing public programs consistent with established land use (for example, but not limited to, stream debris clean-ups, storm drain stenciling, beach debris clean-ups)

