

File No.	Island	Street Address	City	Zip Code	TMK	Applicant	Exempt HAR 11-200-1-16	Action: Title& Description (92 Characters MAX)	Notes
2022-001	Oahu	2727 Kamehameha Hwy	Honolulu	96819	(1) 2-2-003:028	CCH/ENV	1, 2, & 3	Kamehameha Highway Wastewater Pump Station Upgrade - Wet Well Improvements	Rehabilitation Wet Well 1, Wet Well 2 and the Inlet Collection Chamber to restore their intended operational functionality and compliance with US EPA requirements. Replace existing 2,000 gallon diesel fuel underground storage tank nearing its end of service life with a diesel above ground storage tank of equal capacity and function. Re-grade parking lot and surrounding gate access areas to improve access requirements and facilitate operation for maintenance staff. This includes modification of existing on-site stormwater collection systems to accommodate required site re-grading and paving.