

File No.	Island	Street Address	City	ZIP Code	TMK	Applicant (as appropriate)	Exempt. HAR 11-200.1-15(c)	Action: Title & Description	Notes
XX-XXX	Kaua'i	4398 Pua Loke Street	Līhu'e	96766	(4) 3-8-005:013	County of Kaua'i, Department of Water	6	Demolition of the former administrative building for the County of Kaua'i, Department of Water	Submitted Dec. 2022
	Kaua'i	Upper Omao	Omao	96765	(4) 2-5-001:017	County of Kaua'i, Department of Water	2	Replacement of deep well pump for Piwai Well No. 3.	Submitted Sept. 2023
	Kaua'i	Hanalei	Hanalei	96714	Work in County and State road right-of-ways	County of Kaua'i, Department of Water	2	Replacement of existing water mains on Weke, Anae, Mahimahi and He'e Roads. New water mains will meet current fire flow standards.	Submitted Sept. 2023
	Kaua'i	Kilohana Tank Site	Līhu'e	96766	(4) 3-8-005:015	County of Kaua'i, Department of Water	3	Construction of small new building at existing facility for Kilohana OSHG Shed Storage.	Submitted Sept. 2023
	Kaua'i	Līhu'e	Līhu'e	96766	Work in County and State road right-of-ways	County of Kaua'i, Department of Water	2	Replacement of existing water mains on Kūhiō Highway between Hardy Street and Poinciana Street and on Poinciana Street between Kūhiō Highway and Jerves Street. New water mains will meet current fire flow standards. Transferring of existing laterals to the new 16-inch diameter ductile iron water main or existing 8-inch diameter cast iron water main on Kūhiō Highway between Hardy Street and Oxford Street.	Submitted Sept. 2023
	Kaua'i	Līhu'e	Līhu'e	96766	Work in County and State road right-of-ways	County of Kaua'i, Department of Water	2	Replacement of existing water mains on Kūhiō Highway between Hardy Street and Poinciana Street and on Poinciana Street between Kūhiō Highway and Jerves Street. New water mains will meet current fire flow standards. Water main on Kuhio Highway will match the existing water line diameter at the tie-in point near the intersection of Kuhio Highway and Hardy Street for operational requirements and constructability purposes. Transferring of existing laterals to the new 18-inch diameter ductile iron water main or existing 8-inch diameter cast iron water main on Kūhiō Highway between Hardy Street and Oxford Street.	Submitted January 2024