DAVID Y. IGE



VIRGINIA PRESSLER, M.D.

In reply, please refer to: File:

137 ATC – rev plans

STATE OF HAWAII DEPARTMENT OF HEALTH

P. O. BOX 3378 HONOLULU, HI 96801-3378

February 26, 2018

Mr. Jacob Freeman, P.E. CDF Engineering LLC P.O. Box 2985 Wailuku, HI 96793

Email: jake@cdfengineers.com

Dear Mr. Freeman:

Subject:

Approval to Construct

Revised 20,000 GPD Wastewater Treatment Plant

Pulehunui Heavy Industrial Subdivision

Puunene, Maui File No. 137



The Department of Health (Department) acknowledges receipt of your revised construction plans on February 20, 2018.

The plans were revised to use existing injection wells for effluent disposal in place of leachfields. The Safe Drinking Water Branch has approved the use of the existing injection wells (permit number UM-2933) for wastewater disposal from the subject plant. Therefore, the revised plans are approved for construction.

An inspection of the completed project is required to verify the information provided in the submittals. Please notify our office at least three weeks in advance to schedule a final inspection of the completed project.

Should you have any questions, please contact April Matsumura of at (808) 586-4294.

Sincerely,

Sua XI

SINA PRUDER, P.E., CHIEF Wastewater Branch

AM:sp

c: Mr. Norris Uehara (norris.uehara@doh.hawaii.gov)

Mr. Sal Marino (sal.d.marino@gmail.com)

Ms. Blanca Lafolette (blancal@pacificrimland.com)